



1505-01: Cutting Corners Mitre Makers Ltd – Internal Floormitre

Evaluated by the Rapid Review Panel
07 May 2015

Evaluation Level 6: Evidence presented does not demonstrate that the product has a contribution to make to improvements in infection prevention and control interventions to reduce healthcare-associated infections.

- The product is a flexible phthalate free plastic former that fits into the internal corners of rooms where vinyl runs up the wall in order to strengthen the corner and claims to prevent the corner weld from collapsing and allowing the build-up of potential pathogens
- Further microbiological scientific evidence is required to substantiate product claims of preventing the transmission of pathogens responsible for healthcare-associated infections

Evaluation Disclaimer: The RRP does not formally review cost-effectiveness or implementation barriers during its evaluation of products; these factors may be considered in a separate process. It is the responsibility of the applicant to carry out any further required development, including trials, cost-effectiveness assessments or product implementation within the NHS. All statements comparing the efficiency or efficacy of products are in the context of products available for use to the NHS at the date of evaluation.