

## Details for Enforcement Notice No. 031/2016

Notice Type	Enforcement
Operator	Maersk Oil North Sea UK Limited
Address	13 <sup>th</sup> Floor Aldgate tower 2 Lemn Street London E1 8FA
Details	Maersk Oil North Sea UK Limited  During a regulatory inspection, it was found that the Donan Global Producer III had two air conditioning units, each containing 240 kg of the F-Gas R422D. As such, both units contained fluorinated greenhouse gases in quantities of 500 tonnes of CO <sub>2</sub> equivalent or more. Neither unit had an automatic leak detection system as required by Article 5(1) of the 2014 Regulations.
Legislation	REGULATION 25(1)(a)(i) OF THE FLUORINATED GREENHOUSE GASES REGULATIONS 2015
Issue Date	29/06/2016
Compliance Date	04/11/2016