

Details for Enforcement Notice No. 028/2016

Notice Type	Enforcement
Operator	Total E&P UK Ltd
Address	18th Floor 10 Upper Bank Street London SW1W 8PZ
Details	<p>Alwyn North NAA and Alwyn North NAB platforms</p> <p>During a DECC Regulatory inspection of the Alwyn Platforms it was identified that Total E & P UK Ltd failed to comply with Articles 4(1) and 4(3) of Regulation (EU) No 517/2014 of the European Parliament and Council On Fluorinated Greenhouse Gases (the “2014 Regulation”) in that Total failed to put in place adequate arrangements to ensure compliance with the leak checking and record keeping requirements of the 2014</p>
Legislation	REGULATION 25(1)(a)(i) OF THE FLUORINATED GREENHOUSE GASES REGULATIONS 2015
Issue Date	29/06/2016