



| ENVIRONMENTAL ALERT | |
|---|-----------------------------------|
| ALERT NUMBER: 05/2013 | ISSUE DATE: 19 August 2013 |
| INCIDENT / ALERT DETAILS: During recent inspections a number of installations had been found to be using temporary equipment such as diesel generators and chemical pumps. These pieces of equipment were inspected and in all cases management of change and/or risk assessment documentation had been completed and available for review. However, in all cases it was established that the storage and supply of the diesel and/or chemicals for the equipment and the associated potential for environmental incident had not been considered within the management of change/risk assessment documentation. | |
| INITIAL/ALERT FINDINGS: Operators are advised that when compiling management of change and/or risk assessments for temporary equipment to ensure the whole system/process is considered, including the storage and supply routes for the equipment, so as to eliminate the potential of a diesel or chemical release occurring. | |
| Further Information Any queries relating to this alert should be addressed to: Offshore Environmental Inspectorate Offshore Environment and Decommissioning Atholl House 86-88 Guild Street ABERDEEN AB11 6AR Or: Offshore.inspectorate@decc.gsi.gov.uk | |



Department
of Energy &
Climate Change