

Chapter 7

Combined heat and power

Key Points

- The Good Quality CHP capacity increased by 210 MWe between 2016 and 2017 from 5,625 MWe to 5,835 MWe. (Table 7A)
- The amount of good quality electricity produced in 2017 was 21.6 TWh (Table 7.4), which is 6.1 per cent higher than in 2016. The good quality electricity generated by CHP in 2017 corresponds to 6.4 per cent of all electricity generated in the UK.
- Sixty-nine percent of the fuel used in CHP schemes in 2017 was natural gas. This is 2.4 percentage points lower than in 2016. In 2017, the share of total fuel that was renewable was 16.5 per cent, a 3.3 percentage point increase between 2016 and 2017.
- The Oil and Gas sector has the largest Good Quality CHP capacity (38 per cent), followed by the Chemicals sector (19 per cent), Other sector (12 per cent) and then the Transport Commerce and Administration sector (9.1 per cent).
- The absolute CO₂ savings delivered by CHP in 2017 were lower than in 2016. This is due to the provisional values for CO₂ intensity of electricity displaced by CHP electricity being lower in 2017 than in 2016, rather than falls in the outputs of CHP or efficiency of operation.

Introduction

7.1 This chapter sets out the contribution made by Combined Heat and Power (CHP) to the United Kingdom's energy requirements. The data presented in this chapter have been derived from information submitted to the CHP Quality Assurance programme (CHPQA) or by following the CHPQA methodology in respect of data obtained from other sources. The CHPQA programme was introduced by the Government to provide the methods and procedures to assess and certify the quality of the full range of CHP schemes. It is a rigorous system for the Government to ensure that the incentives on offer are targeted fairly and benefit schemes in relation to their environmental performance.

7.2 CHP is the simultaneous generation of usable heat and power (usually electricity) in a single process. The term CHP is synonymous with cogeneration, which is commonly used in other Member States of the European Community and the United States. CHP uses a variety of fuels and technologies across a wide range of sizes and applications. The basic elements of a CHP plant comprise one or more prime movers (a reciprocating engine, gas turbine, Rankine cycle turbine using steam or organic fluids and, more recently, steam screw expanders) driving electrical generators, with the heat generated in the process captured and put to further productive use, such as for industrial processes, hot water and space heating or cooling (via absorption chillers).

7.3 CHP is typically sized to make use of the available heat¹, and connected to the lower voltage distribution system (i.e. embedded). This means that, unlike conventional power stations, CHP can provide efficiency gains by avoiding significant transmission and distribution losses, which currently represent about 7.5 per cent of electricity demand in the UK. These gains are reflected in the calculation of CO₂ savings delivered by CHP (see paragraphs 7.29-7.30). CHP can also provide important network services such improvements to power quality, and some have the ability to operate in island mode if the grid goes down. There are six principal types of CHP system: steam turbine, gas turbine, combined cycle systems, reciprocating engines, Organic Rankine Cycle (ORC) and steam expander systems. Each of these is defined in paragraph 7.37 later in this chapter.

¹ But not always, see paragraph 7.6. In such cases there is an impact upon the electrical capacity and electrical output classified as CHP.

UK energy markets, and their effect on CHP

7.4 Two major factors affecting the economics of CHP are the relative cost of fuel (principally natural gas) and the value that can be realised for electricity both for own use and export. This is known as the spark spread (i.e. the difference between the price of electricity and the price of the gas required to generate that electricity). The larger the spark spread the more favourable are the economics of CHP operation. At the start of 2013 the spark spread started to increase and did so each quarter until the middle of 2016. Since that time, the spark gap has fluctuated in magnitude up and down. Over the last 10 years the spark spread peaked at 5.2 (Q3 of 2016) and was at a minimum of 3.0 (Q1 2013). In Q4 2017 it stood at 4.6.

7.5 The effect of the introduction of a specific solid biomass CHP Renewable Heat Incentive (RHI) tariff for installations commissioned after May 2014 has encouraged the commissioning of a growing number of units based on Organic Rankine Cycle (ORC) and steam screw expander technologies. Statistics tables 7.3 to 7.7 now include a specific entry for schemes based on ORC technology, reflecting this development. These technologies are described in paragraph 7.37.

Use of CHPQA in producing CHP statistics

7.6 The CHPQA programme is the major source for CHP statistics. CHPQA schemes accounted for 92 per cent of the capacity reported in this chapter for 2017. The following factors need to be considered when using the statistics produced:

- Through CHPQA, scheme operators have been given guidance on how to determine the boundary of a CHP scheme (what is regarded as part of the CHP installation and what is not). A scheme can include multiple CHP prime movers², along with supplementary boilers and generating plant, subject to appropriate metering being installed to support the CHP scheme boundaries proposed, and subject to appropriate metering and threshold criteria. (See CHPQA Guidance Note 11 available at www.gov.uk/chpqa-guidance-notes). This point is relevant when considering the figures in Table 7D, where the power efficiencies, heat efficiencies and heat to power ratios stated in that table for 2017 are those of the scheme, which may not be just the prime mover.
- The output of a scheme is based on gross power output. This means that power consumed by parasitic plant such as pumps and fans is included in the power output of the scheme.
- The main purpose of a number of CHP schemes is the generation of electricity including export to other businesses and to the grid. There may not be demand for all of the available heat from such schemes. In such cases, the schemes' total electrical capacity and electrical output have been scaled back using the methodologies outlined in CHPQA (see www.gov.uk/chpqa-guidance-notes). Only the output from highly-efficient or "Good Quality" schemes is counted in this chapter. Chapter 5 includes all CHP capacity, fuel inputs and power outputs, for both highly-efficient, or "Good Quality", and less efficient schemes, under the categories "Other generators".
- For year of operation 2011 onwards, new scale back criteria came into force in order to be consistent with the EU Cogeneration Directive. This results in a more severe scale back than was previously the case. This has contributed to some of the decrease in Good Quality electricity output and associated fuel consumption seen after 2010.
- There are two load factors presented in Table 7A. Load Factor (CHPQA) is based on the Good Quality Power Output and Good Quality Power Capacity reported in this Chapter. Load Factor (Actual) is based on the Total Power Capacity and the Total Power Output. The Load Factor (CHPQA) is lower than the Load Factor (Actual) for schemes that have been scaled back on the power outputs. The load factor gives an indication of the degree to which the power generating capacity is utilized. Between 2007 and 2013 Load Factor (CHPQA) steadily declined but has undergone a modest increase since then. In 2016 there was an appreciable upturn in Load Factor (Actual), which was due to a number of large CHP generators in the Chemicals and Oil Refineries sectors increasing their production of electricity. Load Factor (Actual) in 2017 was lower than in 2016 but is still higher than at any time since 2011.

² The CHP prime mover is the heart of a CHP system and is a mechanical machine which drives the electricity generator or develops mechanical power for direct use

Table 7A: A summary of the recent development of CHP⁽¹⁾

| | Unit | 2013 | 2014 | 2015 | 2016 | 2017 |
|---|----------|--------|--------|--------|--------|--------|
| Number of schemes | | 2,024 | 2,071 | 2,130 | 2,224 | 2,386 |
| <i>Net No. of schemes added during year (2)</i> | | 84 | 47 | 59 | 94 | 162 |
| Electrical capacity (CHP _{QPC}) | MWe | 5,919 | 5,888 | 5,708 | 5,625 | 5,835 |
| <i>Net capacity added during year</i> | | -45 | -32 | -179 | -83 | 209 |
| <i>Capacity added in percentage terms</i> | Per cent | -0.8 | -0.5 | -3.0 | -1.5 | 3.7 |
| Heat capacity | MWth | 22,161 | 22,223 | 20,091 | 19,795 | 20,191 |
| Heat to power ratio (3) | | 2.27 | 2.13 | 2.06 | 1.99 | 1.95 |
| Fuel input (4) | GWh | 88,403 | 86,184 | 82,576 | 85,123 | 90,279 |
| Electricity generation (CHP _{QPO}) | GWh | 19,515 | 19,690 | 19,534 | 20,405 | 21,648 |
| Heat generation (CHP _{QHO}) | GWh | 44,342 | 41,950 | 40,234 | 40,670 | 42,238 |
| Overall efficiency (5) | Per cent | 72.2 | 71.5 | 72.4 | 71.7 | 70.8 |
| Load factor (CHPQA) (6) | Per cent | 37.6 | 38.2 | 39.1 | 41.4 | 42.4 |
| Load factor (Actual) (7) | Per cent | 51.7 | 52.3 | 51.0 | 60.0 | 56.4 |

(1) Data in this table for 2013 and 2016 have been revised since last year's Digest as more up to date information on the performance and status of some CHP schemes has become available.

(2) Net number of schemes added = New schemes – Decommissioned existing schemes.

(3) Heat to power ratios are calculated from the qualifying heat output (QHO) and the qualifying power output (QPO).

(4) Fuel input is the fuel deemed to have generated the qualifying power output (QPO) and qualifying heat output (QHO).

(5) Overall efficiencies are calculated using qualifying power output (QPO), qualifying heat output (QHO) and fuel input. Fuel input is expressed in Gross Calorific Value (GCV) terms. When fuel input is expressed in Net Calorific Value (NCV) terms, efficiencies will be higher.

(6) The load factor (CHPQA) is based on the qualifying power output (QPO) and qualifying power capacity (QPC) and does not correspond exactly to the number of hours run by the prime movers in a year.

(7) The load factor (Actual) is based on the total power generated and total capacity.

Efficiency of CHP schemes


7.7 Good Quality CHP denotes schemes that have been certified as being highly efficient through the UK's CHP Quality Assurance (CHPQA) programme. The criteria used are in line with the requirements for high efficiency CHP set down in the Energy Efficiency Directive (2012/27/EU). A Good Quality CHP scheme, with installed capacity ≥ 1 MWe, must achieve 10 per cent primary energy savings compared with the EU reference values for separate generation of heat and power i.e. via a boiler and power station. Good Quality CHP schemes with installed capacity < 1 MWe must achieve primary energy savings greater than zero per cent.

Changes in CHP capacity

7.8 Chart 7.1 shows the change in installed CHP capacity since 2001, when the CHPQA programme began. Installed capacity at the end of 2017 stood at 5,835 MWe, an increase of 209 MWe (3.7 per cent) compared to 2016. There was also a net increase of 162 (7.3 per cent) in the number of schemes between 2016 and 2017. Overall, between 2016 and 2017, there were 194 new schemes included in the database and a removal of 32 schemes. There have been revisions to the capacity figures for 2013 to 2016 shown in the previous edition of the Digest, as more up to date information on the performance and operational status of some schemes has become available.

7.9 For the first time it has been possible to include in the statistics a number of CHP schemes fuelled by biogas generated by anaerobic digesters which do not submit to CHPQA. These particular schemes are included on the basis that food waste makes up part of the composition of the feedstock and that, therefore, pasteurisation of the feedstock, or digestate, is required. As stated in paragraph 7.1, where data from sources other than CHPQA are used, the CHPQA methodology is nevertheless used to determine the qualifying capacities, fuel inputs, power and heat outputs, which are reported in this chapter. Under CHPQA, heat is only counted if it is deemed "useful heat". Useful heat from CHP is heat that is demonstrably utilised to displace heat that would otherwise be supplied from other sources. In the absence of CHP heat, heat to carry out the necessary pasteurisation of the feedstock or digestate, where the feedstock includes food waste, would have to come from another source. As such, at least some of the heat output from these particular CHP schemes is deemed useful heat, and so these schemes are included in the statistics. It is possible to include these schemes now because robust information has become available about the composition of the feedstock to the digesters. These schemes are included in the statistics just for year of operation 2017 and have not been added retrospectively.

Chart 7.1: Operating CHP capacity by year



7.10 Table 7A gives a summary of the overall CHP market. In 2017, CHP schemes generated 21,648 GWh of Good Quality electricity, 6.1 per cent higher than in 2016. This generated electricity represents 6.4 per cent of the total electricity generated in the UK. Virtually all of this increase in Good Quality outputs may be attributed to the inclusion in the statistics for the first time of a number of CHP schemes running on biogas generated by anaerobic digestion plant, as explained in paragraph 7.9. The quantity of Good Quality electricity generated in industry was more or less unchanged between 2016 and 2017. However, at the individual industrial sector level, there were more notable changes. For example, there was a 9.6 per cent increase in Good Quality power outputs in the Food and Drink sector, but a 5.2 per cent and 26 per cent decrease in the Iron and Steel and Non-ferrous sector. The Transport, Commerce and Administration (TCA) sector continued its more or less uninterrupted, gradual rise in Good Quality power outputs. In the Other sector, the output of Good Quality power outputs increased significantly between 2016 and 2017, and this is due to the inclusion of a number of CHP schemes based on food waste fed anaerobic digestion (see paragraph 7.9 for further information).

7.11 Table 7A shows that CHP schemes supplied a total of 42,238 GWh of heat in 2017. This was an increase of 3.9 per cent (1,568 GWh) compared to 2016. There were two notable components to this increase, one is the inclusion in the statistics for the first time of some CHP schemes fuelled by biogas from anaerobic digestion plant (contributing 421 GWh to the increase – see paragraph 7.9 for further information) and the other was a 777 GWh increase from industrial CHP. This increase in heat output from industrial CHP breaks a ten-year downward trend in industrial heat output from CHP. There were modest relative increases in the heat output from the Chemicals, Oil Refineries and Paper sectors, with a more significant increase (6.2 per cent) increase from the Food and Drink sector. The heat output from CHP in the Transport, Commerce and Administration (TCA) sector continued its long term upward trend, with an increase of 2.8 per cent between 2016 and 2017.

7.12 In terms of electrical capacity by size of scheme, schemes larger than 10 MWe represent 72 per cent of the total electrical capacity of CHP schemes as shown in Table 7B. Schemes less than 1 MWe constitute the majority of scheme numbers (79 per cent), but just 6.3 per cent of the total capacity. Table 7.5 provides data on electrical capacity for each type of CHP installation.

Table 7B: CHP schemes by capacity size ranges in 2017

| Electrical capacity size range | Number of schemes | Share of total (per cent) | Total electricity capacity (MWe) | Share of total (per cent) |
|--------------------------------|-------------------|---------------------------|----------------------------------|---------------------------|
| Less than 100 kWe | 605 | 25 | 36 | 0.6 |
| 100 kWe - 1 MWe | 1,291 | 54 | 331 | 5.7 |
| 1 MWe - 2 MWe | 183 | 7.7 | 259 | 4.4 |
| 2 MWe - 10 MWe | 240 | 10 | 1,027 | 18 |
| > 10 MWe + | 67 | 2.8 | 4,181 | 72 |
| Total | 2,386 | 100 | 5,835 | 100 |

7.13 Table 7.5 shows that 58 per cent of total electrical capacity is in combined cycle gas turbine (CCGT) mode and 26 per cent is from reciprocating engines. In 2007 these proportions were 74 per cent and 12 per cent, respectively. These changes are explained by an absolute fall in the CCGT capacity and an absolute increase in reciprocating engine capacity. There were significant falls in CCGT capacity in the Chemicals and Paper sectors, while there was an increase in reciprocating engine capacity across all but one sector during this period. These changes in technology over time also explain changes in the distribution of capacity within capacity ranges, as shown in Table 7B across different editions of the Digest. As CCGT capacity has been lost, the proportion of total capacity in the size range >10 MWe has decreased from 82 per cent in 2007 to 72 per cent in 2017. Over the long term there has been a fall in the proportion of overall capacity that is back pressure steam turbine, as this relatively inefficient and inflexible technology is phased out. In recent years there has been an increase in pass out condensing steam turbine capacity, as more biomass and waste fuelled CHP schemes have been brought on line.

7.14 Excluded from the statistics tables presented in this chapter are a number of very small CHP schemes (micro-CHP) installed since 2010 in response to the Feed-in Tariff (FiT) scheme. The overwhelming majority of these schemes are domestic. At the end of 2017 there were 517 such schemes registered with Ofgem for FiTs with a total installed capacity of 545 kWe. There are no data on electricity generation or fuel consumption for these schemes and, consequently, they have been left out of the statistics tables. However, if included, there would have a negligible impact upon the capacity and generation figures presented in the statistics tables.

7.15 Table 7.7 provides data on heat capacity for each type of CHP installation. Starting in the 2013 edition of the Digest, there has been a change implemented in how the heat capacity has been derived. Prior to this, for a number of schemes, the data held on heat capacity were either not complete or were not a true reflection of the capacity of the scheme to generate heat in CHP operating mode. To allow for this, a standard methodology was developed and applied for the first time in the 2013 edition of the Digest for the determination of the heat capacity. This is applied to new schemes and schemes undergoing a change in plant. Details of this methodology may be found in the CHP methodology note which is available from the following link:

www.gov.uk/government/publications/combined-heat-and-power-statistics-data-sources-and-methodologies


Fuel used by types of CHP installation

7.16 Table 7.2 shows the fuel used to generate electricity and heat in CHP schemes (see paragraphs 7.38 to 7.40 below for an explanation of the convention for dividing fuel between electricity and heat production). Table 7.3 gives the overall fuel used by types of CHP installation (which are explained in paragraph 7.37). Total fuel use is summarised in Chart 7.2. In 2017, 69 per cent of the total fuel use was natural gas. This is a decrease of 2.4 percentage points compared with 2016. CHP schemes accounted for 7.1 per cent of UK gas demand in 2017 (see Table 4.1). The use of coal and fuel oil is now less than 1 per cent of overall fuel use.

7.17 The proportion of total fuel consumption that was renewable increased between 2016 and 2017 from 13 per cent to 16 per cent of the total. This increase is substantially due to the inclusion of a number of CHP schemes fuelled by biogas generated by anaerobic digestion fed with food waste (see paragraph 7.9 for detailed explanation). Gaseous renewable fuels constitute the single largest type of renewable fuel (45 per cent), followed by biomass fuels (34 per cent) and waste fuels (20 per cent), with the balance being liquid renewable fuels.

7.18 Fuels which are liquids, solids or gases that are by-products or waste products from industrial processes, or are renewable fuels, accounted for 30 per cent of all fuel used in CHP in 2017. This is 2.5 percentage points higher than in 2016, and this is mainly due to the increase in the consumption of renewable fuel included in this chapter, as discussed in paragraphs 7.9 and 7.17.

Chart 7.2: Types of fuel used by CHP schemes in 2017



CHP capacity, output and fuel use by sector


7.19 In this chapter of the Digest, CHP is analysed by the sector using the heat or, where the heat is used by more than one sector, by the sector using the majority of the heat. This method of assigning a CHP scheme to a sector was rigorously applied for the first time in the 2008 edition of the digest and resulted in the movement of CHP schemes between sectors. One consequence of this was the removal of all schemes once allocated to the “electricity supply” sector and their distribution to other sectors. Full details of this reassignment are provided in paragraph 6.33 and Table 6J of the 2008 edition of the digest.

7.20 Table 7.8 gives data on all operational schemes by economic sector. A definition of the sectors used in this table can be found in Chapter 1, paragraph 1.60 and Table 1H:

- 400 schemes (79 per cent of electrical capacity) are in the industrial sector and 1,986 schemes (21 per cent of capacity) are in the agricultural, commercial, public administration, residential and transport sectors. The share of capacity in the industrial sector was 3.8 percentage points lower in 2017 than in 2016. This continues a long-standing trend of a shrinking proportion of total CHP capacity being installed at industrial sites.
- The share of total installed Good Quality capacity taken up by each sector is shown in Chart 7.3. The Oil and gas terminals sector, which has been the largest sector since 2009, continues to have the largest share of total installed capacity, accounting for 38 per cent of all capacity. The Chemicals sector has the second highest share of total installed capacity (19 per cent) followed by the “Other” sector (12 per cent) and Transport, commerce and administration (TCA) at 9.1 per cent. The “Other” sector has overtaken TCA to occupy third position due to the inclusion for a number of anaerobic digestion CHP schemes (see paragraph 7.9 for detailed explanation).

Between 2016 and 2017 the following sectors saw a decrease in installed Good Quality capacity: Chemicals, Oil and gas terminals, Mineral products and Sewage treatment works. There were modest increases in the Paper, Food and drink and Metal products sectors.

Chart 7.3: CHP electrical capacity by sector in 2017



(1) Other sectors include agriculture, community heating, leisure, landfill and incineration
 (2) Other industry includes textiles, clothing and footwear and sewage treatment

7.21 Table 7C gives a summary of the 1,649 schemes installed in the commercial sector, public sector and residential buildings. These schemes form a major part of the “Transport, commerce and administration” and “Other” sectors in Tables 7.8 and 7.9. The vast majority of these schemes are based on spark ignition reciprocating engines fuelled with natural gas, though the larger schemes use compression ignition reciprocating engines or gas turbines. The largest proportion of the capacity is in the health sector (32 per cent), mainly hospitals. The leisure and hotel sectors remain the two sectors with the largest number of installed schemes. This is a reflection of the suitability of CHP for meeting the demand profiles for heating and hot water in these types of building. Of note is the large ratio of heat to power generating capacity in the health sector. This is a reflection of the especially acute need for security of heat supply required at hospitals, provided by back-up boilers, rather than the heat to power capacity ratios inherent in the prime mover used for power generation (see Definitions of schemes under Technical notes and definitions).

Table 7C: Number and capacity of CHP schemes installed in buildings by sector in 2017

| | Number of schemes | Electrical capacity (MWe) | Heat capacity (MWth) |
|---------------------------|-------------------|---------------------------|----------------------|
| Leisure | 545 | 71 | 121 |
| Hotels | 282 | 41 | 67 |
| Health | 231 | 188 | 1050 |
| Residential Group Heating | 122 | 96 | 420 |
| Universities | 99 | 102 | 521 |
| Offices | 43 | 17 | 29 |
| Education | 61 | 15 | 50 |
| Government Estate | 32 | 14 | 48 |
| Retail | 230 | 46 | 74 |
| Other (1) | 4 | 2.6 | 19 |
| Total | 1,649 | 593 | 2,399 |

(1) All schemes under Other are at airports

7.22 According to the Energy Performance in Buildings Directive, District Heating and Cooling (DHC) is the distribution of thermal energy in the form of steam, hot water or chilled products from a centralised place of production through a network to multiple buildings or sites for space or process heating or cooling. For statistical purposes, EUROSTAT further stipulates that, as well as more than one building or site having to be supplied, there must also be more than one customer for the heating or cooling supplied. Comprehensive data on Community Heating (CH) and District Heating (DH) schemes in the United Kingdom became available for the first time in 2017 when data submissions, made to the Office of Public Safety and Standards, as required under Article 3 of The Heat Network (Metering and Billing) Regulations 2014, were processed. Using these data and adopting the EUROSTAT definition of DH, in 2015 there were approximately 246 DH schemes using CHP in the UK, with a heat capacity of 5,619 MWth and supplying 7,099 GWh of heat to their associated DH networks³.

CHP performance by main prime mover

7.23 Table 7D gives a summary of the performance of schemes in 2017 by main prime mover type. In 2017 the prime mover type with the highest average operating hours was gas turbines followed by reciprocating engines.

7.24 In 2017, the average operating hours were 3,710 hours. The average operating hours in 2016 (revised) was 3,627 hours, indicating a slight increase in the utilisation of good quality capacity between the two years. These are the highest average operating hours since 2012.

7.25 In 2017, the average electrical efficiency was 24 per cent and the heat efficiency 47 per cent, giving an overall average of 71 per cent. This is 1.0 percentage points lower than the revised figure for 2016. Overall efficiency is simply the sum of the individual electrical and heat efficiencies.

Table 7D: A summary of scheme performance in 2017

| | Average operating hours per annum (Full load equivalent) | Average electrical efficiency (% GCV) | Average heat efficiency (% GCV) | Average overall efficiency (% GCV) | Average heat to power ratio |
|--------------------------------------|--|---------------------------------------|---------------------------------|------------------------------------|-----------------------------|
| Main prime mover in CHP plant | | | | | |
| Back pressure steam turbine | 2,141 | 8.5 | 75 | 84 | 8.9 |
| Pass out condensing steam turbine | 3,682 | 15 | 38 | 53 | 2.5 |
| Gas turbine | 5,210 | 23 | 50 | 72 | 2.2 |
| Combined cycle | 3,545 | 25 | 49 | 74 | 2.0 |
| Reciprocating engine | 3,870 | 31 | 37 | 67 | 1.2 |
| Organic Rankine Cycle | 3,213 | 9.0 | 55 | 64 | 6.1 |
| All schemes | 3,710 | 24 | 47 | 71 | 2.0 |

CHP schemes which export and schemes with mechanical power output

7.26 Table 7E shows the electrical exports from CHP schemes between 2015 and 2017. In the 2015 edition of the Digest, for the first time we presented rigorous values for both total power exported and the Qualifying Power Output (QPO) exported. In previous editions of the Digest, power export figures have been based upon information voluntarily supplied by scheme operators. From the 2015 edition of the Digest, power export figures are based upon export meter data. The total power exported given below is therefore the value registered on the power export meter, with one adjustment made for some schemes. Where the value registered on a scheme's power export meter is greater than the Total Power Output (TPO) for the scheme, the total power exported is capped at the TPO of the scheme. This adjustment is necessary in some situations where schemes import power from another place and onward supply this power, with the onward supplied power passing through the power export meter. Mathematically, this is shown as:

$$\text{TPO Exported} = \text{Value registered on power export meter}$$

³ When comparing these statistics with other sources, care is required to ensure that the same definition of District Heating (DH) is being used.

If Value registered on power export meter > TPO, then TPO Exported is set to equal TPO.

The QPO exported is the TPO exported that is deemed good quality. This is calculated by assuming that any power consumed by the scheme is good quality power (QPO). This means that only if the scheme's consumption of power is less than the QPO will QPO become available for export. Mathematically, the QPO exported is:

QPO Exported = QPO for the scheme – Electricity consumed by the scheme, where

Electricity consumed by the scheme = Total Power Output – TPO Exported

If QPO for the scheme < Electricity consumed by the scheme, then QPO Exported is set to zero.

Table 7E also sets out the recipients of exported power. In the 2015 edition of the Digest for the first time we rigorously followed up with Schemes to obtain data on recipients of exported power. This means that this follow-up was possible for years of operation 2015, 2016 and 2017, as shown below.

| Table 7E: Electrical exports from CHP (TPO) | | | GWh |
|--|------------------|------------------|---------------|
| | 2015 | 2016 | 2017 |
| To part of same qualifying group (1) | 582 | 775 | 1,129 |
| To a firm NOT part of same qualifying group | 9,365 | 10,040(r) | 9,675 |
| To an electricity supplier | 12,596(r) | 17,931(r) | 15,725 |
| Total | 22,544(r) | 28,747(r) | 26,528 |

(1) A qualifying group is a group of two or more corporate consumers that are connected or related to each other, for example, as a subsidiary, or via a parent or holding company, or in terms of share capital.

Table 7F: Electrical exports from CHP (QPO) GWh

| | 2015 | 2016 | 2017 |
|---|--------------|-----------------|--------------|
| To part of same qualifying group (1) | 343 | 267 | 262 |
| To a firm NOT part of same qualifying group | 3,908 | 4,536(r) | 4,446 |
| To an electricity supplier | 3,482 | 3,900(r) | 3,918 |
| Total | 7,733 | 8,703(r) | 8,626 |

There was a significant increase in the power exports in 2016 relative to 2015, both for total power exports (TPO) and Good Quality (QPO) power exports. Although there was a drop off in 2017, both the TPO and QPO exported is appreciably higher in 2017 than it was in 2015. This is consistent with the step up in Load Factor (Actual) and Load Factor (CHPQA) between 2015 and 2016, which has only dropped off slightly in 2017, caused by some large power exporting CHP schemes generating more power post 2015.

7.27 In 2017, 54 large schemes exported heat, with some exporting to more than one customer. In 2016 there were 52 schemes exporting heat. As Table 7G shows, these schemes supplied 9,802 GWh of heat in 2017, which is a 6.6 per cent increase on the revised 2016 figure.

Table 7G: Heat exports from CHP GWh

| | 2015 | 2016 | 2017 |
|---|-----------------|-----------------|--------------|
| To part of same qualifying group (1) | 760 | 961 | 949 |
| To a firm NOT part of same qualifying group | 7,670(r) | 8,207(r) | 8,783 |
| To an electricity supplier | 4(r) | 25(r) | 70 |
| Total | 8,333(r) | 9,193(r) | 9,802 |

(1) A qualifying group is a group of two or more corporate consumers that are connected or related to each other, for example, as a subsidiary, or via a parent or holding company, or in terms of share capital.

7.28 There are an estimated 10 schemes with mechanical power output. For those schemes, mechanical power accounts for 9 per cent of their total power capacity (Table 7H). These schemes are predominantly on petro-chemicals or steel sites, using by-product fuels in boilers to drive steam turbines. The steam turbine is used to provide mechanical rather than electrical power, driving compressors, blowers or fans, rather than an alternator. The statistics on schemes with mechanical power are substantially unchanged from those for 2016, published in the previous edition of the Digest.

Table 7H: CHP schemes with mechanical power output in 2017

| | Unit | |
|---|------|-------|
| Number of schemes | | 10 |
| Total Power Capacity of these schemes (CHP _{TPC}) | MWe | 2,157 |
| Mechanical power capacity of these schemes | MWe | 203 |

7.29 The calculation of carbon emissions savings from CHP is complex because CHP displaces a variety of fuels, technologies and sizes of plant. The methodology and assumptions used for calculating carbon emission savings are outlined in Energy Trends June 2003⁴ (www.decc.gov.uk/en/content/cms/statistics/publications/trends/trends.aspx). The figures compare CHP with the UK fossil fuel basket carbon intensity and the UK total basket carbon intensity, which includes nuclear and renewable generation. The carbon emission savings from CHP in 2017 as compared to the fossil fuel basket were 10.70 MtCO₂, which equates to 1.83 Mt CO₂ per 1,000 MWe installed capacity. Against the total basket, CHP saved 4.91 Mt CO₂ which equates to 0.84 Mt CO₂ per 1,000 MWe installed capacity.

7.30 Corresponding figures for 2015 and 2016 are shown in Table 7I. The 2015 and 2016 CO₂ savings are revised based on revisions to the relevant data for these years in Tables 7.1, 7.4, 7.6 and 7.9 and revisions to the CO₂ intensity of grid electricity. Absolute savings (MtCO₂) are sensitive to both the levels of CHP heat and power output and the CO₂ factor attributed to grid electricity that CHP electricity displaces. When measured against the total basket of grid electricity (i.e. including nuclear

4

http://webarchive.nationalarchives.gov.uk/20060213234600/http://www.dti.gov.uk/energy/inform/energy_trends/index.shtml

and renewables) both the absolute and relative CO₂ savings delivered by CHP fell each year between 2015-2017. This is in spite of an increase in CHP power and heat outputs over this period and is explained by a 30 per cent decrease in the carbon intensity of all grid electricity over this relatively short period. Over the longer term, this downward trend in absolute and relative savings (when measured against the total basket) has been unbroken since 2012, when the CO₂ intensity of the total basket was more than double what it was in 2017. There has been a similar downward (though not unbroken) trend in savings since 2012 (when measured against the fossil fuel basket) when the CO₂ intensity of fossil fuel generated electricity was 45 per cent higher than it was in 2017, owing to an increasing proportion of fossil fuel generated electricity coming from natural gas.

Table 7I: Carbon dioxide savings due to CHP, absolute and per 1,000 MWe of installed good quality CHP capacity

| | 2015 | | 2016 | | 2017 | |
|---|-------------------|-----------------------------|-------------------|-----------------------------|-------------------|-----------------------------|
| | MtCO ₂ | MtCO ₂ /1000 MWe | MtCO ₂ | MtCO ₂ /1000 MWe | MtCO ₂ | MtCO ₂ /1000 MWe |
| Carbon savings against all fossil fuels | 12.59 | 2.21 | 10.20 | 1.81 | 10.70 | 1.83 |
| Carbon savings against all fuels (including nuclear and renewables) | 6.47 | 1.13 | 5.09 | 0.90 | 4.91 | 0.84 |

Note: (1) The CO₂ savings in Table 7I assume that CHP generated electricity avoids the transmission and distribution losses associated with its conventionally generated equivalent. These losses are assumed to be 1.5% in the case of transmission losses and 6.0% in the case of distribution losses.

(2) The CO₂ savings quoted above for 2017 are based on preliminary CO₂ intensities, for that year, for the fossil fuel basket and the total fuel basket of conventional electricity generation. As such, they are subject to revision at a later date. The CO₂ savings quoted above for 2015 and 2016 have also been revised in response to changes in the CO₂ intensity factors for electricity for these years since reporting in DUKES 2017. The figures have also been revised to reflect revisions to CHP electricity and heat output and fuel consumption.


Government policy towards CHP

7.31 There are a range of support measures to incentivise the growth of Good Quality CHP in the UK. These include:

- Exemption from the Climate Change Levy (CCL) of all fuel inputs to, and electricity outputs from, Good Quality CHP. This exemption has been in place since the introduction of the CCL in 2001.
- From April 2013, exemption from Carbon Price Support (CPS) on fuel to CHP consumed for the generation of heat
- From April 2015, exemption from Carbon Price Support (CPS) on fuel to CHP consumed for the generation of Good Quality CHP electricity which is consumed on site
- Eligibility to Enhanced Capital Allowances for Good Quality CHP plant and machinery.
- Business Rates exemption for CHP power generation plant and machinery.
- Reduction of VAT (from 20 to 5 per cent) on domestic micro-CHP installations.
- Extension of the eligibility for Renewable Obligation Certificates (ROCs) to energy from waste plants that utilise CHP.
- Specific Renewable Heat Incentive (RHI) for biomass fuelled Good Quality CHP certified under CHPQA.
- Contract for Difference (CFD) for biomass fuelled CHP
- The zero-rating of heat under the Carbon Reduction Commitment Energy Efficiency Scheme (CRC), this means that allowances do not have to be purchased by a site covered by CRC for heat that it imports. This incentivises the use of CHP heat outputs.

7.32 Table 7.1 shows the installed Good Quality CHP capacity in each year. However, this table hides the underlying market activity that replaces older capacity as it is taken out of service over time. Chart 7.4 gives an idea of the scale of this activity since 2000 for CHP schemes certified under CHPQA. The dotted line shows how much of the Good Quality CHPQA capacity that was in place in 2000 remained in place in subsequent years, while the upper line shows the actual Good Quality CHPQA capacity in place in each year. For any year since 2000, the gap between these two lines represents the new Good Quality CHPQA capacity installed between 2000 and that year. By 2017 there had been just over 3.1 GWe of new Good Quality CHPQA capacity installed since 2000.

Chart 7.4: Underlying market activity – operating Good Quality CHP versus retained Good Quality CHP



International context

7.33 Phase III of EU ETS runs from 2013 until 2020. Under this phase there is no allocation made in respect of CO₂ emissions associated with the generation of electricity, including electricity generated by CHP. However, there is an allocation made in respect of EU ETS CO₂ emissions associated with measurable CHP heat consumption. The allocation is based upon harmonised benchmarks for heat production. In 2013 an EU ETS installation consuming CHP generated heat (not deemed at risk of carbon leakage) will have received a preliminary free allocation which is 80% of the allocation determined using this benchmark, declining linearly to 30% by 2020. Where the installation consuming the heat is deemed at significant risk of carbon leakage, then it will receive a preliminary free allocation which is 100% of the allocation determined using the benchmark for the duration of Phase III of EU ETS⁵. If the consumer of the heat is not an EU ETS installation, then the allocation is given to the heat producer. The benchmark for heat adopted by the European Commission is based on the use of natural gas with a conversion efficiency of 90% (N.C.V.). This means that the benchmark allocation made for each MWh of heat generated by a CHP scheme which is subsequently is 0.224 tCO₂⁶.

⁵ In determining the final free allocation received by the installation, the preliminary free allocation is multiplied by a factor known as the cross-sectoral correction factor. The cross-sectoral correction factor is applied to ensure that the total amount of free allocation does not exceed a certain cap. For EU ETS Phase III, the cross-sectoral correction factor is a factor that is less than 1 and declines linearly from 0.94 to 0.82 between 2013 and 2020. This means that the final free allocation is always less than the preliminary free allocation.

⁶ Where the CHP supplies heat to an EU ETS Phase III sub-installation or installation and the sub-installation or installation produces a product that is product benchmarked, then an allocation is not made in respect of the heat supplied but in respect of the product produced.

Technical notes and definitions

7.34 These notes and definitions are in addition to the technical notes and definitions covering all fuels and energy as a whole in Chapter 1, paragraphs 1.28 to 1.64.

Data for 2017

7.35 The data are summarised from the results of a long-term project undertaken by Ricardo Energy & Environment on behalf of the Department of Business, Energy and Industrial Strategy (BEIS). Data are included for CHP schemes installed in all sectors of the UK economy.

7.36 Data for 2017 were based on data supplied to the CHPQA programme, information from the Iron and Steel Statistics Bureau (ISSB), information from Ofgem in respect of “Renewables Obligation Certificates” (ROCs), information from the CHP Sales database maintained by the CHPA and from a survey of anaerobic digestion (AD) sites. Ninety-two per cent of the total capacity is from schemes that have been certified under the CHPQA programme. Sewage Treatment Works and other AD schemes that do not provide returns to CHPQA have been included based on ROCs and FITs information from Ofgem returns. The data from these sources accounts for approximately 6.0 per cent of total electrical capacity. The contribution from this source to the overall CHP statistics is higher than in previous years. The reason for this is explained in paragraph 7.9. The balance of the capacity is for schemes covered by ISSB sources (<1 per cent), CHPA Sales Database (<1 per cent) and for schemes not covered by the above sources which were interpolated from historical data (<1 per cent).

Definitions of schemes

7.37 There are four principal types of CHP system:

- **Steam turbine**, where steam at high pressure is generated in a boiler. In **back pressure steam turbine systems**, the steam is wholly or partly used in a turbine before being exhausted from the turbine at the required pressure for the site. In **pass-out condensing steam turbine systems**, a proportion of the steam used by the turbine is extracted at an intermediate pressure from the turbine with the remainder being fully condensed before it is exhausted at the exit. (Condensing steam turbines without pass out and which do not utilise steam are not included in these statistics as they are not CHP). The boilers used in such schemes can burn a wide variety of fuels including coal, gas, oil, and waste-derived fuels. With the exception of waste-fired schemes, a steam turbine plant has often been in service for several decades. Steam turbine schemes capable of supplying useful steam have electrical efficiencies of between 10 and 20 per cent, depending on size, and thus between 70 per cent and 30 per cent of the fuel input is available as useful heat. Steam turbines used in CHP applications typically range in size from a few MWe to over 100 MWe.
- **Gas turbine systems**, often aero-engine derivatives, where fuel (gas or gas-oil) is combusted in the gas turbine and the exhaust gases are normally used in a waste heat boiler to produce usable steam, though the exhaust gases may be used directly in some process applications. Gas turbines range from 30 kWe upwards, achieving electrical efficiency of 23 to 30 per cent (depending on size) and with the potential to recover up to 50 per cent of the fuel input as useful heat. They have been common in CHP since the mid-1980s. The waste heat boiler can include supplementary or auxiliary firing using a wide range of fuels, and thus the heat to power ratio of the scheme can vary.
- **Combined cycle systems**, where the plant comprises more than one prime mover. These are usually gas turbines where the exhaust gases are utilised in a steam generator, the steam from which is passed wholly or in part into one or more steam turbines. In rare cases reciprocating engines may be linked with steam turbines. Combined cycle is suited to larger installations of 7 MWe and over. They achieve higher electrical efficiency and a lower heat to power ratio than steam turbines or gas turbines. Recently installed combined cycle gas turbine (CCGT) schemes have achieved an electrical efficiency approaching 50 per cent, with 20 per cent heat recovery, and a heat to power ratio of less than 1:1.
- **Reciprocating engine systems** range from less than 100 kWe up to around 5 MWe and are found in applications where production of hot water (rather than steam) is the main requirement, for example, on smaller industrial sites as well as in buildings. They are based on auto engine or

marine engine derivatives converted to run on gas. Both compression ignition and spark ignition firing is used. Reciprocating engines operate at around 28 to 33 per cent electrical efficiency with around 50 per cent to 33 per cent of the fuel input available as useful heat. Reciprocating engines produce two grades of waste heat: high grade heat from the engine exhaust and low-grade heat from the engine cooling circuits.

- **Organic Rankine Cycle systems** operate on the same principle as steam turbines but, instead of using water steam as the working fluid, use organic substances with a lower boiling point and higher vapour pressure than water. This allows heat of a lower temperature to be converted into power via evaporation of the organic working fluid and expansion through a turbine. Low and medium temperature heat sources in the temperature range 80 to 350°C are exploited by ORC systems. The accessibility of low grade heat means that geothermal, industrial waste heat, biomass and solar heat sources can be exploited by ORC systems for the generation of power.
- **Steam screw expander systems** are based upon rotary screw expanders, rather than the turbine blades used in conventional steam turbine systems (see above). This allows power to be generated from wet steam, rather than the superheated dry steam that must be utilised in conventional steam turbines if turbine blade damage is to be avoided. Such systems can, for example, be installed in the place of pressure reduction valves in steam distribution systems, allowing the recovery of energy in the form of mechanical power and the onward supply of steam at the conditions desired downstream.

Determining fuel consumption for heat and electricity

7.38 In order to provide a comprehensive picture of electricity generation in the United Kingdom and the fuels used to generate that electricity, the energy input to CHP schemes has to be allocated between heat and electricity production. This allocation is notional and is not determinate.

7.39 The convention used to allocate the fuels to heat and electricity relates the split of fuels to the relative efficiency of heat and electricity supply. The efficiency of utility plant varies widely: electricity generation from as little as 25 per cent to more than 50 per cent and boilers from 50 per cent to more than 90 per cent. Thus, it is around twice as hard to generate a unit of electricity as it is to generate a unit of heat. Accordingly, a simple convention can be implemented whereby twice as many units of fuel are allocated to each unit of electricity generated, as to each unit of heat supplied. This approach is consistent with the Defra Guidelines for Company Reporting on greenhouse gas emissions and for Negotiated Agreements on energy efficiency agreed between Government and industry as part of the Climate Change Levy (CCL) package. It recognises that, in developing a CHP scheme, both the heat customer(s) and the electricity generator share in the savings.

7.40 The assumption in this convention that it is twice as hard to generate a unit of electricity as heat, is appropriate for the majority of CHP schemes. However, for some types of scheme (for example in the iron and steel sector) this allocation is less appropriate and can result in very high apparent heat efficiencies. These, however, are only notional efficiencies.

The effects on the statistics of using CHPQA

7.41 Paragraph 7.5 described how schemes were scaled back so that only CHP_{QPC} and CHP_{QPO} are included in the CHP statistics presented in this Chapter. This is illustrated in Table 7J where it is seen that 419 schemes were scaled back for year of operation 2017. For information, in 2016, 380 schemes (revised) were scaled back.

7.42 In 2017, the power output from these schemes was scaled back from a total of 33,120 GWh to 12,181 GWh. The total fuel input to these schemes was 111,568 GWh of which 55,328 GWh was regarded as being for power only. For 2016, the total power output was scaled back from 35,822 GWh to 12,189 GWh. The scale back of power was greater in 2016 than in 2017 as a number of large schemes generated more power for export in 2016 than in 2017, without a corresponding increase in the useful consumption of heat. This is consistent with the peak in Load Factor (Actual) in 2016 (60.0 per cent).


Table 7J: CHP capacity, output and fuel use which has been scaled back in 2017

| | Units | |
|--|-------|---------|
| Number of schemes requiring scaling back | | 419 |
| Total Power Capacity of these schemes (CHP _{TPC}) | MWe | 6,599 |
| Qualifying Power Capacity of these schemes (CHP _{QPC}) | MWe | 3,818 |
| Total power output of these schemes (CHP _{TPO}) | GWh | 33,120 |
| Qualifying Power Output of these schemes (CHP _{QPO}) | GWh | 12,181 |
| Electricity regarded as "Power only" not from CHP (CHP _{TPO} - CHP _{QPO}) | GWh | 20,939 |
| Total Fuel Input of these schemes (CHP _{TFI}) | GWh | 111,568 |
| Fuel input regarded as being for "Power only" use i.e. not for CHP | GWh | 55,328 |

**This figure includes generation from major power producers*

7.43 The evolution of Total Power Capacity (TPC) and Qualifying Power Capacity (QPC) over time is shown in Chart 7.5.

Chart 7.5: Installed CHP capacity by year



Typical Power and Heat Efficiencies and Heat to Power Ratios of Prime Movers

7.44 The figures quoted above in Table 6D are for CHP schemes. These schemes may contain supplementary boilers, supplementary firing and auxiliary firing. The figures are, therefore, not reflective of the power and heat efficiencies and the heat to power ratios of the prime mover when it is considered in isolation.

Contacts:

Richard Hodges
Ricardo Energy & Environment
Richard.Hodges@ricardo.com
01235 753 047

Liz Waters
BEIS Energy Statistics Team
elizabeth.waters@beis.gov.uk
0300 068 5735

7.1 CHP installations by capacity and size range

| | 2013 | 2014 | 2015 | 2016 | 2017 |
|--------------------------------|--------------|--------------|---------------|---------------|--------------|
| Number of Schemes | 2,029 | 2,076 | 2,130r | 2,224r | 2,386 |
| <= 100 kW _e | 602 | 608 | 615r | 642r | 669 |
| > 100 kW _e to 1 MWe | 1,083 | 1,102 | 1,129r | 1,183r | 1,239 |
| >1 MWe to 2 MWe | 114 | 132 | 141r | 151 | 183 |
| > 2 MWe to 10 MWe | 165 | 169 | 179r | 180 | 228 |
| > 10 MWe + | 65 | 65 | 66r | 68r | 67 |
| Total Capacity | 5,924 | 5,892 | 5,708r | 5,625r | 5,835 |
| <= 100 kW _e | 39 | 39 | 40r | 41r | 43 |
| > 100 kW _e to 1 MWe | 273 | 280 | 296r | 309r | 337 |
| >1 MWe to 2 MWe | 164 | 190 | 206r | 218r | 271 |
| > 2 MWe to 10 MWe | 759 | 781 | 818r | 824r | 1,003 |
| > 10 MWe + | 4,689 | 4,601 | 4,348r | 4,232r | 4,181 |

(1) A site may contain more than one CHP scheme; the capacity categories have changed since publication in the 2013 Digest.

(2) MicroCHP schemes installed under FIT are not included in these figures (or any subsequent figures in chapter 7). At the end of 2017 515 such schemes were registered on Ofgem's Central FIT Register totalling 0.54MWe

7.2 Fuel used to generate electricity and heat in CHP installations

| | GWh | | | | |
|--|---------------|---------------|----------------|----------------|---------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Fuel used to generate electricity (1) | | | | | |
| Coal (2) | 420 | 386 | 137 | 113 | 102 |
| Fuel oil | 145 | 120 | 122r | 133r | 93 |
| Natural gas | 31,314 | 30,615 | 30,435r | 31,496r | 31,797 |
| Renewable fuels (3) | 4,428 | 5,374 | 4,829r | 6,393r | 9,222 |
| Other fuels (4) | 4,735 | 4,773 | 4,180 | 3,877r | 4,078 |
| Total all fuels | 41,042 | 41,268 | 39,704r | 42,011r | 45,291 |
| Fuel used to generate heat | | | | | |
| Coal (2) | 1,592 | 863 | 439 | 371 | 379 |
| Fuel oil | 205 | 140 | 164r | 147r | 69 |
| Natural gas | 32,038 | 29,781 | 27,743r | 28,960r | 30,127 |
| Renewable fuels (3) | 3,429 | 3,924 | 4,187r | 4,799r | 5,636 |
| Other fuels (4) | 10,124 | 10,230 | 10,339 | 8,835r | 8,777 |
| Total all fuels | 47,388 | 44,939 | 42,872r | 43,111r | 44,988 |
| Overall fuel use | | | | | |
| Coal (2) | 2,012 | 1,249 | 577 | 484 | 480 |
| Fuel oil | 350 | 260 | 287r | 279r | 161 |
| Natural gas | 63,352 | 60,397 | 58,178r | 60,456r | 61,924 |
| Renewable Fuel o/w; | 7,856 | 9,298 | 9,016r | 11,192r | 14,858 |
| <i>Bioliquid</i> | 70 | 62 | 60r | 82r | 103 |
| <i>Biomass</i> | 3,363 | 4,042 | 3,179 | 4,233r | 5,103 |
| <i>Waste</i> | 1,205 | 1,691 | 2,011 | 3,039r | 3,027 |
| <i>Biogas/Syngas</i> | 3,218 | 3,504 | 3,766r | 3,837r | 6,625 |
| Other Fuels (3) | 14,859 | 15,003 | 14,519 | 12,712r | 12,855 |
| Total all fuels | 88,430 | 86,207 | 82,576r | 85,123r | 90,279 |

(1) See paragraphs 7.38 to 7.39 and the CHP methodology note on the BEIS website for an explanation of the method used to allocate fuel use between heat generation and electricity generation.

(2) Includes coke.

(3) Other fuels include: process by-products, coke oven gas, blast furnace gas, gas oil and refinery gas.

7.3 Fuel used by types of CHP installation

| | GWh | | | | |
|------------------------------------|---------------|---------------|----------------|----------------|---------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Coal | | | | | |
| Back pressure steam turbine | 550 | 572 | 577 | 484 | 480 |
| Gas turbine | - | - | - | - | - |
| Combined cycle | 1,358 | 674 | - | - | - |
| Reciprocating engine | 1 | 1 | - | - | - |
| Pass out condensing steam turbine | 102 | 2 | - | - | - |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 2,012 | 1,249 | 577 | 484 | 480 |
| Fuel Oil | | | | | |
| Back pressure steam turbine | 145 | 100 | 95 | 77 | 17 |
| Gas turbine | 5 | 3 | 1 | 3 | 1 |
| Combined cycle | 56 | 16 | 25 | 65 | 14 |
| Reciprocating engine | 123 | 122 | 113r | 116r | 113 |
| Pass out condensing steam turbine | 21 | 20 | 52 | 18r | 16 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 350 | 260 | 287r | 279r | 161 |
| Natural Gas | | | | | |
| Back pressure steam turbine | 2,544 | 2,079 | 1,466r | 1,118r | 1,340 |
| Gas turbine | 8,683 | 8,492 | 8,555 | 9,145r | 9,468 |
| Combined cycle | 42,164 | 39,617 | 36,956 | 37,963r | 38,671 |
| Reciprocating engine | 9,574 | 9,988 | 10,897r | 11,986r | 12,243 |
| Pass out condensing steam turbine | 388 | 221 | 305r | 245r | 201 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 63,352 | 60,397 | 58,178r | 60,456r | 61,924 |
| Renewable Fuels (2) | | | | | |
| Back pressure steam turbine | 1,484 | 1,081 | 1,037r | 852r | 1,099 |
| Gas turbine | 12 | 12 | 12 | 12 | 13 |
| Combined cycle | 87 | 60 | 67 | 191r | 213 |
| Reciprocating engine | 3,226 | 3,492 | 3,747r | 3,846r | 6,657 |
| Pass out condensing steam turbine | 3,049 | 4,654 | 4,153 | 6,051r | 6,469 |
| Organic Rankine Cycle ¹ | - | - | | 241r | 407 |
| | 7,856 | 9,298 | 9,016r | 11,192r | 14,858 |
| Other Fuels (3) | | | | | |
| Back pressure steam turbine | 1,581 | 1,634 | 1,737r | 1,678r | 1,795 |
| Gas turbine | 155 | 153 | 212 | 245 | 152 |
| Combined cycle | 10,306 | 9,915 | 9,782 | 9,153r | 9,452 |
| Reciprocating engine | 47 | 68 | 91 | 96r | 47 |
| Pass out condensing steam turbine | 2,771 | 3,234 | 2,697r | 1,540r | 1,410 |
| Organic Rankine Cycle ¹ | - | - | - | - | 0 |
| | 14,859 | 15,003 | 14,519r | 12,712r | 12,855 |
| Total - all fuels | | | | | |
| Back pressure steam turbine | 6,303 | 5,466 | 4,913r | 4,209r | 4,732 |
| Gas turbine | 8,854 | 8,659 | 8,779 | 9,405r | 9,634 |
| Combined cycle | 53,972 | 50,281 | 46,830 | 47,372r | 48,350 |
| Reciprocating engine | 12,971 | 13,670 | 14,848r | 16,043r | 19,060 |
| Pass out condensing steam turbine | 6,331 | 8,131 | 7,207r | 7,854r | 8,096 |
| Organic Rankine Cycle ¹ | - | - | | 241r | 407 |
| | 88,430 | 86,207 | 82,576r | 85,123r | 90,279 |

(1) From 2015, Organic Rankine Cycle CHP schemes are included in the statistics

For 2015, where there is a "...." entered against this category, the data are merged with the back pressure steam turbine technology category, in order to avoid disclosure. In 2017's publication, 2016 was also disclosive but since publication, sufficient data have been received to enable splitting out for that year.

(2) Renewable fuels include: Biomass, sewage gas, other biogases, municipal solid waste and refuse derived fuels

(3) Other fuels include: process by-products, coke oven gas, blast furnace gas, gas oil and refinery gas

7.4 CHP - electricity generated by fuel and type of installation

| | GWh | | | | |
|------------------------------------|---------------|---------------|----------------|----------------|---------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Coal | | | | | |
| Back pressure steam turbine | 63 | 67 | 66 | 56 | 49 |
| Gas turbine | - | - | - | - | - |
| Combined cycle gas turbine | 101 | 113 | - | - | - |
| Reciprocating engine | 0 | 0 | - | - | - |
| Pass-out condensing steam turbine | 9 | 0 | - | - | - |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 173 | 179 | 66 | 56 | 49 |
| Fuel oil | | | | | |
| Back pressure steam turbine | 17 | 13 | 12 | 10 | 2 |
| Gas turbine | 1 | 0 | 0 | 1 | 0 |
| Combined cycle gas turbine | 12 | 3 | 6 | 14 | 3 |
| Reciprocating engine | 42 | 42 | 40r | 40r | 40 |
| Pass-out condensing steam turbine | 1 | 1 | 2 | 1r | 0 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 72 | 59 | 60r | 65r | 46 |
| Natural gas | | | | | |
| Back pressure steam turbine | 168 | 172 | 118r | 85r | 97 |
| Gas turbine | 2,034 | 1,953 | 1,966 | 2,034r | 2,146 |
| Combined cycle gas turbine | 10,467 | 10,097 | 10,210 | 10,357r | 10,084 |
| Reciprocating engine | 2,628 | 2,795 | 3,084r | 3,447r | 3,549 |
| Pass-out condensing steam turbine | 34 | 27 | 35r | 21r | 20 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 15,331 | 15,045 | 15,412r | 15,945r | 15,895 |
| Renewable Fuel | | | | | |
| Back pressure steam turbine | 213 | 168 | 170r | 161r | 206 |
| Gas turbine | 2 | 2 | 2 | 2 | 3 |
| Combined cycle gas turbine | 15 | 16 | 18 | 53r | 61 |
| Reciprocating engine | 971 | 1,056 | 1,132r | 1,177r | 2,241 |
| Pass-out condensing steam turbine | 599 | 885 | 608 | 1,018r | 1,138 |
| Organic Rankine Cycle ¹ | - | - | | 25r | 37 |
| | 1,801 | 2,128 | 1,930r | 2,437r | 3,685 |
| Other Fuels | | | | | |
| Back pressure steam turbine | 82 | 106 | 95r | 59r | 47 |
| Gas turbine | 29 | 21 | 35 | 38r | 21 |
| Combined cycle gas turbine | 1,967 | 1,935 | 1,785 | 1,722r | 1,836 |
| Reciprocating engine | 11 | 16 | 19 | 25r | 13 |
| Pass-out condensing steam turbine | 127 | 206 | 132r | 59r | 56 |
| Organic Rankine Cycle ¹ | - | - | - | -r | - |
| | 2,215 | 2,284 | 2,066 | 1,903r | 1,973 |
| Total - All Fuels | | | | | |
| Back pressure steam turbine | 543 | 526 | 461r | 371r | 401 |
| Gas turbine | 2,066 | 1,977 | 2,003 | 2,075r | 2,169 |
| Combined cycle gas turbine | 12,561 | 12,164 | 12,019 | 12,146r | 11,984 |
| Reciprocating engine | 3,652 | 3,909 | 4,276r | 4,689r | 5,842 |
| Pass-out condensing steam turbine | 770 | 1,119 | 776r | 1,099r | 1,214 |
| Organic Rankine Cycle ¹ | - | - | | 25r | 37 |
| Total | 19,592 | 19,695 | 19,534r | 20,405r | 21,648 |

(1) From 2015, Organic Rankine Cycle CHP schemes are included in the statistics For 2015, where there is a "...." entered against this category, the data are merged with the back pressure steam turbine technology category, in order to avoid disclosure. In 2017's publication,

(2) Renewable fuels include: Biomass, sewage gas, other biogases, municipal solid waste and refuse derived fuels

(3) Other fuels include: process by-products, coke oven gas, blast furnace gas, gas oil and refinery gas

7.5 CHP - electrical capacity by fuel and type of installation

| | MWe | | | | |
|------------------------------------|--------------|--------------|---------------|---------------|--------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Coal | | | | | |
| Back pressure steam turbine | 20 | 21 | 22 | 22 | 22 |
| Gas turbine | - | - | - | - | - |
| Combined cycle gas turbine | 197 | 128 | - | - | - |
| Reciprocating engine | 0 | 0 | - | - | - |
| Pass-out condensing steam turbine | 2 | 0 | - | - | - |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 220 | 150 | 22 | 22 | 22 |
| Fuel oil | | | | | |
| Back pressure steam turbine | 6 | 5 | 4 | 5 | 1 |
| Gas turbine | 0 | 0 | 0 | 0 | 0 |
| Combined cycle gas turbine | 3 | 1 | 1 | 3 | 1 |
| Reciprocating engine | 7 | 6 | 6r | 6r | 6 |
| Pass-out condensing steam turbine | 1 | 1 | 2 | 2r | 0 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 17 | 13 | 13r | 16r | 8 |
| Natural gas | | | | | |
| Back pressure steam turbine | 79 | 71 | 50r | 42r | 48 |
| Gas turbine | 422 | 360 | 401 | 401r | 412 |
| Combined cycle gas turbine | 3,114 | 3,220 | 3,005 | 2,885r | 2,806 |
| Reciprocating engine | 763 | 825 | 857r | 933r | 987 |
| Pass-out condensing steam turbine | 9 | 9 | 13r | 7r | 7 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 4,387 | 4,485 | 4,325r | 4,269r | 4,260 |
| Renewable Fuel (2) | | | | | |
| Back pressure steam turbine | 37 | 28 | 28r | 28r | 30 |
| Gas turbine | 1 | 1 | 1 | 1 | 1 |
| Combined cycle gas turbine | 2 | 3 | 3 | 8r | 8 |
| Reciprocating engine | 230 | 236 | 299r | 315r | 502 |
| Pass-out condensing steam turbine | 162 | 180 | 226 | 274r | 293 |
| Organic Rankine Cycle ¹ | - | - | | 8r | 11 |
| | 432 | 447 | 556r | 634r | 845 |
| Other Fuels (3) | | | | | |
| Back pressure steam turbine | 67 | 67 | 80r | 89r | 86 |
| Gas turbine | 9 | 4 | 10 | 6r | 4 |
| Combined cycle gas turbine | 700 | 602 | 583 | 540r | 565 |
| Reciprocating engine | 15 | 18 | 19 | 20r | 15 |
| Pass-out condensing steam turbine | 77 | 107 | 100r | 29r | 30 |
| Organic Rankine Cycle ¹ | - | - | -r | -r | - |
| | 868 | 798 | 792 | 685r | 699 |
| Total - All Fuels | | | | | |
| Back pressure steam turbine | 210 | 192 | 184r | 185r | 187 |
| Gas turbine | 431 | 364 | 411 | 409r | 416 |
| Combined cycle gas turbine | 4,018 | 3,954 | 3,592 | 3,437r | 3,380 |
| Reciprocating engine | 1,014 | 1,085 | 1,181r | 1,275r | 1,510 |
| Pass-out condensing steam turbine | 251 | 297 | 340r | 312r | 330 |
| Organic Rankine Cycle ¹ | - | - | | 8r | 11 |
| Total | 5,924 | 5,892 | 5,708r | 5,625r | 5,835 |

(1) From 2015, Organic Rankine Cycle CHP schemes are included in the statistics for 2015, where there is a "...." entered against this category, the data are merged with the back pressure steam turbine technology category, in order to avoid disclosure. In 2017's publication, 2016 was also disclosive. However, since publication, sufficient data have been received to enable splitting out for that year.

(2) Renewable fuels include: Biomass, sewage gas, other biogases, municipal solid waste and refuse derived fuels

(3) Other fuels include: process by-products, coke oven gas, blast furnace gas, gas oil and refinery gas

7.6 CHP - heat generated by fuel and type of installation

| | GWh | | | | |
|------------------------------------|---------------|---------------|----------------|----------------|---------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Coal | | | | | |
| Back pressure steam turbine | 434 | 432 | 423 | 366 | 366 |
| Gas turbine | - | - | - | - | - |
| Combined cycle gas turbine | 776 | 381 | - | - | - |
| Reciprocating engine | 1 | 0 | - | - | - |
| Pass-out condensing steam turbine | 92 | 1 | - | - | - |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 1,302 | 813 | 423 | 366 | 366 |
| Fuel oil | | | | | |
| Back pressure steam turbine | 121 | 78 | 71 | 60 | 13 |
| Gas turbine | 3 | 2 | 1 | 2 | 1 |
| Combined cycle gas turbine | 31 | 8 | 13 | 37 | 8 |
| Reciprocating engine | 36 | 35 | 32r | 34r | 32 |
| Pass-out condensing steam turbine | 13 | 13 | 32 | 11r | 10 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 204 | 136 | 149r | 143r | 63 |
| Natural gas | | | | | |
| Back pressure steam turbine | 2,082 | 1,716 | 1,242r | 931r | 1,116 |
| Gas turbine | 4,506 | 4,365 | 4,265 | 4,634r | 4,737 |
| Combined cycle gas turbine | 19,961 | 18,540 | 17,200 | 17,791r | 18,378 |
| Reciprocating engine | 4,443 | 4,424 | 4,864r | 5,358r | 5,467 |
| Pass-out condensing steam turbine | 291 | 121 | 153r | 119r | 101 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 31,283 | 29,164 | 27,724r | 28,833r | 29,800 |
| Renewable Fuel (2) | | | | | |
| Back pressure steam turbine | 758 | 554 | 408r | 300r | 349 |
| Gas turbine | 2 | 2 | 2 | 2 | 3 |
| Combined cycle gas turbine | 34 | 30 | 34 | 95r | 110 |
| Reciprocating engine | 873 | 961 | 991r | 1,013r | 1,509 |
| Pass-out condensing steam turbine | 1,113 | 1,423 | 1,634 | 1,944r | 2,028 |
| Organic Rankine Cycle ¹ | - | - | | 120r | 223 |
| | 2,780 | 2,970 | 3,068 | 3,474 | 4,222 |
| Other Fuels (3) | | | | | |
| Back pressure steam turbine | 1,458 | 1,519 | 1,665r | 1,659r | 1,724 |
| Gas turbine | 83 | 62 | 91 | 115 | 61 |
| Combined cycle gas turbine | 5,564 | 5,243 | 5,528 | 5,110r | 5,090 |
| Reciprocating engine | 15 | 20 | 26 | 33r | 14 |
| Pass-out condensing steam turbine | 1,660 | 2,030 | 1,560r | 938r | 900 |
| Organic Rankine Cycle ¹ | - | - | -r | -r | - |
| | 8,781 | 8,874 | 8,870 | 7,855r | 7,788 |
| Total - All Fuels | | | | | |
| Back pressure steam turbine | 4,853 | 4,298 | 3,809r | 3,316r | 3,568 |
| Gas turbine | 4,595 | 4,430 | 4,359 | 4,753r | 4,801 |
| Combined cycle gas turbine | 26,366 | 24,201 | 22,775 | 23,033r | 23,585 |
| Reciprocating engine | 5,369 | 5,441 | 5,913r | 6,438r | 7,022 |
| Pass-out condensing steam turbine | 3,168 | 3,587 | 3,379r | 3,011r | 3,038 |
| Organic Rankine Cycle ¹ | - | - | | 120r | 223 |
| Total | 44,350 | 41,957 | 40,234r | 40,670r | 42,238 |

(1) From 2015, Organic Rankine Cycle CHP schemes are included in the statistics. For 2015, where there is a "...." entered against this category, the data are merged with the back pressure steam turbine technology category, in order to avoid disclosure. In 2017's publication, 2016 was also disclosive, however, since publication, sufficient data have been received to enable splitting out for that year.

(2) Renewable fuels include: Biomass, sewage gas, other biogases, municipal solid waste and refuse derived fuels

(3) Other fuels include: process by-products, coke oven gas, blast furnace gas, gas oil and refinery gas

7.7 CHP - heat capacity by fuel and type of installation

| | MWth | | | | |
|------------------------------------|---------------|---------------|----------------|----------------|---------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Coal | | | | | |
| Back pressure steam turbine | 124 | 134 | 137 | 134 | 141 |
| Gas turbine | - | - | - | - | - |
| Combined cycle gas turbine | 301 | 169 | - | - | - |
| Reciprocating engine | 2 | 1 | - | - | - |
| Pass-out condensing steam turbine | 48 | 20 | - | - | - |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 474 | 324 | 137 | 134 | 141 |
| Fuel oil | | | | | |
| Back pressure steam turbine | 42 | 32 | 31 | 34 | 7 |
| Gas turbine | 1 | 1 | 1 | 2 | 0 |
| Combined cycle gas turbine | 14 | 6 | 5 | 12 | 3 |
| Reciprocating engine | 8 | 7 | 5r | 7r | 5 |
| Pass-out condensing steam turbine | 5 | 5 | 15 | 9r | 7 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 70 | 51 | 56r | 64r | 22 |
| Natural gas | | | | | |
| Back pressure steam turbine | 829 | 751 | 470r | 393r | 439 |
| Gas turbine | 1,781 | 1,662 | 1,785 | 1,807r | 1,833 |
| Combined cycle gas turbine | 9,750 | 9,836 | 8,946 | 8,680r | 8,566 |
| Reciprocating engine | 2,758 | 2,991 | 3,153r | 3,312r | 3,495 |
| Pass-out condensing steam turbine | 145 | 241 | 72r | 51r | 44 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 15,263 | 15,481 | 14,426r | 14,243r | 14,377 |
| Renewable Fuel (2) | | | | | |
| Back pressure steam turbine | 155 | 129 | 128r | 111r | 118 |
| Gas turbine | 4 | 4 | 4 | 4 | 4 |
| Combined cycle gas turbine | 258 | 12 | 14 | 39r | 41 |
| Reciprocating engine | 303 | 313 | 420r | 433r | 673 |
| Pass-out condensing steam turbine | 737 | 905 | 1,232 | 1,644r | 1,690 |
| Organic Rankine Cycle ¹ | - | - | | 78r | 111 |
| | 1,456 | 1,363 | 1,797r | 2,310r | 2,637 |
| Other Fuels (3) | | | | | |
| Back pressure steam turbine | 586 | 593 | 706r | 784r | 758 |
| Gas turbine | 32 | 7 | 20 | 18r | 7 |
| Combined cycle gas turbine | 3,578 | 1,991 | 1,946 | 1,818r | 1,828 |
| Reciprocating engine | 15 | 18 | 20 | 21r | 13 |
| Pass-out condensing steam turbine | 694 | 2,401 | 983r | 404r | 410 |
| Organic Rankine Cycle ¹ | - | - | - | - | - |
| | 4,904 | 5,010 | 3,675 | 3,045 | 3,015 |
| Total - All Fuels | | | | | |
| Back pressure steam turbine | 1,735 | 1,638 | 1,471r | 1,456r | 1,462 |
| Gas turbine | 1,818 | 1,674 | 1,810 | 1,830r | 1,843 |
| Combined cycle gas turbine | 13,900 | 12,014 | 10,911 | 10,549 | 10,438 |
| Reciprocating engine | 3,085 | 3,330 | 3,597r | 3,773r | 4,186 |
| Pass-out condensing steam turbine | 1,628 | 3,573 | 2,303r | 2,109r | 2,151 |
| Organic Rankine Cycle ¹ | - | - | | 78r | 111 |
| Total | 22,167 | 22,228 | 20,091r | 19,795r | 20,191 |

(1) From 2015, Organic Rankine Cycle CHP schemes are included in the statistics. For 2015, where there is a "...." entered against this category, the data are merged with the back pressure steam turbine technology category, in order to avoid disclosure. In 2017's publication, 2016 was also disclosive; however, since publication, sufficient data have been received so that 2016 is no longer disclosive.

(2) Renewable fuels include: Biomass, sewage gas, other biogases, municipal solid waste and refuse derived fuels

(3) Other fuels include: process by-products, coke oven gas, blast furnace gas, gas oil and refinery gas

7.8 CHP capacity, output and total fuel use⁽¹⁾ by sector

| | Unit | 2013 | 2014 | 2015 | 2016 | 2017 |
|---|------|--------|--------|--------|---------|--------|
| Iron and steel and non ferrous metals | | | | | | |
| Number of sites | | 6 | 6 | 6 | 5 | 5 |
| Electrical capacity | MWe | 81 | 81 | 81 | 40 | 40 |
| Heat capacity | MWth | 674 | 674 | 674 | 435 | 435 |
| Electrical output | GWh | 163 | 158 | 118 | 98r | 73 |
| Heat output | GWh | 1,701 | 1,776 | 1,506 | 1,024r | 949 |
| Fuel use | GWh | 2,885 | 2,743 | 2,720 | 1,739r | 1,503 |
| of which : for electricity | GWh | 435 | 395 | 316 | 255r | 188 |
| for heat | GWh | 2,450 | 2,348 | 2,404 | 1,484r | 1,315 |
| Chemicals | | | | | | |
| Number of sites | | 52 | 52 | 52 | 52 | 51 |
| Electrical capacity | MWe | 1,461 | 1,437 | 1,183 | 1,137 | 1,102 |
| Heat capacity | MWth | 4,828 | 4,878 | 4,458 | 4,363 | 4,252 |
| Electrical output | GWh | 5,212 | 4,574 | 4,977 | 4,792r | 4,542 |
| Heat output | GWh | 12,282 | 11,010 | 10,487 | 10,396r | 10,554 |
| Fuel use | GWh | 25,189 | 22,685 | 22,110 | 22,156r | 21,970 |
| of which : for electricity | GWh | 11,543 | 10,214 | 10,458 | 10,487r | 10,034 |
| for heat | GWh | 13,646 | 12,470 | 11,652 | 11,668r | 11,936 |
| Oil and gas terminals and oil refineries | | | | | | |
| Number of sites | | 11 | 10 | 9 | 9 | 9 |
| Electrical capacity | MWe | 2,380 | 2,278 | 2,235 | 2,226r | 2,208 |
| Heat capacity | MWth | 7,600 | 7,255 | 6,825 | 6,825 | 6,825 |
| Electrical output | GWh | 6,184 | 6,391 | 6,151 | 6,590r | 6,576 |
| Heat output | GWh | 14,446 | 13,615 | 13,060 | 13,864r | 14,222 |
| Fuel use | GWh | 26,634 | 25,759 | 24,164 | 25,346r | 26,501 |
| of which : for electricity | GWh | 12,218 | 12,362 | 11,533 | 12,006r | 12,479 |
| for heat | GWh | 14,416 | 13,397 | 12,631 | 13,340r | 14,022 |
| Paper, publishing and printing | | | | | | |
| Number of sites | | 22 | 21 | 21 | 20 | 22 |
| Electrical capacity | MWe | 451 | 477 | 463 | 367r | 383 |
| Heat capacity | MWth | 1,776 | 1,764 | 1,771 | 1,537 | 1,582 |
| Electrical output | GWh | 1,948 | 2,025 | 1,639 | 1,689r | 1,751 |
| Heat output | GWh | 4,849 | 4,389 | 3,844 | 3,768r | 3,863 |
| Fuel use | GWh | 9,221 | 8,831 | 7,349 | 7,723r | 8,091 |
| of which : for electricity | GWh | 4,138 | 4,295 | 3,410 | 3,718r | 3,925 |
| for heat | GWh | 5,082 | 4,536 | 3,939 | 4,005r | 4,165 |
| Food, beverages and tobacco | | | | | | |
| Number of sites | | 54 | 59 | 61 | 63r | 67 |
| Electrical capacity | MWe | 436 | 455 | 469 | 485r | 492 |
| Heat capacity | MWth | 1,743 | 1,787 | 1,808 | 1,880r | 1,895 |
| Electrical output | GWh | 2,117 | 2,266 | 2,257 | 2,149r | 2,356 |
| Heat output | GWh | 4,277 | 4,291 | 4,119 | 3,896r | 4,137 |
| Fuel use | GWh | 8,362 | 8,717 | 8,563 | 8,187r | 8,900 |
| of which : for electricity | GWh | 4,172 | 4,487 | 4,471 | 4,277r | 4,758 |
| for heat | GWh | 4,190 | 4,230 | 4,092 | 3,909r | 4,142 |
| Metal products, machinery and equipment | | | | | | |
| Number of sites | | 19 | 20 | 21 | 21 | 22 |
| Electrical capacity | MWe | 43 | 43 | 46 | 46 | 48 |
| Heat capacity | MWth | 254 | 254 | 257 | 257 | 259 |
| Electrical output | GWh | 119 | 139 | 153 | 164r | 166 |
| Heat output | GWh | 193 | 190 | 192 | 232r | 225 |
| Fuel use | GWh | 462 | 625 | 654 | 729r | 738 |
| of which : for electricity | GWh | 250 | 301 | 329 | 342r | 357 |
| for heat | GWh | 212 | 324 | 325 | 387r | 381 |

For footnotes see page 213

7.8 CHP capacity, output and total fuel use⁽¹⁾ by sector (continued)

| | Unit | 2013 | 2014 | 2,015 | 2,016 | 2017 |
|--|------|--------|--------|---------|---------|--------|
| Mineral products, extraction, mining and agglomeration of solid fuels | | | | | | |
| Number of sites | | 8 | 8 | 8 | 8 | 8 |
| Electrical capacity | MWe | 54 | 54 | 52 | 52 | 49 |
| Heat capacity | MWth | 183 | 183 | 165 | 165 | 165 |
| Electrical output | GWh | 104 | 109 | 131 | 120 | 125 |
| Heat output | GWh | 526 | 530 | 550 | 498 | 457 |
| Fuel use | GWh | 836 | 881 | 889 | 827 | 793 |
| of which : for electricity | GWh | 230 | 253 | 289 | 269 | 282 |
| for heat | GWh | 605 | 628 | 600 | 558 | 511 |
| Sewage treatment | | | | | | |
| Number of sites | | 197 | 200 | 200r | 207r | 204 |
| Electrical capacity | MWe | 164 | 165 | 202r | 212r | 197 |
| Heat capacity | MWth | 240 | 245 | 343r | 353r | 329 |
| Electrical output | GWh | 657 | 719 | 749r | 769r | 793 |
| Heat output | GWh | 740 | 822 | 851r | 884r | 934 |
| Fuel use | GWh | 2,391 | 2,601 | 2,766r | 2,775r | 2,901 |
| of which : for electricity | GWh | 1,540 | 1,660 | 1,753r | 1,766r | 1,825 |
| for heat | GWh | 851 | 941 | 1,013r | 1,010r | 1,077 |
| Other industrial branches (2) | | | | | | |
| Number of sites | | 12 | 12 | 11r | 12r | 12 |
| Electrical capacity | MWe | 50 | 50 | 53r | 82r | 82 |
| Heat capacity | MWth | 274 | 274 | 166r | 198r | 198 |
| Electrical output | GWh | 225 | 243 | 217r | 313r | 269 |
| Heat output | GWh | 409 | 422 | 369r | 411r | 409 |
| Fuel use | GWh | 812 | 845 | 748r | 912r | 902 |
| of which : for electricity | GWh | 423 | 452 | 409r | 556r | 529 |
| for heat | GWh | 389 | 393 | 340r | 356r | 373 |
| Total industry | | | | | | |
| Number of sites | | 381 | 388 | 389r | 397r | 400 |
| Electrical capacity | MWe | 5,119 | 5,039 | 4,784r | 4,648r | 4,602 |
| Heat capacity | MWth | 17,571 | 17,312 | 16,466r | 16,013r | 15,940 |
| Electrical output | GWh | 16,729 | 16,625 | 16,392r | 16,686r | 16,653 |
| Heat output | GWh | 39,423 | 37,046 | 34,979r | 34,973r | 35,749 |
| Fuel use | GWh | 76,792 | 73,685 | 69,965r | 70,394r | 72,300 |
| of which : for electricity | GWh | 34,950 | 34,419 | 32,969r | 33,677r | 34,377 |
| for heat | GWh | 41,842 | 39,266 | 36,996r | 36,718r | 37,922 |
| Transport, commerce and administration | | | | | | |
| Number of sites | | 956 | 974 | 1,002r | 1,027r | 1,048 |
| Electrical capacity | MWe | 419 | 445 | 499r | 506r | 529 |
| Heat capacity | MWth | 1,729 | 1,823 | 1,999r | 2,049r | 2,148 |
| Electrical output | GWh | 1,742 | 1,867 | 1,875r | 2,212r | 2,247 |
| Heat output | GWh | 3,134 | 3,028 | 3,288r | 3,437r | 3,534 |
| Fuel use | GWh | 6,956 | 7,377 | 7,476r | 8,749r | 8,903 |
| of which : for electricity | GWh | 3,567 | 4,106 | 3,927r | 5,033r | 5,084 |
| for heat | GWh | 3,389 | 3,272 | 3,549r | 3,716r | 3,819 |
| Other (3) | | | | | | |
| Number of sites | | 692 | 714 | 739r | 800r | 938 |
| Electrical capacity | MWe | 386 | 408 | 426r | 471r | 705 |
| Heat capacity | MWth | 2,866 | 3,093 | 1,626r | 1,733r | 2,103 |
| Electrical output | GWh | 1,121 | 1,203 | 1,268r | 1,506r | 2,748 |
| Heat output | GWh | 1,793 | 1,884 | 1,967r | 2,260r | 2,955 |
| Fuel use | GWh | 4,683 | 5,144 | 5,135r | 5,980r | 9,077 |
| of which : for electricity | GWh | 2,525 | 2,744 | 2,809r | 3,302r | 5,830 |
| for heat | GWh | 2,158 | 2,401 | 2,327r | 2,678r | 3,247 |
| Total CHP usage by all sectors | | | | | | |
| Number of sites | | 2,029 | 2,076 | 2,130r | 2,224r | 2,386 |
| Electrical capacity | MWe | 5,924 | 5,892 | 5,708r | 5,625r | 5,835 |
| Heat capacity | MWth | 22,167 | 22,228 | 20,091r | 19,795r | 20,191 |
| Electrical output | GWh | 19,592 | 19,695 | 19,534r | 20,405r | 21,648 |
| Heat output | GWh | 44,350 | 41,957 | 40,234r | 40,670r | 42,238 |
| Fuel use | GWh | 88,430 | 86,207 | 82,576r | 85,123r | 90,279 |
| of which : for electricity | GWh | 41,042 | 41,268 | 39,704r | 42,011r | 45,291 |
| for heat | GWh | 47,388 | 44,939 | 42,872r | 43,111r | 44,988 |

(1) The allocation of fuel use between electricity and heat is largely notional and the methodology is outlined in the methodology note

(2) Other industry includes Textiles, clothing and footwear sector.

(3) Sectors included under Other are agriculture, community heating, leisure, landfill and incineration.

7.9 CHP - use of fuels by sector

| | GWh | | | | |
|---|---------------|---------------|---------------|----------------|---------------|
| | 2013 | 2014 | 2015 | 2016 | 2017 |
| Iron and steel and non ferrous metals | | | | | |
| Coal | - | - | - | - | - |
| Fuel oil | 21 | 20 | 51 | 15r | 16 |
| Natural gas | 204 | 169 | 237 | 218r | 109 |
| Blast furnace gas | 2,169 | 2,114 | 2,001 | 1,291r | 1,152 |
| Coke oven gas | 489 | 440 | 431 | 214r | 227 |
| Other fuels (1) | 2 | 0 | - | -r | 0 |
| Total iron and steel and non ferrous metals | 2,885 | 2,743 | 2,720 | 1,739r | 1,503 |
| Chemicals | | | | | |
| Coal | 1,697 | 1,033 | 359 | 331 | 306 |
| Fuel oil | 10 | 12 | 3 | 4 | 2 |
| Gas oil | 4 | 6 | 4 | 5r | 15 |
| Natural gas | 20,118 | 18,169 | 17,444 | 17,788r | 17,692 |
| Refinery gas | 646 | 653 | 648 | 614 | 630 |
| Renewable fuels (2) | 90 | 92 | 663 | 891r | 910 |
| Other fuels (1) | 2,623 | 2,720 | 2,990 | 2,522r | 2,415 |
| Total chemicals | 25,189 | 22,685 | 22,110 | 22,156r | 21,970 |
| Oil and gas terminals and oil refineries | | | | | |
| Fuel oil | 48 | 7 | 25 | 65 | 14 |
| Gas oil | 763 | 906 | 798 | 766r | 902 |
| Natural gas | 18,484 | 17,847 | 16,380 | 17,549r | 18,360 |
| Refinery gas | 3,872 | 3,996 | 4,264 | 3,722r | 3,912 |
| Other fuels (1) | 3,466 | 3,003 | 2,698 | 3,244 | 3,312 |
| Total oil and gas terminals and oil refineries | 26,634 | 25,759 | 24,164 | 25,346r | 26,501 |
| Paper, publishing and printing | | | | | |
| Coal | 102 | - | - | - | - |
| Fuel oil | - | - | - | - | - |
| Gas oil | 7 | 2 | 1 | 0r | 2 |
| Natural gas | 6,298 | 5,402 | 4,917 | 5,199r | 5,238 |
| Renewable fuels (2) | 2,516 | 2,786 | 2,189 | 2,472r | 2,800 |
| Other fuels (1) | 298 | 641 | 241 | 52r | 52 |
| Total paper, publishing and printing | 9,221 | 8,831 | 7,349 | 7,723r | 8,091 |
| Food, beverages and tobacco | | | | | |
| Coal | 205 | 214 | 218 | 152 | 174 |
| Fuel oil | 148 | 100 | 94 | 80r | 17 |
| Gas oil | 3 | 4 | 3 | 15 | 12 |
| Natural gas | 7,653 | 7,885 | 7,812 | 7,441r | 7,759 |
| Renewable fuels (2) | 354 | 515 | 436 | 499r | 938 |
| Other fuels (1) | - | - | - | - | - |
| Total food, beverages and tobacco | 8,362 | 8,717 | 8,563 | 8,187r | 8,900 |
| Metal products, machinery and equipment | | | | | |
| Coal | - | - | - | - | - |
| Fuel oil | 89 | 89 | 89 | 89 | 89 |
| Gas oil | 0.3 | 0.3 | 0 | 0 | 0.3 |
| Natural gas | 332 | 364 | 399 | 440r | 442 |
| Renewable fuels (2) | 41 | 172 | 166 | 199 | 207 |
| Other fuels (1) | - | - | - | - | - |
| Total metal products, machinery and equipment | 462 | 625 | 654 | 729r | 738 |

For footnotes see page 215

7.9 CHP - use of fuels by sector (continued)

| | GWh | | | | |
|--|---------------|---------------|----------------|----------------|---------------|
| | 2013 | 2014 | 2,015 | 2,016 | 2017 |
| Mineral products, extraction, mining and agglomeration of solid fuels | | | | | |
| Coal | - | - | - | - | - |
| Fuel oil | - | - | - | - | - |
| Gas oil | - | - | - | - | - |
| Natural gas | 606 | 651 | 739 | 677 | 643 |
| Coke oven gas | 230 | 230 | 150 | 150 | 150 |
| Total mineral products, extraction, mining and agglomeration of solid fuels | 836 | 881 | 889 | 827 | 793 |
| Sewage treatment | | | | | |
| Fuel oil | 32 | 33 | 24r | 24r | 24 |
| Gas oil | 17 | 26 | 37 | 22r | 12 |
| Natural gas | 36 | 50 | 71 | 125r | 140 |
| Renewable fuels (2) | 2,305 | 2,491 | 2,634r | 2,604r | 2,726 |
| Total sewage treatment | 2,391 | 2,601 | 2,766r | 2,775r | 2,901 |
| Other industrial branches | | | | | |
| Fuel oil | - | - | - | - | - |
| Gas oil | 0 | 0 | -r | -r | - |
| Natural gas | 803 | 837 | 733r | 884r | 852 |
| Renewable fuels (2) | 9 | 7 | 15r | 28r | 49 |
| Total other industrial branches | 812 | 845 | 748r | 912r | 902 |
| Transport, commerce and administration | | | | | |
| Coal | - | - | - | - | - |
| Fuel oil | - | - | - | 0 | 1 |
| Gas oil | 12 | 34 | 41r | 53r | 24 |
| Natural gas | 6,287 | 6,255 | 6,652r | 6,819r | 6,939 |
| Refinery gas | - | - | - | - | - |
| Renewable fuels (2) | 657 | 1,088 | 782r | 1,876r | 1,940 |
| Other fuels (1) | - | 0 | 0 | 0r | 0 |
| Total transport, commerce and administration | 6,956 | 7,377 | 7,476r | 8,749r | 8,903 |
| Other (3) | | | | | |
| Coal | 7 | 3 | - | - | - |
| Fuel oil | 2 | - | 0 | 2r | 0.3 |
| Gas oil | 14 | 13 | 10 | 14r | 10 |
| Natural gas | 2,530 | 2,768 | 2,794r | 3,315r | 3,751 |
| Renewable fuels (2) | 1,886 | 2,148 | 2,130r | 2,622r | 5,288 |
| Other fuels (1) | 244 | 213 | 201 | 27r | 27 |
| Total other | 4,683 | 5,144 | 5,135r | 5,980r | 9,077 |
| Total - all sectors | | | | | |
| Coal | 2,012 | 1,249 | 577 | 484 | 480 |
| Fuel oil | 350 | 287 | 287r | 279r | 161 |
| Gas oil | 820 | 992 | 895 | 874r | 977 |
| Natural gas | 63,352 | 58,178 | 58,178r | 60,456r | 61,924 |
| Blast furnace gas | 2,169 | 2,114 | 2,001 | 1,291r | 1,152 |
| Coke oven gas | 719 | 670 | 581 | 364r | 377 |
| Refinery gas | 4,519 | 4,650 | 4,911 | 4,337r | 4,542 |
| Renewable fuels (2) | 7,856 | 9,298 | 9,016r | 11,192r | 14,858 |
| Other fuels (1) | 6,633 | 6,577 | 6,130 | 5,845r | 5,807 |
| Total CHP fuel use | 88,430 | 86,207 | 82,576r | 85,123r | 90,279 |

(1) Other fuels include: process by-products.

(2) Renewable fuels include: sewage gas, other biogases, municipal solid waste and refuse derived fuels.

(3) Sectors included under Other are agriculture, community heating, leisure, landfill and incineration.

7.10 Large scale CHP schemes in the United Kingdom (operational at the end of December 2017)⁽¹⁾

| Company Name | Scheme Location | Installed Capacity (MWe) (2) |
|--|--|------------------------------|
| Aberdeen Heat & Power | Stockethill CHP2 | 1 |
| Aberdeen Heat & Power | SEATON ENERGY CENTRE, ABERDEEN HEAT & POWER | 2 |
| Aberdeen Heat & Power | Tillydrone CHP | 1 |
| Adam Wilson & Sons Ltd | Glennon Brothers Troon Limited | 2 |
| ADM Erith Ltd | ERITH OIL WORKS | 14 |
| Agrivert Ltd | Wallingford AD | 2 |
| Agrivert Ltd | Cassington AD | 2 |
| ATKINS POWER | HEDON SALADS - BURSTWICK | 7 |
| ATKINS POWER | HEDON SALADS - NEWPORT | 4 |
| BALCAS LIMITED | Laragh | 3 |
| Balcas Timber Ltd | BALCAS INVERGORDON | 9 |
| BARKANTINE HEAT & POWER COMPANY | BARKANTINE, BARKANTINE HEAT & POWER COMPANY | 1 |
| BASF Bradford | BASF PLC | 16 |
| Boortmalt | Boortmalt - Bury St Edmunds | 5 |
| Briar Chemicals Ltd | Briar Chemicals Ltd | 4 |
| BRITISH SUGAR PLC | CANTLEY SUGAR FACTORY | 15 |
| British Sugar plc | BURY ST EDMUNDS SUGAR FACTORY | 77 |
| British Sugar Plc | WISSINGTON SUGAR FACTORY, BRITISH SUGAR PLC (CHP 2) | 93 |
| Cantelo Nurseries | BRADON FARM | 10 |
| CARGILL PLC | CARGILL MANCHESTER CHP 2 | 28 |
| CARILLION SERVICES LTD, TA CARILLION HEALTH | QUEEN ALEXANDRA HOSPITAL | 3 |
| CEREAL PARTNERS UK | CEREAL PARTNERS UK | 5 |
| CEREAL PARTNERS UK | CEREAL PARTNERS UK | 5 |
| Chichester Power Ltd | Chichester Power | 8 |
| City West Homes Limited | PUMP HOUSE | 3 |
| CLEVELAND POTASH LIMITED | BOULBY MINE, CLEVELAND POTASH LIMITED | 10 |
| COFELY LTD | Rampton Hospital | 1 |
| Cofely Ltd | TRAFFORD PARK, KELLOGG COMPANY OF GREAT BRITAIN | 5 |
| Cofely UK Energy Services Ltd (UK) LTD | SULLOM VOE POWER STATION | 89 |
| Community Energy | Citigen_2 | 9 |
| ContourGlobal Solutions (Northern Ireland) Ltd | KNOCKMORE HILL CHP, CONTOURGLOBAL SOLUTIONS (NORTHERN IRELAND) | 15 |
| CYCLERVAL UK LTD | NEWLINGS EFW, NEWLINGS DEVELOPMENT LTD | 3 |
| Cynergis Projects Limited | VILLA NURSERY LIMITED | 1 |
| Cynergis Projects Limited | George Eliot NHS Trust Hospital | 1 |
| Dalkia | FREEMAN HOSPITAL | 4 |
| Dalkia | ROYAL VICTORIA INFIRMARY | 4 |
| DALKIA UTILITIES SERVICES | ELI LILLY & CO LTD | 10 |
| DS Smith Paper Limited | KEMSLEY CHP | 81 |
| DSM NUTRITIONAL PRODUCTS (UK) LTD | DSM DALRY | 46 |
| DWR Cymru Welsh Water | AFAN WWTW, DWR CYMRU WELSH WATER | 3 |
| DWR Cymru Welsh Water | FIVE FORD WWTW | 1 |
| E.ON | St James University Hospital | 5 |
| E.ON UK Cogeneration Ltd | Nufarm UK Limited | 5 |
| East Sussex Healthcare NHS TRUST | EASTBOURNE DISTRICT GENERAL HOSPITAL | 1 |
| Eco Sustainable Solutions Ltd | Eco Piddlehinton AD | 1 |
| ENGIE | ICC ENERGY CENTRE | 3 |
| ENGIE | LDEC-City Centre and Leicester East | 3 |
| ENGIE | LDEC-LEICESTER NORTH | 2 |
| ENGIE | THE HEAT STATION (CHP 2) | 7 |
| Engie | DOW CORNING CHP | 27 |
| ENGIE | MOD MAIN BUILDING, COFELY LIMITED | 5 |
| ENGIE | SOAS CHP, THE BOILER HOUSE | 1 |
| ENGIE | ASTON UNIVERSITY ENERGY CENTRE, ASTON UNIVERSITY | 3 |
| ENGIE | BIRMINGHAM CHILDRENS HOSPITAL | 2 |
| Engie Group Energy Infrastructure | ENGIE HUMBER ENERGY | 21 |
| ENGIE Services Holding UK Ltd | Leeds GSC | 19 |
| Enviroenergy Ltd | London Road Heat Station | 11 |
| EON | QUEENS MEDICAL CENTRE NHS TRUST | 5 |
| EON UK | CITIGEN CHP, CITIGEN (LONDON) LIMITED | 16 |
| Esso Petroleum Company Limited | Fawley Cogen | 316 |

For footnotes see page 218

7.10 Large scale CHP schemes in the United Kingdom (operational at the end of December 2017)⁽¹⁾ (continued)

| Company Name | Scheme Location | Installed Capacity (MWe) (2) |
|---|--|------------------------------|
| FEC Energy | BUCKLAND GARDEN NURSERIES | 2 |
| FEC Energy | Vitacress Herbs Ltd | 4 |
| Fine Organics Limited | FINE ORGANICS LIMITED | 4 |
| Frimley Park Hospital NHS Foundation Trust | Frimley Park Hospital | 1 |
| G4 Power Grid Ltd | Brookenby Power Station | 2 |
| Genzyme Ltd | GENZYME Ltd | 1 |
| GlaxoSmithKline | GLAXOSMITHKLINE (ULVERSTON) | 2 |
| GLAXOSMITHKLINE | GLAXOSMITHKLINE MONTROSE | 1 |
| GlaxoSmithKline | GLAXOSMITHKLINE, IRVINE | 4 |
| GlaxoSmithKline | WARE GMS | 2 |
| GlaxoSmithKline Research & Development Ltd | GSK R & D Ware | 4 |
| GlaxoSmithKline Research & Development Ltd | Stevenage R&D | 4 |
| Great Ormond Street Hospital | Great Ormond Street Hospital | 1 |
| GSK | Barnard Castle | 2 |
| Guy's and St Thomas' Hospital NHS Foundation Trust | ST THOMAS' HOSPITAL | 3 |
| GUY'S AND ST THOMAS' HOSPITAL NHS FOUNDATION TRUST | GUY'S HOSPITAL | 3 |
| Heathcoat Fabrics Ltd | HEATHCOAT FABRICS LIMITED | 1 |
| Helix Agencies Limited | BLACKPOOL VICTORIA HOSPITAL | 1 |
| Helix Agencies Limited | SOUTH KENSINGTON CAMPUS CHP PLANT | 9 |
| Helix Agencies Limited | NATURAL HISTORY MUSEUM | 2 |
| Iggesund Paperboard (Workington) Ltd | Iggesund Paperboard (Workington) Ltd | 50 |
| Imerys Minerals Ltd | PAR GRADE DRIER | 4 |
| Imerys Minerals Ltd | ROCKS DRIERS | 4 |
| INBEV UK LTD | MAGOR BREWERY, INBEV UK LTD | 7 |
| Inbev UK Ltd | SAMLESBURY BREWERY, INBEV UK LTD | 7 |
| INEOS RUNCORN (TPS) LIMITED | RUNCORN EFW FACILITY | 37 |
| Inovyn Chlorvinyls Ltd | Inovyn Chlorvinyls Ltd | 10 |
| Inovyn Chlorvinyls Ltd | Gas Engine CHP | 2 |
| INTEGRATED ENERGY UTILITIES LTD | CALLENDAR PARK ENERGY CENTRE, FALKIRK COUNCIL | 1 |
| Jacobs Douwe Egberts | JDE Banbury | 8 |
| JAGUAR LAND ROVER LIMITED | CASTLE BROMWICH, JAGUAR LAND ROVER LTD | 6 |
| JAGUAR LANDROVER | LANDROVER GROUP - SOLIHULL NORTH WORKS | 3 |
| JAGUAR LANDROVER | LANDROVER - SOLIHULL PAINT SHOP 21 | 3 |
| JAMES CROPPER PLC | JAMES CROPPER PLC | 7 |
| JOHN THOMPSON AND SON LTD | John Thompson | 6 |
| Johnson Matthey | JOHNSON MATTHEY ENFIELD | 3 |
| Johnson Matthey | JOHNSON MATTHEY - ROYSTON | 6 |
| Kronospan Limited | KRONOSPAN LTD (CHIRK CHP B) | 13 |
| Lawrence Brown Interiors (VMC) Ltd | BROWNS LANE, LAWRENCE AUTOMOTIVE INTERIORS (VMC) LTD | 3 |
| London Borough of Islington | Bunhill Heat and Power | 2 |
| LOUGHBOROUGH UNIVERSITY | Central Park | 2 |
| Medway NHS Foundation Trust | MEDWAY HOSPITAL, MEDWAY MARITIME HOSPITAL | 1 |
| Nestle UK Ltd | NESTLE YORK | 10 |
| NHS Grampian | ABERDEEN ROYAL INFIRMARY | 5 |
| NORTH TEES & HARTLEPOOL NHS FOUNDATION TRUST | UNIVERSITY HOSPITAL OF NORTH TEES | 2 |
| Northumbrian Water | LEVENMOUTH WASTE WATER TREATMENT WORKS | 3 |
| Northumbrian Water Ltd | BRAN SANDS (BIOGAS) | 5 |
| Northumbrian Water Ltd | Howdon STW | 6 |
| Northwood & WEPA Ltd | Bridgend CHP | 9 |
| Novartis Grimsby Ltd | NOVARTIS GRIMSBY LIMITED | 8 |
| P3P Partners | Woodhouse Nurseries | 3 |
| P3P Partners | Harvest Energy Centre | 11 |
| P3P Partners | Glasshouse Energy Centre | 11 |
| P3P Partners | Spark Steam Energy Centre | 7 |
| P3P Partners | Europa Nursery | 15 |
| Peel Utilities Holdings Limited | MEDIA CITY, UTILITIES (MEDIA CITY UK) LTD | 2 |
| Portals De La Rue Limited | Portals De La Rue Overton Mill | 7 |
| Powell Energy | ST. GEORGES HOSPITAL | 4 |
| PRESTON BOARD AND PACKAGING LTD | ROMLEY BOARD | 1 |
| Queen Elizabeth Hospital King's Lynn NHS Foundation Trust | Queen Elizabeth Hospital | 1 |
| Reckitt Benckister | KWE HULL | 2 |
| REG BIO POWER LTD | BENTWATERS CHP | 6 |

For footnotes see page 218

7.10 Large scale CHP schemes in the United Kingdom (operational at the end of December 2017)⁽¹⁾ (continued)

| Company Name | Scheme Location | Installed Capacity |
|---|--|--------------------|
| ROTHERHAM GENERAL HOSPITAL NHS TRUST | ROTHERHAM DISTRICT GENERAL HOSPITAL | 1 |
| Royal Devon and Exeter Foundation Trust | ROYAL DEVON AND EXETER HOSPITAL WONFORD | 1 |
| RWE NPOWER | BASF CHP | 98 |
| RWE npower Cogen Ltd | Markinch CHP | 65 |
| RYOBI ALUMINIUM CASTING (UK) LTD | RYOBI | 1 |
| SARIA LTD | Re-Food AD Plant Saria Ltd | 5 |
| SCOTTISH AND SOUTHERN ENERGY | SLOUGH NURSERIES, G & C PROPERTIES | 2 |
| SELLAFIELD LTD | COMBINED HEAT AND POWER PLANT F238 | 193 |
| Shanks Waste Management Limited | Westcott Biogas Generating Plant | 3 |
| SLOUGH HEAT & POWER LTD | SLOUGH POWER STATION | 21 |
| Smurfit Kappa SSK | SMURFIT KAPPA SSK LIMITED | 9 |
| Solvay Solutions UK Ltd | Oldbury | 2 |
| SOUTHERN WATER SERVICES | BUDDS FARM WTW, SOUTHERN WATER | 2 |
| SOUTHERN WATER SERVICES | MILLBROOK WTW, SOUTHERN WATER | 1 |
| SOUTHERN WATER SERVICES | ASHFORD STC | 2 |
| SPRINGFIELDS FUELS LTD | SPRINGFIELDS | 12 |
| STAPLES BROTHERS LTD | Sibsey 1 | 2 |
| Swansea University | Swansea University | 2 |
| T & L SUGARS LTD | Thames Refinery | 28 |
| Tata Chemicals Europe | Winnington CHP | 103 |
| THAMES WATER UTILITIES LTD | Swindon STW CHP 2015 | 1 |
| THAMES WATER UTILITIES LTD | Mogden STW 2016 | 6 |
| THAMES WATER UTILITIES LTD | Beddington STW | 2 |
| THAMES WATER UTILITIES LTD | Deephams STW 2016 | 3 |
| THAMES WATER UTILITIES LTD | Rye Meads STW CHP 2015 | 2 |
| THAMES WATER UTILITIES LTD | Slough STW CHP 2015 | 1 |
| THAMES WATER UTILITIES LTD | Riverside STW | 6 |
| THAMES WATER UTILITIES LTD | Beckton STW Biogas CHP | 6 |
| THAMES WATER UTILITIES LTD | Crossness STW Biogas CHP | 6 |
| THAMES WATER UTILITIES LTD | MAPLE LODGE STW | 4 |
| THAMES WATER UTILITIES LTD | LONG REACH STW | 3 |
| THAMES WATER UTILITIES LTD | OXFORD STW | 2 |
| THAMES WATER UTILITIES LTD | CRAWLEY STW | 1 |
| THAMES WATER UTILITIES LTD | READING (ISLAND ROAD) STW | 1 |
| THAMES WATER UTILITIES LTD | CHERTSEY STW | 1 |
| Thamesway Central Milton Keynes Ltd | WOKING TOWN CENTRE PHASE I | 1 |
| Thamesway Central Milton Keynes Ltd | TCMK PHASE 1 CHP NO 2 GAS ENGINE | 6 |
| The Royal Marsden Hospital (NHS Foundation Trust) | Royal Marsden Hospital | 2 |
| The University of Birmingham | The University of Birmingham scheme ref 740A | 4 |
| The University of Bradford | Richmond Boiler House | 2 |
| Transport for London | PALESTRA, TRANSPORT FOR LONDON | 1 |
| University College London | UNIVERSITY COLLEGE LONDON, GOWER STREET HEAT AND POWER LTD | 3 |
| University of Aberdeen | OLD ABERDEEN CAMPUS | 2 |
| UNIVERSITY OF BRISTOL | UNIVERSITY OF BRISTOL CHP 2 | 1 |
| UNIVERSITY OF DUNDEE | UNIVERSITY OF DUNDEE, MAIN CHP BOILERHOUSE | 4 |
| University of East Anglia | University of East Anglia | 7 |
| UNIVERSITY OF EDINBURGH UTILITIES SUPPLY COMPANY | KINGS BUILDINGS | 3 |
| UNIVERSITY OF EDINBURGH UTILITIES SUPPLY COMPANY | GEORGE SQUARE ENERGY CENTRE | 2 |
| University of Reading | Whiteknights Energy Centre | 1 |
| University of Southampton | UNIVERSITY OF SOUTHAMPTON | 3 |
| University of Surrey | UNIVERSITY OF SURREY | 1 |
| University of Sussex | UNIVERSITY OF SUSSEX | 1 |
| University of Warwick | Cryfield Energy Centre | 4 |
| University of Warwick | CHP BOILERHOUSE (CHP 2), UNIVERSITY OF WARWICK | 4 |
| UNIVERSITY OF YORK | University of York | 3 |
| University of Edinburgh Utilities Supply Company | Holyrood Energy Centre | 1 |
| UPM-Kymmene (UK) | UPM Shotton | 25 |
| Veolia BioEnergy UK Limited | CHILTON BIOMASS PLANT, Veolia BioEnergy UK Limited | 17 |
| Veolia Environmental Services plc | SHEFFIELD ERF | 21 |
| Veolia Plc | LINCOLN COUNTY HOSPITAL | 1 |
| Vinnolit Hillhouse LTD | Hillhouse International Business Park | 5 |
| VPI Immingham LLP | VPI IMMINGHAM LLP | 1,344 |
| Weetabix | Weetabix Limited | 6 |
| WESSEX WATER SERVICES LTD | BRISTOL WASTE WATER TREATMENT WORKS SCHEME A | 6 |
| Total (2) | | 3,496 |
| Electrical capacity of good quality CHP for these sites in total | | 3,214 |

(1) These are sites of 1 MW installed electrical capacity or more that either have agreed to be listed in the Ofgem register of CHP plants or whose details are publicly available elsewhere, or who have provided the information directly to BEIS. It excludes CHP sites that have been listed as major power producers in Table 5.10.

(2) This is the total power capacity from these sites and includes all the capacity at that site, not just that classed as good quality CHP under CHPQA.