



# Summary of Results

## External Quality Assessment of Water Microbiology Endoscope Rinse Water Scheme

Distribution Number: EW21

Sample Numbers: EW21A, EW21B

Distribution Date:	January 2019
Results Due:	22 February 2019
Report Date:	15 March 2019
Samples prepared and quality control tested by:	Angela Appea Richard Borrill Thomas Harper Margaret Njenga Zak Prior Lili Tsegaye Vanessa Waite
Data analysed by:	Nita Patel Manchari Rajkumar
Report compiled by:	Nita Patel Manchari Rajkumar
Authorised by:	Nita Patel

This report must not be reproduced without permission of the organisers.

**Public Health England**  
**Food and Environmental Proficiency Testing Unit (FEPTU)**

61 Colindale Avenue  
London  
NW9 5EQ

Tel: +44 (0)20 8327 7119  
Fax: +44 (0)20 8200 8264  
Email: foodeqa@phe.gov.uk

For further information on the scheme please refer to:

**Scheme Guide:** <https://www.gov.uk/government/publications/food-and-water-proficiency-testing-schemes-scheme-guide>

**Guide to Scoring and Statistics:**

<https://www.gov.uk/government/publications/food-and-water-proficiency-testing-schemes-scoring-systems-and-statistics>

**General guidance for z-scores:**

Participants' enumeration results are converted into z-scores using the following formula:

$$Z = \frac{(X_i - X_{pt})}{\sigma_{pt}}$$

$X_i$  = participants' result expressed (expressed as a log<sub>10</sub> value)  
 $X_{pt}$  = assigned value (participants' consensus median (expressed as a log<sub>10</sub> value))  
 $\sigma_{pt}$  = the fixed standard deviation for the examination (calculated by FEPTU)

The  $\sigma_{pt}$ -value expresses the acceptable difference between the individual participant's result and the participants' consensus median. The  $\sigma_{pt}$ -value used for calculating z-scores for all parameters in the Endoscope Rinse Water Scheme is 0.35. A guide to interpreting z-scores follows, although laboratories must interpret their scores in the context of their own laboratory situation.

z = -1.99 to +1.99                    **satisfactory**  
z = -2 to -2.99 or +2 to +2.99      **questionable**  
z = < -3.00 or > + 3.00              **unsatisfactory**

It is usually recommended that z-scores exceeding +/-2 are investigated to establish the possible cause. As a general rule, PHE recommends that all questionable and unsatisfactory results are investigated.

**FEPTU Quality Control:** To demonstrate homogeneity of the sample, a minimum of 10 LENTICULE® discs, selected randomly from a batch, are tested in duplicate for enumeration.

To demonstrate stability of the sample, a minimum of six LENTICULE discs, selected randomly from a batch, are examined throughout the distribution period for enumeration.

Public Health England uses methods stipulated in (Health Technical Memorandum 01-06: Decontamination of flexible endoscopes: Part E - Testing methods - March 2016).

The FEPTU results are used for guidance in the preliminary informed results notification, dispatched immediately after every distribution.

Refer to section 17.0 of the Scheme Guide if you have experienced difficulties with any of the examinations.

<https://www.gov.uk/government/publications/food-and-water-proficiency-testing-schemes-scheme-guide>

Participants are reminded that reporting an incorrect or false negative results could have serious public health implications.

Please contact FEPTU staff for advice and information:

<b>Repeat samples</b>	Carmen Gomes or Kermin Daruwalla	<b>Tel:</b> +44 (0)20 8327 7119
<b>Data Analysis</b>	Manchari Rajkumar or Nita Patel	<b>Fax:</b> +44 (0)20 8200 8264
<b>Microbiological advice</b>	Nita Patel or Zak Prior	<b>Email:</b> foodeqa@phe.gov.uk
<b>General comments and complaints</b>	Nita Patel or Zak Prior	<a href="#">FEPTU's website</a>
<b>Scheme consultants</b>	Caroline Willis or Julie E. Russell	
<b>Scheme Co-ordinator</b>	Nita Patel	

**Accreditation:** PHE Water EQA Scheme for Endoscope Rinse Water is accredited by the United Kingdom Accreditation Service (UKAS) to ISO/IEC 17043:2010.



## Sample: EW21A

### Contents:

*Candida tropicalis* 36 (wild strain), *Pseudomonas aeruginosa* 27 (wild strain)

### Expected Results:

All counts are expressed as colony forming units (cfu) per 100mL.

The fixed standard deviation value ( $\sigma_{pt}$  value) used for calculation of the z-scores is **0.35** for all parameters.

Results	
FEPTU median (MF)*	63
No. results returned	77
Assigned value (Participants median all results)	54
Conclusion based on assigned value**	Risk assessment required
Uncertainty of assigned value	2
Participants mean (all results)	52
Expected Range	30 - 78
Standard deviation***	13
No of outlying counts	11
False positives	N/A
False negatives	0
Your result	
Your conclusion	
Score for performance assessment	
Z-score	

\* Membrane filtration

\*\* Reference: [https://www.gov.uk/government/uploads/system/uploads/attachment\\_data/file/553303/HTM01-06\\_PartE.pdf](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/553303/HTM01-06_PartE.pdf)

\*\*\* Robust  $S^*$  based on median absolute deviation about the participants' median ( $MADe$ )

Examination	Expected Result	Your Result	Your Score
<b><i>P.aeruginosa</i></b>	Detected		

<b><i>P.aeruginosa</i></b>	
Total participants reporting for <i>P.aeruginosa</i>	71
Participants reporting correctly the <b>presence</b> of <i>P.aeruginosa</i>	69 (97%)

Examination	Expected Result	Your Result	Your Score
<b>Yeast/Moulds</b>	Detected		

<b>Yeast/Moulds</b>	
Total participants reporting for Yeast/Moulds	58
Participants reporting correctly the <b>presence</b> of Yeast/Moulds	39 (67%)

Total sent samples	82
Not examined	2
Non returns	3

## Sample: EW21B

### Contents:

*Aspergillus niger* 10 (wild strain), *Pseudomonas aeruginosa* 21 (wild strain)

### Expected Results:

All counts are expressed as colony forming units (cfu) per 100mL.

The fixed standard deviation value ( $\sigma_{pt}$  value) used for calculation of the z-scores is **0.35** for all parameters.

Results	
FEPTU median (MF)*	21
No. results returned	77
Assigned value (Participants median all results)	37
Conclusion based on assigned value**	Risk assessment required
Uncertainty of assigned value	3
Participants mean (all results)	35
Expected Range	1 - 73
Standard deviation***	19
No of outlying counts	12
False positives	N/A
False negatives	2
Your result	
Your conclusion	
Score for performance assessment	
Z-score	

\* Membrane filtration

\*\* Reference: [https://www.gov.uk/government/uploads/system/uploads/attachment\\_data/file/553303/HTM01-06\\_PartE.pdf](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/553303/HTM01-06_PartE.pdf)

\*\*\* Robust  $S^*$  based on median absolute deviation about the participants' median ( $MADe$ )

Examination	Expected Result	Your Result	Your Score
<b><i>P.aeruginosa</i></b>	Detected		

<b><i>P.aeruginosa</i></b>	
Total participants reporting for <i>P.aeruginosa</i>	70
Participants reporting correctly the <b>presence</b> of <i>P.aeruginosa</i>	59 (84%)

Examination	Expected Result	Your Result	Your Score
<b>Yeast/Moulds</b>	Detected		

<b>Yeast/Moulds</b>	
Total participants reporting for Yeast/Moulds	60
Participants reporting correctly the <b>presence</b> of Yeast/Moulds	59 (98%)

Total sent samples	82
Not examined	2
Non returns	3

## Performance Assessment Sheet

Distribution	Sample	Total Viable Counts 28°C - 32°C for 5 days score
EW21	EW21A	
	EW21B	
EW20	EW20A	
	EW20B	
EW19	EW19A	
	EW19B	
Total maximum possible score		
Total percentage		


### Performance Assessment Comment:

Participants are reminded that to take advantage of the performance assessment overtime tool provided in the reports they need to take part in more than one distribution a year.

Performance assessments are designed to alert participants to on-going problems with their examinations and are provided after every distribution. Scores are allocated to results reported for every parameter, for every sample to help assess performance.

Cumulative scores are calculated for the current and previous two distributions for the Endoscope Rinse Water Scheme. Participants' cumulative scores for each of the examinations are compared with the maximum possible scores after every distribution.

Your overall performance with the enumerations in the endoscope rinse water proficiency testing samples for the current and previous two distributions is collated in the chart to the right.




### Performance Assessment Comment:

Laboratories that achieve less than 70% of the maximum possible score are likely to be experiencing significant problems with their examination and are advised to:

- refer to the relevant distribution reports for sample-specific comments
- refer to the website guidance documents: <https://www.gov.uk/government/collections/external-quality-assessment-ega-and-proficiency-testing-pt-for-food-water-and-environmental-microbiology>
- contact the organisers for advice


### EW21A - Total Viable Counts 28°C - 32°C for 5 days

Key: ♦ Reported result



### EW21B - Total Viable Counts 28°C - 32°C for 5 days

Key: ♦ Reported result



**Sample specific comment**

**EW21A: Yeasts**

This sample contained a *Candida tropicalis* at levels of about 36 colony forming unit per 100mL. Of those laboratories reporting a result for yeast, 19/58 (33%) reported a false negative for this examination.

In the FEPTU laboratory the yeast grew as small grey opaque colonies which was confirmed by Gram staining and a wet mount preparation.

Laboratories are reminded that they should only report results for examinations routinely carried out as part of their procedure. Laboratories reporting an incorrect yeast result can request a repeat sample for their own internal investigation.

**EW21B: Pseudomonas aeruginosa**

This sample contained a *Pseudomonas aeruginosa* at levels of about 21 colony forming units per 100mL. 11/70 (16%) laboratories reported a false negative for this examination. In the FEPTU laboratory the *P. aeruginosa* grew as 2mm blue-green colonies on PCN agar. This strain gave typical results with oxidase, casein hydrolysis and fluorescence which were positive. It is unclear why some laboratories failed to report the presence of this organism.

Laboratories reporting an incorrect *P. aeruginosa* result can request a repeat sample for their own internal investigation

**EW21A: 59 laboratories provided an actual conclusion on the results obtained, responses are shown in the tables below:**

Colony forming counts reported per 100mL	Conclusion reported by the laboratories (number of laboratories)
Range reported 7 – 31	Acceptable/Satisfactory (3)
Range reported 12 – 84 >100	Risk assessment required (25) (1)
Range reported 16 – 82	Unsatisfactory/Unacceptable (30)
Range reported 27 – 74 >100	Not routinely reported (17) (1)

Example Report

**EW21B:** 58 laboratories provided an actual conclusion on the results obtained; responses are shown in the tables below:

Colony forming counts reported per 100mL	Conclusion reported by the laboratories (number of laboratories)
Range reported 2 – 4 Reported 0 Reported 400	Acceptable/Satisfactory (4) (2) (1)
Range reported 8 – 80 >100	Risk assessment required (22) (1)
Range reported 4 – 80 >100	Unsatisfactory/unacceptable (27) (1)
Range reported 1 – 90 >100	Not routinely reported (18) (1)

Participants are reminded to only report a conclusion on a test result if this is part of your reporting procedures.

In the UK the interpretation of test results can be found in this document on page 15. [https://www.gov.uk/government/uploads/system/uploads/attachment\\_data/file/414856/CFPP\\_01-06\\_Testing\\_methods\\_Final.pdf](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/414856/CFPP_01-06_Testing_methods_Final.pdf). However, the Interpretation/conclusions of microbiological test results in your country may vary to those published in this document.

For EW21A one laboratory was removed from the statistical calculations due to a high count reported.

#### General comment

If you do not return a result for a distribution, you will not be able to view all the participants' results data in your individualised report. Therefore we will post generic reports on the website, which will be available for 12 months after the distribution has closed, so you can access the missing data.

End of report

Example Report

Example Report