

WHITBURN STEEL PUMPING STATION OUTFALL PUMPS  
**2007** -BATHING SEASON-MAY TO SEPTEMBER **ONLY**

After analyzing these figure supplied to me [Eddy Moore] by the Environment Agency  
These are the calculations/conversions figures from the 3 pumps installed in the Pumping Stn.

Pumps are rated at 1500 lts.per.sec == 90 Tonnes per. Min. EACH

Source—NWL's Evidence as supplied in evidence for the Oct. 2001 'Public Inquiry'

Duration of pump No 1 .No2 and No3 running time== 4451 mins

**Total== 4451 Mins.**

**4451 mins. \* 90 Tonnes/per/min.== 400590 TONNES**

*It must to be noticed that the Pumping Station DID NOT pump to Sea at from April until 12<sup>th</sup> June 2007?????*

*Fact Verified by Environment Ageny*

Conclusion ---400,590 Tonnes of Screened Storm Sewage pumped out of  
Whitburn Steel Pumping Station during the 2007 Bathing Season  
[Calculation agreed by Environment Agency 24<sup>th</sup> 2007]

Eddy Moore  
C.A.S.S.S.  
24<sup>th</sup> October 2007.