

07.06.09

WHITBURN STEEL PUMPING STATION OUTFALL PUMPS

2008 -BATHING SEASON-MAY TO SEPTEMBER ONLY

After analyzing these figure supplied to me [Eddy Moore] by the Environment Agency
These are the calculations/conversions figures from the 3 pumps installed in the Pumping Stn.

Pumps are rated at 1500 lts.per.sec == 90 Tonnes per. Min. EACH

Source—NWL's Evidence as supplied in evidence for the Oct. 2001 'Public Inquiry'

Duration of pump No 1 .No2 and No3 running time==5367 mins

Total== 5367 Mins.

5367mins. * 90 Tonnes/per/min.==433,030 TONNES

Fact to be Verified by Environment Agency

Conclusion ---433,030 Tonnes of Screened Storm Sewage pumped out of

Whitburn Steel Pumping Station to sea during the 2008 Bathing Season

[Calculation agreed by Environment Agency 24th October 2007]