

Determination of an Application for an Environmental Permit under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process

The Permit Number is: EPR/WP3738DE/A001
The Applicant / Operator is: GB Bio Limited
The Installation is located at: Tansterne Biomass Power
 Plant

What this document is about

This is a decision document, which accompanies a permit.

It explains how we have considered the Applicant's Application, and why we have included the specific conditions in the permit we are issuing to the Applicant. It is our record of our decision-making process, to show how we have taken into account all relevant factors in reaching our position. Unless the document explains otherwise, we have accepted the Applicant's proposals.

We try to explain our decision as accurately, comprehensively and plainly as possible. Achieving all three objectives is not always easy, and we would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

Preliminary information and use of terms

We gave the application the reference number EPR/WP3738DE/A001. We refer to the application as "the **Application**" in this document in order to be consistent.

The number we have given to the permit is EPR/WP3738DE. We refer to the permit as "the **Permit**" in this document.

The Application was duly made on 8 February 2017.

The Applicant is GB Bio Limited. We refer to GB Bio Limited as "the **Applicant**" in this document. Where we are talking about what would happen after the Permit is granted (if that is our final decision), we call GB Bio Limited "the **Operator**".

GB Bio Limited's proposed facility is located at Tansterne Biomass Power Plant, Hull Road, Aldbrough, HU11 4RE. We refer to this as "the **Installation**" in this document.

How this document is structured

- Glossary of acronyms
- Our proposed decision
- How we reached our decision
- The legal framework
- The Installation
 - Description of the Installation and general issues
 - The site and its protection
 - Operation of the Installation – general issues
- Minimising the installation's environmental impact
 - Assessment Methodology
 - Air Quality Assessment
 - Human health risk assessment
 - Impact on Habitats sites, SSSIs, non-statutory conservation sites, etc.
 - Impact of abnormal operations
 - Noise and vibration
- Application of Best Available Techniques
 - Scope of Consideration
 - BAT and emissions control
 - BAT and global warming potential
 - BAT and POPs
 - Other Emissions to the Environment
 - Setting ELVs and other Permit conditions
 - Monitoring
 - Reporting
- Other legal requirements
 - The EPR 2016 (as amended) and related Directives
 - National primary legislation
 - National secondary legislation
 - Other relevant legal requirements
- Annexes
 - Application of the Industrial Emissions Directive
 - Pre-Operational Conditions
 - Improvement Conditions
 - Consultation Responses

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

AAD	Ambient Air Directive (2008/50/EC)
APC	Air Pollution Control
AQS	Air Quality Strategy
BAT	Best Available Technique(s)
BAT-AEL	BAT Associated Emission Level
BREF	BAT Reference Note
CEM	Continuous emissions monitor
CFD	Computerised fluid dynamics
CHP	Combined heat and power
COMEAP	Committee on the Medical Effects of Air Pollutants
CROW	Countryside and rights of way Act 2000
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DD	Decision document
EAL	Environmental assessment level
EIAD	Environmental Impact Assessment Directive (85/337/EEC)
ELV	Emission limit value
EMAS	EU Eco Management and Audit Scheme
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154) as amended
ES	Environmental standard
EWC	European waste catalogue
FSA	Food Standards Agency
GWP	Global Warming Potential
HHRAP	Human Health Risk Assessment Protocol
HPA	Health Protection Agency (now PHE – Public Health England)
HRA	Human Rights Act 1998
HW	Hazardous waste
HWI	Hazardous waste incinerator

IBA	Incinerator Bottom Ash
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
I-TEF	Toxic Equivalent Factors set out in Annex VI Part 2 of IED
I-TEQ	Toxic Equivalent Quotient calculated using I-TEF
LCPD	Large Combustion Plant Directive (2001/80/EC) – now superseded by IED
LCV	Lower calorific value – also termed net calorific value
LfD	Landfill Directive (1999/31/EC)
LADPH	Local Authority Director(s) of Public Health
LOI	Loss on Ignition
MBT	Mechanical biological treatment
MSW	Municipal Solid Waste
MWI	Municipal waste incinerator
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
Opra	Operator Performance Risk Appraisal
PAH	Polycyclic aromatic hydrocarbons
PC	Process Contribution
PCB	Polychlorinated biphenyls
PEC	Predicted Environmental Concentration
PHE	Public Health England
POP(s)	Persistent organic pollutant(s)
PPS	Public participation statement
PR	Public register
PXDD	Poly-halogenated di-benzo-p-dioxins
PXB	Poly-halogenated biphenyls
PXDF	Poly-halogenated di-benzo furans
RDF	Refuse derived fuel
RGS	Regulatory Guidance Series
SAC	Special Area of Conservation
SED	Solvent Emissions Directive (1999/13/EC) – now superseded by IED
SCR	Selective catalytic reduction
SGN	Sector guidance note
SHPI(s)	Site(s) of High Public Interest

SNCR	Selective non-catalytic reduction
SPA(s)	Special Protection Area(s)
SS	Sewage sludge
SSSI(s)	Site(s) of Special Scientific Interest
SWMA	Specified waste management activity
TDI	Tolerable daily intake
TEF	Toxic Equivalent Factors
TGN	Technical guidance note
TOC	Total Organic Carbon
UHV	Upper heating value –also termed gross calorific value
UN_ECE	United Nations Environmental Commission for Europe
US EPA	United States Environmental Protection Agency
WFD	Waste Framework Directive (2008/98/EC)
WHO	World Health Organisation
WID	Waste Incineration Directive (2000/76/EC) – now superseded by IED

1 Our decision

We have decided to grant the Permit to the Applicant. This will allow it to operate the Installation, subject to the conditions in the Permit.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the permit will ensure that a high level of protection is provided for the environment and human health.

This Application is to operate an installation which is subject principally to the Industrial Emissions Directive (IED).

The Permit contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the permit, we have considered the Application and accepted the details are sufficient and satisfactory to make the standard condition appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Receipt of Application

The Application was duly made on 8 February 2017. This means we considered it was in the correct form and contained sufficient information for us to begin our determination but not that it necessarily contained all the information we would need to complete that determination:

The Applicant made no claim for commercial confidentiality. We have not received any information in relation to the Application that appears to be confidential in relation to any party.

2.2 Consultation on the Application

We carried out consultation on the Application in accordance with the EPR, our statutory PPS and our own internal guidance RGS Note 6 for Determinations involving Sites of High Public Interest. We consider that this process satisfies, and frequently goes beyond the requirements of the Aarhus Convention on Access to Information, Public Participation in Decision-Making and Access to Justice in Environmental Matters, which are directly incorporated into the IED, which applies to the Installation and the Application. We have also taken into account our obligations under the Local Democracy, Economic Development and Construction Act 2009 (particularly Section 23). This requires us, where we consider it appropriate, to take such steps as we

consider appropriate to secure the involvement of representatives of interested persons in the exercise of our functions, by providing them with information, consulting them or involving them in any other way. In this case, our consultation already satisfies the Act's requirements.

We advertised the Application by a notice placed on our website, which contained all the information required by the IED, including telling people where and when they could see a copy of the Application.

We made a copy of the Application and all other documents relevant to our determination (see below) available to view on our Public Register. Anyone wishing to see these documents could do so and arrange for copies to be made.

We sent copies of the Application to the following bodies, which includes those with whom we have "Working Together Agreements":

- Local Authority Environmental Health department
- Health and Safety Executive
- Food Standards Agency
- Public Health England and Director of Public Health
- National Grid
- Fire and Rescue Service

These are bodies whose expertise, democratic accountability and/or local knowledge make it appropriate for us to seek their views directly. Note under our Working Together Agreement with Natural England, we only inform Natural England of the results of our assessment of the impact of the installation on designated Habitats sites.

Further details along with a summary of consultation comments and our response to the representations we received can be found in Annex 4. We have taken all relevant representations into consideration in reaching our determination.

2.3 Requests for Further Information

Although we were able to consider the Application duly made, we did in fact need more information with regard to the Applicant's proposals for fire prevention in order to determine it, and issued an information notice on 3 April 2017. A copy of the information notice was placed on our public register.

3 The legal framework

The Permit will be granted under Regulation 13 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an installation and a waste co-incineration plant as described by the IED;
- an operation covered by the WFD, and
- subject to aspects of other relevant legislation which also have to be addressed.

We address some of the major legal requirements directly where relevant in the body of this document. Other requirements are covered in a section towards the end of this document.

We consider that in granting the Permit, it will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The Installation

4.1 Description of the Installation and related issues

4.1.1 The permitted activities

The Installation is subject to the EPR because it carries out an activity listed in Part 1 of Schedule 1 to the EPR:

- Section 5.1 Part A(1)(b) – incineration of non-hazardous waste in a waste incineration plant or waste co-incineration plant with a capacity of 3 tonnes or more per hour.

The IED definition of “waste incineration plants” and “waste co-incineration plants” says that it includes:

“all incineration lines or co-incineration lines, waste reception, storage, on-site pre-treatment facilities, waste, fuel and air supply systems, boilers, facilities for the treatment of waste gases, on-site facilities for treatment or storage of residues and waste water, stacks, devices for controlling incineration or co-incineration operations, recording and monitoring incineration or co-incineration conditions.”

Many activities which would normally be categorised as “directly associated activities” for EPR purposes (see below), such as air pollution control plant, and the ash storage bunker, are therefore included in the listed activity description.

An installation may also comprise “directly associated activities”, which at this Installation includes the generation of electricity using a steam turbine. These activities comprise one installation, because the incineration plant and the steam turbine are successive steps in an integrated activity.

Together, these listed and directly associated activities comprise the Installation.

4.1.2 The Site

The site is located at National Grid Reference TA 225 374, between Tansterne Lane and the B1238 near Aldbrough, approximately 10km south of Hornsea town centre and 16km northeast of Kingston upon Hull. The site, which was formally agricultural land, is relatively flat and occupies an area of approximately 3.24 hectares.

The site is bounded on all sides by agricultural fields. Residential premises are located 1.5km to the north at East Carlton Farm; 1km to the south at the village of Flinton; 0.4km to the east at Etherdwick Grange; and 0.2km to the west at Tansterne Fishery and Moat Farm.

The site is located upon chalk principal aquifer but not within a groundwater source protection zone. It is not within a designated flood zone. The nearest surface watercourse is Fox Covert Drain which runs along the edge of the site boundary in a northwest to southeast direction.

There are no Special Areas of Conservation (SAC) or Ramsar sites, but one Special Protection Area (SPA) (Hornsea Mere), within 10km of the installation.

The Applicant submitted a plan which we consider is satisfactory, showing the site of the Installation and its extent. A plan is included in Schedule 7 to the Permit, and the Operator is required to carry on the permitted activities within the site boundary.

Further information on the site is addressed below in section 4.3.


4.1.3 What the Installation does

The Applicant has described the facility as a biomass power plant, generating energy from biomass (waste wood). Our view is that for the purposes of IED (in particular Chapter IV) and EPR, the installation is a waste co-incineration plant because:

Notwithstanding the fact that waste will be thermally treated by the process; the process is never the less 'co-incineration' because it is considered that main purpose of this plant is the generation of energy.

The key features of the Installation are summarised in the table and schematic diagram below.

Waste throughput, Tonnes/line	Approximately 128,500/annum	16/hour
Waste processed	Wood	
Number of lines	2	
Furnace technology	Gasification	
Auxiliary Fuel	Gas Oil	
Acid gas abatement	Dry	Sodium bicarbonate
NOx abatement	SNCR	Ammonia
Reagent consumption	Auxiliary Fuel: 123 te/annum during first year, 42 te/annum thereafter Ammonia: 1,060 te/annum Sodium bicarbonate: 1,600 te/annum Activated carbon: 41.6 te/annum Process water: 16,000 te/annum	
Flue gas recirculation	Yes	
Dioxin abatement	Activated carbon	
Stack	Grid Reference TA 22573 37482	
	Height, 55 m	2 flues within a common windshield, each flue 1.5m internal diameter
Flue gas	Flow, 18 Nm ³ /s per flue	Velocity, 10.2 m/s
	Temperature 65 °C	
Electricity generated	23 MWe	184,000 MWh
Electricity exported	21 MWe	168,000 MWh
Steam conditions	Temperature, 480 °C	Pressure, 65 barg



4.1.4 Key Issues in the Determination

The key issues arising during this determination were emissions to air, emissions of noise, and fire prevention, and we therefore describe how we determined these issues in most detail in this document.

4.2 The site and its protection

4.2.1 Site setting, layout and history

The development site is located on former agricultural land, within the setting described in section 4.1.2 above. No industrial processes were undertaken on the site prior to the commencement of construction.

4.2.2 Proposed site design: potentially polluting substances and prevention measures

There will be no point source releases to groundwater from the installation. Fugitive releases to groundwater will be prevented via a range of pollution control and containment measures. The site will be comprised mainly of impervious concrete hardstanding with sealed construction joints, and with a sealed drainage system. There will be very few soft landscaped areas. All process areas, loading/unloading areas, storage areas (for raw materials, chemicals, fuels, and wastes), and roadways will be covered with such concrete, which will be laid to slab over a geo-membrane layer to provide an additional barrier to protect groundwater below. All biomass fuel will be unloaded directly into reception pits within the fuel barn to reduce the risk of contaminated run-off being generated outdoors.

Under normal circumstances uncontaminated surface water run-off from roofs and clean yard areas will be discharged to surface watercourse via an on-site lagoon, with the yard areas being served by Class 1 oil interceptors. Foul water from staff welfare facilities will be treated in a dedicated on-site package sewage treatment plant and discharged to surface watercourse. There are no discharges to public sewer from the installation. Process effluent (consisting of condensate and boiler blowdown) will be recycled back to the boilers via a reverse osmosis plant, with the resultant wastewater being collected and removed off-site by contractor. The Applicant has submitted a detailed drainage plan for the site showing the location of foul, process and surface water drains, monitoring points and emissions points, which we consider to be satisfactory.

The Installation will require the use of a number of potentially polluting raw materials, chemicals and fuels including gas oil, reagents such as aqueous ammonia and sodium bicarbonate, activated carbon, boiler treatment chemicals, and lubrication oils and fluids. All such substances will be stored within suitably constructed tanks or silos, with (where necessary) bunding designed to be (a) resistant to the materials being stored and (b) to contain either 110% of the tank volume, or 25% of the total tankage, as appropriate. Regular inspection and maintenance of all containment measures such as

bunding, hardstanding and the drainage infrastructure will be undertaken. This programme will form part of the operator's Environmental Management System (EMS).

Adequate quantities of spillage absorbent materials will be available on-site, at an easily accessible location(s), where liquids are handled and/or stored. The EMS will contain procedures in place for the management of spillages and emergencies.

In the event of a fire, deluge water contained within the fuel barn, and from other areas which do not involve the handling of biomass fuel, will discharge into the on-site lagoon via the sealed drainage system. The design of the fuel barn and yard areas will be such as to contain this deluge water. The lagoon incorporates a reedbed (to 'polish' any site run-off under normal circumstances prior to discharge to surface water) and a penstock valve to prevent any water escaping the lagoon to the nearby surface water drainage culvert. This would have to be pumped across also so this would prevent any excess firewater escaping the lagoon. Should the lagoon have been used to contain firewater it would be emptied by pumping the contents of the lagoon into tankers for removal and disposal off-site. Once emptied the surface lining of the lagoon, and the reedbed, would be removed and replaced with new material, with the removed material going to a suitable waste contractor.

Under Article 22(2) of the IED the Applicant is required to provide a baseline report containing at least the information set out in paragraphs (a) and (b) of the Article before starting operation.

The Applicant has submitted a site condition report which includes a report on the baseline conditions as required by Article 22. We have reviewed that report and consider that it adequately describes the condition of the soil and groundwater prior to the start of operations.

The baseline report is an important reference document in the assessment of contamination that might arise during the operational lifetime of the installation and at cessation of activities at the installation.

The IED also requires that periodic monitoring of soil and groundwater beneath the site should be undertaken throughout the life of the permit such that the absence of pollution to these media from operations at the site can be demonstrated. Condition 3.2.4 and pre-operational condition PO6 of the permit secures and makes provision for this requirement.

4.2.3 Closure and decommissioning

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place for the closure and decommissioning of the Installation, as referred to in Section 3 of the Application. Pre-operational condition PO1 requires the Operator to have an Environmental Management System in place before the Installation is operational, and this will include a site closure plan.

At the definitive cessation of activities, the Operator has to satisfy us that the necessary measures have been taken so that the site ceases to pose a risk to soil or groundwater, taking into accounts both the baseline conditions and the site's current or approved future use. To do this, the Operator will apply to us for surrender of the permit, which we will not grant unless and until we are satisfied that these requirements have been met.

4.3 Operation of the Installation – general issues

4.3.1 Administrative issues

The Applicant is the sole Operator of the Installation.

We are satisfied that the Applicant is the person who will have control over the operation of the Installation after the granting of the Permit; and that the Applicant will be able to operate the Installation so as to comply with the conditions included in the Permit.

The co-incineration of waste is not a specified waste management activity (SWMA). The Environment Agency has considered whether any of the other activities taking place at the Installation are SWMAs and is satisfied that none are taking place.

We are satisfied that the Applicant's submitted Opra profile is accurate. The Applicant's Opra score at permit application is 277.

The Opra score will be used as the basis for subsistence and other charging, in accordance with our Charging Scheme. Opra is the Environment Agency's method of ensuring application and subsistence fees are appropriate and proportionate for the level of regulation required.

4.3.2 Management

The Applicant has stated in the Application that they will develop an Environmental Management System (EMS) that will be compliant with ISO14001 within 2 years of plant start-up. During this interim period they will implement an internal EMS, which initially will be designed to ensure that the following activities associated with start-up are appropriately managed:

- Raw material receipt & handling
- Plant maintenance
- Abatement equipment maintenance
- Records & reporting
- Operating procedures.

A pre-operational condition (PO1) is included requiring the Operator to provide a summary of the EMS prior to commissioning of the plant and to make available for inspection all EMS documentation. The Environment

Agency recognises that certification of the EMS cannot take place until the Installation is operational. An improvement condition (IC1) is included requiring the Operator to report progress towards gaining certification of its EMS.

We are satisfied that appropriate management systems and management structures will be in place for this Installation, and that sufficient resources are available to the Operator to ensure compliance with all the Permit conditions.

4.3.3 Site security

Having considered the information submitted in the Application, we are satisfied that appropriate infrastructure and procedures will be in place to ensure that the site remains secure.

4.3.4 Accident management

The Applicant has submitted an Accident Management Plan. Having considered the Plan and other information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that accidents that may cause pollution are prevented but that, if they should occur, their consequences are minimised. An Accident Management Plan will form part of the Environmental Management System and must be in place prior to commissioning as required by a pre-operational condition (PO1).

The Applicant submitted a Fire Prevention Plan (FPP) which we considered acceptable and which has been approved. We have referenced the approved FPP in Table S1.2 of the permit as an 'Operating technique.'

We have a regulatory duty to protect the environment and people. A fire that occurs on a site storing combustible waste materials can have a severe impact on the environment and on local communities. Waste fires can produce smoke that contains a variety of harmful emissions including asphyxiants and irritants. The longer the exposure to smoke the more likely there may be significant pollution or harm to human health. Therefore our approach is first to minimise the risk of a fire occurring and then to recognise that if a fire does occur it should be extinguished as quickly as possible whilst at the same time preventing it from spreading.

The measures set out in the Fire prevention plans: environmental permits guidance (November 2016) (the guidance) have therefore been designed to meet the following three objectives:

- minimise the likelihood of a fire happening;
- aim for a fire to be extinguished within 4 hours; and
- minimise the spread of fire within the site and to neighbouring sites.

We consider that if an operator submits a fire prevention plan (FPP) that includes the measures set out in the guidance we are likely to approve that FPP. If an operator is unable to meet the measures in the guidance but can

propose alternative measures that nevertheless meet the aims of the guidance we can still approve that FPP. It is for the operator to demonstrate these measures, so that we can be satisfied that the alternative measures meet the objectives of the guidance.

The operator has identified the potential risk of fire from the installation due to the treatment and storage of combustible non-hazardous wastes on site. In this case, waste wood. The FPP sets out the measures put in place to prevent a fire and the actions that will be taken in the event of a fire occurring.

The FPP did not include all of the measures set out in our guidance. However the FPP did include alternative measures and so the operator was required to demonstrate that the alternative measures could meet the objectives in accordance with our guidance.

We have assessed the FPP and set out below where measures in line with the guidance are in place and where we have agreed alternative measures.

Appropriate measures are in place for non-waste materials, managing common causes of fire (with the exception of 'hot works' where we have agreed an alternative measure - see below), preventing self-combustion, preventing fire spread, fire detection and suppression, fire water supply and containment, and contingency planning during and after an incident. We consider these to be in line with the guidance.

Alternative measures that we have assessed and are satisfied that they meet the objectives of the guidance are as follows:

- Manage common causes of fire (Hot works)

The operator has stated that a 'fire watch' will not necessarily be undertaken following every instance of 'hot works', rather that this requirement will be determined following an activity specific risk assessment which may result in the issue of a 'Hot Work Certificate' specifying that a fire watch is maintained for a set period following cessation of the hot works in question. This is a risk based, pragmatic approach which we deem to be acceptable. The FPP states that if hot works are required to be undertaken in the fuel barn, the barn will be run down so that there is no wood waste present during hot works; and that any containers used to store other wastes such as the oversize material and general waste will be emptied prior to the commencement of any hot works to ensure that there is no risk of catching fire.

- Manage waste piles

Pile sizes for waste wood exceed the maximum pile sizes set out in our guidance. Wood waste biomass fuel, which will arrive on site to a required specification in terms of size and quality, will be stored in two large piles, one in each half of the fuel barn. Each half of the fuel barn is identical in design / operation and has two high definition thermal

imaging cameras. One is fixed on the wall and is programmed to scan the surface of the fuel for any raised temperature, and the other is mounted on the crane and wirelessly linked to the control room. If an anomaly is found, the crane with the mobile thermal camera will be dispatched to the area for further investigation. If confirmed, suspect material will be removed. If it is considered that there is a serious potential for fire i.e. smouldering or smoke, the remote fire monitors may be activated to douse the area with water before removing the material using the crane. If the crane is not available, the material will be removed with a front loading shovel. Therefore, although the waste piles do not comply with our guidance on size, we are satisfied that the operator's proposed approach with respect to detection and suppression of fire within the fuel barn; the management of hot-spots, combined with the use of quarantine areas, is acceptable, based on their explanation of how the fuel barn will be operated and the mitigation measures that will be put in place, as described in the FPP.

- Quarantine area

Two quarantine areas are proposed, namely, (1) the non-compliant material quarantine area (measuring 13m x 6m), for parking lorries with suspect incoming loads which could be a risk to operation, and (2) the loose material quarantine area (measuring 15m x 10m), for the temporary storage (and dousing if necessary) of any material required to be removed from within the fuel barn, for example, following detection of a 'hot-spot'. Both quarantine areas are smaller than 50% of the largest wood pile as set out in the guidance. Both quarantine areas are appropriately located and full details of how these areas will be used in practice are contained in the FPP. Therefore, although neither quarantine area complies with our guidance on size / storage capability, we are satisfied that the operator's risk based approach to sizing is acceptable, based on their explanation of how the site will be operated and the mitigation measures that will be put in place, as described in the FPP.

In conclusion we are satisfied overall that the Applicant's FPP meets the objectives of our guidance.

4.3.5 Off-site conditions

We do not consider that any off-site conditions are necessary.

4.3.6 Operating techniques

We have specified that the Applicant must operate the Installation in accordance with the following documents contained in the Application:

Description	Parts Included	Justification
Application	Parts B2 and B3 of the	Together these sections

Description	Parts Included	Justification
EPR/3738DE/A001	Application Form. The Supporting Information document including associated Appendices, with the exception of the Fire Prevention Plan.	describe key operating techniques and how the Installation will be operated to ensure that best available techniques are applied.
Response to Not Duly Made letter, dated 26/01/17	Response to following questions: Q5 - incineration process diagram Q6 - biomass handling system diagram Q7 - emission points plan Q8 - site plan showing installation boundary Q11 - waste types accepted for incineration	
Fire Prevention Plan	Report No. 70022642 Appendix J, Tansterne Biomass Power Plant, Fire Prevention Plan, June 2017 - Rev 2. Site Layout Plan (Drawing no. 15457-H-DG-005, Rev. P1, dated June 2017)	

The details set out above describe the techniques that will be used for the operation of the Installation that have been assessed by the Environment Agency as BAT; they form part of the Permit through Permit condition 2.3.1 and Table S1.2 in the Permit Schedules.

We have also specified the following limits and controls on the use of raw materials and fuels:

Raw Material or Fuel	Specifications	Justification
Gas Oil	< 0.1% sulphur content	As required by Sulphur Content of Liquid Fuels Regulations.

Article 45(1) of the IED requires that the Permit must include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2005/532/EC, EC, if possible, and containing information on the quantity of each type of waste, where appropriate. The Application contains a list of those wastes wood types, coded by the European Waste Catalogue (EWC) number, which the Applicant will accept in the waste streams entering the plant and which the plant is capable of burning in an environmentally acceptable way. We have specified the permitted waste types, descriptions and where appropriate quantities which can be accepted at the installation in Table S2.2.

We are satisfied that the Applicant can accept the wastes contained in Table S2.2 of the Permit because: -

- (i) these wastes are categorised as municipal waste in the European Waste Catalogue or are non-hazardous wastes similar in character to municipal waste;
- (ii) the wastes are all categorised as non-hazardous in the European Waste Catalogue and are capable of being safely burnt at the installation.
- (iii) these wastes are likely to be within the design calorific value (CV) range for the plant;
- (iv) these wastes are unlikely to contain harmful components that cannot be safely processed at the Installation.

We have limited the capacity of the Installation to 257,120 tonnes per annum. This is based on the installation operating 8,000 hours per year at a nominal capacity of approximately 16 tonnes per hour.

The Installation will be designed, constructed and operated using BAT for the incineration of the permitted wastes. We are satisfied that the operating and abatement techniques are BAT for incinerating these types of waste. Our assessment of BAT is set out later in this document.

4.3.7 Energy efficiency

(i) Consideration of energy efficiency

We have considered the issue of energy efficiency in the following ways:

1. The use of energy within, and generated by, the Installation which are normal aspects of all EPR permit determinations. This issue is dealt with in this section.
2. The extent to which the Installation meets the requirements of Article 50(5) of the IED, which requires "*the heat generated during the incineration and co-incineration process is recovered as far as practicable through the generation of heat, steam or power*". This issue is covered in this section.

3. The combustion efficiency and energy utilisation of different design options for the Installation are relevant considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options. This aspect is covered in the BAT assessment in section 6 of this Decision Document.
4. The extent to which the Installation meets the requirement of Article 14(5) of the Energy Efficiency Directive which requires new thermal electricity generation installations with a total thermal input exceeding 20 MW to carry out a cost-benefit assessment to “*assess the cost and benefits of providing for the operation of the installation as a high-efficiency cogeneration installation*”.

Cogeneration means the simultaneous generation in one process of thermal energy and electrical or mechanical energy and is also known as combined heat and power (CHP)

High-efficiency co-generation is cogeneration which achieves at least 10% savings in primary energy usage compared to the separate generation of heat and power – see Annex II of the Energy Efficiency Directive for detail on how to calculate this.

(ii) Use of energy within the Installation

Having considered the information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that energy is used efficiently within the Installation.

The Application details a number of measures that will be implemented at the Installation in order to increase its energy efficiency. It will be designed to include all normal energy efficiency design features, including the following:

- The use of variable speed drives rather than fixed speed drives.
- Ensuring that motors are always effectively lubricated, as part of general ongoing maintenance programme.
- The pre-heating of condensate using the condensing economiser meaning that less heat is required to heat it back to steam for use within the system.
- The use of a hybrid impulse turbine which offers higher efficiency, up to 97%, when compared to conventional turbines at 90%.
- Making use of all available heat for electricity generation. For example, flue gas recirculation (FGR) will be used to assist heating of the fluidised beds and primary combustion air. In addition each fluidised bed combustor will have a heat recovery steam generator (HRSG) for the further capture of heat.

- The condensing steam turbine will be fitted with blanket type insulation. In addition the interconnecting pipework will also be appropriately insulated. The fluidised bed boiler will be fitted with ceramic fibre insulation.
- The thermal process will be within a building and not subject to significant variations in ambient temperature.
- The use of a SCADA system to manage the fluidised bed combustors to ensure that the whole combustion process and electrical recovery is maximised as appropriate and the demand is managed effectively across the two lines.
- Minimisation of air ingress to the fluidised bed combustors. The only air added is intentionally done so via nozzles to aid primary and secondary combustion.

The Application states that energy consumption and efficiency will be monitored throughout the operation of the plant to ensure that heat and electricity generation are maximised for export. This ongoing assessment will be controlled by via the EMS once it is developed.

The Application states that the specific energy consumption, a measure of total energy consumed per unit of waste processed, will be 79.5 kWh/tonne. The installation capacity is 257,120 t/a.

Data from the BREF for Municipal Waste Incinerators shows that the range of specific energy consumptions is as in the table below.

MSWI plant size range (t/yr)	Process energy demand (kWh/t waste input)
Up to 150,000	300 – 700
150,000 – 250,000	150 – 500
More than 250,000	60 – 200

The BREF says that it is BAT to reduce the average installation electrical demand to generally below 150 kWh/tonne of waste with an LCV of 10.4 MJ/kg. The specific energy consumption in the Application is in line with that set out above.

(iii) Generation of energy within the Installation - Compliance with Article 50(5) of the IED

Article 50(5) of the IED requires that *“the heat generated during the incineration and co-incineration process is recovered as far as practicable”*.

Our CHP Ready Guidance - February 2013 considers that BAT for energy efficiency for Energy from Waste (EfW) plant is the use of CHP in

circumstances where there are technically and economically viable opportunities for the supply of heat from the outset.

The term CHP in this context represents a plant which also provides a supply of heat from the electrical power generation process to either a district heating network or to an industrial / commercial building or process. However, it is recognised that opportunities for the supply of heat do not always exist from the outset (i.e. when a plant is first consented, constructed and commissioned).

In cases where there are no immediate opportunities for the supply of heat from the outset, the Environment Agency considers that BAT is to build the plant to be CHP Ready (CHP-R) to a degree which is dictated by the likely future opportunities which are technically viable and which may, in time, also become economically viable.

The BREF says that where a plant generates electricity only, it is BAT to recover 0.4 – 0.65 MWh/ tonne of waste (based on LCV of 10.4 MJ/kg) for raw waste inputs or 0.6 – 1.0 MWh/tonne of waste (based on LCV of 15.2 MJ/kg) for pre-treated wastes. Our technical guidance note, SGN EPR S5.01, states that where electricity only is generated, 5-9 MW of electricity should be recoverable per 100,000 tonnes/annum of waste (which equates to 0.4 – 0.72 MWh/tonne of waste).

The Installation will generate electricity only and has been specified to maximise electrical output with little or no use of waste heat. The Application indicates that 23 MW of electricity is produced for an annual burn of approximately 257,120 tonnes, which represents 8.9 MW per 100,000 tonnes/yr of waste burned (0.7 MWh/tonne of waste). The Installation is therefore within the indicative BAT range.

The SGN and Chapter IV of the IED both require that, as well as maximising the primary use of heat to generate electricity; waste heat should be recovered as far as practicable.

The location of the Installation largely determines the extent to which waste heat can be utilised, and this is a matter for the planning authority. The Applicant carried out a feasibility study but determined that there were currently no significant viable heat loads for the supply of waste heat. They stated that installation is to be operated in order to recover the maximum electrical output in order to achieve the economic aims of the power plant. However they did confirm that the fluidised bed combustors could easily be retrofitted with the connections necessary to extract waste heat should a viable heat load become available and that there was adequate space on site to fit the additional equipment.

Our CHP-R guidance also states that opportunities to maximise the potential for heat recovery should be considered at the early planning stage, when sites are being identified for incineration facilities. In our role as a statutory consultee on the planning application, we ensured that the issue of energy utilisation was brought to the planning authority's attention.

We consider that, within the constraints of the location of the Installation explained above, the Installation will recover heat as far as practicable, and therefore that the requirements of Article 50(5) are met.

(iv) R1 Calculation

The R1 calculation does not form part of the matters relevant to our determination. It is however a general indicator that the installation is achieving a high level of energy recovery.

The Applicant has not presented an R1 calculation with this application, nor have we received a separate application for a determination on whether the installation is a recovery or disposal facility.

Note that the availability or non-availability of financial incentives for renewable energy such as the ROC and RHI schemes is not a consideration in determining this application.

(v) Compliance with Article 14(5) of the Energy Efficiency Directive

The Applicant has carried out an assessment of the potential for operating the installation as a high-efficiency cogeneration installation and has concluded that this will not be possible because there are currently insufficient viable heat loads within 15 km of the installation.

In terms of industrial heat loads they stated that there are two large industrial sources within 15km which have heat loads of 42,642 MWh and 33,428 MWh respectively, although they had no details on what form any heat requirement would take, and in any case, these industrial sources were ideally located near to Saltend Cogeneration Plant for the provision of their waste heat. Saltend Cogeneration Plant is approximately 12 km southwest from the proposed installation.

The Applicant has also considered commercial and municipal heat loads within 15km of the installation. In this regard they stated that in addition to there being no domestic heat networks to link any excess heat into, the area is a very rural with dispersed populations and a limited number of commercial sites. They report that the municipal heat demand is typically in the 2-10,000 MWh/km² whilst for commercial heat the only demand in the area is 1-2,000 MWh/km² in the centre of Hull which is more than 15km away.

The Applicant did confirm that they have had one discussion with a local site operated by a large national energy company. However they stated that the main issue with regards the supply of heat to this site was that the operator of the site required a heat supply at 90°C whilst the heat from the proposed biomass plant would be hot water at 46°C. They said that to supply the required heat would reduce the electricity they could supply to the national grid and make the cost of the providing the heat more expensive, in order to compensate for the loss of electricity revenue from the grid. They concluded by saying that “heat supply arrangements are not the primary financial source

for the project and as such can be supplied if a suitable source is available of the type that could use the heat without impacting maximum electricity generation.”

Having considered the Applicant’s comments we have concluded that no cost benefit assessment is required and that we will not require the installation to operate as a high-efficiency cogeneration installation.

Notwithstanding the outcome of their initial investigations as described above, the Applicant used our guidance to complete a cost-benefit assessment (CBA) for installations under Article 14 of the Energy Efficiency Directive, to review the financial viability of opportunities for high efficiency cogeneration within 15 km of the installation. In their CBA they calculated the net present value (NPV) using project specific costs data. If the NPV is positive (i.e. any number more than zero) it means that the investors will make a rate of return that makes the scheme commercially viable. A negative NPV means that the project will not be commercially viable. The Applicant’s assessment showed a net present value of £-27.92 million over 23 years, demonstrating that operating as a high-efficiency cogeneration installation would not be financially viable.

(vi) Permit conditions concerning energy efficiency

Pre-operational condition PO2 requires the Operator to carry out a comprehensive review of the available heat recovery options prior to commissioning, in order to ensure that waste heat from the plant is recovered as far as possible.

Conditions 1.2.2 and 1.2.3 have also been included in the Permit, which require the Operator to review the options available for heat recovery on an ongoing basis, and to provide and maintain the proposed steam/hot water pass-outs.

The Operator is required to report energy usage and energy generated under condition 4.2 and Schedule 5. The following parameters are required to be reported: total electrical energy generated; electrical energy exported; total energy usage and energy exported as heat (if any). Together with the total MSW burned per year, this will enable the Environment Agency to monitor energy recovery efficiency at the Installation and take action if at any stage the energy recovery efficiency is less than proposed.

There are no site-specific considerations that require the imposition of standards beyond indicative BAT, and so the Environment Agency accepts that the Applicant’s proposals represent BAT for this Installation.

4.3.8 Efficient use of raw materials

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place to ensure the efficient use of raw materials and water.

The Operator is required to report with respect to raw material usage under condition 4.2. and Schedule 5, including consumption of sodium bicarbonate, activated carbon and urea used per tonne of waste burned. This will enable the Environment Agency to assess whether there have been any changes in the efficiency of the air pollution control plant, and the operation of the SNCR to abate NO_x. These are the most significant raw materials that will be used at the Installation, other than the waste feed itself (addressed elsewhere). The efficiency of the use of auxiliary fuel will be tracked separately as part of the energy reporting requirement under condition 4.2.1. Optimising reagent dosage for air abatement systems and minimising the use of auxiliary fuels is further considered in the section on BAT.

4.3.9 Avoidance, recovery or disposal with minimal environmental impact of wastes produced by the activities

This requirement addresses wastes produced at the Installation and does not apply to the waste being treated there. The principal waste streams the Installation will produce are bottom ash, fly ash, air pollution control residues and recovered metals.

The first objective is to avoid producing waste at all. Waste production will be avoided by achieving a high degree of burnout of the ash in the furnace, which results in a material that is both reduced in volume and in chemical reactivity. Condition 3.1.3 and associated Table S3.4 specify limits for total organic carbon (TOC) of <3% / loss on ignition (LOI) of <5% in bottom ash. Compliance with this limit will demonstrate that good combustion control and waste burnout is being achieved in the furnaces and waste generation is being avoided where practicable.

Incinerator bottom ash (IBA) will normally be classified as non-hazardous waste. However, IBA is classified on the European List of Wastes as a “mirror entry”, which means IBA is a hazardous waste if it possesses a hazardous property relating to the content of dangerous substances. Monitoring of incinerator ash will be carried out in accordance with the requirements of Article 53(3) of IED. Classification of IBA for its subsequent use or disposal is controlled by other legislation and so is not duplicated within the permit.

Air pollution control (APC) residues from flue gas treatment are hazardous waste and therefore must be sent for disposal to a landfill site permitted to accept hazardous waste, or to an appropriately permitted facility for hazardous waste treatment. The amount of APC residues is minimised through optimising the performance of the air emissions abatement plant.

In order to ensure that the IBA and APC residues are adequately characterised, pre-operational condition PO2 requires the Operator to provide a written plan for approval detailing the ash sampling protocols. Table S3.4 requires the Operator to carry out an ongoing programme of monitoring.

Having considered the information submitted in the Application, we are satisfied that the waste hierarchy referred to in Article 4 of the WFD will be applied to the generation of waste and that any waste generated will be treated in accordance with this Article.

We are satisfied that waste from the Installation that cannot be recovered will be disposed of using a method that minimises any impact on the environment. Standard condition 1.4.1 will ensure that this position is maintained.

5. Minimising the Installation’s environmental impact

Regulated activities can present different types of risk to the environment, these include odour, noise and vibration; accidents, fugitive emissions to air and water; as well as point source releases to air, discharges to ground or groundwater, global warming potential and generation of waste and other environmental impacts. Consideration may also have to be given to the effect of emissions being subsequently deposited onto land (where there are ecological receptors). All these factors are discussed in this and other sections of this document.

For an installation of this kind, the principal emissions are those to air, although we also consider those to land and water.

The next sections of this document explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and what measures we are requiring to ensure a high level of protection.

5.1 Assessment Methodology

5.1.1 Application of Environment Agency guidance ‘risk assessments for your environmental permit’

A methodology for risk assessment of point source emissions to air, which we use to assess the risk of applications we receive for permits, is set out in our guidance ‘Air emissions risk assessment for your environmental permit’ and has the following steps:

- Describe emissions and receptors
- Calculate process contributions
- Screen out insignificant emissions that do not warrant further investigation
- Decide if detailed air modelling is needed
- Assess emissions against relevant standards
- Summarise the effects of emissions

The methodology uses a concept of “process contribution (PC)”, which is the estimated concentration of emitted substances after dispersion into the receiving environmental media at the point where the magnitude of the

concentration is greatest. The methodology provides a simple method of calculating PC primarily for screening purposes and for estimating process contributions where environmental consequences are relatively low. It is based on using dispersion factors. These factors assume worst case dispersion conditions with no allowance made for thermal or momentum plume rise and so the process contributions calculated are likely to be an overestimate of the actual maximum concentrations. More accurate calculation of process contributions can be achieved by mathematical dispersion models, which take into account relevant parameters of the release and surrounding conditions, including local meteorology – these techniques are expensive but normally lead to a lower prediction of PC.

5.1.2 Use of Air Dispersion Modelling

For incineration applications, we normally require the Applicant to submit a full air dispersion model as part of their application. Air dispersion modelling enables the process contribution to be predicted at any environmental receptor that might be impacted by the plant.

Once short-term and long-term PCs have been calculated in this way, they are compared with Environmental Standards (ES).

Where an Ambient Air Directive (AAD) Limit Value exists, the relevant standard is the AAD Limit Value. Where an AAD Limit Value does not exist, AAD target values, UK Air Quality Strategy (AQS) Objectives or Environmental Assessment Levels (EALs) are used. Our web guide sets out EALs which have been derived to provide a similar level of protection to Human Health and the Environment as the AAD limit values, AAD target and AQS objectives. In a very small number of cases, e.g. for emissions of lead, the AQS objective is more stringent than the AAD value. In such cases, we use the AQS objective for our assessment.

AAD target values, AQS objectives and EALs do not have the same legal status as AAD limit values, and there is no explicit requirement to impose stricter conditions than BAT in order to comply with them. However, they are a standard for harm and any significant contribution to a breach is likely to be unacceptable.

PCs are considered **Insignificant** if:

- the **long-term** process contribution is less than **1%** of the relevant ES; and
- the **short-term** process contribution is less than **10%** of the relevant ES.

The **long term** 1% process contribution insignificance threshold is based on the judgements that:

- It is unlikely that an emission at this level will make a significant contribution to air quality;
- The threshold provides a substantial safety margin to protect health and the environment.

The **short term** 10% process contribution insignificance threshold is based on the judgements that:

- spatial and temporal conditions mean that short term process contributions are transient and limited in comparison with long term process contributions;
- the threshold provides a substantial safety margin to protect health and the environment.

Where an emission is screened out in this way, we would normally consider that the Applicant's proposals for the prevention and control of the emission to be BAT. That is because if the impact of the emission is already insignificant, it follows that any further reduction in this emission will also be insignificant.

However, where an emission cannot be screened out as insignificant, it does not mean it will necessarily be significant.

For those pollutants which do not screen out as insignificant, we determine whether exceedences of the relevant ES are likely. This is done through detailed audit and review of the Applicant's air dispersion modelling taking background concentrations and modelling uncertainties into account. Where an exceedance of an AAD limit value is identified, we may require the Applicant to go beyond what would normally be considered BAT for the Installation or we may refuse the application if the applicant is unable to provide suitable proposals. Whether or not exceedences are considered likely, the application is subject to the requirement to operate in accordance with BAT.

This is not the end of the risk assessment, because we also take into account local factors (for example, particularly sensitive receptors nearby such as a SSSIs, SACs or SPAs). These additional factors may also lead us to include more stringent conditions than BAT.

If, as a result of reviewing of the risk assessment and taking account of any additional techniques that could be applied to limit emissions, we consider that emissions **would cause significant pollution**, we would refuse the Application.

5.2 Assessment of Impact on Air Quality

The Applicant's assessment of the impact of air quality is set out in Report No. 70022642 contained within the Application. The assessment comprises:

- A screening assessment using the Environment Agency screening tool of emissions to air from the operation of the incinerator.
- Dispersion modelling of emissions to air from the operation of the incinerator.
- A study of the impact of emissions on nearby sensitive habitat / conservation sites.

This section of the decision document deals primarily with the dispersion modelling of emissions to air from the incinerator chimney and its impact on local air quality. The impact on conservation sites is considered in section 5.4.

The Applicant has assessed the Installation's potential emissions to air against the relevant air quality standards, and the potential impact upon local conservation and habitat sites and human health. These assessments predict the potential effects on local air quality from the Installation's stack emissions using the ADMS 5.1 dispersion model, which is a commonly used computer model for regulatory dispersion modelling. The model used 5 years of meteorological data collected from the weather station at Bridlington between 2011 and 2015.

The air impact assessments, and the dispersion modelling upon which they were based, employed the following assumptions.

- First, they assumed that the ELVs in the Permit would be the maximum permitted by Article 46(2) and Annex VI of the IED. These substances are:
 - Oxides of nitrogen (NO_x), expressed as NO₂
 - Total dust
 - Sulphur dioxide (SO₂)
 - Hydrogen chloride (HCl)
 - Hydrogen fluoride (HF)
 - Metals (Cadmium, Thallium, Mercury, Antimony, Arsenic, Lead, Chromium, Cobalt, Copper, Manganese, Nickel and Vanadium)
 - Polychlorinated dibenzo-para-dioxins and polychlorinated dibenzo furans (referred to as dioxins and furans)
 - Gaseous and vaporous organic substances, expressed as Total Organic Carbon (TOC)

- Second, they assumed that the Installation operates continuously at the relevant long-term or short-term ELVs., i.e. the maximum permitted emission rate (except for emissions of arsenic, chromium and nickel, which are considered in section 5.2.3 of this decision document). For these metals they have used a percentage based on the maximum measured concentration from currently permitted municipal waste incinerators and waste wood co-incinerators referenced in our guidance.

- Third, the model also considered emissions of pollutants not covered by Annex VI of IED, specifically ammonia (NH₃).

We are in agreement with this approach. The assumptions underpinning the model have been checked and are reasonably precautionary.

The Applicant has used background pollutant concentrations (to calculate the PEC) from a variety of data sources, namely, Defra modelled background maps; UK heavy metals and polycyclic aromatics networks, acid gas and aerosol network and toxic organic micro pollutants network. Based on the

rural location of the site some of the consultant selected background data is likely to be reasonably conservative as it includes sources from more polluted background areas. However, the report references background metals data from Sheffield Tinsley. This is an urban background monitoring station and is unlikely to represent the background for the biomass plant site. It is unclear whether the background data presented in the Applicant's report (table 9) were used in the assessment for PEC as some of the data for Sheffield Tinsley is already above the EQS's. We have conducted our own background data checks from the same sources to include any more appropriate and updated data. Where there are discrepancies, and where appropriate, we have used the worst case background concentrations to provide conservative and robust results.

As well as calculating the peak ground level concentration, the Applicant has modelled the concentration of key pollutants at a number of specified locations within the surrounding area, including 11 sensitive (predominantly residential) receptors and 4 ecological receptors. The Applicant also included on-site discrete receptors. Predictions at these locations on the Installation are not representative of exposure and are not relevant for assessment purposes. In addition to the discrete receptor locations, a grid covering an area of 800m by 800m centred on the proposed plant, with a grid spacing of 5m, was included in the model set up, so that contour plots showing the impact of the proposed plant on ground level concentrations of the key pollutants assessed could be produced.

The way in which the Applicant used dispersion models, its selection of input data, use of background data and the assumptions it made have been reviewed by the Environment Agency's modelling specialists to establish the robustness of the Applicant's air impact assessment. The output from the model has then been used to inform further assessment of health impacts and impact on habitats and conservation sites.

Our review of the Applicant's assessment leads us to agree with the Applicant's conclusions. We have also audited the air quality and human health impact assessment and similarly agree that the conclusions drawn in the reports were acceptable.

The Applicant's modelling predictions are summarised in the following sections.

5.2.1 Assessment of Air Dispersion Modelling Outputs

The Applicant's modelling predictions are summarised in the tables below.

The Applicant's modelling predicted peak ground level exposure to pollutants in ambient air and at discrete receptors. The tables below show the ground level concentrations at the most impacted receptor.

Whilst we have used the Applicant's modelling predictions in the table below, we have made our own simple verification calculation of the percentage

process contribution and predicted environmental concentration. These are the numbers shown in the tables below and so may be very slightly different to those shown in the Application. Any such minor discrepancies do not materially impact on our conclusions.

Non-metals

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$
NO ₂	40	1	10.1	1.3	3.25	11.4	28.5
	200	2	20.2	27.4	13.7	47.6	23.8
PM ₁₀	40	1	16.8	0.1	0.25	-	-
	50	3	33.6	1.1	2.20	-	-
PM _{2.5}	25	1	11	0.06	0.24	-	-
SO ₂	266	4	9.2	47	17.7	56.2	21.1
	350	5	9.2	37.9	10.83	47.1	13.5
	125	6	9.2	17.7	14.2	26.9	21.5
HCl	750	7	0.26	13.8	1.84	-	-
HF	16	8	2.46	0.01	0.06	-	-
	160	7	4.92	0.92	0.575	-	-
TOC	5	1	0.17	0.1	2.00	0.270	5.40
NH ₃	180	1	-	0.3	0.16	-	-
	2500	7	-	11.8	0.47	-	-

TOC as benzene

- 1 Annual Mean
- 2 99.79th %ile of 1-hour means
- 3 90.41st %ile of 24-hour means
- 4 99.9th %ile of 15-min means
- 5 99.73rd %ile of 1-hour means
- 6 99.18th %ile of 24-hour means
- 7 1-hour average
- 8 Monthly average
- 9 Maximum daily running 8-hour mean
- 10 1-hour maximum

Metals

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$
Cd	0.005	1	0.00045	0.00047	9.4	0.00092	18.4
Tl	1	1	-	0.00047	0.047	-	-
	30	2	-	0.0113	0.038	-	-
Hg	0.25	1	0.00128	0.00047	0.19	-	-
Sb	5	1	0.1	0.0047	0.09	-	-
	150	2	0.2	0.115	0.08	-	-
Pb	0.25	1	0.01498	0.0047	1.88	0.01968	7.87
Co	0.2	1	0.00059	0.0047	2.4	0.0053	2.7
	6	2	0.00118	0.115	1.9	-	-
Cu	10	1	0.01928	0.0047	0.05	-	-
	200	2	0.03856	0.115	0.06	-	-
Mn	0.15	1	0.02773	0.0047	3.13	0.03243	21.62
	1500	2	0.05546	0.115	0.01	-	-
V	5	1	0.00142	0.0047	0.09	-	-
	1	3	0.00284	0.115	11.50	0.11784	11.78
As	0.003	1	0.00955	0.000028	0.93	-	-
Cr (II)(III)	5	1	0.02838	0.00031	0.01	-	-
	150	2	0.05676	0.0076	0.01	-	-
Cr (VI)	0.0002	1	-	0.000007	3.50	See (iii) below	See (iii) below
Ni	0.02	1	0.01755	0.0013	6.50	0.01885	94.3

- 1 Annual Mean
2 1-hr Maximum
3 24-hr Maximum

(i) Screening out emissions which are insignificant

From the tables above the following emissions can be screened out as insignificant in that the process contribution is <1% of the long term ES and <10% of the short term ES. These are:

- PM₁₀, PM_{2.5}, HCl, HF, NH₃, TI, Hg, Sb, Cu, As and Cr (II)(III).

Therefore we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation subject to the detailed audit referred to below.

(ii) Emissions unlikely to give rise to significant pollution

Also from the tables above the following emissions (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% (taking expected modelling uncertainties into account) of both the long term and short term ES.

- NO₂, SO₂, TOC, Cd, Co, Pb, Mn, V and Ni.

For these emissions, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the Best Available Techniques to prevent and minimise emissions of these substances. This is reported in section 6 of this document.

(iii) Emissions requiring further assessment

Finally from the tables above Cr (VI) cannot be considered to be insignificant as the process contribution is > 1% of the long term ES. The Applicant did not calculate the PEC, stating that background concentrations were unavailable for the Cr (VI) component. They concluded however that as the process contribution to total concentration of this pollutant was very small and no exceedances of the relevant objectives levels are caused, the impact could be considered insignificant.

Chromium (VI) is not specifically referenced in Annex VI of IED, which includes only total Chromium as one of the nine Group 3 metals, the impact of which has been assessed above. The EPAQS guidelines refer only to that portion of the metal emissions contained within PM₁₀ in ambient air. The guideline for Chromium (VI) is 0.2 ng/m³.

Measurement of chromium (VI) at the levels anticipated at the stack emission points is expected to be difficult, with the likely levels being below the level of detection by the most advanced methods. We have considered the concentration of total chromium and chromium (VI) in the APC residues collected upstream of the emission point for existing Municipal Waste incinerators and have assumed these to be similar to the particulate matter released from the emission point. This data shows that the mean chromium (VI) emission concentration (based on the bag dust ratio) is $3.5 * 10^{-5}$ mg/m³ (max $1.3 * 10^{-4}$).

The Applicant did not use the above data to model the predicted chromium (VI) impact. We have therefore undertaken check modelling using the maximum emissions data from Appendix A of our current metals assessment guidance, i.e. using the above emission concentration of 1.3×10^{-4} mg/m³. Our check modelling shows that the worse-case PC for Cr (VI) at relevant receptors is insignificant, i.e. < 1% of the EAL.

5.2.2 Consideration of key pollutants

(i) Nitrogen dioxide (NO₂)

The impact on air quality from NO₂ emissions has been assessed against the ES of 40 µg/m³ as a long term annual average and a short term hourly average of 200 µg/m³. The model assumes a 70% NO_x to NO₂ conversion for the long term and 35% for the short term assessment in line with Environment Agency guidance on the use of air dispersion modelling.

The above tables show that the peak long term PC is greater than 1% of the ES and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the ES being exceeded. The peak short term PC also exceeds the level that would screen out as insignificant (>10% of the ES). However it is not expected to result in the ES being exceeded.

(ii) Particulate matter PM₁₀ and PM_{2.5}

The impact on air quality from particulate emissions has been assessed against the ES for PM₁₀ (particles of 10 microns and smaller) and PM_{2.5} (particles of 2.5 microns and smaller). For PM₁₀, the ES are a long term annual average of 40 µg/m³ and a short term daily average of 50 µg/m³. For PM_{2.5} the ES of 25 µg/m³ as a long-term annual average to be achieved by 2010 as a Target Value and by 2015 as a Limit Value has been used.

The Applicant's predicted impact of the Installation against these ESs is shown in the tables above. The assessment assumes that **all** particulate emissions are present as PM₁₀ for the PM₁₀ assessment and that two thirds of particulate emissions are present as PM_{2.5} for the PM_{2.5} assessment.

The above assessment is considered to represent a worst case assessment in that: -

- It assumes that the plant emits particulates continuously at the IED Annex VI limit for total dust, whereas actual emissions from similar plant are normally lower.
- It assumes that (a) all particulates emitted are below either 10 microns (PM₁₀) or (b) two thirds are below 2.5 microns (PM_{2.5}), when in both cases, some are expected to be larger.

We have reviewed the Applicant's particulate matter impact assessment and are satisfied in the robustness of the Applicant's conclusions.

The above assessment shows that the predicted process contribution for emissions of PM₁₀ is below 1% of the long term ES and below 10% of the short term ES and so can be screened out as insignificant. Therefore we consider the Applicant's proposals for preventing and minimising the emissions of particulates to be BAT for the Installation.

The above assessment also shows that the predicted process contribution for emissions of PM_{2.5} is also below 1% of the ES. Therefore the Environment Agency concludes that particulate emissions from the installation, including emissions of PM₁₀ or PM_{2.5}, will not give rise to significant pollution.

There is currently no emission limit prescribed nor any continuous emissions monitor for particulate matter specifically in the PM₁₀ or PM_{2.5} fraction. Whilst the Environment Agency is confident that current monitoring techniques will capture the fine particle fraction (PM_{2.5}) for inclusion in the measurement of total particulate matter, an improvement condition (IC2) has been included that will require a full analysis of particle size distribution in the flue gas, and hence determine the ratio of fine to coarse particles. In the light of current knowledge and available data however the Environment Agency is satisfied that the health of the public would not be put at risk by such emissions, as explained in section 5.3.3.

(iii) Acid gases, SO₂, HCl and HF

From the tables above, emissions of HCl and HF can be screened out as insignificant in that the process contribution is <10% of the short term ES. There is no long term ES for HCl. HF has 2 assessment criteria – a 1-hr ES and a monthly EAL – the process contribution is <1% of the monthly EAL and so the emission screens out as insignificant if the monthly ES is interpreted as representing a long term ES.

There is no long term EAL for SO₂ for the protection of human health. Protection of ecological receptors from SO₂ for which there is a long term ES is considered in section 5.4.

Whilst SO₂ emissions cannot be screened out as insignificant, the Applicant's modelling shows that the installation is unlikely to result in a breach of the ES. The Applicant is required to prevent, minimise and control SO₂ emissions using BAT, this is considered further in Section 6. We are satisfied that SO₂ emissions will not result in significant pollution.

(iv) Emissions to air of VOCs, Dioxins and NH₃

The above tables show that for VOC emissions, which were modelled as TOC, the peak long term PC is greater than 1% of the ES and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the ES being exceeded.

The Applicant has used the ES for 1,3 butadiene for their assessment of the impact of VOC. This is based on 1,3 butadiene having the lowest ES of organic species likely to be present in VOC (other than PAH, PCBs, dioxins and furans).

The above tables show that for NH₃ emissions, the peak long term PC is less than 1% of the ES and the peak short term PC is less than 10% of the ES and so can be screened out as insignificant. Therefore we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation.

There is no ES for dioxins and furans as the principal exposure route for these substances is by ingestion and the risk to human health is through the accumulation of these substances in the body over an extended period of time. This issue is considered in more detail in section 5.3.

The ammonia emission is based on a release concentration of 30 mg/m³, whereas our expectation is that a level of emission of 10 mg/m³ is more consistent with the operation of a well controlled SNCR NO_x abatement system. The Applicant has used the higher emission concentration to provide a more conservative assessment and given that the ammonia emission screens out as insignificant we are therefore satisfied with this approach.

Whilst all emissions cannot be screened out as insignificant, the Applicant's modelling shows that the installation is unlikely to result in a breach of the EALs. The Applicant is required to prevent, minimise and control VOC emissions using BAT, this is considered further in Section 6. We are satisfied that VOC emissions will not result in significant pollution.

(v) Summary

For the above emissions to air, for those emissions that do not screen out, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the BAT to prevent and minimise emissions of these substances. This is reported in section 6 of this document. Therefore we consider the Applicant's proposals for preventing and minimising emissions to be BAT for the Installation. Dioxins and furans are considered further in section 5.3.2.

5.2.3 Assessment of Emission of Metals

The Applicant has assessed the impact of metal emissions to air, as previously described.

Annex VI of IED sets three limits for metal emissions:

- An emission limit value of 0.05 mg/m³ for mercury and its compounds (formerly WID group 1 metals).
- An aggregate emission limit value of 0.05 mg/m³ for cadmium and thallium and their compounds (formerly WID group 2 metals).

- An aggregate emission limit of 0.5 mg/m³ for antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium and their compounds (formerly WID group 3 metals).

In addition the UK is a Party to the Heavy Metals Protocol within the framework of the UN-ECE Convention on long-range trans-boundary air pollution. Compliance with the IED Annex VI emission limits for metals along with the Application of BAT also ensures that these requirements are met.

In section 5.2.1 above, the following emissions of metals were screened out as insignificant:

- Tl, Hg, Sb, Cu, As, Cr (II)(III) and Cr (VI).

Also in section 5.2.1, the following emissions of metals whilst not screened out as insignificant were assessed as being unlikely to give rise to significant pollution:

- Cd, Co, Pb, Mn, V and Ni.

There were no metal emissions requiring further assessment. The Applicant has concluded that exceedences of the EAL for all metals are not likely to occur. The installation has been assessed as meeting BAT for control of metal emissions to air. See section 6 of this document. The Environment Agency's experience of regulating incineration plant is that emissions of metals are in any event below the Annex VI limits set in IED, and that the above assessment is an over prediction of the likely impact. We therefore agree with the Applicant's conclusions.

(i) Impact on Air Quality Management Areas (AQMAs)

No Air Quality Management Areas (AQMAs) have been declared within an area likely to be affected by emissions from the incinerator.

5.3 Human health risk assessment

5.3.1 Our role in preventing harm to human health

The Environment Agency has a statutory role to protect the environment and human health from all processes and activities it regulates. We assessed the effects on human health for this application in the following ways:

i) Applying Statutory Controls

The plant will be regulated under EPR. These regulations include the requirements of relevant EU Directives, notably, the industrial emissions directive (IED), the waste framework directive (WFD), and ambient air directive (AAD).

The main conditions in an EfW permit are based on the requirements of the IED. Specific conditions have been introduced to specifically ensure compliance with the requirements of Chapter IV. The aim of the IED is to prevent or, where that is not practicable, to reduce emissions to air, water and land and prevent the generation of waste, in order to achieve a high level of protection of the environment taken as a whole. IED achieves this aim by setting operational conditions, technical requirements and emission limit values to meet the requirements set out in Articles 11 and 18 of the IED. These requirements include the application of BAT, which may in some circumstances dictate tighter emission limits and controls than those set out in Chapter IV of IED on waste incineration and co-incineration plants. The assessment of BAT for this installation is detailed in section 6 of this document.

ii) Environmental Impact Assessment

Industrial activities can give rise to odour, noise and vibration, accidents, fugitive emissions to air and water, releases to air (including the impact on Photochemical Ozone Creation Potential (POCP)), discharges to ground or groundwater, global warming potential and generation of waste. For an installation of this kind, the principal environmental effects are through emissions to air, although we also consider all of the other impacts listed. Section 5.1 and 5.2 above explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and any measures we are requiring to ensure a high level of protection.

iii) Expert Scientific Opinion

We take account of the views of national and international expert bodies. The gathering of evidence is a continuing process. Although gathering evidence is not our role we keep the available evidence under review. The following is a summary of some of the publications which we have considered (in no particular order).

An independent review of evidence on the health effects of municipal waste incinerators was published by **DEFRA** in 2004. It concluded that there was no convincing link between the emissions from MSW incinerators and adverse effects on public health in terms of cancer, respiratory disease or birth defects. On air quality effects, the report concluded “Waste incinerators contribute to local air pollution. This contribution, however, is usually a small proportion of existing background levels which is not detectable through environmental monitoring (for example, by comparing upwind and downwind levels of airborne pollutants or substances deposited to land). In some cases, waste incinerator facilities may make a more detectable contribution to air pollution. Because current MSW incinerators are located predominantly in urban areas, effects on air quality are likely to be so small as to be undetectable in practice.”

The European Integrated Pollution Prevention and Control Bureau stated in the Reference Document on the Best Available Techniques for Waste Incineration August 2006 “European health impact assessment studies, on the basis of current evidence and modern emission performance, suggest that the local impacts of incinerator emissions to air are either negligible or not detectable.”

HPA (now PHE) in 2009 states that “The Health Protection Agency has reviewed research undertaken to examine the suggested links between emissions from municipal waste incinerators and effects on health. While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable”. In January 2012 PHE confirmed they would be undertaking a study to look for evidence of any link between municipal waste incinerators and health outcomes including low birth weight, still births and infant deaths. Their current position that modern, well run municipal waste incinerators are not a significant risk to public health remains valid. The study will extend the evidence base and provide the public with further information

Policy Advice from Government also points out that the minimal risk from modern incinerators. Paragraph 22 (Chapter 5) of WS2007 says that “research carried out to date has revealed no credible evidence of adverse health outcomes for those living near incinerators.” It points out that “the relevant health effects, mainly cancers, have long incubation times. But the research that is available shows an absence of symptoms relating to exposures twenty or more years ago when emissions from incinerators were much greater than is now the case.” **Paragraph 30 of PPS10** explains that “modern, appropriately located, well run and well regulated waste management facilities should pose little risk to public health.”

The **Committee on Carcinogenicity of Chemicals in Food, Consumer Products and the Environment (CoC)** issued a statement in 2000 which said that “any potential risk of cancer due to residency (for periods in excess of 10 years) near to municipal solid waste incinerators was exceedingly low and probably not measurable by the most modern epidemiological techniques.” In 2009, CoC considered six further relevant epidemiological papers that had been published since the 2000 statement, and concluded that “there is no need to change the advice given in the previous statement in 2000 but that the situation should be kept under review”.

Republic of Ireland Health Research Board report stated that “It is hard to separate the influences of other sources of pollutants, and other causes of cancer and, as a result, the evidence for a link between cancer and proximity to an incinerator is not conclusive”.

The **Food Safety Authority of Ireland (FSAI) (2003)** investigated possible implications on health associated with food contamination from waste incineration and concluded: “In relation to the possible impact of introduction of waste incineration in Ireland, as part of a national waste management

strategy, on this currently largely satisfactory situation, the FSAI considers that such incineration facilities, if properly managed, will not contribute to dioxin levels in the food supply to any significant extent. The risks to health and sustainable development presented by the continued dependency on landfill as a method of waste disposal far outweigh any possible effects on food safety and quality.”

Health Protection Scotland (2009) considered scientific studies on health effects associated with the incineration of waste particularly those published after the Defra review discussed earlier. The main conclusions of this report were: “(a) For waste incineration as a whole topic, the body of evidence for an association with (non-occupational) adverse health effects is both inconsistent and inconclusive. However, more recent work suggests, more strongly, that there may have been an association between emissions (particularly dioxins) in the past from industrial, clinical and municipal waste incinerators and some forms of cancer, before more stringent regulatory requirements were implemented. (b) For individual waste streams, the evidence for an association with (non-occupational) adverse health effects is inconclusive. (c) The magnitude of any past health effects on residential populations living near incinerators that did occur is likely to have been small. (d) Levels of airborne emissions from individual incinerators should be lower now than in the past, due to stricter legislative controls and improved technology. Hence, any risk to the health of a local population living near an incinerator, associated with its emissions, should also now be lower.”

The **US National Research Council Committee on Health Effects of Waste Incineration (NRC) (NRC 2000)** reviewed evidence as part of a wide ranging report. The Committee view of the published evidence was summarised in a key conclusion: “Few epidemiological studies have attempted to assess whether adverse health effects have actually occurred near individual incinerators, and most of them have been unable to detect any effects. The studies of which the committee is aware that did report finding health effects had shortcomings and failed to provide convincing evidence. That result is not surprising given the small populations typically available for study and the fact that such effects, if any, might occur only infrequently or take many years to appear. Also, factors such as emissions from other pollution sources and variations in human activity patterns often decrease the likelihood of determining a relationship between small contributions of pollutants from incinerators and observed health effects. Lack of evidence of such relationships might mean that adverse health effects did not occur, but it could mean that such relationships might not be detectable using available methods and sources.”

The **British Society for Ecological Medicine (BSEM) published a report in 2005** on the health effects associated with incineration and concluded that “Large studies have shown higher rates of adult and childhood cancer and also birth defects around municipal waste incinerators: the results are consistent with the associations being causal. A number of smaller epidemiological studies support this interpretation and suggest that the range of illnesses produced by incinerators may be much wider. Incinerator

emissions are a major source of fine particulates, of toxic metals and of more than 200 organic chemicals, including known carcinogens, mutagens, and hormone disrupters. Emissions also contain other unidentified compounds whose potential for harm is as yet unknown, as was once the case with dioxins. Abatement equipment in modern incinerators merely transfers the toxic load, notably that of dioxins and heavy metals, from airborne emissions to the fly ash. This fly ash is light, readily windborne and mostly of low particle size. It represents a considerable and poorly understood health hazard.”

The BSEM report was reviewed by the HPA and they concluded that “Having considered the BSEM report the HPA maintains its position that contemporary and effectively managed and regulated waste incineration processes contribute little to the concentrations of monitored pollutants in ambient air and that the emissions from such plants have little effect on health.” The BSEM report was also commented on by the consultants who produced the Defra 2004 report referred to above. They said that “It fails to consider the significance of incineration as a source of the substances of concern. It does not consider the possible significance of the dose of pollutants that could result from incinerators. It does not fairly consider the adverse effects that could be associated with alternatives to incineration. It relies on inaccurate and outdated material. In view of these shortcomings, the report’s conclusions with regard to the health effects of incineration are not reliable.”

A **Greenpeace** review on incineration and human health concluded that a broad range of health effects have been associated with living near to incinerators as well as with working at these installations. Such effects include cancer (among both children and adults), adverse impacts on the respiratory system, heart disease, immune system effects, increased allergies and congenital abnormalities. Some studies, particularly those on cancer, relate to old rather than modern incinerators. However, modern incinerators operating in the last few years have also been associated with adverse health effects.”

The Health Protection Scotland report referred to above says that “the authors of the Greenpeace review do not explain the basis for their conclusion that there is an association between incineration and adverse effects in terms of criteria used to assess the strength of evidence. The weighting factors used to derive the assessment are not detailed. The objectivity of the conclusion cannot therefore be easily tested.”

From this published body of scientific opinion, we take the view stated by the HPA that “While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable”. We therefore ensure that permits contain conditions which require the installation to be well-run and regulate the installation to ensure compliance with such permit conditions.

iv) **Health Risk Models**

Comparing the results of air dispersion modelling as part of the Environmental Impact assessment against European and national air quality standards effectively makes a health risk assessment for those pollutants for which a standard has been derived. These air quality standards have been developed primarily in order to protect human health via known intake mechanisms, such as inhalation and ingestion. Some pollutants, such as dioxins, furans and dioxin like PCBs, have human health impacts at lower ingestion levels than lend themselves to setting an air quality standard to control against. For these pollutants, a different human health risk model is required which better reflects the level of dioxin intake.

Models are available to predict the dioxin, furan and dioxin like PCBs intake for comparison with the Tolerable Daily Intake (TDI) recommended by the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment, known as COT. These include the HHRAP model.

HHRAP has been developed by the US EPA to calculate the human body intake of a range of carcinogenic pollutants and to determine the mathematic quantitative risk in probabilistic terms. In the UK, in common with other European Countries, we consider a threshold dose below which the likelihood of an adverse effect is regarded as being very low or effectively zero.

The TDI is the amount of a substance that can be ingested daily over a lifetime without appreciable health risk. It is expressed in relation to bodyweight in order to allow for different body size, such as for children of different ages. In the UK, the COT has set a TDI for dioxins, furans and dioxin like PCB's of 2 picograms I-TEQ/Kg-body weight/day (N.B. a picogram is a million millionths (10⁻¹²) of a gram).

In addition to an assessment of risk from dioxins, furans and dioxin like PCB's, the HHRAP model enables a risk assessment from human intake of a range of heavy metals. In principle, the respective ES for these metals are protective of human health. It is not therefore necessary to model the human body intake.

COMEAP developed a methodology based on the results of time series epidemiological studies which allows calculation of the public health impact of exposure to the classical air pollutants (NO₂, SO₂ and particulates) in terms of the numbers of "deaths brought forward" and the "number of hospital admissions for respiratory disease brought forward or additional". COMEAP has issued a statement expressing some reservations about the applicability of applying its methodology to small affected areas. Those concerns generally relate to the fact that the exposure-response coefficients used in the COMEAP report derive from studies of whole urban populations where the air pollution climate may differ from that around a new industrial installation. COMEAP identified a number of factors and assumptions that would contribute to the uncertainty of the estimates. These were summarised in the Defra review as below:

- Assumption that the spatial distribution of the air pollutants considered is the same in the area under study as in those areas, usually cities or large towns, in which the studies which generated the coefficients were undertaken.
- Assumption that the temporal pattern of pollutant concentrations in the area under study is similar to that in the areas in which the studies which generated the coefficients were undertaken (i.e. urban areas).
- It should be recognised that a difference in the pattern of socio-economic conditions between the areas to be studied and the reference areas could lead to inaccuracy in the predicted level of effects.
- In the same way, a difference in the pattern of personal exposures between the areas to be studied and the reference areas will affect the accuracy of the predictions of effects.

The use of the COMEAP methodology is not generally recommended for modelling the human health impacts of individual installations. However it may have limited applicability where emissions of NO_x, SO₂ and particulates cannot be screened out as insignificant in the Environmental Impact assessment, there are high ambient background levels of these pollutants and we are advised that its use was appropriate by our public health consultees.

Our recommended approach is therefore the use of the methodology set out in our guidance for comparison for most pollutants (including metals) and dioxin intake model using the HHRAP model as described above for dioxins, furans and dioxin like PCBs. Where an alternative approach is adopted for dioxins, we check the predictions ourselves.

v) Consultations

As part of our normal procedures for the determination of a permit application, we consult with Local Authorities, Local Authority Directors of Public Health, FSA and PHE. We also consult the local communities who may raise health related issues. All issues raised by these consultations are considered in determining the application as described in Annex 4 of this document.

5.3.2 Assessment of Intake of Dioxins, Furans and Dioxin like PCBs

For dioxins, furans and dioxin like PCBs, the principal exposure route is through ingestion, usually through the food chain, and the main risk to health is through accumulation in the body over a period of time.

The human health risk assessment calculates the dose of dioxins and furans that would be received by local receptors if their food and water were sourced from the locality where the deposition of dioxins, furans and dioxin like PCBs is predicted to be the highest. This is then assessed against the Tolerable Daily Intake (TDI) levels established by the COT of 2 picograms I-TEQ / Kg bodyweight/ day.

The results of the Applicant’s assessment of dioxin intake are detailed in the table below. (worst – case results for each category are shown). The results showed that the predicted daily intake of dioxins, furans and dioxin like PCBs at all receptors, resulting from emissions from the proposed facility, were significantly below the recommended TDI levels.

Receptor	Adult	% of TDI	Child	% of TDI
Resident	0.071	3.6	0.138	6.9

Calculated maximum daily intake of dioxins by local receptors resulting from the operation of the proposed facility (pg I-TEQ/ kg-BW/day)

The FSA has reported that dietary studies have shown that estimated total dietary intakes of dioxins and dioxin-like PCBs from all sources by all age groups fell by around 50% between 1997 and 2001, and are expected to continue to fall. A report in 2012 showed that Dioxin and PCB levels in food have fallen slightly since 2001. In 2001, the average daily intake by adults in the UK from diet was 0.9 pg WHO-TEQ/kg bodyweight. The additional daily intake predicted by the modelling as shown in the table above is substantially below this figure.

In 2010, FSA studied the levels of chlorinated, brominated and mixed (chlorinated-brominated) dioxins and dioxin-like PCBs in fish, shellfish, meat and eggs consumed in UK. It asked COT to consider the results and to advise on whether the measured levels of these PXDDs, PXDFs and PXBs indicated a health concern (‘X’ means a halogen). COT issued a statement in December 2010 and concluded that “ The major contribution to the total dioxin toxic activity in the foods measured came from chlorinated compounds. Brominated compounds made a much smaller contribution, and mixed halogenated compounds contributed even less (1% or less of TDI). Measured levels of PXDDs, PXDFs and dioxin-like PXBs do not indicate a health concern”. COT recognised the lack of quantified TEFs for these compounds but said that “even if the TEFs for PXDDs, PXDFs and dioxin-like PXBs were up to four fold higher than assumed, their contribution to the total TEQ in the diet would still be small. Thus, further research on PXDDs, PXDFs and dioxin-like PXBs is not considered a priority.”

In the light of this statement, we assess the impact of chlorinated compounds as representing the impact of all chlorinated, brominated and mixed dioxins / furans and dioxin like PCBs.

5.3.3 Particulates smaller than 2.5 microns

The Operator will be required to monitor particulate emissions using the method set out in Table S3.1 of Schedule 3 of the Permit. This method requires that the filter efficiency must be at least 99.5 % on a test aerosol with a mean particle diameter of 0.3 µm, at the maximum flow rate anticipated. The filter efficiency for larger particles will be at least as high as this. This means that particulate monitoring data effectively captures everything above

0.3 µm and much of what is smaller. It is not expected that particles smaller than 0.3 µm will contribute significantly to the mass release rate / concentration of particulates because of their very small mass, even if present. This means that emissions monitoring data can be relied upon to measure the true mass emission rate of particulates.

Nano-particles are considered to refer to those particulates less than 0.1 µm in diameter (PM_{0.1}). Questions are often raised about the effect of nano-particles on human health, in particular on children's health, because of their high surface to volume ratio, making them more reactive, and their very small size, giving them the potential to penetrate cell walls of living organisms. The small size also means there will be a larger number of small particles for a given mass concentration. However the HPA statement (referenced below) says that due to the small effects of incinerators on local concentration of particles, it is highly unlikely that there will be detectable effects of any particular incinerator on local infant mortality.

The HPA (now PHE) addresses the issue of the health effects of particulates in their September 2009 statement 'The Impact on Health of Emissions to Air from Municipal Incinerators'. It refers to the coefficients linking PM₁₀ and PM_{2.5} with effects on health derived by COMEAP and goes on to say that if these coefficients are applied to small increases in concentrations produced, locally, by incinerators; the estimated effects on health are likely to be small. PHE note that the coefficients that allow the use of number concentrations in impact calculations have not yet been defined because the national experts have not judged that the evidence is sufficient to do so. This is an area being kept under review by COMEAP.

In December 2010, COMEAP published a report on The Mortality Effects of Long-Term Exposure to Particulate Air Pollution in the United Kingdom. It says that "a policy which aims to reduce the annual average concentration of PM_{2.5} by 1 µg/m³ would result in an increase in life expectancy of 20 days for people born in 2008." However, "The Committee stresses the need for careful interpretation of these metrics to avoid incorrect inferences being drawn – they are valid representations of population aggregate or average effects, but they can be misleading when interpreted as reflecting the experience of individuals."

PHE also point out that in 2007 incinerators contributed 0.02% to ambient ground level PM₁₀ levels compared with 18% for road traffic and 22% for industry in general. PHE noted that in a sample collected in a day at a typical urban area the proportion of PM_{0.1} is around 5-10% of PM₁₀. It goes on to say that PM₁₀ includes and exceeds PM_{2.5} which in turn includes and exceeds PM_{0.1}.

This is consistent with the assessment of this application which shows emissions of PM₁₀ to air to be insignificant.

We take the view, based on the foregoing evidence, that techniques which control the release of particulates to levels which will not cause harm to

human health will also control the release of fine particulate matter to a level which will not cause harm to human health.

5.3.4 Assessment of Health Effects from the Installation

We have assessed the health effects from the operation of this installation in relation to the above (sections 5.3.1 to 5.3.3). We have applied the relevant requirements of the national and European legislation in imposing the permit conditions. We are satisfied that compliance with these conditions will ensure protection of the environment and human health.

Taking into account all of the expert opinion available, we agree with the conclusion reached by PHE that “While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable.”

In carrying out air dispersion modelling as part of the Environmental Impact assessment and comparing the predicted environmental concentrations with European and national air quality standards, the Applicant has effectively made a health risk assessment for many pollutants. These air quality standards have been developed primarily in order to protect human health.

The Applicant’s assessment of the impact from PM₁₀, PM_{2.5}, HCl, HF, NH₃, Tl, Hg, Sb, Cu, As Cr (II)(III) and Cr (VI) have all indicated that the Installation emissions screen out as insignificant; where the impact of emissions of NO₂, SO₂, TOC, Cd, Co, Pb, Mn, V and Ni have not been screened out as insignificant, the assessment still shows that the predicted environmental concentrations are well within air quality standards or environmental action levels.

The Environment Agency has reviewed the methodology employed by the Applicant to carry out the health impact assessment.

For both normal and abnormal operation, our predictions from screening check calculations confirm that the Installation will not cause significant impacts or exceedances of the environmental standards for air at human receptors. With regard to dioxins, furans and dioxin-like PCB intakes, our checks indicate process contributions that are less than those predicted by the Applicant, which are not likely to be significant and do not require further investigation.

Overall, taking into account the conservative nature of the impact assessment (i.e. that it is based upon an individual exposed for a life-time to the effects of the highest predicted relevant airborne concentrations and consuming mostly locally grown food), it was concluded that the operation of the proposed facility will not pose a significant carcinogenic or non-carcinogenic risk to human health.

Public Health England and the Local Authority Director of Public Health were consulted on the Application and concluded that they had no significant concerns regarding the risk to the health of humans from the installation. The Food Standards Agency was also consulted during the permit determination process and it concluded that it is unlikely that there will be any unacceptable effects on the human food chain as a result of the operations at the Installation. Details of the responses provided by Public Health England, the Local Authority Director of Public Health and the FSA to the consultation on this Application can be found in Annex 4.

The Environment Agency is therefore satisfied that the Applicant's conclusions presented above are soundly based and we conclude that the potential emissions of pollutants including dioxins, furans and metals from the proposed facility are unlikely to have an impact upon human health.

5.4 Impact on Habitats sites, SSSIs, non-statutory conservation sites etc.

5.4.1 Sites Considered

The following Habitats (i.e. Special Areas of Conservation, Special Protection Areas and Ramsar) sites are located within 10Km of the Installation:

- Hornsea Mere SPA

There are no Sites of Special Scientific Interest within 2Km of the proposed Installation.

There are no non-statutory local wildlife and conservation sites within 2Km of the proposed Installation.

No further assessment is required.

5.4.2 Habitats Assessment

The Applicant's Habitats assessment was reviewed by the Environment Agency's technical specialists who agreed with the assessment's conclusions, that there would be no likely significant effect on the interest feature(s) of the protected site(s).

Pollutant	ES / EAL ($\mu\text{g}/\text{m}^3$)	Back-ground ($\mu\text{g}/\text{m}^3$)	PC ($\mu\text{g}/\text{m}^3$)	PC as % of ES	PEC ($\mu\text{g}/\text{m}^3$)	PEC as % of ES
Direct Impacts¹						
NO_x (as NO₂) (annual mean)	30	-	0.0219	0.1	-	-
SO₂ (annual mean)	20	-	0.0055	0.03	-	-

Pollutant	ES / EAL ($\mu\text{g}/\text{m}^3$)	Back-ground ($\mu\text{g}/\text{m}^3$)	PC ($\mu\text{g}/\text{m}^3$)	PC as % of ES	PEC ($\mu\text{g}/\text{m}^3$)	PEC as % of ES
Ammonia (annual mean)	3	-	0.0033	0.1	-	-
HF (daily mean)	5	-	0.0001	0.002	-	-
Deposition Impacts ¹						
N Deposition (kg N/ha/yr)	n/a (see below)	-	-	-	-	-
Acidification (Keq/ha/yr)	n/a (see below)	-	-	-	-	-

1. Direct impact units are $\mu\text{g}/\text{m}^3$ and deposition impact units are kg N/ha/yr or Keq/ha/yr.

From the table above the direct impacts due to emissions of NO_x , SO_2 , ammonia and HF can be screened out as insignificant and their impact considered not discernable, in that the PC is less than 1% of the long term Critical Level and less than 10% of the short term Critical Level.

With regard to deposition impacts the Applicant noted that Hornsea Mere SPA is a habitat classed as 'standing open water' and as such is not sensitive to nitrogen and acid deposition. As there are no comparable habitats with established critical load estimates, available for the site; and as no Critical Loads have been assigned to the EUNIS (European nature information system) classes for meso/eutrophic systems, the Applicant has been unable to undertake a deposition impact assessment. We are satisfied that no further assessment is required for this habitat type.

Our checks of the Applicant's ecological assessment at Hornsea Mere SPA confirm that emissions to air from the Installation will not have a likely significant effect on the designated site.

5.5 Impact of abnormal operations

Article 50(4)(c) of IED requires that waste incineration and co-incineration plants shall operate an automatic system to prevent waste feed whenever any of the continuous emission monitors show that an emission limit value (ELV) is exceeded due to disturbances or failures of the purification devices. Notwithstanding this, Article 46(6) allows for the continued incineration and co-incineration of waste under such conditions provided that this period does not (in any circumstances) exceed 4 hours uninterrupted continuous operation or the cumulative period of operation does not exceed 60 hours in a calendar year. This is a recognition that the emissions during transient states (e.g. start-up and shut-down) are higher than during steady-state operation, and

the overall environmental impact of continued operation with a limited exceedance of an ELV may be less than that of a partial shut-down and re-start.

For incineration plant, IED sets backstop limits for particulates, CO and TOC which must continue to be met at all times. The CO and TOC limits are the same as for normal operation, and are intended to ensure that good combustion conditions are maintained. The backstop limit for particulates is 150 mg/m³ (as a half hourly average) which is five times the limit in normal operation.

Article 45(1)(f) requires that the permit shall specify the maximum permissible period of any technically unavoidable stoppages, disturbances, or failures of the purification devices or the measurement devices, during which the concentrations in the discharges into the air may exceed the prescribed emission limit values. In this case we have decided to set the time limit at 4 hours, which is the maximum period prescribed by Article 46(6) of the IED.

These abnormal operations are limited to no more than a period of 4 hours continuous operation and no more than 60 hour aggregated operation in any calendar year. This is less than 1% of total operating hours and so abnormal operating conditions are not expected to have any significant long term environmental impact unless the background conditions were already close to, or exceeding, an ES. For the most part therefore consideration of abnormal operations is limited to consideration of its impact on short term ESs.

Emissions data during abnormal operation have been submitted by the Applicant as typical unabated pollutant concentrations for the principal pollutants of NO_x, SO₂ and HCl, with the exception of emissions of dust, for which they submitted emissions data for the simultaneous failure of a single bag filter unit in each boiler unit. To take account of variation at short timescales, and to ensure a conservative assessment, they based their assessment of abnormal operations on short term concentrations (daily or less) was based on an emission rate of twice the typical unabated emissions concentrations.

This is a worst case scenario in that these abnormal conditions include a number of different equipment failures not all of which will necessarily result in an adverse impact on the environment (e.g. a failure of a monitoring instrument does not necessarily mean that the incinerator or abatement plant is malfunctioning). This analysis assumes that any failure of any equipment results in all the negative impacts set out above occurring simultaneously.

The result on the Applicant's short-term environmental impact is summarised in the table below.

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$	% of EAL
NO₂	200	2	20.2	117.6	58.8	137.8	68.9
PM₁₀	50	3	33.6	3.5	7.00	37.1	74.2
SO₂	125	7	9.2	20	16.00	29.2	23.4
	266	4	9.2	82.2	30.9	91.4	34.4
	350	5	9.2	66.3	18.94	75.5	21.6
HCl	750	6	0.26	52.1	6.95	52.4	6.98

- 2 99.79th %ile of 1-hour means
- 3 90.41st %ile of 24-hour means
- 4 99.9th ile of 15-min means
- 5 99.73rd %ile of 1-hour means
- 6 1-hour average
- 7 99.18th %ile of 24-hour means

From the table above the emissions of PM₁₀ and HCl can be considered insignificant, in that the PC is <10% of the short-term ES. Also from the table above emissions of NO₂ and SO₂ (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% of short term ES.

We are therefore satisfied that it is not necessary to further constrain the conditions and duration of the periods of abnormal operation beyond those permitted under Chapter IV of the IED.

We have not assessed the impact of abnormal operations against long term ESs for the reasons set out above. Except that if dioxin emissions were at 10 ng/m³ for the maximum period of abnormal operation, this would result in increases of approximately 69% (adult) and 67% (child) in the TDI's reported in section 5.3.2. In these circumstances the TDI (adult) would be 0.12 pg(I-TEQ/ kg-BW/day), which is 6% of the COT TDI, and the TDI (child) would be

0.23 pg(I-TEQ/ kg-BW/day), which is 11.5% of the COT TDI. At these levels, emissions of dioxins will still not pose a risk to human health.

5.6 Noise and vibration

5.6.1 Impact Assessment

The application contained an assessment of the potential noise impact during operation of the installation. This predictive assessment was based on the modelling software package CadnaA, which is a commonly used computer model for regulatory noise modelling. The assessment considered operations during both the daytime and the night-time period. Modelling predictions were made at the following sensitive receptors:

Receptor reference	Receptor name / location	Receptor type	Distance / direction from Installation boundary
R1	Tansterne Grange Farm	Two storey detached farmhouse dwelling	247m due northwest
R2	Tansterne Lane (right)	Right hand side of two storey semi-detached dwelling on Tansterne Lane	337m due west
R5	Tansterne lane dwelling and kennels	Detached dwelling (bungalow)	401m due southwest
R6	Etherdwick Grange	Detached two / three storey dwelling	426m due southeast
R7	Etherdwick Cottage	Detached two / three storey dwelling	580m due southeast

The potential impact due to the operation of the installation has been determined in accordance with the methodology in British Standard BS4142:2014, 'Methods for rating and assessing industrial and commercial sound.' The significance of industrial/commercial sound depends on the difference between the rating level (which is the predicted sound output of the industrial/commercial premises, corrected to account for tonality, impulsivity, intermittency or other applicable sound characteristics) and the background sound level. Typically, the greater the difference, the greater the magnitude of the impact.

A difference of around +10dB or more is likely to be an indication of a significant adverse impact, while a difference of around +5dB is likely to be an indication of an adverse impact. The lower the rating is, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. If the rating level does not exceed the background sound level, this is an indication of a low impact.

BS4142:2014 requires that the assessment of potential impact takes into account the 'context' in which the sound occurs. This entails having a sufficient understanding of the situation to be rated and assessed, and placing the sound being assessed in context when making conclusions. The Applicant's assessment highlights the consideration of context within BS4142, in particular, where background sound levels / rating levels are low (around 30 dB(A)). For this scenario BS4142 states that "absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night." Therefore the Applicant considered absolute levels against their own criteria based on BS8233: 2014: *Guidance on sound insulation and noise reduction for buildings* and the World Health Organisation: *Guidelines for community noise*.

They considered that for 'non-involved receptors', i.e. third party properties, where the rating level from the proposed development can be controlled to be no greater than 35dB during the daytime or night time period, the resulting noise impact would be low at worst. For these receptors (R2, R5, R6 and R7) an assessment criteria of 35dB was adopted. For Tansterne Grange Farm (receptor R1) which is in the ownership of the scheme developers, they adopted a higher assessment criteria of 40dB.

The way in which the Applicant has used the noise model, the selection of input data, use of background data and the assumptions made have been reviewed by the Environment Agency's modelling specialists to establish the robustness of the Applicant's noise impact assessment. Our view is that the methodology used by the Applicant is acceptable.

The results of the Applicant's daytime assessment are shown in the table below.

Receptor Reference	Receptor name / location	Rating level (dB) (absolute)	Adopted assessment criteria (dB)	Criteria achieved?
R1	Tansterne Grange Farm	37	40	Yes
R2	Tansterne Lane (right)	35	35	Yes
R5	Tansterne lane dwelling and	34	35	Yes

Receptor Reference	Receptor name / location	Rating level (dB) (absolute)	Adopted assessment criteria (dB)	Criteria achieved?
	kennels			
R6	Etherdwick Grange	34	35	Yes
R7	Etherdwick Cottage	31	35	Yes

The results of the Applicant's night-time assessment are shown in the table below.

Receptor Reference	Receptor name / location	Rating level (dB) (absolute)	Adopted assessment criteria (dB)	Criteria achieved?
R1	Tansterne Grange Farm	37	40	Yes
R2	Tansterne Lane (right)	34	35	Yes
R5	Tansterne lane dwelling and kennels	33	35	Yes
R6	Etherdwick Grange	35	35	Yes
R7	Etherdwick Cottage	33	35	Yes

The results show that during the both daytime and night-time periods the adopted assessment criteria are met at all receptor locations. The greatest predicted impact was a daytime level of 37dB at Tansterne Grange Farm.

In our audit of the Applicant's assessment we considered the predicted night time absolute levels against the World Health Organisation (WHO) Europe, Night Noise Guidelines for Europe, 2009 guidelines, which specify a level of 40-45dB(A) for sleep disturbance. We also considered the Noise Policy Statement for England (NPSE) March 2010, whose adverse levels allow for a more robust assessment. The NPSE refers to (a) Lowest Observed Adverse Effect Level (LOAEL) as being above 40dB where adverse effects on health and quality of life can be detected and (b) Significant Observed Adverse Effect Level (SOAEL) as above 55dB where significant adverse effects occur.

The NPSE states where impacts lie somewhere between LOAEL and SOAEL all reasonable steps should be taken to mitigate and minimise adverse effects on health and quality of life.

Based on our audit we agree with the Applicant in that there will not likely be an exceedance of the 40 dB night time WHO guideline for sleep disturbance at all receptors, and the NPSE LOAEL criteria for daytime operations will be met. The possible exception to this is Tansterne Grange Farm, which is in the ownership of the developers. Following sensitivity checking we are unable to rule out a potential exceedance at Tansterne Grange Farm. Verification of the outcome of the Applicant's assessment will be dependent on them being able to achieve the sound power levels for the stack and the boiler feed conveyors detailed in their noise model and ensuring that the proposed noise barrier and bund is installed as indicated.

We have therefore included an Improvement Condition in the permit (IC7) requiring the Operator to undertake an assessment of operational noise from the facility in accordance with BS4142:2014 to validate the model predictions. The IC also requires that proposals for remedial action should be submitted and an associated timetable agreed, should the results of the assessment be indicative of an adverse impact (or greater) at residential receptors.

In addition to our audit of the Applicant's predictions at the sensitive receptors R1, R2, R5, R6 and R7, we have also undertaken check modelling of potential noise impact in the village of Aldbrough (in response to concerns from a local residents (as reported in Annex 4). Although Aldbrough is much further from the Installation than the 5 sensitive receptors considered by the Applicant, unlike Aldbrough, none of those receptors are directly downwind of the Installation. Furthermore the intervening ground towards the village is open fields, potentially allowing for sound to travel more readily. We have undertaken check modelling at 2 locations, in the centre of Aldbrough and on the southwest outskirts of the village, nearest to the Installation. We have considered the potential noise impact both during the daytime and night-time periods. Our modelling checks are indicative of a low risk of noise impact in the village due to operation of the Installation.

5.6.2 Application of BAT

The Applicant has stated that the proposed installation incorporates the following mitigation measures to reduce noise emissions at sensitive receptors:

- Location of the site at a distance of over 300m to isolated farmhouses and over 1.2km to the nearest community.
- Installation of a 4.5m high earth bund around the western and northern site boundaries.

- Installation of a 2.5m high acoustic barrier from the southern end of the earth bund, extending along the southern side of the onsite haulage route.
- Potential sources of noise 'escape' being designed with acoustic performance in mind, for example, doors and louvres;
- The reduction of activities such as tanker deliveries and mobile plant movements during nights and weekends.
- The switching off of vehicles and other equipment when not in use.
- Equipment maintained in accordance with manufacturer's recommendations and a planned maintenance schedule.
- Cessation of any activities that are producing noise and corrective action taken in accordance with procedures within the EMS.

We consider that the above measures represent BAT and broadly follow the noise hierarchy outlined in our H3, Part 2 guidance on 'Noise Assessment and Control'.

5.6.3 Conclusion

Based upon the information in the application we are satisfied that the appropriate measures will be in place, to prevent or where that is not practicable to minimise noise and vibration and to prevent pollution from noise and vibration outside the site.

6. Application of Best Available Techniques

6.1 Scope of Consideration

In this section, we explain how we have determined whether the Applicant's proposals are the Best Available Techniques for this Installation.

- The first issue we address is the fundamental choice of incineration technology. There are a number of alternatives, and the Applicant has explained why it has chosen one particular kind for this Installation.
- We then consider in particular control measures for the emissions which were not screened out as insignificant in the previous section on minimising the installation's environmental impact. They are: NO₂, SO₂, TOC, Cd, Co, Pb, Mn, V and Ni.
- We also have to consider the combustion efficiency and energy utilisation of different design options for the Installation, which are relevant

considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options.

- Finally, the prevention and minimisation of Persistent Organic Pollutants (POPs) must be considered, as we explain below.

Chapter IV of the IED specifies a set of maximum emission limit values. Although these limits are designed to be stringent, and to provide a high level of environmental protection, they do not necessarily reflect what can be achieved by new plant. Article 14(3) of the IED says that BAT Conclusions shall be the reference for setting the permit conditions, so it may be possible and desirable to achieve emissions below the limits referenced in Chapter IV. However BAT Conclusions and a revised BREF for Incineration have not yet been drafted or published, so the existing BREF and Chapter IV of the IED remain relevant.

Even if the Chapter IV limits are appropriate, operational controls complement the emission limits and should generally result in emissions below the maximum allowed; whilst the limits themselves provide headroom to allow for unavoidable process fluctuations. Actual emissions are therefore almost certain to be below emission limits in practice, because any Operator who sought to operate its installation continually at the maximum permitted level would almost inevitably breach those limits regularly, simply by virtue of normal fluctuations in plant performance, resulting in enforcement action (including potentially prosecution) being taken. Assessments based on, say, Chapter IV limits are therefore “worst-case” scenarios.

Should the Installation, once in operation, emit at rates significantly below the limits included in the Permit, we will consider tightening ELVs appropriately. We are, however, satisfied that emissions at the permitted limits would ensure a high level of protection for human health and the environment in any event.

6.1.1 Consideration of Furnace Type

The prime function of the furnace is to achieve maximum combustion of the waste. Chapter IV of the IED requires that the plant (furnace in this context) should be designed to deliver its requirements. The main requirements of Chapter IV in relation to the choice of a furnace are compliance with air emission limits for CO and TOC and achieving a low TOC/LOI level in the bottom ash.

The Waste Incineration BREF elaborates the furnace selection criteria as:

- the use of a furnace (including secondary combustion chamber) dimensions that are large enough to provide for an effective combination of gas residence time and temperature such that combustion reactions may approach completion and result in low and stable CO and TOC emissions to air and low TOC in residues.

- use of a combination of furnace design, operation and waste throughput rate that provides sufficient agitation and residence time of the waste in the furnace at sufficiently high temperatures.
- The use of furnace design that, as far as possible, physically retain the waste within the combustion chamber (e.g. grate bar spacing) to allow its complete combustion.

The BREF also provides a comparison of combustion and thermal treatment technologies and factors affecting their applicability and operational suitability used in EU and for all types of wastes. There is also some information on the comparative costs. The table below has been extracted from the BREF tables. This table is also in line with the Guidance Note “The Incineration of Waste (EPR 5.01)). However, it should not be taken as an exhaustive list nor that all technologies listed have found equal application across Europe.

Overall, any of the furnace technologies listed below would be considered as BAT provided the Applicant has justified it in terms of:

- nature/physical state of the waste and its variability
- proposed plant throughput which may affect the number of incineration lines
- preference and experience of chosen technology including plant availability
- nature and quantity/quality of residues produced.
- emissions to air – usually NOx as the furnace choice could have an effect on the amount of unabated NOx produced
- energy consumption – whole plant, waste preparation, effect on GWP
- Need, if any, for further processing of residues to comply with TOC
- Costs

Summary comparison of thermal treatment technologies (reproduced from the Waste Incineration BREF)

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Moving grate (air-cooled)	<p>Low to medium heat values (LCV 5 – 16.5 GJ/t)</p> <p>Municipal and other heterogeneous solid wastes</p> <p>Can accept a proportion of sewage sludge and/or medical waste with municipal waste</p> <p>Applied at most modern MSW installations</p>	<p>1 to 50 t/h with most projects 5 to 30 t/h.</p> <p>Most industrial applications not below 2.5 or 3 t/h.</p>	<p>Widely proven at large scales.</p> <p>Robust</p> <p>Low maintenance cost</p> <p>Long operational history</p> <p>Can take heterogeneous wastes without special preparation</p>	<p>generally not suited to powders, liquids or materials that melt through the grate</p>	<p>TOC 0.5 % to 3 %</p>	<p>High capacity reduces specific cost per tonne of waste</p>
Moving grate (liquid Cooled)	<p>Same as air-cooled grates except:</p> <p>LCV 10 – 20 GJ/t</p>	<p>Same as air-cooled grates</p>	<p>As air-cooled grates but: higher heat value waste is treatable better Combustion control possible.</p>	<p>As air-cooled grates but: risk of grate damage/ leaks</p> <p>higher complexity</p>	<p>TOC 0.5 % to 3 %</p>	<p>Slightly higher capital cost than air-cooled</p>

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Rotary Kiln	Can accept liquids and pastes solid feeds more limited than grate (owing to refractory damage) often applied to hazardous Wastes	<10 t/h	Very well proven with broad range of wastes and good burn out even of HW	Throughputs lower than grates	TOC <3 %	Higher specific cost due to reduced capacity
Fluid bed - bubbling	Only finely divided consistent wastes. Limited use for raw MSW □ often applied to sludges	1 to 10 t/h	Good mixing Fly ashes of good leaching quality	Careful operation required to avoid clogging bed. Higher fly ash quantities.	TOC <3 %	FGT cost may be lower. Costs of waste preparation
Fluid bed - circulating	Only finely divided consistent wastes. Limited use for raw MSW, often applied to sludges / RDF.	1 to 20 t/h most used above 10 t/h	Greater fuel flexibility than BFB Fly ashes of good leaching quality	Cyclone required to conserve bed material Higher fly ash quantities	TOC <3 %	FGT cost may be lower. Costs of preparation.
Oscillating furnace	MSW / □ heterogeneous wastes	1 – 10 t/h	Robust Low maintenance Long history	-higher thermal loss than with grate furnace - LCV under 15 GJ/t	TOC 0.5 – 3 %	Similar to other technologies

			Low NOX level Low LOI of bottom ash			
--	--	--	--	--	--	--

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Pulsed hearth	Only higher CV waste (LCV >20 GJ/t) □ mainly used for clinical wastes	<7 t/h	can deal with liquids and powders	bed agitation may be lower	Dependent on waste type	Higher specific cost due to reduced capacity
Stepped and static hearths	Only higher CV waste (LCV >20 GJ/t) Mainly used for clinical wastes	No information	Can deal with liquids and powders	Bed agitation may be lower	Dependent on waste type	Higher specific cost due to reduced capacity
Spreader - stoker combustor	- RDF and other particle feeds - poultry manure - wood wastes	No information	- simple grate construction - less sensitive to particle size than FB	only for well defined mono-streams	No information	No information
Gasification - fixed bed	- mixed plastic wastes - other similar consistent streams - gasification less widely used/proven than incineration	1 to 20 t/h	-low leaching residue -good burnout if oxygen blown - syngas available - Reduced oxidation of recyclable metals	- limited waste feed - not full combustion - high skill level - tar in raw gas - less widely proven	-Low leaching bottom ash -good burnout with oxygen	High operation/maintenance costs

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Gasification - entrained flow	<ul style="list-style-type: none"> - mixed plastic wastes - other similar consistent streams - not suited to untreated MSW - gasification less widely used/proven than incineration 	To 10 t/h	<ul style="list-style-type: none"> - low leaching slag - reduced oxidation of recyclable metals 	<ul style="list-style-type: none"> - limited waste feed - not full combustion - high skill level - less widely proven 	low leaching slag	High operation/ maintenance costs pre-treatment costs high
Gasification - fluid bed	<ul style="list-style-type: none"> - mixed plastic wastes - shredded MSW - shredder residues - sludges - metal rich wastes - other similar consistent streams - less widely used/proven than incineration 	5 – 20 t/h	<ul style="list-style-type: none"> -temperatures e.g. for Al recovery - separation of non-combustibles -can be combined with ash melting - reduced oxidation of recyclable metals 	<ul style="list-style-type: none"> -limited waste size (<30cm) - tar in raw gas - higher UHV raw gas - less widely proven 	If Combined with ash melting chamber ash is vitrified	Lower than other gasifiers
Pyrolysis	<ul style="list-style-type: none"> - pre-treated MSW - high metal inert streams - shredder residues/plastics - pyrolysis is less widely used/proven than incineration 	~ 5 t/h (short drum) 5 – 10 t/h (medium drum)	<ul style="list-style-type: none"> - no oxidation of metals - no combustion energy for metals/inert - in reactor acid neutralisation possible - syngas available 	<ul style="list-style-type: none"> - limited wastes - process control and engineering critical - high skill req. - not widely proven - need market for syngas 	<ul style="list-style-type: none"> - dependent on process temperature - residue produced requires further processing e.g. combustion 	High pre-treatment, operation and capital costs

The Applicant has carried out a review of the following candidate furnace types:

- Fluidised bed
- Moving grate furnace
- Pulverised fuel firing.

The Applicant considered these furnace types as being appropriate for the combustion of biomass as defined by the Integrated Pollution Prevention and Control Reference Document on Best Available Techniques for Large Combustion Plants Final Draft June 2016.

The Applicant assessed the suitability of above furnace types by considering them against the following criteria: emissions, global warming potential, energy conversion efficiencies, indirect energy use, residue generation, odour, raw materials, noise and vibration, accidents, and costs.

The Applicant stated that each furnace type has relative benefits and disadvantages, but that all would be capable, subject to appropriate abatement measures being taken, of performing within IED emissions limits. They stated that the performance of each option in terms of carbon dioxide releases is dependant on the carbon content of the fuel which the energy recovery technology utilises and that carbon dioxide releases associated with the combustion of the fuel would be limited by throughput capacity. They recognised that potential releases of carbon dioxide are also associated with:

- a) the efficiencies of techniques for converting combusted/combustible gases resulting from the process to heat and/or power;
- b) the requirement for supplementary combustion of fuel to maintain the thermal treatment process; and
- c) measures to maximise internal energy efficiency of the plant itself (including the 'parasitic' load required to drive supporting plant and equipment and undertake any fuel pre-treatment).

The stated that compared with the other options considered, fluidised bed combustion systems have similar or improved performance on (a) and (b) above, whereas the additional pre-treatment of the fuel in preparation for use in the fluidised bed would mean that the parasitic load would be slightly greater for a fluidised bed system.

Overall, they opted for a fluidised bed system as it would offer improved performance compared to the other furnace types in relation to electrical efficiency, residue generation and raw material consumption. They concluded that in this context, and due to the fact that its reliability at a commercial scale is proven for homogenous fuels, a fluidised bed furnace is considered BAT for the proposed plant.

The Applicant has proposed to use a furnace technology comprising a fluidised bed gasification system which is identified in the table above as being considered BAT in the BREF or TGN for consistent, or homogeneous, feedstock.

The Applicant proposes to use low sulphur content gasoil as support fuel for bed pre-heating and supplementary firing if required. Their choice of support fuel is based on the fact that although they consider natural gas to be the main viable alternative (which would produce lower emissions with regards to SO₂ and particulates), the cost of installing the supply infrastructure would be prohibitive particularly as they would need a guaranteed, uninterrupted supply, which would then only be needed on an intermittent basis.

Boiler Design

In accordance with our Technical Guidance Note, EPR 5.01, the Applicant has confirmed that the boiler design will include the following features to minimise the potential for reformation of dioxins within the de-novo synthesis range:

- ensuring that the steam/metal heat transfer surface temperature is a minimum where the exhaust gases are within the de-novo synthesis range;
- design of the boilers using CFD to ensure no pockets of stagnant or low velocity gas;
- boiler passes are progressively decreased in volume so that the gas velocity increases through the boiler; and
- Design of boiler surfaces to prevent boundary layers of slow moving gas.

Any of the options listed in the BREF and summarised in the table above can be BAT. The Applicant has chosen a furnace technique that is listed in the BREF and we are satisfied that the Applicant has provided sufficient justification to show that their technique is BAT. This is not to say that the other techniques could not also be BAT, but that the Applicant has shown that their chosen technique is at least comparable with the other BAT options. We believe that, based on the information gathered by the BREF process, the chosen technology will achieve the requirements of Chapter IV of the IED for the air emission of TOC/CO and the TOC on bottom ash.

6.2 BAT and emissions control

The prime function of flue gas treatment is to reduce the concentration of pollutants in the exhaust gas as far as practicable. The techniques which are described as BAT individually are targeted to remove specific pollutants, but the BREF notes that there is benefit from considering the FGT system as a whole unit. Individual units often interact, providing a primary abatement for some pollutants and an additional effect on others.

The BREF lists the general factors requiring consideration when selecting flue-gas treatment (FGT) systems as:

- type of waste, its composition and variation
- type of combustion process, and its size
- flue-gas flow and temperature
- flue-gas content, size and rate of fluctuations in composition
- target emission limit values
- restrictions on discharge of aqueous effluents
- plume visibility requirements
- land and space availability
- availability and cost of outlets for residues accumulated/recovered
- compatibility with any existing process components (existing plants)
- availability and cost of water and other reagents
- energy supply possibilities (e.g. supply of heat from condensing scrubbers)
- reduction of emissions by primary methods
- release of noise.

Taking these factors into account the Technical Guidance Note points to a range of technologies being BAT subject to circumstances of the Installation.

6.2.1 Particulate Matter

Particulate matter				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Bag / Fabric filters (BF)	Reliable abatement of particulate matter to below 5mg/m ³	Max temp 250°C	Multiple compartments Bag burst detectors	Most plants
Wet scrubbing	May reduce acid gases simultaneously.	Not normally BAT. Liquid effluent produced	Require reheat to prevent visible plume and dew point problems.	Where scrubbing required for other pollutants
Ceramic filters	High temperature	May "blind" more than		Small plant.

	applications Smaller plant.	fabric filters		High temperature gas cleaning required.
Electrostatic precipitators	Low pressure gradient. Use with BF may reduce the energy consumption of the induced draft fan.	Not normally BAT.		When used with other particulate abatement plant

The Applicant proposes to use fabric filters for the abatement of particulate matter. Fabric filters provide reliable abatement of particulate matter to below 5 mg/m³ and are BAT for most installations. The Applicant proposes to use multiple compartment filters with burst bag detection to minimise the risk of increased particulate emissions in the event of bag rupture.

Emissions of particulate matter have been previously screened out as insignificant, and so the Environment Agency agrees that the Applicant's proposed technique is BAT for the installation.

6.2.2 Oxides of Nitrogen

Oxides of Nitrogen : Primary Measures				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Low NOx burners	Reduces NOx at source		Start-up, supplementary firing.	Where auxiliary burners required.
Starved air systems	Reduce CO simultaneously.			Pyrolysis, Gasification systems.
Optimise primary and secondary air injection				All plant.
Flue Gas Recirculation (FGR)	Reduces the consumption of reagents used for secondary NOx control. May increase overall energy recovery	Some applications experience corrosion problems.		All plant unless impractical in design (needs to be demonstrated)

Oxides of Nitrogen : Secondary Measures (BAT is to apply Primary Measures first)				
Technique	Advantages	Disadvantages	Optimisation	Defined as

				BAT in BREF or TGN for:
Selective catalytic reduction (SCR)	NO _x emissions < 70mg/ m ³ Reduces CO, VOC, dioxins	Expensive. Re-heat required – reduces plant efficiency		All plant
Selective non-catalytic reduction (SNCR)	NO _x emissions typically 150 - 180mg/m ³	Relies on an optimum temperature around 900 °C, and sufficient retention time for reduction May lead to Ammonia slip	Port injection location	All plant unless lower NO _x release required for local environmental protection.
Reagent Type: Ammonia	Likely to be BAT Lower nitrous oxide formation	More difficult to handle Narrower temperature window		All plant
Reagent Type: Urea	Likely to be BAT			All plant

The Applicant proposes to implement the following primary measures:

- Low NO_x burners – this technique reduces NO_x at source and is defined as BAT where auxiliary burners are required.
- Starved air systems – this technique also simultaneously reduces CO and is defined as BAT for pyrolysis and gasification systems.
- Optimise primary and secondary air injection – this technique is BAT for all plant.
- Flue gas recirculation – this technique reduces the consumption of reagents for secondary NO_x control and can increase overall energy recovery, although in some applications there can be corrosion problems – the technique is considered BAT for all plant.

There are two recognised techniques for secondary measures to reduce NO_x. These are Selective Catalytic Reduction (SCR) and Selective Non-Catalytic Reduction (SNCR). For each technique, there is a choice of urea or ammonia reagent.

SCR can reduce NO_x levels to below 70 mg/m³ and can be applied to all plant, it is generally more expensive than SNCR and requires reheating of the waste gas stream which reduces energy efficiency, periodic replacement of the catalysts also produces a hazardous waste. SNCR can typically reduce NO_x levels to between 150 and 180 mg/m³, it relies on an optimum

temperature of around 900 deg C and sufficient retention time for reduction. SNCR is more likely to have higher levels of ammonia slip. The technique can be applied to all plant unless lower NO_x releases are required for local environmental protection. Urea or ammonia can be used as the reagent with either technique, urea is somewhat easier to handle than ammonia and has a wider operating temperature window, but tends to result in higher emissions of N₂O. Either reagent is BAT and the use of one over the other is not normally significant in environmental terms.

The Applicant proposes to use SNCR with ammonia as the reagent.

Emissions of NO_x cannot be screened out as insignificant. Therefore the Applicant has carried out a cost / benefit study of the alternative techniques.

The Applicant states that the choice of BAT with regard to secondary abatement is a balance between pollutant reduction, global warming potential and ozone creation potential (associated with energy use and emissions of NO_x), reagent usage and other cross media effects such as water use and effluent discharge, energy use, waste generation, accidents and operational complexity. They have given consideration to these factors in their assessment, as well as considering the relative costs of SNCR and SCR.

In terms of capital costs the Applicant has calculated that the cost of SCR will be 4 times greater than SNCR. In terms of operational costs, the Applicant has calculated the equivalent annual operating costs for SNCR over a nominal 25 year lifetime (with associated discounting rate applied) to be approximately half that of SCR. They concluded that as the modelled emissions to air show that the proposed installation does not cause any breach of AQS/EAL (in an area with no declared AQMA) whilst operating an SNCR system, the greater cost for SCR in terms of tonne of NO_x abated cannot be justified. The Applicant considers that the additional cost of SCR over SNCR is not justified by the reduction in environmental impact resultant from the use of SCR, and thus SCR is not BAT in this case, and SNCR is BAT for the Installation.

The amount of ammonia used for NO_x abatement will need to be optimised to maximise NO_x reduction and minimise NH₃ slip. Improvement condition IC5 requires the Operator to report to the Environment Agency on optimising the performance of the NO_x abatement system. The Operator is also required to monitor and report on NH₃ and N₂O emissions every 6 months.

6.2.3 Acid Gases, SO_x, HCl and HF

Acid gases and halogens : Primary Measures				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Low sulphur fuel, (< 0.1%S gasoil or natural gas)	Reduces SO _x at source		Start-up, supplementary firing.	Where auxiliary fuel required.

Management of waste streams	Disperses sources of acid gases (e.g. PVC) through feed.	Requires closer control of waste management		All plant with heterogeneous waste feed
------------------------------------	--	---	--	---

Acid gases and halogens : Secondary Measures (BAT is to apply Primary Measures first)

Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Wet	<p>High reaction rates</p> <p>Low solid residues production</p> <p>Reagent delivery may be optimised by concentration and flow rate</p>	<p>Large effluent disposal and water consumption if not fully treated for recycle</p> <p>Effluent treatment plant required</p> <p>May result in wet plume</p> <p>Energy required for effluent treatment and plume reheat</p>		Plants with high acid gas and metal components in exhaust gas – HWIs
Dry	<p>Low water use</p> <p>Reagent consumption may be reduced by recycling in plant</p> <p>Lower energy use</p> <p>Higher reliability</p>	<p>Higher solid residue production</p> <p>Reagent consumption controlled only by input rate</p>		All plant
Semi-dry	<p>Medium reaction rates</p> <p>Reagent delivery may</p>	<p>Higher solid waste residues</p>		All plant

	be varied by concentration and input rate			
Reagent Type: Sodium Hydroxide	Highest removal rates Low solid waste production	Corrosive material ETP sludge for disposal		HWIs
Reagent Type: Lime	Very good removal rates Low leaching solid residue Temperature of reaction well suited to use with bag filters	Corrosive material May give greater residue volume if no in-plant recycle	Wide range of uses	MWIs, CWIs
Reagent Type: Sodium Bicarbonate	Good removal rates Easiest to handle Dry recycle systems proven	Efficient temperature range may be at upper end for use with bag filters – Leachable solid residues Bicarbonate more expensive	Not proven at large plant	CWIs

The Applicant proposes to implement the following primary measures:

- Use of low sulphur fuels for start up and auxiliary burners – gas should be used if available, where fuel oil is used, this will be low sulphur (i.e. <0.1%), this will reduce SO_x at source. The Applicant has justified its choice of gasoil as the support fuel on the basis described in section 6.1.1.abopve and we agree with that assessment.
- Management of heterogeneous wastes – this will disperse problem wastes such as PVC by ensuring a homogeneous waste feed.

In addition they propose to:

- use low sulphur (<0.25%) and chlorine (<0.1%) waste wood fuel during operation;
- accept provision of waste derived biomass fuel to a specification therefore controlling the sulphur and chlorine content which is periodically sampled and analysed; and
- provide a homogenous fuel to ensure better process stability.

There are three recognised techniques for secondary measures to reduce acid gases. These are wet, dry and semi-dry. Wet scrubbing produces an effluent for treatment and disposal in compliance with Article 46(3) of IED. It will also require reheat of the exhaust to avoid a visible plume. Wet scrubbing is unlikely to be BAT except where there are high acid gas and metal components in the exhaust gas as may be the case for some hazardous waste incinerators. In this case, the Applicant does not propose using wet scrubbing, and the Environment Agency agrees that wet scrubbing is not appropriate in this case.

The Applicant has therefore considered dry and semi-dry methods of secondary measures for acid gas abatement. Either can be BAT for this type of facility.

Both dry and semi-dry methods rely on the dosing of powdered materials into the exhaust gas stream. Semi-dry systems (i.e. hydrated reagent) offer reduced material consumption through faster reaction rates, but reagent recycling in dry systems can offset this.

In both dry and semi-dry systems, the injected powdered reagent reacts with the acid gases and is removed from the gas stream by the bag filter system. The powdered materials are either lime or sodium bicarbonate. Both are effective at reducing acid gases, and dosing rates can be controlled from continuously monitoring acid gas emissions. The decision on which reagent to use is normally economic. Lime produces a lower leaching solid residue in the APC residues than sodium bicarbonate and the reaction temperature is well suited to bag filters, it tends to be lower cost, but it is a corrosive material and can generate a greater volume of solid waste residues than sodium bicarbonate. Either reagent is BAT, and the use of one over the other is not significant in environmental terms in this case.

The Applicant has considered the performance of both types of system in terms of air quality impacts, photochemical ozone creation potential (POCP), reagent use, energy use, waste hazard, water use, effluent disposal, plume visibility; and accidents. Overall, across this range of cross media issues, and having taking into consideration both capital and operational costs, the Applicant concluded that the dry system provides the most proven, reliable and cost effective system for acid gas control.

In this case, the Applicant proposes to use a dry system (involving the use of sodium bicarbonate). The Environment Agency is satisfied that this is BAT.

6.2.4 Carbon monoxide and volatile organic compounds (VOCs)

The prevention and minimisation of emissions of carbon monoxide and volatile organic compounds is through the optimisation of combustion controls, where all measures will increase the oxidation of these species.

Carbon monoxide and volatile organic compounds (VOCs)				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Optimise combustion control	All measures will increase oxidation of these species.		Covered in section on furnace selection	All plants

6.2.5 Dioxins and furans (and other POPs)

Dioxins and furans				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Optimise combustion control	All measures will increase oxidation of these species.		Covered in section on furnace selection	All plants
Avoid <i>de novo</i> synthesis			Covered in boiler design	All plant
Effective Particulate matter removal			Covered in section on particulate matter	All plant
Activated Carbon injection	Can be combined with acid gas absorber or fed separately.	Combined feed rate usually controlled by acid gas content.		All plant. Separate feed normally BAT unless feed is constant and acid gas control also controls dioxin release.

The prevention and minimisation of emissions of dioxins and furans is achieved through:

- optimisation of combustion control including the maintenance of permit conditions on combustion temperature and residence time, which has been considered in 6.1.1 above;
- avoidance of de novo synthesis, which has been covered in the consideration of boiler design;
- the effective removal of particulate matter, which has been considered in 6.2.1 above;

- injection of activated carbon. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant. Effective control of acid gas emissions also assists in the control of dioxin releases.

In this case the Applicant proposes separate feed and we are satisfied their proposals are BAT.

6.2.6 Metals

Metals				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Effective Particulate matter removal			Covered in section on particulate matter	All plant
Activated Carbon injection for mercury recovery	Can be combined with acid gas absorber or fed separately.	Combined feed rate usually controlled by acid gas content.		All plant. Separate feed normally BAT unless feed is constant and acid gas control also controls dioxin release.

The prevention and minimisation of metal emissions is achieved through the effective removal of particulate matter, and this has been considered in 6.2.1 above.

Unlike other metals however, mercury if present will be in the vapour phase. BAT for mercury removal is also dosing of activated carbon into the exhaust gas stream. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant.

In this case the Applicant proposes separate feed and we are satisfied their proposals are BAT.

6.3 BAT and global warming potential

This section summarises the assessment of greenhouse gas impacts which has been made in the determination of this Permit. Emissions of carbon dioxide (CO₂) and other greenhouse gases differ from those of other pollutants in that, except at gross levels, they have no localised environmental impact. Their impact is at a global level and in terms of climate change. Nonetheless, CO₂ is clearly a pollutant for IED purposes.

The principal greenhouse gas emitted is CO₂, but the plant also emits small amounts of N₂O arising from the operation of secondary NO_x abatement. N₂O has a global warming potential 310 times that of CO₂. The Applicant will therefore be required to optimise the performance of the secondary NO_x abatement system to ensure its GWP impact is minimised.

The major source of greenhouse gas emissions from the installation is however CO₂ from the combustion of waste. There will also be CO₂ emissions from the burning of support fuels at start up, shut down and should it be necessary to maintain combustion temperatures. BAT for greenhouse gas emissions is to maximise energy recovery and efficiency.

The electricity that is generated by the Installation will displace emissions of CO₂ elsewhere in the UK, as virgin fossil fuels will not be burnt to create the same electricity.

The Installation is not subject to the Greenhouse Gas Emissions Trading Scheme Regulations 2012 therefore it is a requirement of IED to investigate how emissions of greenhouse gases emitted from the installation might be prevented or minimised.

Factors influencing GWP and CO₂ emissions from the Installation are:

On the debit side:

- CO₂ emissions from the burning of the waste;
- CO₂ emissions from burning auxiliary or supplementary fuels;
- CO₂ emissions associated with electrical energy used;
- N₂O from the de-NO_x process.

On the credit side:

- CO₂ saved from the export of electricity to the public supply by displacement of burning of virgin fuels;

The GWP of the plant will be dominated by the emissions of carbon dioxide that are released as a result of waste combustion. This will be constant for all options considered in the BAT assessment. Any differences in the GWP of the options in the BAT appraisal will therefore arise from small differences in energy recovery and in the amount of N₂O emitted.

The Applicant considered energy efficiency and compared SCR to SNCR in its BAT assessment. This is set out in sections 4.3.7, 6.1.1 and 6.2.2 of this decision document.

Note: avoidance of methane which would be formed if the waste was landfilled has not been included in this assessment. If it were included due to its avoidance it would be included on the credit side. Ammonia has no direct GWP effect.

Taking all these factors into account, the Applicant's assessment shows that the difference in global warming potential between the best option in terms of GWP (SCR) and the Applicant's preferred option (SNCR) is minor. The purpose of a BAT appraisal is to determine which option minimises the impact on the environment as a whole. In this context the small benefit in terms of GWP of the other option is considered to be more than offset by the other benefits of the preferred option.

The Environment Agency agrees with this assessment and that the chosen option is BAT for the installation.

6.4 BAT and POPs

International action on Persistent Organic pollutants (POPs) is required under the UN's Stockholm Convention, which entered into force in 2004. The EU implemented the Convention through the POPs Regulation (850/2004), which is directly applicable in UK law. The Environment Agency is required by national POPs Regulations (SI 2007 No 3106) to give effect to Article 6(3) of the EC POPs Regulation when determining applications for environmental Permits.

However, it needs to be borne in mind that this application is for a particular type of installation, namely a waste co-incinerator. The Stockholm Convention distinguishes between intentionally-produced and unintentionally-produced POPs. Intentionally-produced POPs are those used deliberately (mainly in the past) in agriculture (primarily as pesticides) and industry. Those intentionally-produced POPs are not relevant where waste incineration is concerned, as in fact high-temperature incineration is one of the prescribed methods for destroying POPs.

The unintentionally-produced POPs addressed by the Convention are:

- dioxins and furans;
- HCB (hexachlorobenzene)
- PCBs (polychlorobiphenyls) and
- PeCB (pentachlorobenzene)

The UK's national implementation plan for the Stockholm Convention, published in 2007, makes explicit that the relevant controls for unintentionally-produced POPs, such as might be produced by waste incineration, are delivered through the requirements of IED. That would include an

examination of BAT, including potential alternative techniques, with a view to preventing or minimising harmful emissions. These have been applied as explained in this document, which explicitly addresses alternative techniques and BAT for the minimisation of emissions of dioxins.

Our legal obligation, under regulation 4(b) of the POPs Regulations, is, when considering an application for an environmental permit, to comply with article 6(3) of the POPs Regulation:

“Member States shall, when considering proposals to construct new facilities or significantly to modify existing facilities using processes that release chemicals listed in Annex III, without prejudice to Council Directive 1996/61/EC, give priority consideration to alternative processes, techniques or practices that have similar usefulness but which avoid the formation and release of substances listed in Annex III.”

The 1998 Protocol to the Convention recommended that unintentionally produced should be controlled by imposing emission limits (e.g 0.1 ng/m³ for MWIs) and using BAT for incineration. UN Economic Commission for Europe (Executive Body for the Convention) (ECE-EB) produced BAT guidance for the parties to the Convention in 2009. This document considers various control techniques and concludes that primary measures involving management of feed material by reducing halogenated substances are not technically effective. This is not surprising because halogenated wastes still need to be disposed of and because POPs can be generated from relatively low concentrations of halogens. In summary, the successful control techniques for waste incinerators listed in the ECE-EB BAT are:

- maintaining furnace temperature of 850°C and a combustion gas residence time of at least 2 seconds
- rapid cooling of flue gases to avoid the *de novo* reformation temperature range of 250-450°C
- use of bag filters and the injection of activated carbon or coke to adsorb residual POPs components.

Using the methods listed above, the UN-ECE BAT document concludes that incinerators can achieve an emission concentration of 0.1 ng TEQ/m³.

We believe that the Permit ensures that the formation and release of POPs will be prevented or minimised. As we explain above, high-temperature incineration is one of the prescribed methods for destroying POPs. Permit conditions are based on the use of BAT and Chapter IV of IED and incorporate all the above requirements of the UN-ECE BAT guidance and deliver the requirements of the Stockholm Convention in relation to unintentionally produced POPs.

The release of **dioxins and furans** to air is required by the IED to be assessed against the I-TEQ (International Toxic Equivalence) limit of 0.1 ng/m³. Further development of the understanding of the harm caused by dioxins has resulted in the World Health Organisation (WHO) producing updated factors to calculate the WHO-TEQ value. Certain **PCBs** have

structures which make them behave like dioxins (dioxin-like PCBs), and these also have toxic equivalence factors defined by WHO to make them capable of being considered together with dioxins. The UK's independent health advisory committee, the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment (COT) has adopted WHO-TEQ values for both dioxins and dioxin-like PCBs in their review of Tolerable Daily Intake (TDI) criteria. The Permit requires that, in addition to the requirements of the IED, the WHO-TEQ values for both dioxins and dioxin-like PCBs should be monitored for reporting purposes, to enable evaluation of exposure to dioxins and dioxin-like PCBs to be made using the revised TDI recommended by COT. The release of dioxin-like PCBs and PAHs is expected to be low where measures have been taken to control dioxin releases. The Permit also requires monitoring of a range of PAHs and dioxin-like PCBs at the same frequency as dioxins are monitored. We have included a requirement to monitor and report against these WHO-TEQ values for dioxins and dioxin-like PCBs and the range of PAHs as listed in the Permit. We are confident that the measures taken to control the release of dioxins will also control the releases of dioxin-like PCBs and PAHs. Section 5.2.1 of this document details the assessment of emissions to air, which includes dioxins and concludes that there will be no adverse effect on human health from either normal or abnormal operation.

Hexachlorobenzene (HCB) is released into the atmosphere as an accidental product from the combustion of coal, waste incineration and certain metal processes. It has also been used as a fungicide, especially for seed treatment although this use has been banned in the UK since 1975. Natural fires and volcanoes may serve as natural sources. Releases of (HCB) are addressed by the European Environment Agency (EEA), which advises that:

"due to comparatively low levels in emissions from most (combustion) processes special measures for HCB control are usually not proposed. HCB emissions can be controlled generally like other chlorinated organic compounds in emissions, for instance dioxins/furans and PCBs: regulation of time of combustion, combustion temperature, temperature in cleaning devices, sorbents application for waste gases cleaning etc." [reference http://www.eea.europa.eu/publications/EMEPCORINAIR4/sources_of_HCB.pdf]

Pentachlorobenzene (PeCB) is another of the POPs list to be considered under incineration. PeCB has been used as a fungicide or flame retardant, there is no data available however on production, recent or past, outside the UN-ECE region. PeCBs can be emitted from the same sources as for PCDD/F: waste incineration, thermal metallurgic processes and combustion plants providing energy. As discussed above, the control techniques described in the UN-ECE BAT guidance and included in the permit, are effective in controlling the emissions of all relevant POPs including PeCB.

We have assessed the control techniques proposed for dioxins by the Applicant and have concluded that they are appropriate for dioxin control. We

are confident that these controls are in line with the UN-ECE BAT guidance and will minimise the release of HCB, PCB and PeCB.

We are therefore satisfied that the substantive requirements of the Convention and the POPs Regulation have been addressed and complied with.

6.5 Other Emissions to the Environment

6.5.1 Emissions to water

Uncontaminated surface water run-off from roofs and clean yard areas will be discharged to surface watercourse via an on-site lagoon, with the yard areas being served by Class 1 oil interceptors. Foul water from staff welfare facilities will be treated in a dedicated on-site package sewage treatment plant and discharged to surface watercourse (under a separate environmental permit).

Based upon the information in the application we are satisfied that appropriate measures will be in place to prevent and /or minimise emissions to water.

6.5.2 Emissions to sewer

There are no discharges to public sewer from the installation. Process effluent (consisting of condensate and boiler blowdown) will be recycled back to the boilers via a reverse osmosis plant, with the resultant wastewater being collected and removed off-site by contractor.

Based upon the information in the application we are satisfied that appropriate measures will be in place to prevent and /or minimise emissions to sewer.

6.5.3 Fugitive emissions

The IED specifies that plants must be able to demonstrate that the plant is designed in such a way as to prevent the unauthorised and accidental release of polluting substances into soil, surface water and groundwater. In addition storage requirements for waste and for contaminated water of Article 46(5) must be arranged.

The Applicant has provided a risk assessment and management plan for fugitive emissions, which the Environment Agency considers to be satisfactory and should ensure compliance with permit conditions, specifically condition 3.2.

The Applicant states that there is the potential for fugitive releases to air from the ash and air pollution control residue silos and from the storage of dry raw materials such as sodium bicarbonate and sand. They expect that fugitive releases to air will be insignificant as the process design (which includes filters fitted to vents on ash silos, pressure drop sensors on bag filters, use of enclosed conveyors and containers, etc) and the choice of equipment is such that general leaks will be prevented. In addition they state that a preventative maintenance system will be developed to ensure that the integrity of plant and equipment remains high.

In terms of the potential for fugitive emissions to surface and/or groundwater the Applicant states that control and containment measures such as sealed drainage, high level alarms, double skinned tanks, bunding as well as spill management procedures will be in place to ensure there are no unplanned discharges to surface water. Installation and maintenance programme will be in place for all containment measures such as bunding as well as hardstanding and drainage infrastructure. The outlet from the on-site lagoon to the surface watercourse can be isolated using a penstock valve to prevent pollution should an emergency situation arise.

The facility also includes a back-up diesel generator to provide electrical power to safely shut down the incinerator in the event of the non-availability of electrical power.

Based upon the information in the application we are satisfied that appropriate measures will be in place to prevent and /or minimise fugitive emissions.

6.5.4 Odour

Odour emissions will principally be minimised due to the low odour potential of the incoming waste wood used to fuel the plant, and by the following methods:

- biomass transfer and storage within enclosed systems or buildings;
- management of biomass to avoid material remaining in one position, i.e. the feedstock grab records where the oldest biomass is stored within the fuel barn based on its reception date and takes that to use within the fluidised bed combustors;
- regular cleaning of site to remove residual biomass;
- storage of ammonia solution in closed vessels and transfer to process via closed pipework;
- all process equipment located in buildings and/or /structures constructed to minimise any releases from vents and with fast acting roller shutter doors;
- optimisation of combustion process to ensure complete oxidation of the fuel and negligible VOCs in flue gases;
- stack designed to increase buoyancy and eliminate grounding risks of emissions plume;
- any unusual odours to be investigated immediately in accordance with procedures within the EMS; and
- record and act on complaints in accordance with the non-conformance procedure under the EMS.

Based upon the information in the application we are satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise odour and to prevent pollution from odour.

6.6 Setting ELVs and other Permit conditions

6.6.1 Translating BAT into Permit conditions

Article 14(3) of IED states that BAT conclusions shall be the reference for permit conditions. Article 15(3) further requires that under normal operating conditions; emissions do not exceed the emission levels associated with the best available techniques as laid down in the decisions on BAT conclusions.

At the time of writing of this document, no BAT conclusions have been published for waste incineration or co-incineration.

The use of IED Chapter IV emission limits for air dispersion modelling sets the worst case scenario. If this shows emissions are insignificant then we have accepted that the Applicant's proposals are BAT, and that there is no justification to reduce ELVs below the Chapter IV limits in these circumstances.

Below we consider whether, for those emission not screened out as insignificant, different conditions are required as a result of consideration of local or other factors, so that no significant pollution is caused (Article 11(c)) or to comply with environmental quality standards (Article 18).

(i) Local factors

We have considered the impact on local receptors and habitat conservation sites for those emissions not screened out as insignificant and do not consider it necessary to impose further conditions, or set more stringent emission limits than those specified by IED.

(ii) National and European ESs

There are no additional National or European EQSs that indicate that IED limits are insufficient to protect the local environment.

(iii) Global Warming

CO₂ is an inevitable product of the combustion of waste. The amount of CO₂ emitted will be essentially determined by the quantity and characteristics of waste being incinerated, which are already subject to conditions in the Permit. It is therefore inappropriate to set an emission limit value for CO₂, which could do no more than recognise what is going to be emitted. The gas is not therefore targeted as a key pollutant under Annex II of IED, which lists the main polluting substances that are to be considered when setting emission limit values (ELVs) in Permits.

We have therefore considered setting equivalent parameters or technical measures for CO₂. However, provided energy is recovered efficiently (see section 4.3.7 above), there are no additional equivalent technical measures (beyond those relating to the quantity and characteristics of the waste) that can be imposed that do not run counter to the primary purpose of the plant, which is the recovery of energy from waste. Controls in the form of restrictions on the volume and type of waste that can be accepted at the

Installation and permit conditions relating to energy efficiency effectively apply equivalent technical measures to limit CO₂ emissions.

(iv) Commissioning

Before the plant can become fully operational it will be necessary for it to be commissioned. Before commissioning can commence the Operator is required by pre-operational condition PO3 to submit a commissioning plan to the Agency for approval. Commissioning can only begin and be carried out in accordance with the approved proposals in the plan.

In addition, it is recognised that certain information presented in the Application was based on design data, or data from comparable equipment, the commissioning phase is the earliest opportunity to verify much of this information. The following improvement conditions have been included in the permit so that appropriate verifications will be determined by the Applicant:

- Calibration of CEMs in accordance with BS EN 14181 (a requirement in improvement condition IC6).
- Verification of furnace residence time, temperature and oxygen content (IC4).
- The plant in total conforms with the permit conditions and that satisfactory process control procedures for the plant have been developed (IC3).
- Abatement plant optimisation details (IC5).

6.7 Monitoring

6.7.1 Monitoring during normal operations

We have decided that monitoring should be carried out for the parameters listed in Schedule 3 using the methods and to the frequencies specified in those tables. These monitoring requirements have been imposed in order to demonstrate compliance with emission limit values and to enable correction of measured concentration of substances to the appropriate reference conditions; to gather information about the performance of the SNCR system; to establish data on the release of dioxin-like PCBs and PAHs from the incineration process and to deliver the requirements of Chapter IV of IED for monitoring of residues and temperature in the combustion chamber.

For emissions to air, the methods for continuous and periodic monitoring are in accordance with the Environment Agency's Guidance M2 for monitoring of stack emissions to air.

Based on the information in the Application and the requirements set in the conditions of the permit we are satisfied that the Operator's techniques, personnel and equipment will have either MCERTS certification or MCERTS accreditation as appropriate.

6.7.2 Monitoring under abnormal operations arising from the failure of the installed CEMs

The Operator has stated that they will provide back-up CEMS working in parallel to the operating CEMS. These will be switched into full operation immediately in the event that there is any failure in the regular monitoring equipment. The back-up CEMS measure the same parameters as the operating CEMS. In the unlikely event that the back-up CEMS also fail Condition 2.3.7 of the permit requires that the abnormal operating conditions apply.

6.7.3 Continuous emissions monitoring for dioxins and heavy metals

Chapter IV of IED specifies manual extractive sampling for heavy metals and dioxin monitoring. However, Article 48(5) of the IED enables The Commission to act through delegated, authority to set the date from which continuous measurements of the air emission limit values for heavy metals, dioxins and furans shall be carried out, as soon as appropriate measurement techniques are available within the Community. No such decision has yet been made by the Commission.

The Environment Agency has reviewed the applicability of continuous sampling and monitoring techniques to the installation.

Recent advances in mercury monitoring techniques have allowed standards to be developed for continuous mercury monitoring, including both vapour-phase and particulate mercury. There is a standard which can apply to CEMs which measure mercury (EN 15267-3) and standards to certify CEMs for mercury, which are EN 15267-1 and EN 15267-3. Furthermore, there is an MCERTS-certified CEM which has been used in trials in the UK and which has been verified on-site using many parallel reference tests as specified using the steps outlined in EN 14181.

In the case of dioxins, equipment is available for taking a sample for an extended period (several weeks), but the sample must then be analysed in the conventional way. A CEN committee has agreed Technical Specifications (EN TS 1948-5) for continuous sampling of dioxins. This specification will lead to a CEN standard following a validation exercise which is currently underway. According to IED Article 48(5), "As soon as appropriate measurement techniques are available within the Union, the Commission shall, by means of delegated acts in accordance with Article 76 and subject to the conditions laid down in Articles 77 and 78, set the date from which continuous measurements of emissions into the air of heavy metals and dioxins and furans are to be carried out. This is yet to happen. However, our extant 'dioxin enforcement policy' recommends continuous sampling of dioxins where multiple emission exceedances occur and no clear root cause can be identified. Therefore should continuous sampling be required at a later date during the operation of the installation, then sampling and analysis shall comply with the requirements of EN TS 1948.

For either continuous monitoring of mercury or continuous sampling of dioxins to be used for regulatory purposes, an emission limit value would need to be

devised which is applicable to continuous monitoring. Such limits for mercury and dioxins have not been set by the European Commission. Use of a manual sample train is the only technique which fulfils the requirements of the IED. At the present time, it is considered that in view of the predicted low levels of mercury and dioxin emission it is not justifiable to require the Operator to install additionally continuous monitoring or sampling devices for these substances.

In accordance with its legal requirement to do so, the Environment Agency reviews the development of new methods and standards and their performance in industrial applications. In particular the Environment Agency considers continuous sampling systems for dioxins to have promise as a potential means of improving process control and obtaining more accurate mass emission estimates.

6.8 Reporting

We have specified the reporting requirements in Schedule 5 of the Permit either to meet the reporting requirements set out in the IED, or to ensure data is reported to enable timely review by the Environment Agency to ensure compliance with permit conditions and to monitor the efficiency of material use and energy recovery at the installation.

7 Other legal requirements

In this section we explain how we have addressed other relevant legal requirements, to the extent that we have not addressed them elsewhere in this document.

7.1 The EPR 2016 and related Directives

The EPR delivers the requirements of a number of European and national laws.

7.1.1 Schedules 1 and 7 to the EPR 2016 – IED Directive

We address the requirements of the IED in the body of this document above and the specific requirements of Chapter IV in Annex 1 of this document.

There is one requirement not addressed above, which is that contained in Article 5(3) IED. Article 5(3) requires that “In the case of a new installation or a substantial change where Article 4 of Directive 85/337/EC (now Directive 2011/92/EU) (the EIA Directive) applies, any relevant information obtained or conclusion arrived at pursuant to articles 5, 6 and 7 of that Directive shall be examined and used for the purposes of granting the permit.”

- Article 5 of EIA Directive relates to the obligation on developers to supply the information set out in Annex IV of the Directive when making an application for development consent.
- Article 6(1) requires Member States to ensure that the authorities likely to be concerned by a development by reason of their specific environmental responsibilities are consulted on the Environmental Statement and the request for development consent.
- Article 6(2)-6(6) makes provision for public consultation on applications for development consent.
- Article 7 relates to projects with transboundary effects and consequential obligations to consult with affected Member States.

The grant or refusal of development consent is a matter for the relevant local planning authority. The Environment Agency’s obligation is therefore to examine and use any relevant information obtained or conclusion arrived at by the local planning authorities pursuant to those EIA Directive articles.

In determining the Application we have considered the following documents: -

- The Environmental Statement submitted with the planning application.
- The response of the Environment Agency to the local planning authority in its role as consultee to the planning process.

From consideration of all the documents above, the Environment Agency considers that no additional or different conditions are necessary.

The Environment Agency has also carried out its own consultation on the Environmental Permitting Application. The results of our consultation are described elsewhere in this decision document.

7.1.2 Schedule 9 to the EPR 2016 – Waste Framework Directive

As the Installation involves the treatment of waste, it is carrying out a *waste operation* for the purposes of the EPR 2016, and the requirements of Schedule 9 therefore apply. This means that we must exercise our functions so as to ensure implementation of certain articles of the WFD.

We must exercise our relevant functions for the purposes of ensuring that the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste and that any waste generated is treated in accordance with Article 4 of the Waste Framework Directive. (See also section 4.3.9)

The conditions of the permit ensure that waste generation from the facility is minimised. Where the production of waste cannot be prevented it will be recovered wherever possible or otherwise disposed of in a manner that minimises its impact on the environment. This is in accordance with Article 4.

We must also exercise our relevant functions for the purposes of implementing Article 13 of the Waste Framework Directive; ensuring that the requirements in the second paragraph of Article 23(1) of the Waste Framework Directive are met; and ensuring compliance with Articles 18(2)(b), 18(2)(c), 23(3), 23(4) and 35(1) of the Waste Framework Directive.

Article 13 relates to the protection of human health and the environment. These objectives are addressed elsewhere in this document.

Article 23(1) requires the permit to specify:

- (a) the types and quantities of waste that may be treated;
- (b) for each type of operation permitted, the technical and any other requirements relevant to the site concerned;
- (c) the safety and precautionary measures to be taken;
- (d) the method to be used for each type of operation;
- (e) such monitoring and control operations as may be necessary;
- (f) such closure and after-care provisions as may be necessary.

These are all covered by permit conditions.

The permit does not allow the mixing of hazardous waste so Article 18(2) is not relevant.

We consider that the intended method of waste treatment is acceptable from the point of view of environmental protection so Article 23(3) does not apply.

Energy efficiency is dealt with elsewhere in this document but we consider the conditions of the permit ensure that the recovery of energy take place with a high level of energy efficiency in accordance with Article 23(4).

Article 35(1) relates to record keeping and its requirements are delivered through permit conditions.

7.1.3 Schedule 22 to the EPR 2016 – Water Framework and Groundwater Directives

To the extent that it might lead to a discharge of pollutants to groundwater (a “groundwater activity” under the EPR 2016), the Permit is subject to the requirements of Schedule 22, which delivers the requirements of EU Directives relating to pollution of groundwater. The Permit will require the taking of all necessary measures to prevent the input of any hazardous substances to groundwater, and to limit the input of non-hazardous pollutants into groundwater so as to ensure such pollutants do not cause pollution, and satisfies the requirements of Schedule 22.

No releases to groundwater from the Installation are permitted. The Permit also requires material storage areas to be designed and maintained to a high standard to prevent accidental releases.

7.1.4 Directive 2003/35/EC – The Public Participation Directive

Regulation 60 of the EPR 2016 requires the Environment Agency to prepare and publish a statement of its policies for complying with its public participation duties. We have published our public participation statement.

This Application has been consulted upon in line with this statement. This satisfies the requirements of the Public Participation Directive. A summary of the responses received to our consultations and our consideration of them is set out in Annex 2.

7.2 National primary legislation

7.2.1 **Environment Act 1995**

(i) Section 4 (Pursuit of Sustainable Development)

We are required to contribute towards achieving sustainable development, as considered appropriate by Ministers and set out in guidance issued to us. The Secretary of State for Environment, Food and Rural Affairs has issued *The Environment Agency’s Objectives and Contribution to Sustainable Development: Statutory Guidance (December 2002)*. This document:

“provides guidance to the Agency on such matters as the formulation of approaches that the Agency should take to its work, decisions about priorities for the Agency and the allocation of resources. It is not directly applicable to individual regulatory decisions of the Agency”.

In respect of regulation of industrial pollution through the EPR, the Guidance refers in particular to the objective of setting permit conditions “*in a consistent and proportionate fashion based on Best Available Techniques and taking into account all relevant matters...*”. The Environment Agency considers that it has pursued the objectives set out in the Government’s guidance, where relevant, and that there are no additional conditions that should be included in this Permit to take account of the Section 4 duty.

(ii) Section 5 (Preventing or Minimising Effects of Pollution of the Environment)

We are satisfied that our pollution control powers have been exercised for the purpose of preventing or minimising, remedying or mitigating the effects of pollution.

(iii) Section 7 (Pursuit of Conservation Objectives)

This places a duty on us, when considering any proposal relating to our functions, to have regard amongst other things to any effect which the proposals would have on sites of archaeological, architectural, or historic interest; the economic and social well-being of local communities in rural areas; and to take into account any effect which the proposals would have on the beauty or amenity of any rural area.

We considered whether we should impose any additional or different requirements in terms of our duty to have regard to the various conservation objectives set out in Section 7, but concluded that we should not.

(iv) Section 39 (Costs and Benefits)

We have a duty to take into account the likely costs and benefits of our decisions on the applications (‘costs’ being defined as including costs to the environment as well as any person). This duty, however, does not affect our obligation to discharge any duties imposed upon us in other legislative provisions.

In so far as relevant we consider that the costs that the permit may impose on the applicant are reasonable and proportionate in terms of the benefits it provides.

(v) Section 108 (Deregulation Act 2015 – Growth duty)

We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.

Paragraph 1.3 of the guidance says:

“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”

We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.

We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.

(vi) Section 81 (National Air Quality Strategy)

We have had regard to the National Air Quality Strategy and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

7.2.2 Human Rights Act 1998

We have considered potential interference with rights addressed by the European Convention on Human Rights in reaching our decision and consider that our decision is compatible with our duties under the Human Rights Act 1998. In particular, we have considered the right to life (Article 2), the right to a fair trial (Article 6), the right to respect for private and family life (Article 8) and the right to protection of property (Article 1, First Protocol). We do not believe that Convention rights are engaged in relation to this determination.

7.2.3 Countryside and Rights of Way Act 2000 (CROW 2000)

Section 85 of this Act imposes a duty on Environment Agency to have regard to the purpose of conserving and enhancing the natural beauty of the area of outstanding natural beauty (AONB). There is no AONB which could be affected by the Installation.

7.2.4 Wildlife and Countryside Act 1981

Under section 28G of the Wildlife and Countryside Act 1981 the Environment Agency has a duty to take reasonable steps to further the conservation and enhancement of the flora, fauna or geological or physiographical features by reason of which a site is of special scientific interest. Under section 28I the

Environment Agency has a duty to consult Natural England in relation to any permit that is likely to damage SSSIs.

There are no SSSIs within 2km of the installation therefore no further assessment was necessary. The Installation will not damage the special features of any SSSI.

7.2.5 Natural Environment and Rural Communities Act 2006

Section 40 of this Act requires us to have regard, so far as is consistent with the proper exercise of our functions, to the purpose of conserving biodiversity. We have done so and consider that no different or additional conditions in the Permit are required.

7.3 National secondary legislation

7.3.1 Conservation of Habitats and Species Regulations 2010

We have assessed the Application in accordance with guidance agreed jointly with Natural England and concluded that there will be no likely significant effect on any European Site.

We recorded our decision by means of an Appendix 11 assessment, and sent this to Natural England for information only in accordance with our permitting guidance.

The habitat assessment is summarised in greater detail in section 5.4.2 of this document. A copy of the full Appendix 11 Assessment can be found on the public register.

7.3.2 Water Environment (Water Framework Directive) Regulations 2003

Consideration has been given to whether any additional requirements should be imposed in terms of the Environment Agency's duty under regulation 3 to secure compliance with the requirements of the Water Framework Directive and the EQS Directive through (inter alia) environmental permits, and its obligation in regulation 17 to have regard to the river basin management plan (RBMP) approved under regulation 14 and any supplementary plans prepared under regulation 16. However, it is felt that existing conditions are sufficient in this regard and no other appropriate requirements have been identified.

7.3.3 The Persistent Organic Pollutants Regulations 2007

We have explained our approach to these Regulations, which give effect to the Stockholm Convention on POPs and the EU's POPs Regulation, above.

7.4 Other relevant legal requirements

7.4.1 Duty to Involve

S23 of the Local Democracy, Economic Development and Construction Act 2009 require us where we consider it appropriate to take such steps as we consider appropriate to secure the involvement of interested persons in the exercise of our functions by providing them with information, consulting them or involving them in any other way. S24 requires us to have regard to any Secretary of State guidance as to how we should do that.

The way in which the Environment Agency has consulted with the public and other interested parties is set out in section 2.2 of this document. The way in which we have taken account of the representations we have received is set out in Annex 4. Our public consultation duties are also set out in the EP Regulations, and our statutory Public Participation Statement, which implement the requirements of the Public Participation Directive

ANNEX 1: APPLICATION OF CHAPTER IV OF THE INDUSTRIAL EMISSIONS DIRECTIVE

IED Article	Requirement	Delivered by
45(1)(a)	The permit shall include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2000/532/EC, if possible, and containing information on the quantity of each type of waste, where appropriate.	Condition 2.3.4(a) and Table S2.2 in Schedule 2 of the Permit.
45(1)(b)	The permit shall include the total waste incinerating or co-incinerating capacity of the plant.	Condition 2.3.3(a) and Table S2.2 in Schedule 2 of the Permit.
45(1)(c)	The permit shall include the limit values for emissions into air and water.	Conditions 3.1.1 and 3.1.2 and Tables S3.1, S3.1(a) and S3.2 in Schedule 3 of the Permit.
45(1)(e)	The permit shall include the sampling and measurement procedures and frequencies to be used to comply with the conditions set for emissions monitoring.	Conditions 3.5.1 to 3.5.5 and Tables S3.1, S3.1(a), S3.2, S3.3 and S3.4 in Schedule 3 of the Permit.
45(1)(f)	The permit shall include the maximum permissible period of unavoidable stoppages, disturbances or failures of the purification devices or the measurement devices, during which the emissions into the air and the discharges of waste water may exceed the prescribed emission limit values.	Condition 2.3.12
46(1)	Waste gases shall be discharged in a controlled way by means of a stack the height of which is calculated in such a way as to safeguard human health and the environment.	Condition 2.3.1(a) and Table S1.2 of Schedule 1 of the Permit.
46(2)	Emission into air shall not exceed the emission limit values set out in parts 4 or determined in accordance with part 4 of Annex VI.	Conditions 3.1.1 and 3.1.2 and Tables S3.1 and S3.1a.

IED Article	Requirement	Delivered by
46(5)	Prevention of unauthorised and accidental release of any polluting substances into soil, surface water or groundwater. Adequate storage capacity for contaminated rainwater run-off from the site or for contaminated water from spillage or fire-fighting.	The application explains the measures to be in place for achieving the directive requirements
46(6)	Limits the maximum period of operation when an ELV is exceeded to 4 hours uninterrupted duration in any one instance, and with a maximum cumulative limit of 60 hours per year.	Condition 2.3.12
47	In the event of breakdown, reduce or close down operations as soon as practicable.	Condition 2.3.12
48(1)	Monitoring of emissions is carried out in accordance with Parts 6 and 7 of Annex VI.	Conditions 3.5.1 to 3.5.5. Reference conditions are defined in Schedule 6 of the Permit.
48(2)	Installation and functioning of the automated measurement systems shall be subject to control and to annual surveillance tests as set out in point 1 of Part 6 of Annex VI.	Condition 3.5.3, and tables S3.1, S3.1(a), and S3.3
48(3)	The competent authority shall determine the location of sampling or measurement points to be used for monitoring of emissions.	Conditions 3.5.3 and 3.5.4
48(4)	All monitoring results shall be recorded, processed and presented in such a way as to enable the competent authority to verify compliance with the operating conditions and emission limit values which are included in the permit.	Conditions 4.1.1 and 4.1.2, and Tables S4.1 and S4.4
49	The emission limit values for air and water shall be regarded as being complied with if the conditions described in Part 8 of Annex VI are fulfilled.	Conditions 3.1.1 and 3.1.2 and 3.5.5
50(1)	Slag and bottom ash to have Total Organic Carbon (TOC) < 3% or loss on ignition (LOI) < 5%.	Conditions 3.5.1 and Table S3.4
50(2)	Flue gas to be raised to a temperature of 850°C for two seconds, as measured at	Condition 2.3.7, Pre-operational condition PO5 and

IED Article	Requirement	Delivered by
	representative point of the combustion chamber.	Improvement condition IC4 and Table S3.3
50(4)(a)	Automatic shut to prevent waste feed if at start up until the specified temperature has been reached.	Condition 2.3.7
50(4)(b)	Automatic shut to prevent waste feed if the combustion temperature is not maintained.	Condition 2.3.7
50(4)(c)	Automatic shut to prevent waste feed if the CEMs show that ELVs are exceeded due to disturbances or failure of waste cleaning devices.	Condition 2.3.7
50(5)	Any heat generated from the process shall be recovered as far as practicable.	(a) The plant will generate electricity (b) Operator to review the available heat recovery options every 4 years (Conditions 1.2.1 to 1.2.3)
50(6)	Relates to the feeding of infectious clinical waste into the furnace.	No infectious clinical waste will be burnt
50(7)	Management of the Installation to be in the hands of a natural person who is competent to manage it.	Conditions 1.1.1 to 1.1.3 and 2.3.1 of the Permit.
51(1)	Different conditions than those laid down in Article 50(1), (2) and (3) and, as regards the temperature Article 50(4) may be authorised, provided the other requirements of this chapter are met.	No such conditions Have been allowed
52(1)	Take all necessary precautions concerning delivery and reception of Wastes, to prevent or minimise pollution.	Conditions 2.3.1, 2.3.3, 3.2, 3.3, 3.4 and 3.6.
52(2)	Determine the mass of each category of wastes, if possible according to the EWC, prior to accepting the waste.	Condition 2.3.4(a) and Table S2.2 in Schedule 3 of the Permit.
53(1)	Residues to be minimised in their amount and harmfulness, and recycled where appropriate.	Conditions 1.4.1, 1.4.2 and 3.5.1 with Table S3.4
53(2)	Prevent dispersal of dry residues and dust during transport and storage.	Conditions 1.4.1 2.3.1, 2.3.2 and 3.2.1.
53(3)	Test residues for their physical and chemical characteristics and	Condition 3.5.1 and Table S3.4 and pre-

IED Article	Requirement	Delivered by
	polluting potential including heavy metal content (soluble fraction).	operational condition PO2.
55(1)	Application, decision and permit to be publicly available.	All documents are accessible from the Environment Agency Public Register.
55(2)	An annual report on plant operation and monitoring for all plants burning more than 2 tonne/hour waste.	Condition 4.2.2 and 4.2.3.

ANNEX 2: Pre-Operational Conditions

Based on the information on the Application, we consider that we do need to impose pre-operational conditions. These conditions are set out below and referred to, where applicable, in the text of the decision document. We are using these conditions to require the Operator to confirm that the details and measures proposed in the Application have been adopted or implemented prior to the operation of the Installation.

Table S1.4 Pre-operational measures	
Reference	Pre-operational measures
PO1	Prior to the commencement of commissioning, the Operator shall send a summary of the site Environment Management System (EMS) to the Environment Agency and make available for inspection all documents and procedures which form part of the EMS. The EMS shall be developed in line with the requirements set out in Environment Agency web guide on developing a management system for environmental permits (found on www.gov.uk). The documents and procedures set out in the EMS shall form the written management system referenced in condition 1.1.1 (a) of the permit.
PO2	Prior to the commencement of commissioning, the Operator shall submit to the Environment Agency for approval a protocol for the sampling and testing of incinerator bottom ash for the purposes of assessing its hazard status. Sampling and testing shall be carried out in accordance with the protocol as approved.
PO3	Prior to the commencement of commissioning, the Operator shall provide a written commissioning plan, including timelines for completion, for approval by the Environment Agency. The commissioning plan shall include the expected emissions to the environment during the different stages of commissioning, the expected durations of commissioning activities and the actions to be taken to protect the environment and report to the Environment Agency in the event that actual emissions exceed expected emissions. Commissioning shall be carried out in accordance with the commissioning plan as approved.
PO4	Prior to the commencement of commissioning, the Operator shall submit a written report to the Agency detailing the waste acceptance procedure to be used at the site. The waste acceptance procedure shall include the process and systems by which wastes unsuitable for incineration at the site will be controlled. The procedure shall be implemented in accordance with the written approval from the Agency.
PO5	After completion of furnace design and at least three calendar months before commencement of commissioning; the operator shall submit a written report to the Agency of the details of the computational fluid dynamic (CFD) modelling. The report shall

Table S1.4 Pre-operational measures	
Reference	Pre-operational measures
	demonstrate whether the design combustion conditions comply with the residence time and temperature requirements as defined by Chapter IV and Annex VI of the IED.
PO6	<p>The Operator shall submit the written protocol referenced in condition 3.2.4 for the monitoring of soil and groundwater for approval by the Environment Agency. The protocol shall demonstrate how the Operator will meet the requirements of Articles 14(1)(b), 14(1)(e) and 16(2) of the IED.</p> <p>The procedure shall be implemented in accordance with the written approval from the Agency.</p>

ANNEX 3: Improvement Conditions

Based in the information in the Application we consider that we need to set improvement conditions. These conditions are set out below - justifications for these is provided at the relevant section of the decision document. We are using these conditions to require the Operator to provide the Environment Agency with details that need to be established or confirmed during and/or after commissioning.

Table S1.3 Improvement programme requirements		
Reference	Requirement	Date
IC1	The Operator shall submit a written report to the Environment Agency on the implementation of its Environmental Management System (EMS) and the progress made in the certification of the system by an external body or if appropriate submit a schedule by which the EMS will be certified.	Within 12 months of the completion of commissioning.
IC2	The Operator shall submit a written proposal to the Environment Agency to carry out tests to determine the size distribution of the particulate matter in the exhaust gas emissions to air from emission points A1 and A2, identifying the fractions within the PM ₁₀ , and PM _{2.5} ranges. On receipt of written approval from the Environment Agency to the proposal and the timetable, the Operator shall carry out the tests and submit to the Environment Agency a report on the results.	Within 6 months of the completion of commissioning.
IC3	The Operator shall submit a written report to the Environment Agency on the commissioning of the installation. The report shall summarise the environmental performance of the plant as installed against the design parameters set out in the Application. The report shall also include a review of the performance of the facility against the conditions of this permit and details of procedures developed during commissioning for achieving and demonstrating compliance with permit conditions and confirm that the Environmental Management System (EMS) has been updated accordingly.	Within 4 months of the completion of commissioning.
IC4	The Operator shall carry out checks to verify the residence time, minimum temperature and oxygen content of the exhaust gases in the furnace whilst operating under the anticipated most unfavourable operating conditions. The results shall be submitted in writing to the Environment Agency and include a comparison with the CFD modelling submitted with PO6.	Within 4 months of the completion of commissioning.

Table S1.3 Improvement programme requirements		
Reference	Requirement	Date
IC5	<p>The Operator shall submit a written report to the Environment Agency describing the performance and optimisation of:</p> <ul style="list-style-type: none"> • The Selective Non Catalytic Reduction (SNCR) system and combustion settings to minimise oxides of nitrogen (NO_x). The report shall include an assessment of the level of NO_x, N₂O and NH₃ emissions that can be achieved under optimum operating conditions. • The sodium bicarbonate injection system for minimisation of acid gas emissions. • The carbon injection system for minimisation of dioxin and heavy metal emissions. 	Within 4 months of the completion of commissioning.
IC6	<p>The Operator shall submit a written summary report to the Environment Agency to confirm by the results of calibration and verification testing that the performance of Continuous Emission Monitors for parameters as specified in Table S3.1 and Table S3.1(a) complies with the requirements of BS EN 14181, specifically the requirements of QAL1, QAL2 and QAL3.</p>	<p>Initial calibration report to be submitted to the Agency within 3 months of completion of commissioning.</p> <p>Full summary evidence compliance report to be submitted within 18 months of completion of commissioning.</p>
IC7	<p>The Operator shall submit a noise impact assessment report undertaken in accordance with the procedures given in BS4142:2014, <i>Methods for rating and assessing industrial and commercial sound</i>. The assessment shall include the identification and assessment of the impact of noise emissions upon surrounding sensitive receptors arising from the operation of the installation, in order to verify the results of the predictive noise modelling submitted with the permit application.</p> <p>In the event that the report indicates an adverse impact (or greater) at residential receptors, the report shall include proposals for the further attenuation and/or management of noise and shall include a timescale, to be agreed with the</p>	Within 12 months of the completion of commissioning.

Table S1.3 Improvement programme requirements		
Reference	Requirement	Date
	Environment Agency, for the implementation of these proposed measures.	

ANNEX 4: Consultation Responses

A) Advertising and Consultation on the Application

The Application has been advertised and consulted upon in accordance with the Environment Agency's Public Participation Statement. The way in which this has been carried out along with the results of our consultation and how we have taken consultation responses into account in reaching our draft decision is summarised in this Annex. Copies of all consultation responses have been placed on the Environment Agency public register.

The Application was advertised on the Environment Agency website and was made available to view at the Environment Public Register. The following statutory and non-statutory bodies were consulted:

- Local Authority Environmental Health department
- Health and Safety Executive
- Food Standards Agency
- Public Health England and Director of Public Health
- National Grid
- Fire and Rescue Service

1) Consultation Responses from Statutory and Non-Statutory Bodies

Response Received from Public Health England	
Brief summary of issues raised:	Summary of action taken / how this has been covered
<p>PHE stated that the emissions of potential concern were products of combustion, including nitrogen dioxide and particulate matter.</p> <p>They noted that the Applicant's air dispersion modelling indicated that maximum Predicted Environmental Concentrations (PECs) for both short-term and long-term impacts are below health-based Environmental Assessment Levels (EALs); and that the Applicant had considered the potential for fires to break out on site and had included a Fire Prevention Plan with their application.</p> <p>PHE concluded by stating that based on the application information they had no significant concerns regarding the risk to the health of the local</p>	<p>No further action required.</p>

Response Received from Public Health England	
Brief summary of issues raised:	Summary of action taken / how this has been covered
<p>population from the installation.</p> <p>Their consultation was also based on the assumption that the permit holder shall take all appropriate measures to prevent or control pollution, in accordance with the relevant sector guidance and industry best practice.</p>	

2) Consultation Responses from Members of the Public and Community Organisations

The consultation responses received were wide ranging and a number of the issues raised were outside the Environment Agency's remit in reaching its permitting decisions. Specifically questions were raised which fall within the jurisdiction of the planning system.

a) Representations from Community and Other Organisations

Response received from an environmental organisation called Biofuelwatch.

The response suggests that the Applicant has not provided sufficient evidence to demonstrate that their proposals comply with the waste hierarchy principle as set out in Article 4 of the Waste Framework Directive. They suggest that recycling, rather than incineration, is the more appropriate for the types of waste wood proposed to fuel the biomass plant.

Summary of action taken / how this has been covered: Guidance on the interaction between planning and pollution control is given in the National Planning Policy Framework. It says that the planning and pollution control systems are separate but complementary regulatory regimes. Operators must comply with both regimes, however the Environment Agency is only able to take into account those issues which fall within the scope of the Environmental Permitting Regulations (EPR).

Defra's guidance on applying the waste hierarchy, as referred to in Article 4 of the Waste Framework Directive (WFD), sets out the obligations for business and public bodies (including local authorities on behalf of householders) who produce or handle waste. Section 3.1(a) states that business and public bodies who produce or handle waste must take all such measures as are reasonable in the circumstances to apply the waste hierarchy to prevent waste, and to apply the hierarchy as a priority order when transferring wastes to another person. Section 3.1(b) states that operators of facilities regulated under EPR must apply the waste hierarchy in relation to waste produced at

the facility. We implement this requirement through the conditions in our environmental permits to ensure that waste generation at regulated facilities is minimised, and where the production of waste cannot be prevented it will be recovered wherever possible or otherwise disposed of in a manner that minimises its impact on the environment. This is in accordance with Article 4 of the WFD.

The proposed facility will form part of an integrated waste management strategy, the shape and content of which is a matter for the local authority. The co-incinerator will form one element of that strategy, and our environmental permit will ensure that it can be operated without giving rise to significant pollution or harm to human health. It is for the local authority to decide if a particular type of facility is needed and what provision needs to be made in terms of local waste management. Therefore the waste hierarchy should have been applied to the types of waste wood proposed for Tansterne biomass power plant before a decision is made to send the waste to the facility. This decision falls outside of the permitting remit of the Environment Agency.

b) Representations from Individual Members of the Public

A total of 3 responses were received from individual members of the public, all local residents in the vicinity of the Installation. The key issues raised are summarised below along with our response.

1. Concern that the potential impacts from the Installation on the residents of the village of Aldbrough, located downwind of the new facility, had not been appropriately considered, risk assessed and mitigated. The potential for air quality and noise impacts were raised, particularly as the Installation will operate 24 hours per day.

Summary of action taken / how this has been covered: *We have undertaken a detailed audit of the Applicant's impact assessments of emissions to air, and of noise and vibration. We have undertaken specific check modelling of potential impacts on air quality and on the noise environment in the village of Aldbrough, the results of which are detailed in sections 5.2 and 5.6 of this document.*

2. Concern regarding the impact of emissions from the Installation on local air quality and queried whether the Environment Agency could request the installation of a continuous air quality monitoring system in Aldbrough.

Summary of action taken / how this has been covered: *The installation of a permanent monitoring station would typically be a measure identified as being necessary due to potential concerns about poor air quality in an area, and in any case, would fall under the remit of the local authority, rather than the Environment Agency.*

3. Concern regarding process operating parameters which are vital to achieve effective combustion and control of emission. Queried whether regular flue monitoring by an independent authority could be prescribed in the environmental permit to ensure that the installation meets the required operating parameters.

Summary of action taken / how this has been covered: *The Operator will be required to regularly monitor flue gases and other operational parameters as specified in the environmental permit. The permit does not require that monitoring should be carried out by an independent authority, however it does require that all monitoring equipment, techniques, personnel and organisations employed for the emissions monitoring programme and the environmental or other monitoring specified in the permit, must have either MCERTS certification or MCERTS accreditation (as appropriate). MCERTS is the Environment Agency's Monitoring Certification Scheme. It provides the framework for businesses to meet our quality requirements, and is used to approve instruments, people and laboratories.*

4. Concern that the Applicant, in their permit application, does not appear to commit to informing the local communities about the activities of the Installation. Queried whether the Environment Agency could include on the permit, the requirement for the Operator to liaise with local community/representatives on the performance of the Installation, for Health and Safety, co-operation and discussion on issues such as light pollution (which was raised as a potential issue).

Summary of action taken / how this has been covered: *Engagement between the Operator and local community is not a matter that is routinely addressed via the conditions on the environmental permit. The possible exception may be where the Operator commits to undertaking community engagement as part of a formal plan designed to manage site-specific amenity risks such as odour, noise, dust, etc. Such plans, once approved by the Environment Agency, are enforceable via permit conditions.*

5. Question as to where water would be drawn from for both the operation and the fire-fighting provision? Concern that low water pressure in the village could be an issue during a fire fighting incident, as the village has reportedly suffered low water pressure in the past when demand is increased during the summer months. How would this be addressed?

Summary of action taken / how this has been covered: *The Application states that all process water will be sourced from combustion flue gas condensate, which is captured from the flue gases and returned to the water treatment plant for treatment prior to reuse in the plant, thus alleviating the need for an external water supply. Potable water, as well as water required for plant start-up, will be sourced from a borehole. In terms of firewater provision, the Applicant has submitted a Fire Prevention Plan (FPP) as part of their permit*

application, which the Environment Agency has reviewed and approved. The FPP sets out how fire-fighting water will be supplied and disposed of. The prime focus of the FPP in terms of fire-fighting provision is ensuring that there is sufficient water available to fight a fire, and that appropriate infrastructure is in place to deliver that water.

6. Concern about the potential effect of residual heat from the process on the local environment, in particular on water quality in the lagoon. Queried what monitoring would be undertaken during commissioning of the plant?

Summary of action taken / how this has been covered: *The Applicant is required through pre-operational conditions on the permit to submit a commissioning plan for approval by the Environment Agency prior to operation of the plant. The commissioning plan will include the expected emissions to the environment during the different stages of commissioning, the expected durations of commissioning activities and the actions to be taken to protect the environment and report to the Environment Agency in the event that actual emissions exceed expected emissions. Commissioning should be carried out in accordance with the commissioning plan as approved.*

7. Concern regarding the amount of vehicular traffic arriving at the site, reportedly up to 48 trucks in any one day, in terms of carbon footprint, and disturbance to the local roads and residents of the area.

Summary of action taken / how this has been covered: *Vehicle access to the installation and traffic movements are relevant considerations for the grant of planning permission, but do not form part of the Environmental Permit decision making process except where there are established high background concentrations contributing to poor air quality and the increased level of traffic might be significant in these limited circumstances. This is not the case in the vicinity of the Installation.*

8. Concern that the rural location of the plant will not allow for the residual heat from the process to be utilised by anyone, now or in the future due to land access and ownership.

Summary of action taken / how this has been covered: *The location of the Installation can have an impact on the ability to recover waste heat for use in any nearby residential, commercial or industrial premises. In terms of Combined Heat and Power (CHP), the conditions of the environmental permit require that the Installation is maintained in such a state so that opportunities for the further use of waste heat may be capitalised upon should they become practicable. Furthermore the permit requires the Operator to review the viability of CHP implementation at least every 4 years.*

9. Concern that the application states that there is a possibility of failure of the purification equipment and that there can be a 4 hour time gap for

corrective actions to be taken which means for every 24 hour period there is a possibility of uncontrolled emissions.

Summary of action taken / how this has been covered: Article 50(4)(c) of the Industrial Emissions Directive (IED) specifies that waste incineration and co-incineration plants shall operate an automatic system to prevent waste feed whenever any of the continuous emission monitors show that an emission limit value (ELV) is exceeded due to disturbances or failures of the purification devices. In addition, Article 46(6) allows for the continued incineration and co-incineration of waste under such conditions provided that this period does not (in any circumstances) exceed 4 hours uninterrupted continuous operation or the cumulative period of operation does not exceed 60 hours in a calendar year. For incineration and co-incineration plant this is typically less than 1% of total operating hours and so abnormal operating conditions would not be expected to have any significant long term environmental impact unless the background conditions were already close to, or exceeding, an environmental standard. However, consideration is required of the impact on short term environmental standards. The Applicant has submitted an impact assessment of potential short term emissions arising under abnormal operation. The Environment Agency's assessment of this submission is discussed in section 5.5 of this document.