Confirmation of Receipt of Product Safety Notice Ringmaster ring main unit PSA-111201-318

Please fill in this form an	d:
Mail to:	Schneider Electric Neil Broadley +441132903761 Schneider Electric Office 123 Jack Lane, Leeds, LS10 1BS, West Yorkshire, United Kingdom
Fax to:	OR Neil Broadley +1132903710
Email to:	OR neil.broadley@schneider-electric.com
Your name, company name and	address:
Telephone or email address:	
I, the undersigned, confirm that y	Please tick one or several boxes: We have received the Notice and will follow the recommended action for all Ringmaster manufactured between 1st November 2006 and 31st November 2009 If you suspect that you have found a Ringmaster with a disconnected mechanism to drive shaft you will contact the local Schneider office and advise what you have found If any Ringmaster was sold or installed at your customer(s) site below please confirm that you have sent a copy of this Notice to each customer. This Product Safety Notice does NOT affect me, therefore please remove me from your mailing list
318, referring to the Schneider E	Electric Ringmaster Products. Consibility to inform my company's customers who have purchased the Schneider
Name	Signature
Schneider Electric will support ye	ou as best as practicable through this period and you are welcome to contact your local

Schneider Electric office who will be happy to help you.

Confirmation of Receipt of Product Safety Notice Ringmaster ring main unit PSA-111201-318

If you would prefer that we contact your customers, please provide their details below. Please attach additional sheets if required.

Company Name	Company Name
Contact/Phone #	Contact/Phone #
Street	Street
City	City
Country & Postal Code	Country & Postal Code
Company Name	Company Name
Contact/Phone #	Contact/Phone #
Street	Street
City	City
Country & Postal Code	Country & Postal Code