



EC Type Examination Certificate Number: **0120/ SGS0017**

# **Janz-Contadores de Energia,SA**

Av. Infante D. Henrique 328  
1800-223 Lisboa  
Portugal

Instrument Identification:

**B1##**

**Poly phase, Credit, Active Import, Single & Multi-rate, Electricity Meter**

Instrument Traceable Number

**0120/ SGS0017**

has been assessed and certified as meeting the requirements of

## **EC Directive 2004/22/EC**

**on Measuring Instruments Annex B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F.

This certificate is valid for 10 years from 13th March 2008 until 12th March 2018

Issue 8

Certification is based on report number(s)

EMA101440 dated 2<sup>nd</sup> August 2007

EMA105697 dated 11<sup>th</sup> December 2007

EMA115289 dated 13<sup>th</sup> March 2008

EMA122303 dated 14<sup>th</sup> November 2008


EMA115289 FW Update dated 23<sup>rd</sup> July 2009

Authorised Signature

Jan Saunders


SGS United Kingdom Limited, Notified Body 0120  
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK  
t +44 (0)1934 522917 f +44 (0)1934 522137 [www.sgs.com](http://www.sgs.com)

Contact Address  
SGS United Kingdom Ltd, Unit 10, South Industrial Estate, Bowburn, Durham, DH6 5AD UK  
t +44 (0)191 377 2000 f +44 (0)191 377 2020 [www.sgs.com](http://www.sgs.com)

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0017</b>	
	Issue Number: 8	Dated: 3 <sup>rd</sup> April 2013

## 1. Technical Data

<b>Manufacturer</b>	Janz-Contadores de Energia,SA
<b>Meter Type</b>	B1##
<b>Voltage Rating (<math>U_n</math>)</b>	3 x 220-240/380-415V
<b>Current Rating (<math>I_{min}</math> – <math>I_{ref}</math> (<math>I_{max}</math>))</b>	0,5-10(60)A, 0,25-5(80)A, 0,25-5(100)A
<b>Frequency (<math>F_n</math>)</b>	50Hz
<b>Active Accuracy Class (kWh)</b>	A or B (kWh)
<b>Type of circuit</b>	3p4w
<b>Temperature Range</b>	-25°C to +60°C
<b>Software/ Firmware Version No's</b>	v00.01, v02.20, v02.21 v03.01 anti tamper version v03.12 anti fraud version v04.01.0; v04.02.0 LCD & Nameplate
<b>Identification Location</b>	
<b>Bill Of Materials Number</b>	See over leaf
<b>IP Rating</b>	IP51
<b>Insulation Protective Class</b>	Class II
<b>LED Pulse Constant</b>	1000 imp/ kWh
<b>Impulse Voltage Rating</b>	6kV
<b>AC Voltage Rating</b>	4kV
<b>Main Cover Sealing Type</b>	Wire & Crimp Or Un-peelable sealing tape concealing cover screw
<b>Integrity of meter</b>	Inaccessible without breaking seals under terminal cover
<b>Intended Location of the Meter</b>	Indoor
<b>Type of Register</b>	LCD
<b>Terminal Arrangement(s)</b>	BS or DIN


	EC-Type Examination Certificate Number:	
	0120/ SGS0017	
	Issue Number: 8	Dated: 3 <sup>rd</sup> April 2013

**Bill Of Materials Numbers**

**Basic Layout Drawing:** 9 1740 9001 f1a  
**PCB BOM No:** 9 1700 9001 f5e  
**Mechanical BOM No:** 9 1700 9001 f4h  
**Assembly Drawing No:** 9 1700 9001 f2g

**2. Photograph of Meter and Sealing Plan**



	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0017</b>	
	Issue Number: 8	Dated: 3 <sup>rd</sup> April 2013

### 3. Calculation of the composite error/ MPE

In addition to the accuracy requirements the composite error  $e_c$  of the meter is shown below

The composite error at a certain load is calculated from the following formula:


$$e_c = \sqrt{e^2(l.\cos\theta) + e^2(T.l.\cos\theta) + e^2(U.l.\cos\theta) + e^2(f.l.\cos\theta)}$$

where

$e^2(l.\cos\theta)$	=	Intrinsic error of meter at a certain load
$e^2(T.l.\cos\theta)$	=	Additional error due to variation of the temperature at the same load
$e^2(U.l.\cos\theta)$	=	Additional error due to variation of the voltage at the same load
$e^2(f.l.\cos\theta)$	=	Additional error due to variation of the frequency at the same load


Ambient Temperature Range 5 to 30 Degrees C						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.15	0.17	-0.08	-0.02	<b>0.24</b>
Itr	1.0	0.11	0.16	-0.08	-0.01	<b>0.21</b>
10Itr	1.0	0.08	0.19	0.06	0.02	<b>0.22</b>
Imax	1.0	0.08	0.19	0.06	0.02	<b>0.22</b>
Itr	0.5ind	0.12	0.19	-0.09	0.02	<b>0.24</b>
10Itr	0.5ind	0.06	0.21	0.06	0.01	<b>0.23</b>
Imax	0.5ind	-0.10	0.19	0.05	0.01	<b>0.22</b>
Itr	0.8cap	0.15	0.16	0.08	0.02	<b>0.23</b>
10Itr	0.8cap	0.09	0.18	0.06	0.01	<b>0.21</b>
Imax	0.8cap	0.17	0.19	0.06	0.02	<b>0.26</b>

Ambient Temperature Range -10 to 40 Degrees C						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.15	0.31	-0.08	-0.02	<b>0.35</b>
Itr	1.0	0.11	0.31	-0.08	-0.01	<b>0.34</b>
10Itr	1.0	0.08	0.34	0.06	0.02	<b>0.35</b>
Imax	1.0	0.08	0.33	0.06	0.02	<b>0.35</b>
Itr	0.5ind	0.12	0.40	-0.09	0.02	<b>0.43</b>
10Itr	0.5ind	0.06	0.35	0.06	0.01	<b>0.36</b>
Imax	0.5ind	-0.10	0.33	0.05	0.01	<b>0.35</b>
Itr	0.8cap	0.15	0.31	0.08	0.02	<b>0.35</b>
10Itr	0.8cap	0.09	0.31	0.06	0.01	<b>0.33</b>
Imax	0.8cap	0.17	0.31	0.06	0.02	<b>0.36</b>

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0017</b>	
	Issue Number: 8	Dated: 3 <sup>rd</sup> April 2013

Ambient Temperature Range -25 to 55 Degrees C						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.15	0.34	-0.08	-0.02	<b>0.38</b>
Itr	1.0	0.11	0.36	-0.08	-0.01	<b>0.38</b>
10ltr	1.0	0.08	0.37	0.06	0.02	<b>0.38</b>
Imax	1.0	0.08	0.37	0.06	0.02	<b>0.38</b>
Itr	0.5ind	0.12	0.35	-0.09	0.02	<b>0.38</b>
10ltr	0.5ind	0.06	0.36	0.06	0.01	<b>0.37</b>
Imax	0.5ind	-0.10	-0.36	0.05	0.01	<b>0.38</b>
Itr	0.8cap	0.15	-0.37	0.08	0.02	<b>0.41</b>
10ltr	0.8cap	0.09	-0.36	0.06	0.01	<b>0.38</b>
Imax	0.8cap	0.17	-0.36	0.06	0.02	<b>0.40</b>

Results taken from test report EMA115289 issued 23<sup>rd</sup> July 2009

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0017</b>	
	Issue Number: 8	Dated: 3 <sup>rd</sup> April 2013

#### 4. Annex of Variants

Product Variant Identification Details:

Type Designation		Description of meter
CONNECTION MODE	B	Polyphase meter for direct connection (3 or 4 wire)
SERIES	1	The concept of series is related with the physical aspect of meter (meter case), eight series remain available
TARIFF	11	Single rate (LCD), kWh
	40	Programmable Multirate, kWh (no demand registers, no load profile)
INTERFACE TO THE USER	-	Without push buttons (LCD scrolls the programmed data)
PULSE OUTPUT	-	No pulse output
	E1	One pulse output (through terminals 21/22)
	E2	Two pulse outputs (through terminals 21/22 & 22/24)
PULSE INPUT	-	No pulse input for tariff switch
AUXILIARY COMMUNICATIONS	-	No auxiliary communications
	R2	With RS232 port
	R4	With RS485 port
ANTI-TAMPER	-	Without external cover opening detection device
VERSION	-	The initial version is not identified

Modifications to the meter(s) described according to approval No.0120/ SGS0017 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

#### 5. Document Revision History

Issue	Date	Comments
1	13/03/2008	Initial Issue
2	13/03/2008	Amended approval number with prefix UK/0120
3	13/03/2008	Corrected test report file reference
4	14/11/2008	New firmware update to v3.12 anti fraud version
5	23/07/2009	New firmware update to v3.01 anti tamper version
6	20/06/2012	New firmware update to v04.01.00
7	15/03/2013	BOM & Minor Firmware Update to Version v04.02.0
8	03/04/2013	Certificate corrected