



EC Type Examination Certificate Number: **0120/ SGS0055**

**GE Energy**

130 Main Street  
Somersworth  
NH 03878  
USA

Instrument Identification:

**SM1011 & SM1012**

**Single Phase, Credit/ Pre-payment, Import/ Export, Multi-rate, Electricity Meter**

Instrument Traceable Number

**0120/ SGS0055**

has been assessed and certified as meeting the requirements of

**EC Directive 2004/22/EC**

**on Measuring Instruments Annex B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F.

This certificate is valid for 10 years from 30th April 2010 until 29th April 2020  
Issue 7

Certification is based on report number(s)

EMA131254 Issued 30th April 2010

EMA141888 Issued 20th December 2010

EMA143939 Issued 29th March 2011

EMA146152 Issued 4th April 2011


EMA150814 Issued 19th January 2012

Authorised Signature

Jan Saunders


SGS United Kingdom Limited, Notified Body 0120  
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK  
t +44 (0)1934 522917 f +44 (0)1934 522137 [www.sgs.com](http://www.sgs.com)

Contact Address  
SGS United Kingdom Ltd, Unit 10, South Industrial Estate, Bowburn, Durham, DH6 5AD UK  
t +44 (0)191 377 2000 f +44 (0)191 377 2020 [www.sgs.com](http://www.sgs.com)


	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0055</b>	
	Issue Number: 7	Dated: 25 <sup>th</sup> July 2012


## 1. Technical Data

<b>Manufacturer</b>	GE Energy
<b>Meter Type</b>	SM1011 & SM1012
<b>Voltage Rating (<math>U_n</math>)</b>	230V
<b>Current Rating (<math>I_{min}</math> – <math>I_{ref}</math> (<math>I_{max}</math>))</b>	1-20(100)A
<b>Frequency (<math>F_n</math>)</b>	50Hz
<b>Active Accuracy Class (<math>kWh</math>)</b>	A or B ( $kWh$ )
<b>Type of circuit</b>	1p2w
<b>Temperature Range</b>	-25°C to +55°C
<b>Software/ Firmware Version No Identification Location</b>	2.3.5 or 2.4.0 or 2.4.0.04 LCD
<b>Hardware Version No Identification Location</b>	2.1.0 or 2.1.1 Nameplate
<b>Bill Of Materials Number</b>	BOM v2.1.1 r01
<b>IP Rating</b>	IP51
<b>Insulation Protective Class</b>	Class II
<b>LED Pulse Constant</b>	1000 imp/ kWh
<b>Impulse Voltage Rating</b>	6kV
<b>AC Voltage Rating</b>	4kV
<b>Main Cover Sealing Type</b>	Sealed for life Ultrasonic Welding
<b>Integrity of meter</b>	Inaccessible without breaking seals
<b>Intended Location of the Meter</b>	Indoor
<b>Type of Register</b>	LCD
<b>Terminal Arrangement(s)</b>	BS

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0055</b>	
	Issue Number: 7	Dated: 25 <sup>th</sup> July 2012

**2. Photograph of Meter and Sealing Plan**



	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0055</b>	
	Issue Number: 7	Dated: 25 <sup>th</sup> July 2012

### 3. Calculation of the composite error/ MPE

In addition to the accuracy requirements the composite error  $e_c$  of the meter is shown below

The composite error at a certain load is calculated from the following formula:

$$e_c = \sqrt{e^2(l.\cos\theta) + e^2(T.l.\cos\theta) + e^2(U.l.\cos\theta) + e^2(f.l.\cos\theta)}$$

where

$e^2(l.\cos\theta)$	=	Intrinsic error of meter at a certain load
$e^2(T.l.\cos\theta)$	=	Additional error due to variation of the temperature at the same load
$e^2(U.l.\cos\theta)$	=	Additional error due to variation of the voltage at the same load
$e^2(f.l.\cos\theta)$	=	Additional error due to variation of the frequency at the same load

Ambient Temperature Range 5 to 30 Degrees C						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.13	0.48	0.12	0.14	<b>0.53</b>
Itr	1.0	0.27	-0.09	0.06	0.06	<b>0.30</b>
10Itr	1.0	0.18	-0.45	0.07	0.02	<b>0.49</b>
Imax	1.0	-0.04	-0.48	0.08	0.02	<b>0.49</b>
Itr	0.5ind	0.11	-1.13	0.01	-0.04	<b>1.14</b>
10Itr	0.5ind	0.27	-0.53	-0.05	0.1	<b>0.61</b>
Imax	0.5ind	0.21	-0.62	-0.06	-0.2	<b>0.69</b>
Itr	0.8cap	0.09	-0.83	0.03	0.07	<b>0.84</b>
10Itr	0.8cap	0.1	-0.52	-0.03	0.03	<b>0.53</b>
Imax	0.8cap	-0.18	-0.57	-0.06	-0.03	<b>0.60</b>

Ambient Temperature Range -10 to 40 Degrees C						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.13	-1.48	0.12	0.14	<b>1.50</b>
Itr	1.0	0.27	-1.22	0.06	0.06	<b>1.25</b>
10Itr	1.0	0.18	-0.93	0.07	0.02	<b>0.95</b>
Imax	1.0	-0.04	-1.34	0.08	0.02	<b>1.34</b>
Itr	0.5ind	0.11	-1.55	0.01	-0.04	<b>1.55</b>
10Itr	0.5ind	0.27	-1.43	-0.05	0.1	<b>1.46</b>
Imax	0.5ind	0.21	-1.24	-0.06	-0.2	<b>1.27</b>
Itr	0.8cap	0.09	-1.22	0.03	0.07	<b>1.23</b>
10Itr	0.8cap	0.1	-0.88	-0.03	0.03	<b>0.89</b>
Imax	0.8cap	-0.18	-1.10	-0.06	-0.03	<b>1.12</b>



EC-Type Examination Certificate Number:

**0120/ SGS0055**


Issue Number: 7

Dated: 25<sup>th</sup> July 2012

Ambient Temperature Range -25 to 55 Degrees C						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.13	-2.23	0.12	0.14	<b>2.24</b>
Itr	1.0	0.27	-1.81	0.06	0.06	<b>1.83</b>
10ltr	1.0	0.18	-1.48	0.07	0.02	<b>1.49</b>
Imax	1.0	-0.04	-1.94	0.08	0.02	<b>1.94</b>
Itr	0.5ind	0.11	-2.19	0.01	-0.04	<b>2.19</b>
10ltr	0.5ind	0.27	-1.92	-0.05	0.1	<b>1.94</b>
Imax	0.5ind	0.21	-1.79	-0.06	-0.2	<b>1.81</b>
Itr	0.8cap	0.09	-1.88	0.03	0.07	<b>1.88</b>
10ltr	0.8cap	0.1	-1.37	-0.03	0.03	<b>1.37</b>
Imax	0.8cap	-0.18	-1.68	-0.06	-0.03	<b>1.69</b>

Ambient Temperature Range -40 to 70 Degrees C (OUTDOOR ONLY)						
Current	PF Cos	e(lcos)	e(Tlcos)	e(Ulcos)	e(flcos)	%MPE
Imin	1.0	0.13	2.69	0.12	0.14	<b>2.70</b>
Itr	1.0	0.27	-2.19	0.06	0.06	<b>2.21</b>
10ltr	1.0	0.18	-1.79	0.07	0.02	<b>1.80</b>
Imax	1.0	-0.04	-2.34	0.08	0.02	<b>2.34</b>
Itr	0.5ind	0.11	-2.74	0.01	-0.04	<b>2.74</b>
10ltr	0.5ind	0.27	-2.31	-0.05	0.1	<b>2.33</b>
Imax	0.5ind	0.21	-2.22	-0.06	-0.2	<b>2.24</b>
Itr	0.8cap	0.09	-2.35	0.03	0.07	<b>2.35</b>
10ltr	0.8cap	0.1	-1.73	-0.03	0.03	<b>1.73</b>
Imax	0.8cap	-0.18	-2.13	-0.06	-0.03	<b>2.14</b>

Taken from report EMA146152 Issued 4th April 2011

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0055</b>	
	Issue Number: 7	Dated: 25 <sup>th</sup> July 2012

#### 4. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
SM1011	Meter with internal 100A relay
SM1012	Meter with internal 100A relay with optional auxiliary 2A relay with communication output for optional use of communication module:-
CM1011	Zigbee & GPRS Comms Module
or	
CM1001	GPRS only Comms Module

Modifications to the meter(s) described according to approval No. **0120/ SGS0055** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

#### 5. Document Revision History

Issue	Date	Comments
1	30/04/2010	Initial Issue
2	14/12/2010	Software update to 2.02.02.27, Firmware update to 2.0.07.
3	18/01/2011	Certificate updated for Manufacturer and Meter Type change to GE Energy SM1001
4	29/03/2011	New Firmware and Hardware updated to 2.3.5 and 2.1.00 respectively, meeting Class B accuracy requirements.
5	06/04/2011	New Firmware and Hardware updated to 2.4.0 and 2.1.1 respectively.
6	19/01/2012	New comms module options of CM1001 (GPRS) and CM1011 (Zigbee & GSM)
7	25/07/2012	Firmware update to 2.4.0.04