



EC Type Examination Certificate Number: **0120/ SGS0129**

## **EDMI (Shenzhen) Co. Ltd**

Floor 2 & 3  
Building 2  
Zhong Yuntai Industrial Park  
Tang Tou 1st Road  
Shi Yan  
Bao An  
Shenzhen  
Guangdong  
Province  
P. R. China

Instrument Identification:  
**Mk31**

### **Single Phase, Active Import/ Export, Multi-rate, Electricity Meter**

Instrument Traceable Number

**0120/ SGS0129**

has been assessed and certified as meeting the requirements of

## **EC Directive 2004/22/EC**

### **on Measuring Instruments Annex B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F.

This certificate is valid for 10 years from 6<sup>th</sup> February 2014 until 5<sup>th</sup> February 2024  
Issue 1


Certification is based on report number(s)  
Report 179466 dated 6<sup>th</sup> February 2014

Authorised Signature

Jan Saunders


SGS United Kingdom Limited, Notified Body 0120  
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK  
t +44 (0)1934 522917 f +44 (0)1934 522137 [www.sgs.com](http://www.sgs.com)

Contact Address  
SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK  
t +44 (0)191 377 2000 f +44 (0)191 377 2020 [www.sgs.com](http://www.sgs.com)

|   |   |                                      |
|---|---|--------------------------------------|
|  | EC-Type Examination Certificate Number: |                                      |
|   | <b>0120/ SGS0129</b>                    |                                      |
|   | Issue Number: 1                         | Dated: 6 <sup>th</sup> February 2014 |


## 1. Technical Data

|  |   |
|--|---|
| <b>Manufacturer</b>  | EDMI (Shenzhen)   |
| <b>Meter Type</b>  | Mk31  |
| <b>Voltage Rating (<math>U_n</math>)</b>                         | 220-240V  |
| <b>Current Rating (<math>I_{min} - I_{ref} (I_{max})</math>)</b> | 0,25-5(100)A  |
| <b>Frequency (<math>F_n</math>)</b>                              | 50Hz  |
| <b>Active Accuracy Class (<math>kWh</math>)</b>                  | A or B (kWh)  |
| <b>Type of circuit</b>   | 1p2w  |
| <b>Temperature Range</b>   | -40°C to +70°C  |
| <b>Software/ Firmware Version No<br/>Identification Location</b> | Software Version V1.5.4 r3<br>Firmware Version V1.5b<br>LCD |
| <b>Bill Of Materials Number</b>                                  | BOM-MK3100-907 10-15  |
| <b>IP Rating</b>   | IP54  |
| <b>Insulation Protective Class</b>                               | Class II  |
| <b>LED Pulse Constant</b>  | 1600 imp/ kWh   |
| <b>Impulse Voltage Rating</b>                                    | 4kV   |
| <b>AC Voltage Rating</b>   | 10kV  |
| <b>Main Cover Sealing Type</b>                                   | Wire & Crimp  |
| <b>Integrity of meter</b>  | Inaccessible without breaking seals                         |
| <b>Intended Location of the Meter</b>                            | Indoor  |
| <b>Type of Register</b>  | LCD   |
| <b>Terminal Arrangement(s)</b>                                   | BS  |

|   |   |                                      |
|---|---|--------------------------------------|
|  | EC-Type Examination Certificate Number: |                                      |
|   | <b>0120/ SGS0129</b>                    |                                      |
|   | Issue Number: 1                         | Dated: 6 <sup>th</sup> February 2014 |

**2. Photograph of Meter and Sealing Plan**



|   |   |                                      |
|---|---|--------------------------------------|
|  | EC-Type Examination Certificate Number: |                                      |
|   | <b>0120/ SGS0129</b>                    |                                      |
|   | Issue Number: 1                         | Dated: 6 <sup>th</sup> February 2014 |

### 3. Influence factors for temperature, frequency and voltage


|                   |        | Influence Factors for temperature, frequency and voltage |      |      |      |      |      |      |      |
|-------------------|--------|--|------|------|------|------|------|------|------|
| Current           | PF Cos | -40  | -25  | -10  | 5    | 30   | 40   | 55   | 70   |
| I <sub>min</sub>  | 1.0    | 0.56   | 0.45 | 0.29 | 0.15 | 0.01 | 0.04 | 0.07 | 0.12 |
| I <sub>tr</sub>   | 1.0    | 0.56   | 0.42 | 0.32 | 0.06 | 0.02 | 0.07 | 0.12 | 0.23 |
| 10I <sub>tr</sub> | 1.0    | 0.46   | 0.36 | 0.24 | 0.13 | 0.04 | 0.09 | 0.18 | 0.26 |
| I <sub>max</sub>  | 1.0    | 0.28   | 0.23 | 0.15 | 0.08 | 0.04 | 0.09 | 0.16 | 0.21 |
| I <sub>tr</sub>   | 0.5ind | 0.59   | 0.44 | 0.34 | 0.06 | 0.04 | 0.04 | 0.07 | 0.10 |
| 10I <sub>tr</sub> | 0.5ind | 0.40   | 0.31 | 0.19 | 0.11 | 0.04 | 0.09 | 0.16 | 0.22 |
| I <sub>max</sub>  | 0.5ind | 0.15   | 0.11 | 0.04 | 0.02 | 0.12 | 0.16 | 0.22 | 0.26 |
| I <sub>tr</sub>   | 0.8cap | 0.60   | 0.46 | 0.33 | 0.06 | 0.01 | 0.04 | 0.10 | 0.17 |
| 10I <sub>tr</sub> | 0.8cap | 0.46   | 0.37 | 0.25 | 0.14 | 0.03 | 0.09 | 0.17 | 0.26 |
| I <sub>max</sub>  | 0.8cap | 0.25   | 0.19 | 0.11 | 0.04 | 0.09 | 0.13 | 0.21 | 0.26 |

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below presents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$

where

$\delta e(T, I, \cos\phi) =$  Additional error due to variation of the temperature at the same load  
 $\delta e(U, I, \cos\phi) =$  Additional error due to variation of the voltage at the same load  
 $\delta e(f, I, \cos\phi) =$  Additional error due to variation of the frequency at the same load

|   |   |                                      |
|---|---|--------------------------------------|
|  | EC-Type Examination Certificate Number: |                                      |
|   | <b>0120/ SGS0129</b>                    |                                      |
|   | Issue Number: 1                         | Dated: 6 <sup>th</sup> February 2014 |

#### 4. Annex of Variants

Product Variant Identification Details:

| Type Designation   | Description of meter                                |
|--|---|
| 2001 – 31 Mk31 Single Phase, Multi-rate, Electricity Meter | eg S - 41E - 2M11 – 01210 – 113 – 11110 – 0032 - 10 |

##### Market Area Code

S = Sample  
T =Thailand  
M =Malaysia  
C =China  
P =Philippine  
I = Indonesia  
V =Vietnam  
L = Latin  
A = Africa  
O= Others

##### Rated Voltage

2 = 220V  
3 = 230V  
4 = 240V

##### Accuracy

1 = Class B, Class 1, 50Hz  
2 = Class A, Class 2, 50Hz

##### Current Range

A = 5(15)A  
B = 5(20)A  
C = 5(30)A  
D = 5(60)A  
E = 5(100)A  
F = 10(40)A  
G = 10(60)A  
H = 10(100)A  
I = 15(45)A  
J = 20(80)A  
K = 30(100)A

##### Terminal O/P configuration

1 = LLNN (Future Features)  
2 = LNNL  
3 = L1L2L2L1,1P3W (Future Features)  
4 = L1L1L2L2,1P3W (Future Features)

##### Terminal Cover Length

M = Middle length Terminal Cover  
S = Short Terminal Cover (Future Features)

##### Terminal Cover type

0 = Opaque PC  
1 = Transparent PC

##### Button option

0 = No Button  
1 = Single Button  
2 = Reserved

##### Local Communication port

0 = IEC Flag  
1 = No optical port  
2 = Modulated Infra Red

##### Remote Comm Port (Aux Port 1/2/3)

0 = No remote comm  
1 = RS485 (2-wire)  
4 = RF, for CIU or HHU  
5 = RF, for CIU or HHU Dry contact input  
6 = Reserved

##### Aux Port 1 Opt (upper Screw terminals)

0 = No I/O  
1 = Energy pulse output



EC-Type Examination Certificate Number:

**0120/ SGS0129**

Issue Number: 1

Dated: 6<sup>th</sup> February 2014

2 = RS485

3 = Dry contact input

4 = Reserved

**Aux Port 2 Options(Plug-in Type)**

0 = No I/O

1 = Energy pulse output

2 = RS485

3 = Open terminal cover detection

4 = Time signal output

5 = Dry contact input

6 = Reserved

**Aux Port 3 Opt (lower screw terminals)**

0 = No I/O

1 = Energy pulse output

2 = RS485

3 = Time signal output

4 = Dry contact input

5 = Reserved

**LCD Display**

0 = Not fitted

1 = LCD, 16x7.1mm, 7 digits

**LCD Backlight**

0 = No Backlight

1 = With Backlight

**LED Options**

0 = No LED

1 = 1 Pulse LED

2 = Pulse LED + Rev Energy LED

3 = Pulse LED + Rev Energy LED + Tamper LED

4 = Pulse LED + Rev Energy LED + Tamper LED + 1 Spare LED

5 = Energy Pulse LED + Reverse Energy LED + Tamper LED + 2 Spare LEDs

**Open terminal cover detection option (tamper feature,Assigned to Auxiliary Port 2)**

0 = Not Fitted

1 = Fitted

**Open lid cover detection option (tamper feature)**

0 = Not fitted

1 = Fitted

**Neutral Current Sensor**

0 = Without Neutral Current Sensor

1 = With Neutral / L2 Current Sensor

**Magnetic Tamper**

0 = No magnetic tamper detection

1 = With magnetic tamper detection

**Other Tamper Detection (future features)**

0 = Reserved

1 = Reserved

**Battery Options**

0 = Standard 3.6V Lithium internal battery

1 = no battery

**Internal Clock Options**

0 = Calibrated Clock, 15s/month at 23°C

1 = standard clock 60s/month at 23°C

2 = no RTC

**EEPROM Size**

1 = 64k Bits

2 = 128k Bits

3 = 256k Bits

4 = Reserved

**Flash Memory Size**

0 = Not fitted

1 = 1M Bytes

2 = 2M Bytes

3 = 4M Bytes


4 = 8M Bytes

5 = Reserved

**Disconnection Relay**

0 = Not fitted

1 = Fitted

|   |   |                                      |
|---|---|--------------------------------------|
|  | EC-Type Examination Certificate Number: |                                      |
|   | <b>0120/ SGS0129</b>                    |                                      |
|   | Issue Number: 1                         | Dated: 6 <sup>th</sup> February 2014 |

**Reserved**  
0 = Reserved  
1 = Reserved

Modifications to the meter(s) described according to approval No.**0120/ SGS0129** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

## 5. Document Revision History

| Issue | Date     | Comments      |
|-------|----------|---------------|
| 1     | 06/02/14 | Initial Issue |
|       |          |               |