

EC Type Examination Certificate Number: **UK/ 0120/ SGS0075**

# **Kohler Elektrik Sayaclari San ve Tic. A.S**

Bankalar Cad. Tenha Sok. No:8 Uçarlar Han Karaköy  
Beyoğlu  
İSTANBUL  
TURKEY

Instrument Identification:  
**AEL.MF.07**

Instrument Traceable Number  
**0120/SGS0075**

Single Phase, Multi-rate, Active Import / Export, Outdoor, Electricity Meter

has been assessed and certified as meeting the requirements of

## **EC Directive 2004/22/EC**

**Measuring Instruments Annex B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F

This certificate is valid for 10 years from 20<sup>th</sup> May 2010 until 19<sup>th</sup> May 2020  
Issue 3

Certification is based on report number(s)  
EMA136111 dated 20<sup>th</sup> May 2010, EMA187627 dated 27<sup>th</sup> March 2014


Authorised Signature

Jan Saunders




SGS United Kingdom Limited, Notified Body 0120  
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK  
t +44 (0)1934 522917 f +44 (0)1934 522137 [www.sgs.com](http://www.sgs.com)

Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK  
t +44 (0)191 377 2000 f +44 (0)191 377 2020 [www.sgs.com](http://www.sgs.com)

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0075</b>	
	Issue Number: 3	Dated: 4 <sup>th</sup> April 2014


## 1. Technical Data

Manufacturer	Kohler Elektrik Sayaclari San ve Tic. A.S
Meter Type	AEL.MF.07
Voltage Rating ( $U_n$ )	230V
Current Rating ( $I_{min}$ – $I_{ref}$ ( $I_{max}$ ))	0,25-5(90)A, 0,25-5(85)A 0,25-5(80)A, 0,25-5(60)A
Frequency ( $F_n$ )	50Hz
Active Accuracy Class ( $kWh$ )	A or B ( $kWh$ )
Type of circuit	1p2w
Temperature Range	-40°C to 70°C
Software Version No's.	PR0G:0007 & PROG: 0008
Identification Location	LCD
Bill Of Materials No.'s	MF201003ML - REV: 006 or MF201304ML - REV: 007
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	1600imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Main Meter Cover – Lead Inserts Terminal Cover - Plastic Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Outdoor
Type of Register	LCD


	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0075</b>	
	Issue Number: 3	Dated: 4 <sup>th</sup> April 2014


## 2. Photograph of Meter



	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0075</b>	
	Issue Number: 3	Dated: 4 <sup>th</sup> April 2014

### 3. SEALING POINTS FOR AEL.MF.07 MODEL



	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0075</b>	
	Issue Number: 3	Dated: 4 <sup>th</sup> April 2014

#### 4. Influence factors for temperature, frequency and voltage


		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40	-25	-10	5	30	40	55	70
I <sub>min</sub>	1.0	0.27	0.23	0.31	0.27	0.24	0.39	0.54	1.01
I <sub>tr</sub>	1.0	0.45	0.56	0.60	0.55	0.41	0.39	0.43	0.85
10I <sub>tr</sub>	1.0	0.13	0.22	0.26	0.22	0.13	0.24	0.39	0.88
I <sub>max</sub>	1.0	0.30	0.32	0.31	0.21	0.14	0.27	0.47	0.35
I <sub>tr</sub>	0.5ind	0.35	0.43	0.37	0.37	0.20	0.33	0.65	1.20
10I <sub>tr</sub>	0.5ind	0.22	0.31	0.33	0.24	0.18	0.28	0.57	1.02
I <sub>max</sub>	0.5ind	0.47	0.42	0.36	0.25	0.19	0.34	0.62	0.68
I <sub>tr</sub>	0.8cap	0.13	0.24	0.33	0.23	0.16	0.28	0.47	0.98
10I <sub>tr</sub>	0.8cap	0.15	0.20	0.26	0.22	0.16	0.26	0.48	0.90
I <sub>max</sub>	0.8cap	0.22	0.25	0.28	0.21	0.15	0.28	0.52	0.68

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi) + \delta e^2(U, I, \cos\phi) + \delta e^2(f, I, \cos\phi))}$$

where

$\delta e(T, I, \cos\phi)$	=	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos\phi)$	=	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos\phi)$	=	Additional error due to variation of the frequency at the same load

	EC-Type Examination Certificate Number:	
	<b>0120/ SGS0075</b>	
	Issue Number: 3	Dated: 4 <sup>th</sup> April 2014

## 5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
AEL.MF.07	0,25-5(90)A, 0,25-5(85)A, 0,25-5(80)A, 0,25-5(60)A 230V, Single Phase, Multi-rate, Active Import/ Export (kWh), Outdoor, Electricity Meter

Modifications to the meter(s) described according to approval No.**0120/ SGS0075** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

## 6. Document Revision History

Issue	Date	Comments
1	20/05/2010	Initial issue
2	01/02/2011	Additional current ranges added
3	04/04/2014	Minor modification and software change