

Determination of an Application for an Environmental Permit under the Environmental Permitting (England & Wales) Regulations 2010

Decision document recording our decision-making process

The Application Number is: EPR/KP3936ZB/A001
The Applicant is: Tilbury Green Power Limited
The Installation is located at: Tilbury Dock, Essex

What this document is about

This is a decision document, which accompanies a permit.

It explains how we have considered the Applicant's Application, and why we have included the specific conditions in the permit we are issuing to the Applicant. It is our record of our decision-making process, to show how we have taken into account all relevant factors in reaching our position. Unless the document explains otherwise, we have accepted the Applicant's proposals.

We try to explain our decision as accurately, comprehensively and plainly as possible. Achieving all three objectives is not always easy, and we would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

Preliminary information and use of terms

We gave the application the reference number EPR/KP3936ZB/A001. We refer to the application as "the **Application**" in this document in order to be consistent.

The number we have given to the permit is EPR/KP3936ZB. We refer to the permit as "the **Permit**" in this document.

The Application was duly made on 21 November 2013.

The Applicant is Tilbury Green Power Limited. We refer to Tilbury Green Power Limited as "the **Applicant**" in this document. Where we are talking

about what would happen after the Permit is granted, we call Tilbury Green Power Limited “the **Operator**”.

Tilbury Green Power Limited’s proposed facility is located at Tilbury Dock. We refer to this as “the **Installation**” in this document.

How this document is structured

- Glossary of acronyms
- Our proposed decision
- How we reached our decision
- The legal framework
- The Installation
 - Description of the Installation and general issues
 - The site and its protection
 - Operation of the Installation – general issues
- Minimising the installation's environmental impact
 - Assessment Methodology
 - Air Quality Assessment
 - Human health risk assessment
 - Impact on Habitats sites, SSSIs, non-statutory conservation sites etc.
 - Impact of abnormal operations
- Application of Best Available Techniques
 - Scope of Consideration
 - BAT and emissions control
 - BAT and global warming potential
 - BAT and POPs
 - Other Emissions to the Environment
 - Setting ELVs and other Permit conditions
 - Monitoring
 - Reporting
- Other legal requirements
 - The EPR 2010 (as amended) and related Directives
 - National primary legislation
 - National secondary legislation
 - Other relevant legal requirements
- Annexes
 - Application of Chapter IV of the Industrial Emissions Directive
 - Pre-Operational Conditions
 - Improvement Conditions
 - Consultation Responses

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
APIS	Air Pollution Information System
BAT	Best Available Technique(s)
BAT-AEL	BAT Associated Emission Level
BREF	BAT Reference Note
CEM	Continuous emissions monitor
CFD	Computerised fluid dynamics
CHP	Combined heat and power
C & I	Commercial & Industrial waste
COMEAP	Committee on the Medical Effects of Air Pollutants
CROW	Countryside and rights of way Act 2000
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DD	Decision document
EAL	Environmental assessment level
EfW	Energy from Waste
EIAD	Environmental Impact Assessment Directive (85/337/EEC)
ELV	Emission limit value
EMAS	EU Eco Management and Audit Scheme
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2010 (SI 2010 No. 675) as amended
EQS	Environmental quality standard
EU-EQS	European Union Environmental Quality Standard
EWC	European waste catalogue
FSA	Food Standards Agency
GWP	Global Warming Potential
HHRAP	Human Health Risk Assessment Protocol
HMIP	Her Majesty's Inspectorate of Pollution
HPA	Health Protection Agency
HRA	Human Rights Act 1998

HW	Hazardous waste
HWI	Hazardous waste incinerator
IBA	Incinerator Bottom Ash
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
I-TEF	Toxic Equivalent Factors set out in Annex VI Part 2 of IED
I-TEQ	Toxic Equivalent Quotient calculated using I-TEF
LCV	Lower calorific value – also termed net calorific value
LfD	Landfill Directive (1999/31/EC)
LHB	Local Health Board
LOI	Loss on Ignition
MBT	Mechanical biological treatment
MSW	Municipal Solid Waste
MWI	Municipal waste incinerator
NO _x	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
Opra	Operator Performance Risk Appraisal
PAH	Polycyclic aromatic hydrocarbons
PC	Process Contribution
PCB	Polychlorinated biphenyls
PCT	Primary Care Trust
PEC	Predicted Environmental Concentration
PHE	Public Health England
POP(s)	Persistent organic pollutant(s)
PPS	Public participation statement
PR	Public register
PXDD	Poly-halogenated di-benzo-p-dioxins
PXB	Poly-halogenated biphenyls
PXDF	Poly-halogenated di-benzo furans
RDF	Refuse derived fuel
RGS	Regulatory Guidance Series
SAC	Special Area of Conservation
SCR	Selective catalytic reduction
SGN	Sector guidance note

SHPI(s)	Site(s) of High Public Interest
SNCR	Selective non-catalytic reduction
SPA(s)	Special Protection Area(s)
SRF	Solid Recovered Fuel
SS	Sewage sludge
SSSI(s)	Site(s) of Special Scientific Interest
SWMA	Specified waste management activity
TDI	Tolerable daily intake
TEF	Toxic Equivalent Factors
TGN	Technical guidance note
TOC	Total Organic Carbon
UN_ECE	United Nations Environmental Commission for Europe
US EPA	United States Environmental Protection Agency
WFD	Waste Framework Directive (2008/98/EC)
WHO	World Health Organisation
WID	Waste Incineration Directive (2000/76/EC) – now superseded by IED

1 Our decision

We have decided to grant the Permit to the Applicant. This will allow it to operate the Installation, subject to the conditions in the Permit.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the permit will ensure that a high level of protection is provided for the environment and human health.

This Application is to operate an Installation which is subject principally to the Industrial Emissions Directive (IED).

The Permit contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the permit, we have considered the Application and accepted the details are sufficient and satisfactory to make the standard condition appropriate. This document does, however, provide an explanation of our use of “tailor-made” or Installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Receipt of Application

The Application was duly made on 21 November 2013. This means we considered it was in the correct form and contained sufficient information for us to begin our determination but not that it necessarily contained all the information we would need to complete that determination: see below.

The Applicant made no claim for commercial confidentiality. We have not received any information in relation to the Application that appears to be confidential in relation to any party.

2.2 Consultation on the Application

We carried out consultation on the Application in accordance with the EPR, our statutory PPS and our own RGS Note 6 for Determinations involving Sites of High Public Interest. We consider that this process satisfies, and frequently goes beyond the requirements of the Aarhus Convention on Access to Information, Public Participation in Decision-Making and Access to Justice in Environmental Matters, which are directly incorporated into the IED, which applies to the Installation and the Application. We have also taken into account our obligations under the Local Democracy, Economic Development and Construction Act 2009 (particularly Section 23). This requires us, where we consider it appropriate, to take such steps as we consider appropriate to

secure the involvement of representatives of interested persons in the exercise of our functions, by providing them with information, consulting them or involving them in any other way. In this case, our consultation already satisfies the Act's requirements.

We advertised the Application by a notice placed on our website, which contained all the information required by the IED, including telling people where and when they could see a copy of the Application. We also placed an advertisement in the Thurrock Gazette on the 19 December 2013. We extended the formal consultation period to the 3 February 2014 to give interested parties additional time to send any comments to us.

The Application was made available to view at Icen House, Cobham Road, Ipswich, IP3 9JD. We also sent a copy to Thurrock Council at Civic Offices, New Road, Grays, RM17 6SL, for its own Public Register. Anyone wishing to see these documents could do so and arrange for copies to be made. The Applicant also provided a number of copies of the Application on CD which were also made accessible from the Public Registers.

We sent copies of the Application to the following bodies, which includes those with whom we have "Working Together Agreements":

- Local Council (Thurrock) Planning Department
- Local Council (Thurrock) Environmental Health
- Gravesham Council
- Public Health England (PHE)
- Director of Public Health
- Food Standards Agency (FSA)
- Health & Safety Executive (HSE)
- Local Fire & Rescue Service
- National Grid
- Thames Water
- Port of London Authority
- Port of Tilbury
- Civil Aviation Authority

These are bodies whose expertise, democratic accountability and/or local knowledge make it appropriate for us to seek their views directly. Note under our Working Together Agreement with Natural England, we only inform Natural England of the results of our assessment of the impact of the Installation on designated Habitats sites.

In addition to our advertising the Application, we undertook a programme of extended public consultation. A public information event was held at Tilbury Football Club on the 7 January 2014, written comments were also accepted by the Environment Agency well beyond the formal consultation period. Further details along with a summary of consultation comments and our response to the representations we received can be found in Annex 4. We

have taken all relevant representations into consideration in reaching our determination.

2.3 Requests for Further Information

Although we were able to consider the Application duly made, we did in fact need more information in order to determine it, and issued information notices on:

Detail	Date	Comments
Further Information Notice dated 13/12/13	Response received/dated 16/01/14 CHP ready assessment received electronically 14/03/14	Waste production, air quality, abatement, CEMs, fuel capacity & CHP ready.
Further Information Notice dated 30/01/14	Applicant response received electronically 14/03/14 Noise dated 25 February 2014 Air Quality dated March 2014	Noise assessment Updated Air Quality and Emissions Assessment & Human Health Risk Assessment.
Further Information Notice dated 05/03/14	Applicant response dated 12 March 2014 and additional email sent 08/04/14	Noise (additional)

A copy of each information notice was placed on our public register and sent to Thurrock local authority for inclusion on its register, as was the response when received.

In addition to our information notices, we received additional information during the determination as detailed in the table below. We made a copy of this information available to the public in the same way as the responses to our information notices.

Detail	Date	Comments
Email requiring clarification sent 21/01/14	Applicant response received electronically 08/04/14 08/04/14 & 29/04/14	Fuel capacity /design basis Biomass storage.

Having carefully considered the Application and all other relevant information, we put our draft decision before the public and other interested parties in the form of a draft Permit, together with the explanatory document. As a result of this stage in the process, the public was provided with all the information relevant to our determination, including the original Application and additional information obtained subsequently, and we have given the public two

separate opportunities to comment on the Application and its determination. Once again, we have considered all relevant representations received in response to the final consultation and have amended this explanatory document as appropriate to explain how we have done this, in publishing our final decision.

We consulted on our draft decision from 12 June and 10 July 2014. A summary of the consultation responses and how we have taken into account all relevant representations is shown in Annex 4B.

3 The legal framework

The Permit will be granted under Regulation 13 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* and a *waste incineration plant* as described by the IED;
- an *operation* covered by the WFD, and
- subject to aspects of other relevant legislation which also have to be addressed.

We address some of the major legal requirements directly where relevant in the body of this document. Other requirements are covered in a section towards the end of this document.

We consider that, in granting the Permit, it will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The Installation

4.1 Description of the Installation and related issues

4.1.1 The permitted activities

The Installation is subject to the EPR because it carries out an activity listed in Part 1 of Schedule 1 to the EPR:

- Section 5.1 Part A(1)(b) – incineration of non-hazardous waste in a waste incineration plant with a capacity exceeding 3 tonnes per hour.

The IED definition of “waste incineration plants” and “waste co-incineration plants” says that it includes:

“all incineration lines or co-incineration lines, waste reception, storage, on site pre-treatment facilities, waste, fuel and air supply systems, boilers, facilities for the treatment of waste gases, on-site facilities for treatment or storage of residues and waste water, stacks, devices for controlling incineration or co-incineration operations, recording and monitoring incineration or co-incineration conditions.”

Many activities which would normally be categorised as “directly associated activities” for EPR purposes (see below), such as air pollution control plant, (including storage and preparation of treatment chemicals), and the ash storage bunker, are therefore included in the listed activity description.

We consider the waste wood processing facility and the SRF preparation facility fall within the scope of the definition of the waste incineration plant as it is a process for the pre-treatment of waste. The purpose of the pre-treatment is to improve combustion properties, produce a more homogeneous feedstock etc.

An Installation may also comprise “directly associated activities”, which at this Installation includes the generation of electricity using a steam turbine and a back up electricity generator for emergencies. These activities comprise one Installation, because the incineration plant and the steam turbine are successive steps in an integrated activity.

Together, these listed and directly associated activities comprise the Installation.

4.1.2 The Site

The facility is located in the western section of the Port of Tilbury which is on the north side of the Thames Estuary at national grid reference TQ620771. The residential areas of Grays and Tilbury are situated nearby. The Thames Estuary & Marches Special Protection Area (SPA) and Ramsar are located within the 10km screening distance and there are also several Sites of Special Scientific Interest (SSSIs) and local wildlife sites located within the 2km screening distance as detailed in Section 5.4 of this document. An assessment of the impact from air emissions from the proposed facility is included in Section 5 of this document.

The Applicant submitted a plan which we consider is satisfactory, showing the site of the Installation and its extent. A plan is included in Schedule 7 to the Permit, and the Operator is required to carry on the permitted activities within the site boundary.

Further information on the site is addressed below at 4.3.

4.1.3 What the Installation does

The Applicant has described the facility as a multi-fuel renewable electricity generating facility. Our view is that for the purposes of IED (in particular Chapter IV) and EPR, the Installation is a waste incineration plant because:

Mixed waste (Line 2), some of which has undergone pre-treatment, is burnt as the principal source of fuel with the principal output being electricity which is mainly supplied to the national grid (Environment Agency briefing note – Guidance on when a plant is Co-Incineration Plant – v3).

Following this same guidance, the waste wood (Line 1) would be classified as having consistent characteristics with energy recovery above 0.8 MW/tonne which falls under the definition of a co-incinerator.

The Applicant has applied for a waste incineration facility (revised Application form B3) with impact assessments also being based on incineration limits, so for the purposes of this determination the Installation is a waste incineration plant. Having both lines defined as incinerators also allows for future flexibility.

Notwithstanding the fact that energy will be recovered from the process; the process is never the less ‘incineration’ because it is considered that its main purpose is the thermal treatment of waste.

The Installation will comprise of two incineration lines, Line 1 (biomass) and Line 2 (Solid Recovered Fuel (SRF)) with a maximum capacity totalling 535,000 tonnes per annum (tpa) and will be designed to be compliant with the requirements of Chapter IV of the IED – Waste Incineration. Each line will have the capacity to generate up to 30MW (total 60MW) of electricity and will be designed to be Combined Heat and Power (CHP) ready with the capacity to produce up to 4.5 MWth of heat for export to local users as either low-pressure steam or hot water.

Line 1 will consist of a biomass incineration facility with a maximum capacity of 235,000 tpa. It will also include a waste wood processing facility for the preparation of biomass for incineration.

Line 2 will consist of a SRF incineration facility with a maximum capacity of 300,000 tpa. This will include an SRF preparation facility for separating recyclates from non-hazardous municipal (MSW) and commercial and industrial waste (C&I) waste to produce SRF.

It is proposed that the combustion technology for the plant will be a moving grate. In outline the process will be as follows:

- All waste will be delivered to the facility in covered vehicles.
- Unprocessed biomass will be stored externally on an area of hard standing.
- Biomass processing will take place within an enclosed building to produce the biomass fuel.

- Processing will comprise removal of metal contaminants using a magnet and/or an eddy current separator and wood chippers.
- Biomass fuel will be conveyed to the biomass storage building.
- Pre-processed biomass delivered to the facility will be received in the biomass storage building.
- Unprocessed MSW and C&I waste will be delivered to the facility and unloaded into the SRF production facility reception area for subsequent processing into a fuel.
- Processing will comprise mechanical treatment consisting of trommels and separation processes to recover recyclates.
- Pre-processed SRF will be delivered to the facility and unloaded into the appropriate fuel storage area within an enclosed building.
- Fuel will be transferred from the fuel storage facilities into the spreader stoker fuel feed system for the combustion unit.
- Residues (bottom ash) from the combustion chamber will be removed in a water bath to contain dust releases.
- Emissions of nitrogen oxides will be controlled by the injection of urea into the combustion chamber.
- Hot gases from the waste combustion will be passed through a boiler to raise steam. The steam will then be passed to a steam turbine to generate electricity for use at the facility and export to the National Grid.
- The facility will be “CHP ready”. When a district heating market becomes available, the provision of a heat off-take to supply a network would be possible without any modifications to the installed system.
- The combustion gases will be cleaned in a flue gas treatment plant. This will include the injection of carbon, primarily to control dioxin emissions, the injection of lime to control acid gas emissions, and the use of a fabric filter to remove dust.
- The cleaned exhaust gases will be released to atmosphere via two 100m stacks.




Figure 1 – Indicative Process Schematic

1. Fuel reception & storage	6. Generator
2. Fuel transport and feed system	7. Condensate system/ACC
3. Steam boiler	8. Feed water system
4. Flue gas filter and stack	9. Electrical supply and export system,
5. Turbine	10. Fuel preparation

The key features of the installation can be summarised in the table below.

Waste throughput TOTAL	<u>Maximum</u> 535,000 tonnes/annum (tpa)	<u>Nominal</u>
Tonnes/line	Line 1 capacity: 235,000 tpa Line 2 capacity: 300,000 tpa	Lines 1 & 2 capacity: 195,000 tpa/line
Waste processed	Line 1 Biomass Line 2 SRF (MSW and C&I)	
Number of lines	2	
Furnace technology	Moving grate	
Auxiliary Fuel	Gas Oil	
Acid gas abatement	Dry	hydrated lime
NOx abatement	SNCR	urea
Reagent consumption	Auxiliary Fuel: 200 tpa Urea: 3,600 tpa Lime: 2,000 tpa Activated carbon: 250 tpa Process water: 35 tpa	
Flue gas recirculation	Yes	
Dioxin abatement	Activated carbon	
Stack	Height 2 x 100 m	Diameter, 2.83 m Twin stacks modelled as 2 separate stacks
Flue gas	Flow, 161.7 Nm ³ /s	Velocity, 25.74 m/s
Electricity generated (nominal capacity)	30 MWe/line	240,000 MWh/line
Electricity exported (nominal capacity)	27 MWe/line	216,000 MWh/line
Waste heat use	<p>Low grade heat will be extracted from the turbine and used to preheat combustion air in order to improve the efficiency of the thermal cycle.</p> <p>A secondary economiser will recover heat downstream of the main boiler to cool down the flue gas to the right temperature for lime injection. The heat recovered will be used to preheat condensate before it is sent to the de-aerator / feed water tank.</p>	


4.1.4 Key Issues in the Determination

The key issues arising during this determination were the emissions to air from the Installation and their impact on human health and the environment. We therefore describe how we determined these issues in most detail in this document.

4.2 The site and its protection

4.2.1 Site setting, layout and history

The site covers an area of approximately 9.3 hectares in the western section of the Port of Tilbury on the north side of the Thames Estuary. The residential areas of Grays and Tilbury are situated nearby. It is bounded by the River Thames to the south west; the riverside park (Grays Beach) to the North West; and by the main Grays-Tilbury railway line to the north east.



Between 1872 and 1974 the site comprised fields bisected by drainage ditches with two small ponds. By 1984 the site had been developed as a “works” and was occupied by a number of large buildings and roads. Groups of tanks and silos were evident.

4.2.2 Proposed site design: potentially polluting substances and prevention measures

The Applicant carried out an Environmental Risk Assessment following the Environment Agency Horizontal Guidance Note H1. This was included within Annex 4 of the Application. The assessment considered all potential sources of ground and surface water pollution that could occur due to fugitive

emissions from the facility or from accidents occurring at the facility. The risk assessment also detailed any mitigation measures that would be employed to reduce the frequency or impact of these events.

The land use and pollution history of the site was considered in the desk study section of the site condition report.

The Environmental Risk Assessment identified that the facility would require the storage of various chemicals, which could pose a risk to the ground and groundwater during normal operation. All process areas, loading/unloading, materials handling areas and roadways would be covered in concrete and/or tarmac hardstanding. It was therefore not regarded that there would be any risk of ground/groundwater contamination during normal operation of the Installation.

The Environmental Risk Assessment concluded that for land, groundwater and surface water, the residual impacts of the facility would be insignificant provided the recommended mitigation measures are employed.

The Applicant therefore concluded that the Installation would pose little risk of pollution.

Under Article 22(2) of the IED the Applicant is required to provide a baseline report containing at least the information set out in paragraphs (a) and (b) of the Article before starting operation.

The Applicant has submitted a site condition report which includes a report on the baseline conditions as required by Article 22. We have reviewed this report and consider that it adequately describes the condition of the soil and groundwater prior to the start of operations.

The baseline report is an important reference document in the assessment of contamination that might arise during the operational lifetime of the Installation and at cessation of activities at the Installation.

4.2.3 Closure and decommissioning

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place for the closure and decommissioning of the Installation, as referred to in Section 2.9 of the Application. A pre-operational condition requires the Operator to have an Environmental Management System in place before the Installation is operational, and this will include a site closure plan.

At the definitive cessation of activities, the Operator has to satisfy us that the necessary measures have been taken so that the site ceases to pose a risk to soil or groundwater, taking into account both the baseline conditions and the site's current or approved future use. To do this, the Operator has to apply to us for surrender, which we will not grant unless and until we are satisfied that these requirements have been met.

4.3 Operation of the Installation – general issues

4.3.1 Administrative issues

The Applicant is the sole Operator of the Installation.

We are satisfied that the Applicant is the person who will have control over the operation of the Installation after the granting of the Permit; and that the Applicant will be able to operate the Installation so as to comply with the conditions included in the Permit.

The incineration of waste is not a specified waste management activity (SWMA). The Environment Agency has considered whether any of the other activities taking place at the Installation are SWMAs and is satisfied that none are taking place.

We made some changes to the Applicant's Opra profile; however this did not result in any changes to the overall score of 308. The main change was to the Operator Performance attribute with the removal of the ISO 14001 certification (refer to Section 4.3.2). We are satisfied that the Applicant's Opra profile is now accurate.

The Opra score will be used as the basis for subsistence and other charging, in accordance with our Charging Scheme. Opra is the Environment Agency's method of ensuring application and subsistence fees are appropriate and proportionate for the level of regulation required.

4.3.2 Management

The Applicant has stated in the Application that they will implement an Environmental Management System (EMS) that will be certified under ISO14001. A pre-operational condition is included requiring the Operator to provide a summary of the EMS prior to commissioning of the plant and to make available for inspection all EMS documentation. The Environment Agency recognises that certification of the EMS cannot take place until the Installation is operational. An improvement condition is included requiring the Operator to report progress towards gaining accreditation of its EMS.

We are satisfied that appropriate management systems and management structures will be in place for this Installation, and that sufficient resources are available to the Operator to ensure compliance with all the Permit conditions.

4.3.3 Site security

Having considered the information submitted in the Application, we are satisfied that appropriate infrastructure and procedures will be in place to ensure that the site remains secure.

4.3.4 Accident management

The Applicant has not submitted an Accident Management Plan. Having considered the other information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that accidents that may cause pollution are prevented but that, if they should occur, their consequences are minimised. An Accident Management Plan will form part of the Environmental Management System and must be in place prior to commissioning as required by a pre-operational condition.

4.3.5 Off-site conditions

We do not consider that any off-site conditions are necessary.

4.3.6 Operating techniques

We have specified that the Applicant must operate the Installation in accordance with the following documents contained in the Application and Technical Guidance:

Description	Parts Included	Justification
The Application	The response to question 3 Operating techniques, given in Part B3 of the application form. Includes Table 3a – Technical Standards Application Supporting Information	<ul style="list-style-type: none">▪ the waste feed cessation system▪ start-up and shut-down▪ temperature monitoring in the combustion chamber▪ energy recovery from the Installation▪ temperature, oxygen, water vapour and pressure at air release sampling points▪ ash and residues will be stored and transported in a manner that prevents fugitive dust releases

Response to Schedule 5 Notice dated 16/01/14	The response to items 1, 3 and 4	<ul style="list-style-type: none"> ▪ Waste Production ▪ Abatement ▪ CEMs
Response to email requiring clarification sent 21/01/14	Fuel capacity/design basis - Email from Applicant sent 8 April 2014 – Plant Capacity Clarification	<ul style="list-style-type: none"> ▪ Incineration capacity
Environment Agency Technical Guidance Note (TGN7.01)	All Parts - How to comply with your environmental permit - reducing fire risk at sites storing combustible materials	Reduce fire risk from storage of waste, particularly biomass

The details set out above describe the techniques that will be used for the operation of the Installation that have been assessed by the Environment Agency as BAT; they form part of the Permit through Permit condition 2.3.1 and Table S1.2 in the Permit Schedules.

We have also specified the following limits and controls on the use of raw materials and fuels:

Raw Material or Fuel	Specifications	Justification
Fuel Oil	< 0.1% sulphur content	As required by Sulphur Content of Liquid Fuels Regulations.

Article 45(1) of the IED requires that the Permit must include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2005/532/EC, EC, if possible, and containing information on the quantity of each type of waste, where appropriate. The Application contains a list of those wastes in Tables 5 to 8 of the Supporting information, coded by the European Waste Catalogue (EWC) number, which the Applicant will accept in the waste streams entering the plant and which the plant is capable of burning in an environmentally acceptable way. We have specified the permitted waste types, descriptions and where appropriate quantities which can be accepted at the Installation in Table S2.2 for Line 1 (biomass) and Table S2.3 for Line 2 (SRF).

We are satisfied that the Applicant can accept the wastes contained in Tables S2.2 and S2.3 of the Permit because: -

- (i) the wastes are all categorised as non-hazardous in the European Waste Catalogue and are capable of being safely burnt at the Installation.
- (ii) these wastes are likely to be within the design calorific value (CV) range for the plant;
- (iii) these wastes are unlikely to contain harmful components that cannot be safely processed at the Installation.

Line 2 of the incineration plant will take municipal waste, which has not been source-segregated or separately collected or otherwise recovered, recycled or composted. Waste codes for separately collected fractions of waste (with the exception of waste wood classified under EWC code 20 01 38) are not included in the list of permitted wastes, except that separately collected fractions which prove to be unsuitable for recovery may be included.

The Application contains details on the maximum and nominal design capacity which is summarised as follows:

Maximum Design Capacity

We have limited the maximum capacity of the Installation to 535,000 tonnes per annum (tpa), which equates to 235,000 tpa for Line 1 (biomass) and 300,000 tpa for Line 2 (SRF). The Applicant confirmed that this capacity was used as the design basis for the air quality and human health risk assessments.

This is based on a nominal operational availability for each line of 8,000 hours per year at a maximum capacity of 29 tonnes per hour.

The annual waste input capacity will vary depending on the availability of the lines, with 8000 hours regarded as typical.

For Line 2 (SRF), the CV for the range of fuels will be much greater than for Line 1 (biomass). If the net calorific value of the waste is low, the incineration line will operate at a higher mechanical throughput than the nominal design capacity.

Nominal Design Capacity

The Application confirms the following: both incineration lines will have a nominal design capacity of approximately 24.2 tonnes per hour. Assuming each line has an operational availability of 8,000 hours per annum the nominal design capacity of each line is approximately 195,000 tpa.

The Installation will be designed, constructed and operated using BAT for the incineration of the permitted wastes. We are satisfied that the operating and abatement techniques are BAT for incinerating these types of waste. Our assessment of BAT is set out later in this document.

4.3.7 Energy efficiency

(i) Consideration of energy efficiency

We have considered the issue of energy efficiency in the following ways:

1. The use of energy within, and generated by, the Installation which are normal aspects of all EPR permit determinations. This issue is dealt with in this section.
2. The extent to which the Installation meets the requirements of Article 50(5) of the IED, which requires “*the heat generated during the incineration and co-incineration process is recovered as far as practicable through the generation of heat, steam or power*”. This issue is covered in this section.
3. The combustion efficiency and energy utilisation of different design options for the Installation are relevant considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options. This aspect is covered in the BAT assessment in section 6 of this Decision Document.

(ii) Use of energy within the Installation

Having considered the information submitted in the Application, we are satisfied that appropriate measures will be in place to ensure that energy is used efficiently within the Installation.

The Application details a number of measures that will be implemented at the Installation in order to increase its energy efficiency, such as high efficiency motors, high standards of cladding and insulation, etc. It also confirms that an energy efficiency plan will be built in to the operation and maintenance procedures of the plant which will be reviewed annually as part of the site EMS.

The Application states that the specific energy consumption, a measure of total energy consumed per unit of waste processed, will be:

Maximum Capacity

Line 1 (biomass) - 102 kWh/tonne (235,000 tpa)

Line 2 (SRF) - 80 kWh/tonne (300,000 tpa)

Nominal Capacity

Lines 1 and 2 - 123 kWh/tonne for each line (195,000 tpa x 2)

Data from the BREF for Municipal Waste Incinerators shows that the range of specific energy consumptions is as in the table below.

MSWI plant size range (t/yr)	Process energy demand (kWh/t waste input)
Up to 150,000	300 – 700
150,000 – 250,000	150 – 500
More than 250,000	60 – 200

The BREF says that it is BAT to reduce the average installation electrical demand to generally below 150 kWh/tonne of waste with an LCV of 10.4 MJ/kg. The net CV in this case is expected to be 13.8 MJ/kg. Taking account of the difference in CV, the specific energy consumption in the Application is in line with that set out above.

(iii) Generation of energy within the Installation - Compliance with Article 50(5) of the IED

Article 50(5) of the IED requires that *“the heat generated during the incineration and co-incineration process is recovered as far as practicable”*.

Our draft CHP Ready Guidance (Dec 2012) considers that BAT for energy efficiency for Energy from Waste (EfW) plant is the use of CHP in circumstances where there are technically and economically viable opportunities for the supply of heat from the outset.

The term CHP in this context represents a plant which also provides a supply of heat from the electrical power generation process to either a district heating network or to an industrial / commercial building or process. However, it is recognised that opportunities for the supply of heat do not always exist from the outset (i.e. when a plant is first consented, constructed and commissioned).

In cases where there are no immediate opportunities for the supply of heat from the outset, the Environment Agency considers that BAT is to build the plant to be CHP Ready (CHP-R) to a degree which is dictated by the likely future opportunities which are technically viable and which may, in time, also become economically viable. The Applicant submitted a CHP-R Assessment (Ref: S1386-0010-0271RLB) 13 March 2014.

The BREF says that where a plant generates electricity only, it is BAT to recover 0.4 – 0.65 MWh/ tonne of waste (based on LCV of 10.4 MJ/kg). Our technical guidance note, SGN EPR S5.01, states that where electricity only is generated, 5 - 9 MW of electricity should be recoverable per 100,000 tonnes/annum of waste (which equates to 0.4 – 0.72 MWh/tonne of waste).

The Installation will generate electricity only and has been specified to maximise electrical output with little or no use of waste heat. The Sankey diagram, information provided in Section 2.6 of the Application and the email from the Applicant sent 28 March 2014 shows:

Maximum Capacity

Line 1 (biomass) - 12.7 MW per 100,000 tonnes of waste (0.95 MWh/tonne of waste)

Line 2 (SRF) - 10 MW per 100,000 tonnes of waste (0.75 MWh/tonne of waste)

Nominal Capacity

Lines 1 and 2 - 15.4 MW per 100,000 tonnes of waste (1.15 MWh/tonne of waste)

The Installation is therefore above the indicative BAT range.

The SGN and Chapter IV of the IED both require that, as well as maximising the primary use of heat to generate electricity; waste heat should be recovered as far as practicable.

A CHP Feasibility Review was provided with the Application which took into account existing and potential new developments off-site in the locality and their estimated heat requirements. It concluded that whilst there were no significant process heat loads that could be supplied in the locality, that it was technically feasible; however it was not financially viable under current market conditions.

The location of the Installation largely determines the extent to which waste heat can be utilised, and this is a matter for the planning authority. The Applicant carried out a feasibility study, which showed there was potential to provide district heating to local businesses; suitable opportunities are being explored, though there are no firm commitments at this stage. There is provision within the design of the steam turbine to extract low-grade steam for a district heating scheme. Establishing a district heating network to supply local users would involve significant technical, financial and planning challenges such that this is not seen as a practicable proposition at present.

Our draft CHP guidance also states that opportunities to maximise the potential for heat recovery should be considered at the early planning stage, when sites are being identified for incineration facilities. In our role as a statutory consultee on the planning application, we ensured that the issue of energy utilisation was brought to the planning authority's attention. We have made comments about this to Thurrock Borough Council (the planning authority) in our role as a statutory consultee for the planning application.

We consider that, within the constraints of the location of the Installation explained above, the Installation will recover heat as far as practicable, and therefore that the requirements of Article 50(5) are met.

(iv) R1 Calculation

The R1 calculation does not form part of the matters relevant to our determination. It is however a general indicator that the Installation is achieving a high level of energy recovery.

The Applicant has not presented an R1 calculation with this Application, nor have we received a separate application for a determination on whether the Installation is a recovery or disposal facility.

Note that the availability or non-availability of financial incentives for renewable energy such as the ROC and RHI schemes is not a consideration in determining this application.

(v) Choice of Steam Turbine

The CHP Feasibility Review provided with the Application confirmed that an appropriate turbine design would be selected to facilitate the distribution of heat to third-party customers off-site should suitable opportunities arise in the future.

(vi) Choice of Cooling System

The Applicant confirmed that the plant would operate an Air Cooled Condenser (ACC) to condense the steam output from the turbine to allow return of the condensate to the boiler. The ACC does not require large volumes of water and does not generate a discharge. In addition there would be no significant visual impact as compared to evaporative cooling. It does have the potential to be noisier (Refer to Section 6.5.5 below). The ACC was considered to represent BAT for this Installation and we agree with this conclusion.

(vii) Permit conditions concerning energy efficiency

A pre-operational condition requires the Operator to carry out a comprehensive review of the available heat recovery options prior to commissioning, in order to ensure that waste heat from the plant is recovered as far as possible.

Conditions 1.2.2 and 1.2.3 have also been included in the Permit, which require the Operator to review the options available for heat recovery on an ongoing basis, and to provide and maintain the proposed steam/hot water pass-outs.

The Operator is required to report energy usage and energy generated under condition 4.2 and Schedule 4. The following parameters are required to be reported: total electrical energy generated; electrical energy exported; total energy usage and energy exported as heat (if any). Together with the total waste biomass and SRF burned per year, this will enable the Environment

Agency to monitor energy recovery efficiency at the Installation and take action if at any stage the energy recovery efficiency is less than proposed.

There are no site-specific considerations that require the imposition of standards beyond indicative BAT, and so the Environment Agency accepts that the Applicant's proposals represent BAT for this Installation.

4.3.8 Efficient use of raw materials

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place to ensure the efficient use of raw materials and water.

The Operator is required to report with respect to raw material usage under condition 4.2 and Schedule 4, including consumption of lime, activated carbon and urea used per tonne of waste burned. This will enable the Environment Agency to assess whether there have been any changes in the efficiency of the air pollution control plant, and the operation of the SNCR to abate NO_x. These are the most significant raw materials that will be used at the Installation, other than the waste feed itself (addressed elsewhere). The efficiency of the use of auxiliary fuel will be tracked separately as part of the energy reporting requirement under condition 4.2.1. Optimising reagent dosage for air abatement systems and minimising the use of auxiliary fuels is further considered in the section on BAT.

4.3.9 Avoidance, recovery or disposal with minimal environmental impact of wastes produced by the activities

This requirement addresses wastes produced at the Installation and does not apply to the waste being treated there. The principal waste streams the Installation will produce are bottom ash, air pollution control residues, recyclates (recovered glass, plastics, metals) and residuals (non-recyclable and non-combustible).

The first objective is to avoid producing waste at all. Waste production will be avoided by achieving a high degree of burnout of the ash in the furnace, which results in a material that is both reduced in volume and in chemical reactivity. Condition 3.1.2 and associated Table S3.5 specify limits for total organic carbon TOC of <3% in bottom ash. Compliance with this limit will demonstrate that good combustion control and waste burnout is being achieved in the furnaces and waste generation is being avoided where practicable.

Incinerator bottom ash (IBA) will normally be classified as non-hazardous waste. However, IBA is classified on the European List of Wastes as a "mirror entry", which means IBA is a hazardous waste if it possesses a hazardous property relating to the content of dangerous substances. Monitoring of incinerator ash will be carried out in accordance with the requirements of

Article 53(3) of IED. Classification of IBA for its subsequent use or disposal is controlled by other legislation and so is not duplicated within the permit.

Air pollution control (APC) residues from flue gas treatment are hazardous waste and therefore must be sent for disposal to a landfill site permitted to accept hazardous waste, or to an appropriately permitted facility for hazardous waste treatment. The amount of APC residues is minimised through optimising the performance of the air emissions abatement plant.

In order to ensure that the IBA and APC residues are adequately characterised, a pre-operational condition requires the Operator to provide a written plan for approval detailing the ash sampling protocols. Table S3.5 requires the Operator to carry out an ongoing programme of monitoring.

The Application proposes that the bottom ash from Line 1 (biomass) is not suitable for processing into aggregate. It states that it has the potential to contain higher concentrations of heavy metals, depending on concentrations of metals within the soils where the trees were grown.

The Application proposes that, where possible, bottom ash from Line 2 (SRF) will be transported to a suitable recovery facility, from where it could be re-used in the construction industry as an aggregate. The Applicant is currently investigating suitably licensed facilities for the processing of the bottom ash.

Having considered the information submitted in the Application, we are satisfied that the waste hierarchy referred to in Article 4 of the WFD will be applied to the generation of waste and that any waste generated will be treated in accordance with this Article.

We are satisfied that waste from the Installation that cannot be recovered will be disposed of using a method that minimises any impact on the environment. Standard condition 1.4.1 will ensure that this position is maintained.

5. Minimising the Installation's environmental impact

Regulated activities can present different types of risk to the environment, these include odour, noise and vibration; accidents, fugitive emissions to air and water; as well as point source releases to air, discharges to ground or groundwater, global warming potential and generation of waste. Consideration may also have to be given to the effect of emissions being subsequently deposited onto land (where there are ecological receptors). All these factors are discussed in this and other sections of this document.

For an Installation of this kind, the principal emissions are those to air, although we also consider those to land and water.

The next sections of this document explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the

Installation on human health and the environment and what measures we are requiring to ensure a high level of protection.

5.1 Assessment Methodology

5.1.1 Application of Environment Agency H1 Guidance

A methodology for risk assessment of point source emissions to air, which we use to assess the risk of applications we receive for permits, is set out in our Horizontal Guidance Note H1 and has the following steps:

- Describe emissions and receptors
- Calculate process contributions
- Screen out insignificant emissions that do not warrant further investigation
- Decide if detailed air modelling is needed
- Assess emissions against relevant standards
- Summarise the effects of your emissions

The H1 methodology uses a concept of “process contribution (PC)”, which is the estimated concentration of emitted substances after dispersion into the receiving environmental media at the point where the magnitude of the concentration is greatest. The guidance provides a simple method of calculating PC primarily for screening purposes and for estimating process contributions where environmental consequences are relatively low. It is based on using dispersion factors. These factors assume worst case dispersion conditions with no allowance made for thermal or momentum plume rise and so the process contributions calculated are likely to be an overestimate of the actual maximum concentrations. More accurate calculation of process contributions can be achieved by mathematical dispersion models, which take into account relevant parameters of the release and surrounding conditions, including local meteorology – these techniques are expensive but normally lead to a lower prediction of PC.

5.1.2 Use of Air Dispersion Modelling

For incineration applications, we normally require the Applicant to submit a full air dispersion model as part of their Application. Air dispersion modelling enables the process contribution to be predicted at any environmental receptor that might be impacted by the plant.

Once short-term and long-term PCs have been calculated in this way, they are compared with Environmental Quality Standards (EQS) referred to as “benchmarks” in the H1 Guidance.

Where an EU EQS exists, the relevant standard is the EU EQS. Where an EU EQS does not exist, our guidance sets out a National EQS (also referred to as Environmental Assessment Level - EAL) which has been derived to provide a similar level of protection to Human Health and the Environment as the EU EQS levels. In a very small number of cases, e.g. for emissions of lead, the

National EQS is more stringent than the EU EQS. In such cases, we use the National EQS standard for our assessment.

National EQSs do not have the same legal status as EU EQSs, and there is no explicit requirement to impose stricter conditions than BAT in order to comply with a national EQS. However, national EQSs are a standard for harm and any significant contribution to a breach is likely to be unacceptable.

PCs are considered **Insignificant** if:

- the **long-term** process contribution is less than **1%** of the relevant EQS; and
- the **short-term** process contribution is less than **10%** of the relevant EQS.

The **long term** 1% process contribution insignificance threshold is based on the judgements that:

- It is unlikely that an emission at this level will make a significant contribution to air quality;
- The threshold provides a substantial safety margin to protect health and the environment.

The **short term** 10% process contribution insignificance threshold is based on the judgements that:

- spatial and temporal conditions mean that short term process contributions are transient and limited in comparison with long term process contributions;
- the proposed threshold provides a substantial safety margin to protect health and the environment.

Where an emission is screened out in this way, we would normally consider that the Applicant's proposals for the prevention and control of the emission to be BAT. That is because if the impact of the emission is already insignificant, it follows that any further reduction in this emission will also be insignificant.

However, where an emission cannot be screened out as insignificant, it does not mean it will necessarily be significant.

For those pollutants which do not screen out as insignificant, we determine whether exceedences of the relevant EQS are likely. This is done through detailed audit and review of the Applicant's air dispersion modelling taking background concentrations and modelling uncertainties into account. Where an exceedence of an EU EQS is identified, we may require the Applicant to go beyond what would normally be considered BAT for the Installation or we may refuse the application. Whether or not exceedences are considered likely, the application is subject to the requirement to operate in accordance with BAT.

This is not the end of the risk assessment, because we also take into account local factors (for example, particularly sensitive receptors nearby such as a SSSIs, SACs or SPAs). These additional factors may also lead us to include more stringent conditions than BAT.

If, as a result of reviewing of the risk assessment and taking account of any additional techniques that could be applied to limit emissions, we consider that emissions **would cause significant pollution**, we would refuse the Application.

5.2 Assessment of Impact on Air Quality

The Applicant's assessment of the impact on air quality is set out in the 'Environmental Risk Assessment' and 'Technical Appendix A: Air Quality and Emissions to Air' Sections of the Application.

The assessments were revised in response to a query from our first audit regarding the two stacks being combined as a single point source. The Applicant subsequently remodelled with the two stacks as separate point sources. The assessment comprises:

- An H1 screening assessment of emissions to air from the operation of the incinerator.
- Dispersion modelling of emissions to air from the operation of the incinerator.
- A study of the impact of emissions on nearby sensitive habitat / conservation sites.
- A qualitative assessment of amenity impacts during construction.
- Dispersion modelling of the impact of additional off site road traffic arising from the operation of the incinerator.

Of these the amenity impacts during construction and air quality impacts arising from additional road traffic have not been considered as these are essentially matters for the local planning authority when considering the parallel application for planning permission, and outside the scope of our determination under the Environmental Permitting Regulations.

This section of the decision document deals primarily with the dispersion modelling of emissions to air from the stacks of each incineration line and its impact on local air quality. The impact on conservation sites is considered in section 5.4.

The Applicant has assessed the Installation's potential emissions to air against the relevant air quality standards, and the potential impact upon local conservation and habitat sites and human health. The updated assessments (see above) predict the potential effects on local air quality from the Installation's stack emissions using both the ADMS 5 and AERMOD PRIME dispersion models, which are commonly used computer models for regulatory dispersion modelling. The models used 5 years of meteorological data collected from the weather station at Shoeburyness between 2009 and 2013. The Applicant confirmed that this site was considered most representative following consultation with the Met Office. The Applicant did not find it necessary to consider the impact of the terrain surrounding the site upon

plume dispersion because they claimed that no hill gradients in the study area were greater than 10%.

The air impact assessments and the dispersion modelling upon which they were based, employed the following assumptions:

- They assumed that the ELVs in the Permit would be the maximum permitted by Article 46(2) of the IED.
- Cd and Tl at ½ the aggregate limit
- For metals (former WID group 3), each individual metal is taken as an equal proportion (1/9th) of the total group metal concentration value (Cr (VI) is also considered further in section 5.2.3 of this decision document).

These substances are:

- Oxides of nitrogen (NO_x), expressed as NO₂
 - Total dust
 - Carbon monoxide (CO)
 - Sulphur dioxide (SO₂)
 - Hydrogen chloride (HCl)
 - Hydrogen fluoride (HF)
 - Metals (cadmium, thallium, mercury, antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium)
 - Polychlorinated dibenzo-para-dioxins and polychlorinated dibenzo furans (referred to as dioxins and furans)
 - Gaseous and vaporous organic substances, expressed as Total Organic Carbon (TOC)
- For polycyclic aromatic hydrocarbons (PAH) the PC is based on the BREF Note Concentration Data for <100 MWth biomass incinerators (0.003 mg/m³).
 - They assumed that the Installation operates continuously at the relevant long-term or short-term emission limit values, i.e. the maximum permitted emission rate (except for emissions of Cr (VI) which is considered in section 5.2.3 of this decision document).

We are in agreement with this approach. The assumptions underpinning the model have been checked and are reasonably precautionary.

The background concentrations assumed within the Applicant's assessment have been taken from several sources which include Local Authority monitoring data, National Air Quality Information Archive and various other monitoring networks. This data is summarised in the Application and has been used by the Applicant to establish the background (or existing) air quality against which to measure the potential impact of the Installation. We checked the background concentrations and found them to be reasonably precautionary and valid for the screening assessment.

As well as calculating the peak ground level concentration, the Applicant has modelled the concentration of key pollutants at a number of specified locations within the surrounding area. The maximum process contributions occur in the Dock Road area of Grays which is a residential receptor.

The way in which the Applicant used dispersion models, its selection of input data, use of background data and the assumptions it made have been reviewed by the Environment Agency's modelling specialists to establish the robustness of the Applicant's air impact assessment. The output from the model has then been used to inform further assessment of health impacts and impact on habitats and conservation sites.

Our review of the Applicant's assessments leads us to agree with the Applicant's conclusions. We have also audited the air quality and human health impact assessment and similarly agree that the conclusions drawn in the reports were acceptable.

Our findings from the first audit are documented in report AQMAU_C1105. Our second audit of the revised assessment with the two stacks modelled as separate point sources is documented in report AQMAU_C1134. The revised assessment predicts a general slight increase to short term PCs and slightly lower long term PCs. Our recommendations and conclusions in our first audit apply to the revised assessments.

The Applicant's revised modelling predictions are summarised in the following sections. We used the original modelling predictions for the former WID group 3 metals as these are more conservative than the revised emissions. The revised emissions are based on actual metals data from the Wilton 10 biomass facility.

5.2.1 Assessment of Air Dispersion Modelling Outputs

The Applicant's modelling predictions are summarised in the tables below. The figures shown indicate the predicted peak ground level exposure to pollutants in ambient air. This is indicative of the exposure at the residential receptor in Grays (see above). Whilst we have used the Applicant's modelling predictions in the table below, we have made our own simple verification calculation of the percentage process contribution and predicted environmental concentration. These are the numbers shown in the tables below and so may be very slightly different to those shown in the Application. Any such minor discrepancies do not materially impact on our conclusions.

Assessment of Emissions to Air - non metals

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$
NO₂	40	1	31.90	0.80	2.00	32.70	81.75
	200	2	-	18.20	9.10	-	-
PM₁₀	40	1	-	0.06	0.15	-	-
	50	3	-	0.20	0.40	-	-
PM_{2.5}	25	1	-	0.06	0.30	-	-
SO₂	266	4	-	8.50	3.19	-	-
	350	5	-	6.70	1.91	-	-
	125	6	-	2.10	1.68	-	-
HCl	750	7	-	14.90	2.00	-	-
HF	16	8	2.46	0.20	1.25	2.66	16.63
	160	7	-	1.00	0.63	-	-
CO	10000	9	-	8.00	0.08	-	-
	30000	10	-	8.00	0.03	-	-
TOC	2.25	1	0.454	0.06	2.66	0.514	22.84
PAH	0.00025	1	0.0002	0.00002	8.00	0.00022	88.00

TOC as 1,3 butadiene

PAH as

benzo[a]pyrene

- 1 Annual Mean
- 2 99.79th %ile of 1-hour means
- 3 90.41st %ile of 24-hour means
- 4 99.9th ile of 15-min means
- 5 99.73rd %ile of 1-hour means
- 6 99.18th %ile of 24-hour means
- 7 1-hour average
- 8 Monthly average
Maximum daily running 8-hour
- 9 mean
- 10 1-hour maximum

Assessment of Emissions to Air - metals

Pollutant 4	EQS / EAL		Back-ground	Process Contribution		Predicted Environmental Concentration	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$
Cd	0.005	1	-	0.00001	0.20	-	-
Tl				0.00001		-	
Hg	0.25	1	-	0.0003	0.12	-	-
	7.5	2	-	0.0008	0.01	-	-
Sb	5	1	-	0.0004	0.008	-	-
	150	2	-	0.0079	0.0053	-	-
Pb	0.25	1	-	0.0004	0.16	-	-
Co				0.0004		-	
Cu	10	1	-	0.0004	0.004	-	-
	200	2	-	0.0079	0.004	-	-
Mn	0.15	1	-	0.0004	0.27	-	-
	1500	2	-	0.0079	0.0005	-	-
V	5	1	-	0.0004	0.008	-	-
	1	3	-	0.0079	0.79	-	-
As	0.003	1	0.0013	0.0004	13.33	0.00170	56.70
Cr (II)(III)	5	1	0.-24	0.0004	0.008	-	-
	150	2	-	0.0079	0.0053	-	-
Cr (VI)	0.0002	1	0.00048	0.0004	200.00	0.00088	440.00
Ni	0.02	1	0.0035	0.0004	2.00	0.00390	19.50

1 Annual Mean

2 1-hr Maximum

3 24-hr Maximum

Emissions of individual metals are taken as an equal proportion of their total concentration,

4 (e.g. Sb $0.5 \text{ mgm}^{-3}/9$ and Cd $0.05 \text{ mgm}^{-3}/2$)

(i) Screening out emissions which are insignificant

From the tables above the following emissions can be screened out as insignificant in that the process contribution is < 1% of the long term EQS/EAL and <10% of the short term EAQ/EAL. These are:

- PM₁₀, PM_{2.5}, SO₂, HCl, CO, Cd, Hg, Sb, Pb, Cu, Mn, V, Cr (II) (III).

Therefore, generally, we consider the Applicant's proposals for preventing and minimising the emissions of these substances to be BAT for the Installation subject to the detailed audit referred to below.

(ii) Emissions unlikely to give rise to significant pollution

Also from the tables above the following emissions (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% (taking expected modelling uncertainties into account) of both the long term and short term EQS/EAL

- NO₂, HF, As, Ni, TOC, PAH.

For these emissions, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the Best Available Techniques to prevent and minimise emissions of these substances. This is reported in section 6 of this document.

(iii) Emissions requiring further assessment

Finally from the tables above the following emissions are considered to have the potential to give rise to pollution in that the Predicted Environmental Concentration exceeds 100% of the long term or short term EQS/EAL.

- Cr(VI)

Our further consideration of the risk is detailed in Section 5.2.3 below.

In any case, with respect to this pollutant, we have carefully scrutinised the Applicant's proposals to ensure that they are applying the Best Available Techniques to prevent and minimise emissions of this substance. This is reported in section 6 of this document.

We have also carefully considered whether additional measures are required above what would normally be considered BAT in order to prevent significant pollution. Consideration of additional measures to address the pollution risk from this substance are set out in section 5.2.3.

5.2.2 Consideration of key pollutants

(i) Nitrogen dioxide (NO₂)

The impact on air quality from NO₂ emissions has been assessed against the EU EQS of 40 µg/m³ as a long term annual average and a short term hourly average of 200 µg/m³. The model assumes a 70% NO_x to NO₂ conversion for the long term and 35% for the short term assessment in line with Environment Agency guidance on the use of air dispersion modelling.

The above tables show that the peak long term PC is greater than 1% of the EU EQS and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the EUEQS being exceeded. The peak short term PC is less than 10% of the EU EQS and so can be screened out as insignificant.

(ii) Particulate matter PM₁₀ and PM_{2.5}

The impact on air quality from particulate emissions has been assessed against the EQS for PM₁₀ (particles of 10 microns and smaller) and PM_{2.5} (particles of 2.5 microns and smaller). For PM₁₀, the EU EQS are a long term annual average of 40 µg/m³ and a short term daily average of 50 µg/m³. For PM_{2.5} the EU EQS of 25 µg/m³ as a long-term annual average to be achieved by 2010 as a Target Value and by 2015 as a Limit Value has been used.

The Applicant's predicted impact of the Installation against these EQSs is shown in the tables above. The assessment assumes that **all** particulate emissions are present as PM₁₀ for the PM₁₀ assessment and that **all** particulate emissions are present as PM_{2.5} for the PM_{2.5} assessment.

The above assessment is considered to represent a worst case assessment in that: -

- It assumes that the plant emits particulates continuously at the IED Annex VI limit for total dust, whereas actual emissions from similar plant are normally lower.
- It assumes all particulates emitted are below either 10 microns (PM₁₀) or 2.5 microns (PM_{2.5}), when some are expected to be larger.

We have reviewed the Applicant's particulate matter impact assessment and are satisfied in the robustness of the Applicant's conclusions.

The above assessment shows that the predicted process contribution for emissions of PM₁₀ is below 1% of the long term EQS and below 10% of the short term EQS and so can be considered insignificant. Therefore, generally, we consider the Applicant's proposals for preventing and minimising the emissions of particulates to be BAT for the Installation.

The above assessment also shows that the predicted process contribution for emissions of PM_{2.5} is also below 1% of the Environmental Quality Objective. Therefore the Environment Agency concludes that particulate emissions from the Installation, including emissions of PM₁₀ or PM_{2.5}, will not give rise to significant pollution.

There is currently no emission limit prescribed nor any continuous emissions monitor for particulate matter specifically in the PM₁₀ or PM_{2.5} fraction. Whilst the Environment Agency is confident that current monitoring techniques will capture the fine particle fraction (PM_{2.5}) for inclusion in the measurement of total particulate matter, an improvement condition has been included that will require a full analysis of particle size distribution in the flue gas, and hence determine the ratio of fine to coarse particles. In the light of current knowledge and available data however the Environment Agency is satisfied that the health of the public would not be put at risk by such emissions, as explained in section 5.3.

(iii) Acid gases, SO₂, HCl and HF

There is no long term EAL for SO₂ for the protection of human health. Protection of ecological receptors from SO₂ for which there is a long term EAL is considered in section 5.4.

Emissions of SO₂ can be screened out as insignificant in that the short term process contribution is <10% of each of the three short term EU EQS values.

The above assessment shows that the predicted process contribution for emissions of HCl is below 10% of the EQS and so can be considered insignificant.

From the tables above, emissions of HF cannot be screened out as insignificant if we assume that the monthly EAL is representative of long term EAL. HF has 2 assessment criteria – a 1-hr EAL and a monthly EAL – the process contribution is greater than 1% of the monthly EAL and therefore cannot be screened out as insignificant.

Whilst emissions of HF cannot be screened out as insignificant, the Applicant's modelling shows that the Installation is unlikely to result in a breach of the EAL. The Applicant is required to prevent, minimise and control HF emissions using the best available techniques, this is considered further in Section 6. We are satisfied that HF emissions will not result in significant pollution.

(iv) Emissions to Air of CO, VOCs, PAHs and Dioxins

The above tables show that for CO the peak long term PC is less than 1% of the EAL/EQS and the peak short term PC is less than 10% of the EAL/EQS and so can be screened out as insignificant. Therefore, generally, we consider the Applicant's proposals for preventing and minimising the emissions of this substance to be BAT for the Installation.

The above tables show that for VOC emissions, the peak long term PC is greater than 1% of the EQS and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the EQS being exceeded.

We have used the EQS for 1, 3 butadiene in the above table, the Applicant used benzene for their assessment of the impact from VOCs. Our assessment is based on 1, 3 butadiene having the lowest EQS of organic species likely to be present in VOC (other than PAH, PCBs, dioxins and furans).

The above tables show that for PAH emissions, the peak long term PC is greater than 1% of the EQS and therefore cannot be screened out as insignificant. Even so, from the table above, the emission is not expected to result in the EQS being exceeded.

The Applicant has also used the EQS for benzo[a]pyrene (BaP) for their assessment of the impact of PAH. We agree that the use of the BaP EQS is sufficiently precautionary.

There is no EAL for dioxins and furans as the principal exposure route for these substances is by ingestion and the risk to human health is through the accumulation of these substances in the body over an extended period of time. This issue is considered in more detail in section 5.3.

Whilst all emissions cannot be screened out as insignificant, the Applicant's modelling shows that the Installation is unlikely to result in a breach of the EQS/EAL. The Applicant is required to prevent, minimise and control VOC and PAH emissions using the best available techniques, this is considered further in Section 6. We are satisfied that VOC and PAH emissions will not result in significant pollution.

5.2.3 Assessment of Emission of Metals

The Applicant has assessed the impact of metal emissions to air, as previously described.

Annex VI of IED sets three limits for metal emissions:

- An emission limit value of 0.05 mg/m³ for mercury and its compounds (formerly WID group 1 metal).
- An aggregate emission limit value of 0.05 mg/m³ for cadmium and thallium and their compounds (formerly WID group 2 metals).
- An aggregate emission limit of 0.5 mg/m³ for antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium and their compounds (formerly WID group 3 metals).

In addition the UK is a Party to the Heavy Metals Protocol within the framework of the UN-ECE Convention on long-range trans-boundary air pollution. Compliance with the IED Annex VI emission limits for metals along with the Application of BAT also ensures that these requirements are met.

Where Annex VI of IED sets an aggregate limit, the Applicant's assessment assumes that for cadmium and thallium each metal is emitted at half of the aggregate limit value and for the other metals that each metal is emitted as the proportion of metals in its group (i.e. one ninth of the limit for each of the group 3 metals). Historical data for Municipal Waste Incinerators indicates that 1/9th of the limit is an over estimate of actual emissions, and so we are satisfied that the Applicant's proposal is reasonable in this context. This data is presented in Section 5.2 above.

The assessment then goes on to consider the impact from Cr(VI) using actual analytical data collected from Municipal Waste Incinerators presented in 'Guidance to Applicants on Impact Assessment for Group 3 Metals Stack Releases – V.3 September 2012.

In section 5.2.1 above, the following emissions of metals were screened out as insignificant:

- Cd, Hg, Sb, Pb, Cu, Mn, V, Cr (II) (III).

Also in section 5.2.1, the following emissions of metals whilst not screened out as insignificant were assessed as being unlikely to give rise to significant pollution:

- As, Ni.

An improvement condition is included requiring an assessment of the impact using actual emissions monitoring data.

This left emissions of Cr (VI) requiring further assessment. This means that for emissions of Cr (VI), the assessment predicts that an exceedence of the relevant EAL could occur. For all other metals, the Applicant has concluded that exceedences of the EAL for all metals are not likely to occur.

The 2009 report of the Expert Panel on Air Quality Standards (EPAQS) – “Guidelines for Metal and Metalloids in Ambient Air for the Protection of Human Health”, sets non statutory ambient air quality guidelines for Arsenic, Nickel and Chromium (VI). These guidelines have been incorporated as EALs in the revised H1 Guidance issued by the Agency in 2010.

Chromium (VI) is not specifically referenced in Annex VI of IED, which includes only total Chromium as one of the nine Group 3 metals, the impact of which has been assessed above. The EPAQS guidelines refer only to that portion of the metal emissions contained within PM₁₀ in ambient air. The guideline for Chromium (VI) is 0.2 ng/m³ (0.0002 mg/m³).

- Measurement of Chromium (VI) at the levels anticipated at the stack emission points is expected to be difficult, with the likely levels being below the level of detection by the most advanced methods. We have considered the concentration of total chromium and chromium (VI) in the APC residues collected upstream of the emission point for existing Municipal Waste incinerators and have assumed these to be similar to the particulate matter released from the emission point. This data shows that the mean Cr (VI) emission concentration (based on the bag dust ratio) is $3.5 * 10^{-5}$ mg/m³ (max $1.3 * 10^{-4}$).

Based on this data, we consider it remains a conservative assumption for the Applicant to consider that the Cr (VI) emission concentration will be 0.0004 mg/m³.

There is little data available on the background levels of Cr (VI); so we have assumed this to be 20% of the total Cr background level, 20% is the typical value of Cr (VI) in total Cr reported in the environment in the EPAQS Guidelines.

The Applicant has used the above data to model the predicted Cr (VI) impact. The PC is predicted as 0.47% of the EAL, which is less than the screening threshold of 1%. In this instance consideration of background levels is not necessary.

In the revised assessment the PC is predicted as 0.01% of the EAL. This prediction is based on data from the Wilton 10 Biomass facility.

This assessment shows that emissions of Chromium (VI) are likely to be insignificant.

We agree with the Applicant's conclusions.

5.2.4 Consideration of Local Factors


(i) Impact on Air Quality Management Areas (AQMAS)

Thurrock Council has declared a number of AQMAS for nitrogen dioxide and particulate matter located to the north west of the facility. They cover small areas of localised pollution or are along a length of road.

Dartford Borough Council (south of the River Thames) has also declared four AQMAS with respect to nitrogen dioxide encompassing roads and Dartford town.

Gravesham Borough Council and Sevenoaks District Council have also declared a number of AQMAS.

These closest to the facility are located as follows:



From the Applicant's revised model, the process contribution at all points within each of the AQMAs is predicted to be below 1% of the EU EQS (nitrogen dioxide and particulate) and can therefore be considered insignificant. The only exception to this is annual mean PC of nitrogen dioxide ($0.45\mu\text{g}/\text{m}^3$) within the Northfleet Industrial Area at 1.1% of the EQS of $40\mu\text{g}/\text{m}^3$. They state that the area of maximum impact lies on the northern edge of the AQMA over the Thames.

The Applicant's maximum modelling predictions for nitrogen dioxide in the AQMAs are summarised in the table below. The figures shown indicate the maximum predicted peak ground level impact on nitrogen dioxide concentrations in ambient air within an AQMA.

Local Authority	PC of Annual Mean NO ₂	PC as % EQS ($40\mu\text{g}/\text{m}^3$)
Thurrock Council (Thurrock AQMA)	0.27	0.68
Dartford Borough Council (AQMA No 2)	0.19	0.48
Gravesham Borough Council (Northfleet Industrial Area AQMA)	0.45	1.1
Sevenoaks District Council (AQMA No 2, M25)	0.04	0.1

The Applicant is required to prevent, minimise and control emissions using the best available techniques; this is considered further in Section 6.

5.3 Human health risk assessment

5.3.1 Our role in preventing harm to human health

The Environment Agency has a statutory role to protect the environment and human health from all processes and activities it regulates. We assessed the effects on human health for this application in the following ways:

i) **Applying Statutory Controls**

The plant will be regulated under EPR. These regulations include the requirements of relevant EU Directives, notably, the industrial emissions directive (IED), the waste framework directive (WFD), and ambient air directive (AAD).

The main conditions in an EfW permit are based on the requirements of the IED. Specific conditions have been introduced to specifically ensure compliance with the requirements of Chapter IV. The aim of the IED is to prevent or, where that is not practicable, to reduce emissions to air, water and land and prevent the generation of waste, in order to achieve a high level of protection of the environment taken as a whole. IED achieves this aim by setting operational conditions, technical requirements and emission limit

values to meet the requirements set out in Articles 11 and 18 of the IED. These requirements include the application of BAT, which may in some circumstances dictate tighter emission limits and controls than those set out in Chapter IV of IED on waste incineration and co-incineration plants. The assessment of BAT for this Installation is detailed in section 6 of this document.

ii) Environmental Impact Assessment

Industrial activities can give rise to odour, noise and vibration, accidents, fugitive emissions to air and water, releases to air (including the impact on Photochemical Ozone Creation Potential (POCP)), discharges to ground or groundwater, global warming potential and generation of waste. For an Installation of this kind, the principal environmental effects are through emissions to air, although we also consider all of the other impacts listed. Section 5.1 and 5.2 above explain how we have approached the critical issue of assessing the likely impact of the emissions to air from the Installation on human health and the environment and any measures we are requiring to ensure a high level of protection.

iii) Expert Scientific Opinion

We take account of the views of national and international expert bodies. Following is a summary of some of the publications which we have considered (in no particular order).

An independent review of evidence on the health effects of municipal waste incinerators was published by **DEFRA** in 2004. It concluded that there was no convincing link between the emissions from MSW incinerators and adverse effects on public health in terms of cancer, respiratory disease or birth defects. On air quality effects, the report concluded "Waste incinerators contribute to local air pollution. This contribution, however, is usually a small proportion of existing background levels which is not detectable through environmental monitoring (for example, by comparing upwind and downwind levels of airborne pollutants or substances deposited to land). In some cases, waste incinerator facilities may make a more detectable contribution to air pollution. Because current MSW incinerators are located predominantly in urban areas, effects on air quality are likely to be so small as to be undetectable in practice."

HPA (now PHE) 2009 states that "The Health Protection Agency has reviewed research undertaken to examine the suggested links between emissions from municipal waste incinerators and effects on health. While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable". Revision to statement in 2011.....

Policy Advice from Government also points out that the minimal risk from modern incinerators. Paragraph 22 (Chapter 5) of WS2007 says that

“research carried out to date has revealed no credible evidence of adverse health outcomes for those living near incinerators.” It points out that “the relevant health effects, mainly cancers, have long incubation times. But the research that is available shows an absence of symptoms relating to exposures twenty or more years ago when emissions from incinerators were much greater than is now the case.” **Paragraph 30 of PPS10** explains that “modern, appropriately located, well run and well regulated waste management facilities should pose little risk to public health.”

The **Committee on Carcinogenicity of Chemicals in Food, Consumer Products and the Environment (CoC)** issued a statement in 2000 which said that “any potential risk of cancer due to residency (for periods in excess of 10 years) near to municipal solid waste incinerators was exceedingly low and probably not measurable by the most modern epidemiological techniques.” In 2009, CoC considered six further relevant epidemiological papers that had been published since the 2000 statement, and concluded that “there is no need to change the advice given in the previous statement in 2000 but that the situation should be kept under review”.

Republic of Ireland Health Research Board report stated that “It is hard to separate the influences of other sources of pollutants, and other causes of cancer and, as a result, the evidence for a link between cancer and proximity to an incinerator is not conclusive”.

The **Food Safety Authority of Ireland (FSAI) (2003)** investigated possible implications on health associated with food contamination from waste incineration and concluded: “In relation to the possible impact of introduction of waste incineration in Ireland, as part of a national waste management strategy, on this currently largely satisfactory situation, the FSAI considers that such incineration facilities, if properly managed, will not contribute to dioxin levels in the food supply to any significant extent. The risks to health and sustainable development presented by the continued dependency on landfill as a method of waste disposal far outweigh any possible effects on food safety and quality.”

Health Protection Scotland (2009) considered scientific studies on health effects associated with the incineration of waste particularly those published after the Defra review discussed earlier. The main conclusions of this report were: (a) For waste incineration as a whole topic, the body of evidence for an association with (non-occupational) adverse health effects is both inconsistent and inconclusive. However, more recent work suggests, more strongly, that there may have been an association between emissions (particularly dioxins) in the past from industrial, clinical and municipal waste incinerators and some forms of cancer, before more stringent regulatory requirements were implemented. (b) For individual waste streams, the evidence for an association with (non-occupational) adverse health effects is inconclusive. (c) The magnitude of any past health effects on residential populations living near incinerators that did occur is likely to have been small. (d) Levels of airborne emissions from individual incinerators should be lower now than in the past, due to stricter legislative controls and improved technology. Hence, any risk to

the health of a local population living near an incinerator, associated with its emissions, should also now be lower.”

The **US National Research Council Committee on Health Effects of Waste Incineration (NRC) (NRC 2000)** reviewed evidence as part of a wide ranging report. The Committee view of the published evidence was summarised in a key conclusion: “Few epidemiological studies have attempted to assess whether adverse health effects have actually occurred near individual incinerators, and most of them have been unable to detect any effects. The studies of which the committee is aware that did report finding health effects had shortcomings and failed to provide convincing evidence. That result is not surprising given the small populations typically available for study and the fact that such effects, if any, might occur only infrequently or take many years to appear. Also, factors such as emissions from other pollution sources and variations in human activity patterns often decrease the likelihood of determining a relationship between small contributions of pollutants from incinerators and observed health effects. Lack of evidence of such relationships might mean that adverse health effects did not occur, but it could mean that such relationships might not be detectable using available methods and sources.”

The **British Society for Ecological Medicine (BSEM) published a report in 2005** on the health effects associated with incineration and concluded that “Large studies have shown higher rates of adult and childhood cancer and also birth defects around municipal waste incinerators: the results are consistent with the associations being causal. A number of smaller epidemiological studies support this interpretation and suggest that the range of illnesses produced by incinerators may be much wider. Incinerator emissions are a major source of fine particulates, of toxic metals and of more than 200 organic chemicals, including known carcinogens, mutagens, and hormone disrupters. Emissions also contain other unidentified compounds whose potential for harm is as yet unknown, as was once the case with dioxins. Abatement equipment in modern incinerators merely transfers the toxic load, notably that of dioxins and heavy metals, from airborne emissions to the fly ash. This fly ash is light, readily windborne and mostly of low particle size. It represents a considerable and poorly understood health hazard.”

The BSEM report was reviewed by the HPA and they concluded that “Having considered the BSEM report the HPA maintains its position that contemporary and effectively managed and regulated waste incineration processes contribute little to the concentrations of monitored pollutants in ambient air and that the emissions from such plants have little effect on health.” The BSEM report was also commented on by the consultants who produced the Defra 2004 report referred to above. They said that “It fails to consider the significance of incineration as a source of the substances of concern. It does not consider the possible significance of the dose of pollutants that could result from incinerators. It does not fairly consider the adverse effects that could be associated with alternatives to incineration. It relies on inaccurate and outdated material. In view of these shortcomings, the report’s conclusions with regard to the health effects of incineration are not reliable.”

A **Greenpeace** review on incineration and human health concluded that a broad range of health effects have been associated with living near to incinerators as well as with working at these installations. Such effects include cancer (among both children and adults), adverse impacts on the respiratory system, heart disease, immune system effects, increased allergies and congenital abnormalities. Some studies, particularly those on cancer, relate to old rather than modern incinerators. However, modern incinerators operating in the last few years have also been associated with adverse health effects.”

The Health Protection Scotland report referred to above says that “the authors of the Greenpeace review do not explain the basis for their conclusion that there is an association between incineration and adverse effects in terms of criteria used to assess the strength of evidence. The weighting factors used to derive the assessment are not detailed. The objectivity of the conclusion cannot therefore be easily tested.”

From this published body of scientific opinion, we take the view stated by the HPA that “While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable”. We therefore ensure that permits contain conditions which require the installation to be well-run and regulate the installation to ensure compliance with such permit conditions.

iv) Health Risk Models

Comparing the results of air dispersion modelling as part of the H1 Environmental Impact assessment against European and national air quality standards effectively makes a health risk assessment for those pollutants for which a standard has been derived. These air quality standards have been developed primarily in order to protect human health via known intake mechanisms, such as inhalation and ingestion. Some pollutants, such as dioxins, furans and dioxin like PCB’s, have human health impacts at lower ingestion levels than lend themselves to setting an air quality standard to control against. For these pollutants, a different human health risk model is required which better reflects the level of dioxin intake.

Models are available to predict the dioxin, furan and dioxin like PCB’s intake for comparison with the Tolerable Daily Intake (TDI) recommended by the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment, known as COT. These include HHRAP and the HMIP model.

HHRAP has been developed by the US EPA to calculate the human body intake of a range of carcinogenic pollutants and to determine the mathematic quantitative risk in probabilistic terms. In the UK, in common with other European Countries, we consider a threshold dose below which the likelihood of an adverse effect is regarded as being very low or effectively zero. The HMIP model uses a similar approach to the HHRAP model, but does not

attempt to predict probabilistic risk. Either model can however be used to make comparisons with the TDI.

The TDI is the amount of a substance that can be ingested daily over a lifetime without appreciable health risk. It is expressed in relation to bodyweight in order to allow for different body size, such as for children of different ages. In the UK, the COT has set a TDI for dioxins, furans and dioxin like PCB's of 2 picograms I-TEQ/Kg-body weight/day (N.B. a picogram is a million millionths (10^{-12}) of a gram).

In addition to an assessment of risk from dioxins, furans and dioxin like PCB's, the HHRAP model enables a risk assessment from human intake of a range of heavy metals. The HMIP report does not consider metals and PCB's. In principle, the respective EQS for these metals are protective of human health. It is not therefore necessary to model the human body intake.

COMEAP developed a methodology based on the results of time series epidemiological studies which allows calculation of the public health impact of exposure to the classical air pollutants (NO_2 , SO_2 and particulates) in terms of the numbers of "deaths brought forward" and the "number of hospital admissions for respiratory disease brought forward or additional". COMEAP has issued a statement expressing some reservations about the applicability of applying its methodology to small affected areas. Those concerns generally relate to the fact that the exposure-response coefficients used in the COMEAP report derive from studies of whole urban populations where the air pollution climate may differ from that around a new industrial installation. COMEAP identified a number of factors and assumptions that would contribute to the uncertainty of the estimates. These were summarised in the Defra review as below:

- Assumption that the spatial distribution of the air pollutants considered is the same in the area under study as in those areas, usually cities or large towns, in which the studies which generated the coefficients were undertaken.
- Assumption that the temporal pattern of pollutant concentrations in the area under study is similar to that in the areas in which the studies which generated the coefficients were undertaken (i.e. urban areas).
- It should be recognised that a difference in the pattern of socio-economic conditions between the areas to be studied and the reference areas could lead to inaccuracy in the predicted level of effects.
- In the same way, a difference in the pattern of personal exposures between the areas to be studied and the reference areas will affect the accuracy of the predictions of effects.

The use of the COMEAP methodology is not generally recommended for modelling the human health impacts of individual Installations. However it may have limited applicability where emissions of NO_x , SO_2 and particulates cannot be screened out as insignificant in an H1 Environmental Impact assessment, there are high ambient background levels of these pollutants and we are advised that its use was appropriate by our public health consultees.

Our recommended approach is therefore the use of the H1 assessment methodology comparison for most pollutants (including metals) and dioxin intake model using the HHRAP model as described above for dioxins, furans and dioxin like PCB's. Where an alternative approach is adopted, we check the predictions ourselves.

v) Consultations

As part of our normal procedures for the determination of a permit application, we would consult PHE and FSA; we also consulted with the director of public health at Thurrock Council. We also consult the local communities who may raise health related issues. All issues raised by these consultations are considered in determining the application as described in Annex 4 of this document.

5.3.2 Assessment of Intake of Dioxins and Furans

For dioxins and furans, the principal exposure route is through ingestion, usually through the food chain, and the main risk to health is through accumulation in the body over a period of time.

The human health risk assessment calculates the dose of dioxins and furans that would be received by local receptors if all their food and water were sourced from the locality where the deposition of dioxins and furans is predicted to be the highest. This is then assessed against the Tolerable Daily Intake (TDI) levels established by the COT of 2 picograms I-TEQ / Kg bodyweight/ day.

The results of the Applicant's revised assessment of dioxin intake are detailed in the table below. (worst – case results for each category are shown). The results show that the predicted daily intake of dioxins at all receptors, resulting from emissions from the proposed facility, are significantly below the recommended TDI levels. The contribution from the facility at the worst case farmer receptor was 1.4% of the COT TDI with that for the worst case resident being only 0.4% of the COT TDI.

Receptor	adult	child
Farmer north east A	0.018	0.027
Resident Grays 1	0.0024	0.0076

Calculated maximum daily intake of dioxins by local receptors resulting from the operation of the proposed facility (I-TEQ/ kg-BW/day)

Our check calculations for HHRA modelling predict a contribution that is below the values predicted by the Applicant and less than 1% for both residential and farmer receptors. Some Applicant's use assumptions that are too conservative based on old deposition data.

The FSA has reported that dietary studies have shown that estimated total dietary intakes of dioxins and dioxin-like PCBs from all sources by all age

groups fell by around 50% between 1997 and 2001, and are expected to continue to fall. In 2001, the average daily intake by adults in the UK from diet was 0.9 pg WHO-TEQ/kg bodyweight. The additional daily intake predicted by the modelling as shown in the table above is substantially below this figure.

In 2010, FSA studied the levels of chlorinated, brominated and mixed (chlorinated-brominated) dioxins and dioxin-like PCBs in fish, shellfish, meat and eggs consumed in UK. It asked COT to consider the results and to advise on whether the measured levels of these PXDDs, PXDFs and PXBs indicated a health concern ('X' means a halogen). COT issued a statement in December 2010 and concluded that "The major contribution to the total dioxin toxic activity in the foods measured came from chlorinated compounds. Brominated compounds made a much smaller contribution, and mixed halogenated compounds contributed even less (1% or less of TDI). Measured levels of PXDDs, PXDFs and dioxin-like PXBs do not indicate a health concern". COT recognised the lack of quantified TEFs for these compounds but said that "even if the TEFs for PXDDs, PXDFs and dioxin-like PXBs were up to four fold higher than assumed, their contribution to the total TEQ in the diet would still be small. Thus, further research on PXDDs, PXDFs and dioxin-like PXBs is not considered a priority."

In the light of this statement, we assess the impact of chlorinated compounds as representing the impact of all chlorinated, brominated and mixed dioxins / furans and dioxin like PCBs.

5.3.3 Particulates smaller than 2.5 microns

The Operator will be required to monitor particulate emissions using the method set out in Table S3.1 of Schedule 3 of the Permit. This method requires that the filter efficiency must be at least 99.5 % on a test aerosol with a mean particle diameter of 0.3 µm, at the maximum flow rate anticipated. The filter efficiency for larger particles will be at least as high as this. This means that particulate monitoring data effectively captures everything above 0.3 µm and much of what is smaller. It is not expected that particles smaller than 0.3 µm will contribute significantly to the mass release rate / concentration of particulates because of their very small mass, even if present. This means that emissions monitoring data can be relied upon to measure the true mass emission rate of particulates.

Nano-particles are considered to refer to those particulates less than 0.1 µm in diameter (PM_{0.1}). Questions are often raised about the effect of nano-particles on human health, in particular on children's health, because of their high surface to volume ratio, making them more reactive, and their very small size, giving them the potential to penetrate cell walls of living organisms. The small size also means there will be a larger number of small particles for a given mass concentration. However the HPA statement (referenced below) says that due to the small effects of incinerators on local concentration of particles, it is highly unlikely that there will be detectable effects of any particular incinerator on local infant mortality.

The HPA (now PHE) addresses the issue of the health effects of particulates in their September 2009 statement 'The Impact on Health of Emissions to Air from Municipal Incinerators'. It refers to the coefficients linking PM₁₀ and PM_{2.5} with effects on health derived by COMEAP and goes on to say that if these coefficients are applied to small increases in concentrations produced, locally, by incinerators; the estimated effects on health are likely to be small. The HPA notes that the coefficients that allow the use of number concentrations in impact calculations have not yet been defined because the national experts have not judged that the evidence is sufficient to do so. This is an area being kept under review by COMEAP.

In December 2010, COMEAP published a report on The Mortality Effects of Long-Term Exposure to Particulate Air Pollution in the United Kingdom. It says that "a policy which aims to reduce the annual average concentration of PM_{2.5} by 1 µg/m³ would result in an increase in life expectancy of 20 days for people born in 2008." However, "The Committee stresses the need for careful interpretation of these metrics to avoid incorrect inferences being drawn – they are valid representations of population aggregate or average effects, but they can be misleading when interpreted as reflecting the experience of individuals."

The HPA also point out that in 2007 incinerators contributed 0.02% to ambient ground level PM₁₀ levels compared with 18% for road traffic and 22% for industry in general. The HPA note that in a sample collected in a day at a typical urban area the proportion of PM_{0.1} is around 5-10% of PM₁₀. It goes on to say that PM₁₀ includes and exceeds PM_{2.5} which in turn includes and exceeds PM_{0.1}.

This is consistent with the assessment of this application which shows emissions of PM₁₀ to air to be insignificant.

We take the view, based on the foregoing evidence, that techniques which control the release of particulates to levels which will not cause harm to human health will also control the release of fine particulate matter to a level which will not cause harm to human health.

5.3.4 Assessment of Health Effects from the Installation

We have assessed the health effects from the operation of this Installation in relation to the above (sections 5.3.1 to 5.3.3). We have applied the relevant requirements of the national and European legislation in imposing the permit conditions. We are satisfied that compliance with these conditions will ensure protection of the environment and human health.

Taking into account all of the expert opinion available, we agree with the conclusion reached by the HPA (now PHE) that "While it is not possible to rule out adverse health effects from modern, well regulated municipal waste incinerators with complete certainty, any potential damage to the health of those living close-by is likely to be very small, if detectable."

In carrying out air dispersion modelling as part of the H1 Environmental Impact assessment and comparing the predicted environmental concentrations with European and national air quality standards, the Applicant has effectively made a health risk assessment for many pollutants. These air quality standards have been developed primarily in order to protect human health.

The Applicant's assessment of the impact from PM₁₀, PM_{2.5}, SO₂, HCl, CO, Cd, Hg, Sb, Pb, Cu, Mn, V, Cr(II)(III) and Cr(VI)(refer to Section 5.2.3) have all indicated that the Installation emissions screen out as insignificant; where the impact of emissions of NO₂, HF, As, Ni, TOC and PAH have not been screened out as insignificant, the assessment still shows that the predicted environmental concentrations are well within air quality standards or environmental action levels.

The Environment Agency has reviewed the methodology employed by the Applicant to carry out the health impact assessment and recommend that the conclusions and predictions can be used for permit determination.

Overall, taking into account the conservative nature of the impact assessment (i.e. that it is based upon an individual exposed for a life-time to the effects of the highest predicted airborne concentrations and consuming mostly locally grown food), it was concluded that the operation of the proposed facility will not pose a significant carcinogenic or non-carcinogenic risk to human health. PHE and the Director of Public Health at Thurrock Council were consulted on the Application and concluded that they had no significant concerns regarding the risk to the health of humans from the Installation. The Food Standards Agency was also consulted during the permit determination process. Details of the responses provided by PHE and Director of Public Health to the consultation on this Application can be found in Annex 4.

The Environment Agency is therefore satisfied that the Applicant's conclusions presented above are soundly based and we conclude that the potential emissions of pollutants including dioxins, furans and metals from the proposed facility are unlikely to have an impact upon human health.


5.4 Impact on Habitats sites, SSSIs and non-statutory conservation sites

5.4.1 Sites Considered

Habitats

The following Habitats (i.e. Special Areas of Conservation (SAC), Special Protection Areas (SPA) and Ramsar) sites are located within 10km of the Installation:


- Thames Estuary & Marshes SPA/Ramsar



SSSIs

The following Sites of Special Scientific Interest are located within 2km of the Installation:

- Globe Pit
- Hangman's Wood & Deneholes
- Grays Thurrock Chalk Pit



Non statutory

The following non-statutory local wildlife and conservation sites are located within 2km of the Installation:

- Little Thurrock Reedbeds
- Grays Pit Extensions

5.4.2 Habitats Assessment

The Applicant's Habitats assessment was reviewed by the Environment Agency's technical specialists for modelling, air quality, conservation and ecology technical services, who agreed that the Applicant's conclusions can be used for permit determination.

We also completed an Appendix 11 Habitats Assessment for the SPA/Ramsar which was sent to Natural England for information only, refer to Section 7.3.1. We did not amend the Appendix 11 with the revised predictions as our conclusions were unchanged.

The Applicant's revised modelling predictions are summarised in the Tables below:

**Critical Level Contributions at the Thames Estuary & Marshes-
SPA/Ramsar**

Site Name	Pollutant	Critical Level (CL)		Back-ground	Process Contribution		Predicted Environmental Concentration	
		$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	% of CL	$\mu\text{g}/\text{m}^3$	% of CL
SPA/Ramsar	NO ₂	30	1	-	0.14	0.47	-	-
SPA/Ramsar	NO ₂	75	2	-	1.82	2.42	-	-
SPA/Ramsar	SO ₂	20	3	-	0.03	0.15	-	-
SPA/Ramsar	NH ₃	1	4	-	0.007	0.70	-	-
SPA/Ramsar	NH ₃	3	5	-	0.007	0.23	-	-
SPA/Ramsar	HF	5	2	-	0.01	0.20	-	-
SPA/Ramsar	HF	0.5	6	-	0.01	2.00	-	-

- 1 Annual mean
- 2 Daily mean
- 3 Annual mean (higher plants)
- 4 Annual mean for sensitive lichen communities & bryophytes
- 5 Annual mean (higher plants)
- 6 Weekly mean

The impact at the Thames Estuary & Marshes is screened out as being insignificant. We have assumed that the HF weekly mean CL is more representative of a short term than a long term average.

Max Predicted Acid & Nitrogen Deposition at the Thames Estuary & Marshes-SPA/Ramsar

Site Name	Deposition	Critical Load (CLo)	Back-ground	Process Contribution		Predicted Environmental Concentration	
		*	*	*	% of CLo	*	% of CLo
SPA/Ramsar	Acid	0.35 **(1.389)	2.13	0.013	3.71 **(0.94)	2.143	612
SPA/Ramsar	Nitrogen	20	-	0.056	0.28	-	-
SPA/Ramsar	Nitrogen	30	-	0.056	0.19	-	-

* Acid deposition units: $k_{eq}/ha/yr$ Nitrogen deposition units: $kgN/ha/yr$

The impact at the Thames Estuary & Marshes is screened out as being insignificant for nitrogen deposition, with acid deposition being slightly above the 1% insignificant criteria.

** Based on the Applicant's critical load of 0.35 $k_{eq}/ha/yr$ for acid deposition, the PC for Thames Estuary & Marshes SAC & Ramsar is 3.71% of the critical load, which is in exceedence of the 1% insignificance criteria. However, the Applicant identified the existing background level to be in breach of the critical load and thus "the contribution from the proposed plant is small in comparison to the background." We have established that the correct critical load for the site is 1.389 $k_{eq}/ha/yr$ (some four times higher than the value used by the applicant). We have carried out sensitivity to this using an updated critical load.

We have compared our predicted acid deposition to the corrected critical loads extracted from Air Pollution Information System (APIS). Although we do not agree with absolute numerical predictions, any differences we have observed agrees with the Applicant's conclusions that the PC will be greater than 1% at the Thames Estuary & Marshes (SPA & Ramsar). Compared to the corrected critical load, the PC is likely to be little over 1% rather than the 3.71% predicted by the Applicant.

The process contribution from the Installation is acceptable based on the corrected critical load and taking expected modelling uncertainties and conservative assumptions into account. We can conclude that there will be no likely significant effect.

We completed an Appendix 11 assessment which we sent to Natural England for information purposes as detailed in Section 7.3.

5.4.3 SSSI Assessment

The Applicant's assessment of SSSIs was reviewed by the Environment Agency's technical specialists for modelling, air quality, conservation and ecology technical services, who agreed that the Applicant's conclusions can be used for permit determination.

The Application confirmed that the Globe Pit SSSI is designated on the basis of geological and archaeological importance and as such is not considered relevant to the assessment.

We also completed a CROW, Appendix 4 form for the SSSIs which was sent to Natural England for consultation, refer to Section 7.2.4. Natural England agreed with our conclusions.

We did not amend the Appendix 4 with the revised predictions as our conclusions were unchanged.

The Applicant's revised modelling predictions are summarised in the Tables below:

Critical Level Contributions
Hangman's Wood & Deneholes and Grays Thurrock Chalk Pit-SSSIs

Site Name	Pollutant	Critical Level (CL)		Back-ground Conc µg/m ³	Process Contribution		Predicted Environmental Concentration	
		µg/m ³			µg/m ³	% of CL	µg/m ³	% of CL
Hangman & Deneholes	NO ₂	30	1	36 *(23.68)	0.57	1.90**	36.57 *(24.25)	122 *(80.83)
Chalk Pit	NO ₂	30	1	-	0.24	0.80	-	-
Hangman & Deneholes	NO ₂	75	2	-	4.99	6.65	-	-
Chalk Pit	NO ₂	75	2	-	5.71	7.61	-	-
Hangman & Deneholes	SO ₂	20	3	-	0.14	0.70	-	-
Chalk Pit	SO ₂	20	3	-	0.06	0.30	-	-
Hangman & Deneholes	NH ₃	1	4	1.6	0.028	2.80**	1.628	163
Hangman & Deneholes	NH ₃	3	5	-	0.028	0.93	-	-
Chalk Pit	NH ₃	1	4	1.6	0.012	1.20**	1.612	161
Chalk Pit	NH ₃	3	5	-	0.012	0.40	-	-
Hangman & Deneholes	HF	5	2	-	0.02	0.40	-	-
Chalk Pit	HF	5	2	-	0.03	0.60	-	-
Hangman & Deneholes	HF	0.5	6	-	0.02	4.00	-	-
Chalk Pit	HF	0.5	6	-	0.03	6.00	-	-

- 1 Annual mean
- 2 Daily mean
- 3 Annual mean (higher plants)
- 4 Annual mean for sensitive lichen communities & bryophytes
- 5 Annual mean (higher plants)
- 6 Weekly mean

The impacts screen out as being insignificant, with the exception of NO₂ at Hangman's Wood & Deneholes and NH₃ at both SSSIs when the lower critical level is applied:

Annual mean NO₂ at Hangman's Wood & Deneholes

*The background data from APIS used by the applicant dates back to 2007-2008. According to latest APIS data, the background level recorded in November 2013 for NO_x is 23.68 µg/m³. The PC + Background (PEC) is below the relevant CL of 30ug/m³ for the site (broad vegetation).

It is unlikely that the permission will lead to a breach of any NO₂ critical level for the protection of vegetation at this SSSI.

**We carried out our own check modelling and we agree that the PCs are likely to be insignificant compared to critical levels for all pollutants considered with the exception of Hangman's Wood & Dene Holes SSSI. For this site we agree that the PC is likely to exceed 1% of the NO_x critical level.

The process contribution of NO₂ from the Installation is acceptable taking expected modelling uncertainties, headroom at Hangman and conservative assumptions into account.

NH₃ at both SSSIs applying the lower critical level

The lower critical level only applies where lichens and bryophytes form a key part of the ecosystem integrity. The citations do not indicate that this is the case so using the higher critical level of 3 µg/m³ for higher plants is most likely to be applicable in this case. On this basis the impacts screen out as being insignificant.

Max Predicted Acid & Nitrogen Deposition
Hangman's Wood & Deneholes and Grays Thurrock Chalk Pit-SSSIs

Site Name	Deposition	Critical Load (CLO)	Back-ground	Process Contribution		Predicted Environmental Concentration	
		*	*	*	% of CLo	*	% of CLo
Hangman & Deneholes	Acid	1.41	3.48	0.052	3.69	3.53	250
Chalk Pit	Acid	4.00	-	0.022	0.55	-	-
Hangman & Deneholes	Nitrogen	10.00	36.40	0.229	2.29	36.63	366
Chalk Pit	Nitrogen	10.00	-	0.096	0.96	-	-

* Acid deposition units: $k_{eq}/ha/yr$ Nitrogen deposition units: $kgN/ha/yr$

Hangman's Wood & Deneholes

Acid and nitrogen deposition exceed the 1% insignificance criteria.

Acid deposition is **3.69%** of the critical load. This is relatively small when compared with the background which is **247%** of the critical load.

Nitrogen deposition is **2.29%** of the critical load. This is relatively small when compared with the background which is **364%** of the critical load.

The process contribution from both acid and nitrogen deposition from the Installation is acceptable taking expected modelling uncertainties and conservative assumptions into account.

We can conclude that the proposed permission is not likely to damage the interest features of the sites and Natural England agreed with our conclusions.

5.4.4 Assessment of Non-Statutory Sites

The Applicant's assessment of non-statutory sites was reviewed by the Environment Agency's technical specialists for modelling, air quality, conservation and ecology technical services, who agreed that the Applicant's conclusions can be used for permit determination.

The Applicant's revised modelling predictions are summarised in the Tables below:

Critical Level Contributions
Little Thurrock Reedbeds and Grays Pit Extensions-Local Wildlife Sites

Site Name	Pollutant	Critical Level (CL)		Process Contribution	
		$\mu\text{g}/\text{m}^3$		$\mu\text{g}/\text{m}^3$	% of CL
Reedbeds	NO ₂	30	1	1.06	3.53
Grays Pit	NO ₂	30	1	0.89	2.97
Reedbeds	NO ₂	75	2	14.86	19.81
Grays Pit	NO ₂	75	2	7.23	9.64
Reedbeds	SO ₂	20	3	0.27	1.35
Grays Pit	SO ₂	20	3	0.22	1.10
Reedbeds	NH ₃	1	4	0.053	5.30
Reedbeds	NH ₃	3	5	0.053	1.77
Grays Pit	NH ₃	1	4	0.045	4.50
Grays Pit	NH ₃	3	5	0.045	1.50
Reedbeds	HF	5	2	0.07	1.40
Grays Pit	HF	5	2	0.04	0.80
Reedbeds	HF	0.5	6	0.07	14.00
Grays Pit	HF	0.5	6	0.04	8.00

- 1 Annual mean
- 2 Daily mean
- 3 Annual mean (higher plants)
- 4 Annual mean for sensitive lichen communities & bryophytes
- 5 Annual mean (higher plants)
- 6 Weekly mean

The process contribution is <100% of the critical levels, therefore we are satisfied that the Installation will not cause significant pollution on any of these sites.

Max Predicted Acid & Nitrogen Deposition
Little Thurrock Reedbeds and Grays Pit Extensions-Local Wildlife Sites

Site Name	Deposition	Critical Load (CLo)	Process Contribution	
		*	*	% of CLo
Reedbeds	Acid	Not sensitive	n/a	n/a
Grays Pit	Acid	4	0.081	2.03
Reedbeds	Nitrogen	15	0.43	2.87
Reedbeds	Nitrogen	30	0.43	1.43
Grays Pit	Nitrogen	15	0.36	2.40
Grays Pit	Nitrogen	25	0.36	1.44

* Acid deposition units: keq/ha/yr Nitrogen deposition units: kgN/ha/yr

The Application confirmed that the Reedbeds are not sensitive to acid deposition.

The process contribution is <100% of the critical loads, therefore we are satisfied that the Installation will not cause significant pollution on any of these sites.

5.5 Impact of abnormal operations

Article 50(4)(c) of IED requires that waste incineration and co-incineration plants shall operate an automatic system to prevent waste feed whenever any of the continuous emission monitors show that an emission limit value (ELV) is exceeded due to disturbances or failures of the purification devices. Notwithstanding this, Article 46(6) allows for the continued incineration and co-incineration of waste under such conditions provided that this period does not (in any circumstances) exceed 4 hours uninterrupted continuous operation or the cumulative period of operation does not exceed 60 hours in a calendar year. This is a recognition that the emissions during transient states (e.g. start-up and shut-down) are higher than during steady-state operation, and the overall environmental impact of continued operation with a limited exceedance of an ELV may be less than that of a partial shut-down and re-start.

For incineration plant, IED sets backstop limits for particulates, CO and TOC which must continue to be met at all times. The CO and TOC limits are the same as for normal operation, and are intended to ensure that good combustion conditions are maintained. The backstop limit for particulates is 150 mg/m³ (as a half hourly average) which is five times the limit in normal operation.

Article 45(1)(f) requires that the permit shall specify the maximum permissible period of any technically unavoidable stoppages, disturbances, or failures of the purification devices or the measurement devices, during which the

concentrations in the discharges into the air may exceed the prescribed emission limit values. In this case we have decided to set the time limit at 4 hours, which is the maximum period prescribed by Article 46(6).

Given that these abnormal operations are limited to no more than a period of 4 hours continuous operation and no more than 60 hour aggregated operation in any calendar year. This is less than 1% of total operating hours and so abnormal operating conditions are not expected to have any significant long term environmental impact unless the background conditions were already close to, or exceeding, an EQS. We did not consider it necessary in this instance to include further assessment of the Northfleet Industrial Area AQMA due to the marginal exceedance of the insignificance criteria (1.1%) and that the area of maximum impact is over the Thames. For the most part therefore consideration of abnormal operations is limited to consideration of its impact on short term EQSs.

In making an assessment of abnormal operations the following worst case scenario has been assumed:

- Dioxin emissions of 10 ng/m³ (100 x normal)
- Mercury emissions of 5 mg/m³ (100 x normal)
- NO_x emissions of 550 mg/m³ (1.4 x normal)
- Particulate emissions of 150 mg/m³ (5 x normal)
- Metal emissions other than mercury 2.5 mg/m³ (for those with a short term EAL – 5 x normal)
- SO₂ emissions of 480 mg/m³ (2.4 x normal)
- HCl emissions of 900 mg/m³ (15 x normal)

This is a worst case scenario in that these abnormal conditions include a number of different equipment failures not all of which will necessarily result in an adverse impact on the environment (e.g. a failure of a monitoring instrument does not necessarily mean that the incinerator or abatement plant is malfunctioning). This analysis assumes that any failure of any equipment results in all the negative impacts set out above occurring simultaneously.

The result on the Applicant's short-term environmental impact is summarised in the table below.

Assessment of Emissions to Air - abnormal operation

Pollutant	EQS / EAL		Back-ground	Process Contribution (PC)		Predicted Environmental Concentration (PEC)	
	$\mu\text{g}/\text{m}^3$			$\mu\text{g}/\text{m}^3$	$\mu\text{g}/\text{m}^3$	% of EAL	$\mu\text{g}/\text{m}^3$
NO ₂	200	2	63.9	41.07	20.5	104.97	52.5
PM ₁₀	50	3	-	4.5	9.00	-	-
SO ₂	266	4	13.28	56.4	21.2	69.68	26.2
	350	5	13.28	56.4	16.11	69.68	19.9
HCl	750	6	0.78	126	16.80	126.8	16.90
HF	160	6	-	12.6	7.88	-	-
Hg	7.5	1	-	0.107	1.43	-	-
Sb	150	1	-	0.025	0.02	-	-
Cu	200	1	-	0.035	0.02	-	-
Mn	1500	1	-	0.078	0.0052	-	-
Cr (II)(III)	150	1	-	0.111	0.07	-	-

- 1 1-hr Maximum
- 2 99.79th %ile of 1-hour means
- 3 90.41st %ile of 24-hour means
- 4 99.9th ile of 15-min means
- 5 99.73rd %ile of 1-hour means
- 6 1-hour average

From the table above the emissions of the following substances can still be considered insignificant, in that the PC is still <10% of the short-term EQS/EAL.

PM₁₀, HF, Hg, Sb, Cu, Mn, Cr (II) (III)

Also from the table above emissions of the following emissions (which were not screened out as insignificant) have been assessed as being unlikely to give rise to significant pollution in that the predicted environmental concentration is less than 100% of short term EQS/EAL.

NO₂, SO₂, HCl

We are therefore satisfied that it is not necessary to further constrain the conditions and duration of the periods of abnormal operation beyond those permitted under Chapter IV of the IED.

We have not assessed the impact of abnormal operations against long term EQSs for the reasons set out above. Except that if dioxin emissions were at 10 ng/m³ for the maximum period of abnormal operation, this would result in an increase of approximately 68% in the TDI reported in section 5.3.3. In these circumstances the intake would be 0.0504 pg (I-TEQ/ kg-BW/day), which is 2.52% of the COT TDI. At this level, emissions of dioxins will still not pose a risk to human health.

6. Application of Best Available Techniques

6.1 Scope of Consideration

In this section, we explain how we have determined whether the Applicant's proposals are the Best Available Techniques for this Installation.

- The first issue we address is the fundamental choice of incineration technology. There are a number of alternatives, and the Applicant has explained why it has chosen one particular kind for this Installation.
- We then consider in particular control measures for the emissions which were not screened out as insignificant in the previous section on minimising the installation's environmental impact. They are: NO₂, HF, As, Ni, TOC, PAH.
- We also have to consider the combustion efficiency and energy utilisation of different design options for the Installation, which are relevant considerations in the determination of BAT for the Installation, including the Global Warming Potential of the different options.
- Finally, the prevention and minimisation of Persistent Organic Pollutants (POPs) must be considered, as we explain below.

Chapter IV of the IED specifies a set of maximum emission limit values. Although these limits are designed to be stringent, and to provide a high level of environmental protection, they do not necessarily reflect what can be achieved by new plant. Article 14(3) of the IED says that BAT conclusions shall be the reference for setting the permit conditions, so it may be possible and desirable to achieve emissions below the limits referenced in Chapter IV.

Even if the Chapter IV limits are appropriate, operational controls complement the emission limits and should generally result in emissions below the maximum allowed; whilst the limits themselves provide headroom to allow for unavoidable process fluctuations. Actual emissions are therefore almost certain to be below emission limits in practice, because any Operator who sought to operate its installation continually at the maximum permitted level would almost inevitably breach those limits regularly, simply by virtue of normal fluctuations in plant performance, resulting in enforcement action

(including potentially prosecution) being taken. Assessments based on, say, Chapter IV limits are therefore “worst-case” scenarios.

Should the Installation, once in operation, emit at rates significantly below the limits included in the Permit, we will consider tightening ELVs appropriately. We are, however, satisfied that emissions at the permitted limits would ensure a high level of protection for human health and the environment in any event.

6.1.1 Consideration of Furnace Type

The prime function of the furnace is to achieve maximum combustion of the waste. Chapter IV of the IED requires that the plant (furnace in this context) should be designed to deliver its requirements. The main requirements of Chapter IV in relation to the choice of a furnace are compliance with air emission limits for CO and TOC and achieving a low TOC/LOI level in the bottom ash.

The Waste Incineration BREF elaborates the furnace selection criteria as:

- the use of a furnace (including secondary combustion chamber) dimensions that are large enough to provide for an effective combination of gas residence time and temperature such that combustion reactions may approach completion and result in low and stable CO and TOC emissions to air and low TOC in residues.
- use of a combination of furnace design, operation and waste throughput rate that provides sufficient agitation and residence time of the waste in the furnace at sufficiently high temperatures.
- The use of furnace design that, as far as possible, physically retain the waste within the combustion chamber (e.g. grate bar spacing) to allow its complete combustion.

The BREF also provides a comparison of combustion and thermal treatment technologies and factors affecting their applicability and operational suitability used in EU and for all types of wastes. There is also some information on the comparative costs. The table below has been extracted from the BREF tables. This table is also in line with the Guidance Note “The Incineration of Waste (EPR 5.01)). However, it should not be taken as an exhaustive list nor that all technologies listed have found equal application across Europe.

Overall, any of the furnace technologies listed below would be considered as BAT provided the Applicant has justified it in terms of:

- nature/physical state of the waste and its variability
- proposed plant throughput which may affect the number of incineration lines
- preference and experience of chosen technology including plant availability
- nature and quantity/quality of residues produced.
- emissions to air – usually NO_x as the furnace choice could have an effect on the amount of unabated NO_x produced
- energy consumption – whole plant, waste preparation, effect on GWP

- Need, if any, for further processing of residues to comply with TOC
- Costs

Summary comparison of thermal treatment technologies (reproduced from the Waste Incineration BREF)

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Moving grate (air-cooled)	<p>Low to medium heat values (LCV 5 – 16.5 GJ/t)</p> <p>Municipal and other heterogeneous solid wastes</p> <p>Can accept a proportion of sewage sludge and/or medical waste with municipal waste</p> <p>Applied at most modern MSW installations</p>	<p>1 to 50 t/h with most projects 5 to 30 t/h.</p> <p>Most industrial applications not below 2.5 or 3 t/h.</p>	<p>Widely proven at large scales.</p> <p>Robust</p> <p>Low maintenance cost</p> <p>Long operational history</p> <p>Can take heterogeneous wastes without special preparation</p>	<p>generally not suited to powders, liquids or materials that melt through the grate</p>	<p>TOC 0.5 % to 3 %</p>	<p>High capacity reduces specific cost per tonne of waste</p>
Moving grate (liquid Cooled)	<p>Same as air-cooled grates except:</p> <p>LCV 10 – 20 GJ/t</p>	<p>Same as air-cooled grates</p>	<p>As air-cooled grates but: waste treatable better</p> <p>Combustion control possible.</p>	<p>As air-cooled grates but: risk of grate damaging leaks and <input type="checkbox"/> higher complexity</p>	<p>TOC 0.5 % to 3 %</p>	<p>Slightly higher capital cost than air-cooled</p>

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Rotary Kiln	Can accept liquids and pastes <input type="checkbox"/> solid feeds more limited than grate (owing to refractory damage) <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> applied to hazardous Wastes	<10 t/h	Very well proven with <input type="checkbox"/> <input type="checkbox"/> broad range of wastes and out even of HW	Throughputs lower than grates	TOC <3 %	Higher specific cost due to reduced capacity
Fluid bed - bubbling	Only finely divided consistent wastes. Limited use for raw MSW <input type="checkbox"/> often applied to sludges	1 to 10 t/h	Good mixing Fly ashes of good leaching quality	Careful operation required to avoid clogging bed. Higher fly ash quantities.	TOC <3 %	FGT cost may be lower. Costs of waste preparation
Fluid bed - circulating	Only finely divided consistent wastes. Limited use for raw MSW, often applied to sludges / RDF.	1 to 20 t/h most used above 10 t/h	Greater fuel flexibility than BFB Fly ashes of good leaching quality	Cyclone required to conserve bed material Higher fly ash quantities	TOC <3 %	FGT cost may be lower. Costs of preparation.
Oscillating furnace	MSW / wastes <input type="checkbox"/>	1 – 10 t/h	Robust Low maintenance Long history <input type="checkbox"/> <input type="checkbox"/> Low NOX level Low LOI of bottom ash	-higher thermal loss than with grate furnace - LCV under 15 GJ/t	TOC 0.5 – 3 %	Similar to other technologies

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Pulsed hearth	Only higher CV waste (LCV >20 GJ/t) <input type="checkbox"/> used for clinical wastes	<7 t/h	can deal with liquids and powders	bed agitation may be lower	Dependent on waste type	Higher specific cost due to reduced capacity
Stepped and static hearths	Only higher CV waste (LCV >20 GJ/t) Mainly used for clinical wastes	No information	Can deal with liquids and powders	Bed agitation may be lower	Dependent on waste type	Higher specific cost due to reduced capacity
Spreader - stoker combustor	- RDF and other particle feeds <input type="checkbox"/> <input type="checkbox"/> poultry manure <input type="checkbox"/> <input type="checkbox"/> wood wastes	No information	- simple grate construction <input type="checkbox"/> <input type="checkbox"/> less sensitive to particle size than FB	only for well defined mono-streams	No information	No information
Gasification - fixed bed	- mixed plastic wastes <input type="checkbox"/> <input type="checkbox"/> other similar consistent streams <input type="checkbox"/> <input type="checkbox"/> gasification less widely used/proven than incineration	1 to 20 t/h	-low leaching residue <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> good burnout if oxygen blown <input type="checkbox"/> <input type="checkbox"/> syngas available -Reduced oxidation of recyclable metals	- limited waste feed - not full combustion - high skill level <input type="checkbox"/> <input type="checkbox"/> tar in raw gas - less widely proven	-Low leaching bottom ash <input type="checkbox"/> <input type="checkbox"/> good burnout with oxygen	High operation/maintenance costs

Technique	Key waste characteristics and suitability	Throughput per line	Advantages	Disadvantages / Limitations of use	Bottom Ash Quality	Cost
Gasification - entrained flow	- mixed plastic wastes - other similar consistent streams <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> not suited to untreated MSW <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> gasification less widely used/proven than incineration	To 10 t/h	- low leaching slag <input type="checkbox"/> <input type="checkbox"/> reduced oxidation of recyclable metals	- limited waste feed <input type="checkbox"/> <input type="checkbox"/> not full combustion <input type="checkbox"/> <input type="checkbox"/> high skill level <input type="checkbox"/> <input type="checkbox"/> less widely proven	low leaching slag	High operation/maintenance costs pre-treatment costs high
Gasification - fluid bed	- mixed plastic wastes <input type="checkbox"/> <input type="checkbox"/> shredded MSW <input type="checkbox"/> <input type="checkbox"/> shredder residues <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> sludges <input type="checkbox"/> <input type="checkbox"/> metal rich wastes <input type="checkbox"/> <input type="checkbox"/> other similar consistent streams <input type="checkbox"/> less widely used/proven than incineration	5 – 20 t/h	-temperatures e.g. for Al recovery <input type="checkbox"/> <input type="checkbox"/> separation of non combustibles -can be combined with ash melting - reduced oxidation of recyclable metals	-limited waste size (<30cm) - tar in raw gas - higher UHV raw gas - less widely proven	If Combined with ash melting chamber ash is vitrified	Lower than other gasifiers
Pyrolysis	<input type="checkbox"/> <input type="checkbox"/> pre-treated MSW <input type="checkbox"/> <input type="checkbox"/> high metal inert streams <input type="checkbox"/> <input type="checkbox"/> shredder residues/plastics <input type="checkbox"/> <input type="checkbox"/> pyrolysis is less widely used/proven than incineration	~ 5 t/h (short drum) 5 – 10 t/h (medium drum)	<input type="checkbox"/> no oxidation of metals <input type="checkbox"/> <input type="checkbox"/> no combustion energy for metals/inert <input type="checkbox"/> <input type="checkbox"/> in reactor acid neutralisation possible <input type="checkbox"/> <input type="checkbox"/> syngas available	- limited wastes <input type="checkbox"/> <input type="checkbox"/> process control and engineering critical <input type="checkbox"/> <input type="checkbox"/> high skill req. <input type="checkbox"/> not widely proven <input type="checkbox"/> <input type="checkbox"/> need market for syngas	- dependent on process temperature <input type="checkbox"/> residue produced requires further processing e.g. combustion	High pre-treatment, operation and capital costs

The Applicant has carried out a review of the following candidate furnace types:

- Moving Grate Furnace
- Fluidised Bed

These options were the outcome of a qualitative assessment of a number of technologies for the combustion of waste (fixed hearth, pulsed hearth, rotary kiln, pyrolysis/gasification). The other options were not considered to be suitable for the types and volumes of waste to be treated.

The Applicant's consideration of environmental performance for the two options includes the following:

- Emissions to Air
- Global Warming Potential (GWP)
- Raw Material Consumption (urea and sand)
- Residues
- Operating costs

Both options are suitable for the treatment of wastes identified in the Application and are in accordance with the technologies in the BREF.

The Applicant concludes the following:

For emissions to air both options would require abatement which means that the actual effect would be the amount of reagent required to abate the NO_x.

The direct emissions of greenhouse gases are the same for each option.

The fluidised bed uses less urea but it also requires sand.

The amount of waste produced is similar for both options; however the fluidised bed whilst producing less bottom ash, produces an additional fly ash stream which may not be suitable for re-use as aggregate due to its potential hazardous nature.

The capital costs are higher for the fluidised bed due to additional waste preparation equipment, sand dosing and fly ash separation.

The Applicant concludes that the benefit of reduced urea consumption (due to lower primary NO_x production) for a fluidised bed is far outweighed by the higher energy consumption and operating costs. The moving grate option is considered to be BAT and the Environment Agency agrees with this assessment.

The Applicant has proposed to use a furnace technology comprising a moving grate which is identified in the tables above as being considered BAT in the BREF or TGN for this type of waste feed.

The Applicant proposes to use gas-oil as support fuel for start-up, shut-down and for the auxiliary burners. The choice of support fuel is based on there being no high-pressure gas main within the site; therefore natural gas is not considered to be available for the Installation. Low sulphur gas-oil will be used to minimise emissions. The Environment Agency agrees that the Applicant's choice of gas-oil is BAT for the installation.

Boiler Design

In accordance with our Technical Guidance Note, S5.01, the Applicant has confirmed that the boiler design will include the following features to minimise the potential for reformation of dioxins within the de-novo synthesis range:

- ensuring that the steam/metal heat transfer surface temperature is a minimum where the exhaust gases are within the de-novo synthesis range;
- design of the boilers using CFD to ensure no pockets of stagnant or low velocity gas;
- boiler passes are progressively decreased in volume so that the gas velocity increases through the boiler; and
- Design of boiler surfaces to prevent boundary layers of slow moving gas.

We have considered the assessments made by the Applicant and agree that the furnace technology chosen represents BAT. We believe that, based on the information gathered by the BREF process, the chosen technology will achieve the requirements of Chapter IV of the IED for the air emissions of TOC/CO and the TOC on bottom ash.

6.2 BAT and emissions control

The prime function of flue gas treatment is to reduce the concentration of pollutants in the exhaust gas as far as practicable. The techniques which are described as BAT individually are targeted to remove specific pollutants, but the BREF notes that there is benefit from considering the flue-gas treatment (FGT) system as a whole unit. Individual units often interact, providing a primary abatement for some pollutants and an additional effect on others.

The BREF lists the general factors requiring consideration when selecting FGT systems as:

- type of waste, its composition and variation
- type of combustion process, and its size
- flue-gas flow and temperature
- flue-gas content, size and rate of fluctuations in composition
- target emission limit values
- restrictions on discharge of aqueous effluents
- plume visibility requirements
- land and space availability
- availability and cost of outlets for residues accumulated/recovered
- compatibility with any existing process components (existing plants)
- availability and cost of water and other reagents

- energy supply possibilities (e.g. supply of heat from condensing scrubbers)
- reduction of emissions by primary methods
- release of noise.

Taking these factors into account the Technical Guidance Note points to a range of technologies being BAT subject to circumstances of the Installation.

6.2.1 Particulate Matter

Particulate matter				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Bag / Fabric filters (BF)	Reliable abatement of particulate matter to below 5mg/m ³	Max temp 250°C	Multiple compartments Bag burst detectors	Most plants
Wet scrubbing	May reduce acid gases simultaneously.	Not normally BAT. Liquid effluent produced	Require reheat to prevent visible plume and dew point problems.	Where scrubbing required for other pollutants
Ceramic filters	High temperature applications Smaller plant.	May “blind” more than fabric filters		Small plant. High temperature gas cleaning required.
Electrostatic precipitators	Low pressure gradient. Use with BF may reduce the energy consumption of the induced draft fan.	Not normally BAT.		When used with other particulate abatement plant

The Applicant proposes to use fabric filters for the abatement of particulate matter. Fabric filters provide reliable abatement of particulate matter to below 5 mg/m³ and are BAT for most installations. The Applicant proposes to use multiple compartment filters with burst bag detection to minimise the risk of increased particulate emissions in the event of bag rupture.

Emissions of particulate matter have been previously assessed as insignificant, and so the Environment Agency agrees that the Applicant’s proposed technique is BAT for the installation.

6.2.2 Oxides of Nitrogen

Oxides of Nitrogen : Primary Measures				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Low NOx burners	Reduces NOx at source		Start-up, supplementary firing.	Where auxiliary burners required.
Starved air systems	Reduce CO simultaneously.			Pyrolysis, Gasification systems.
Optimise primary and secondary air injection				All plant.
Flue Gas Recirculation (FGR)	Reduces the consumption of reagents used for secondary NOx control. May increase overall energy recovery	Some applications experience corrosion problems.		All plant unless impractical in design (needs to be demonstrated)

Oxides of Nitrogen : Secondary Measures (BAT is to apply Primary Measures first)				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Selective catalytic reduction (SCR)	NO _x emissions < 70mg/ m ³ Reduces CO, VOC, dioxins	Expensive. Re-heat required – reduces plant efficiency		All plant
Selective non-catalytic reduction (SNCR)	NO _x emissions typically 150 - 180mg/m ³	Relies on an optimum temperature around 900 °C, and sufficient retention time for reduction May lead to Ammonia slip	Port injection location	All plant unless lower NO _x release required for local environmental protection.
Reagent Type: Ammonia	Likely to be BAT Lower nitrous oxide formation	More difficult to handle Narrower temperature window		All plant
Reagent Type: Urea	Likely to be BAT			All plant

The Applicant proposes to implement the following primary measures:

- Low NO_x burners – this technique reduces NO_x at source and is defined as BAT where auxiliary burners are required.
- Optimise primary and secondary air injection – this technique is BAT for all plant.
- Flue gas recirculation – this technique reduces the consumption of reagents for secondary NO_x control and can increase overall energy recovery, although in some applications there can be corrosion problems.

There are two recognised techniques for secondary measures to reduce NO_x. These are Selective Catalytic Reduction (SCR) and Selective Non-Catalytic Reduction (SNCR). For each technique, there is a choice of urea or ammonia reagent.

SCR can reduce NO_x levels to below 70 mg/m³ and can be applied to all plant, it is generally more expensive than SNCR and requires reheating of the waste gas stream which reduces energy efficiency, periodic replacement of the catalysts also produces a hazardous waste. SNCR can typically reduce

NO_x levels to between 150 and 180 mg/m³; it relies on an optimum temperature of around 900 °C and sufficient retention time for reduction. SNCR is more likely to have higher levels of ammonia slip. The technique can be applied to all plant unless lower NO_x releases are required for local environmental protection. Urea or ammonia can be used as the reagent with either technique, urea is somewhat easier to handle than ammonia and has a wider operating temperature window, but tends to result in higher emissions of N₂O. Either reagent is BAT, and the use of one over the other is not normally significant in environmental terms.

The Applicant proposes to use SNCR with urea as the reagent.

Emissions of NO_x cannot be screened out as insignificant. Therefore the Applicant has carried out a cost / benefit study of the alternative techniques. The table below shows that with SCR the annualised cost increases by approximately £476,000. This gives an effective annual cost of £2,800 per additional tonne of NO_x abated.

	NO _x abated (tpa)	PC (long term)	PEC (long term)	Annualised Cost (£ pa)
SCR	330	0.43	32.33	1,210,000
SNCR	160	1.10	33.00	734,000

Based on the figures above the Applicant considers that the additional cost of SCR over SNCR is not justified by the reduction in environmental impact. Thus SCR is not BAT in this case, and SNCR is BAT for the Installation. The Applicant has justified the use of urea as the reagent on the basis of it being safer to handle than ammonia. The Environment Agency agrees with this assessment.

The amount of urea used for NO_x abatement will need to be optimised to maximise NO_x reduction and minimise NH₃ slip. An Improvement condition requires the Operator to report to the Environment Agency on optimising the performance of the NO_x abatement system. The Operator is also required to monitor and report on NH₃ and N₂O emissions every 6 months.

6.2.3 Acid Gases, SO_x, HCl and HF

Acid gases and halogens : Primary Measures				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Low sulphur fuel, (< 0.1%S gas-oil or natural gas)	Reduces SO _x at source		Start-up, supplementary firing.	Where auxiliary fuel required.
Management of waste streams	Disperses sources of acid gases (e.g. PVC) through feed.	Requires closer control of waste management		All plant with heterogeneous waste feed

Acid gases and halogens : Secondary Measures (BAT is to apply Primary Measures first)				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Wet	High reaction rates Low solid residues production Reagent delivery may be optimised by concentration and flow rate	Large effluent disposal and water consumption if not fully treated for re-cycle Effluent treatment plant required May result in wet plume Energy required for effluent treatment and plume reheat		Plants with high acid gas and metal components in exhaust gas – HWIs
Dry	Low water use Reagent consumption may be reduced by recycling in plant	Higher solid residue production Reagent consumption controlled only by input rate		All plant

	<p>Lower energy use</p> <p>Higher reliability</p>			
Semi-dry	<p>Medium reaction rates</p> <p>Reagent delivery may be varied by concentration and input rate</p>	<p>Higher solid waste residues</p>		All plant
Reagent Type: Sodium Hydroxide	<p>Highest removal rates</p> <p>Low solid waste production</p>	<p>Corrosive material</p> <p>ETP sludge for disposal</p>		HWIs
Reagent Type: Lime	<p>Very good removal rates</p> <p>Low leaching solid residue</p> <p>Temperature of reaction well suited to use with bag filters</p>	<p>Corrosive material</p> <p>May give greater residue volume if no in-plant recycle</p>	Wide range of uses	MWIs, CWIs
Reagent Type: Sodium Bicarbonate	<p>Good removal rates</p> <p>Easiest to handle</p> <p>Dry recycle systems proven</p>	<p>Efficient temperature range may be at upper end for use with bag filters</p> <p>– Leachable solid residues</p> <p>Bicarbonate more expensive</p>	Not proven at large plant	CWIs

The Applicant proposes to implement the following primary measures:

- Use of low sulphur fuels for start up and auxiliary burners – gas should be used if available, where fuel oil is used, this will be low sulphur (i.e. <0.1%), this will reduce SO_x at source. The Applicant has justified its choice of gas-oil as the support fuel on the basis that there is no high-pressure gas main within the site, therefore natural gas is not considered to be available for the Installation, and we agree with that assessment.
- Management of heterogeneous wastes – this will disperse problem wastes such as PVC by ensuring a homogeneous waste feed.

There are three recognised techniques for secondary measures to reduce acid gases. These are wet, dry and semi-dry. Wet scrubbing produces an effluent for treatment and disposal in compliance with Article 46(3) of IED. It will also require reheat of the exhaust to avoid a visible plume. Wet scrubbing is unlikely to be BAT except where there are high acid gas and metal components in the exhaust gas as may be the case for some hazardous waste incinerators. In this case, the Applicant does not propose using wet scrubbing, and the Environment Agency agrees that wet scrubbing is not appropriate in this case.

The Applicant has therefore considered dry and semi-dry methods of secondary measures for acid gas abatement. Either can be BAT for this type of facility.

Both dry and semi-dry methods rely on the dosing of powdered materials into the exhaust gas stream. Semi-dry systems (i.e. hydrated reagent) offer reduced material consumption through faster reaction rates, but reagent recycling in dry systems can offset this.

In both dry and semi-dry systems, the injected powdered reagent reacts with the acid gases and is removed from the gas stream by the bag filter system. The powdered materials are either lime or sodium bicarbonate. Both are effective at reducing acid gases, and dosing rates can be controlled from continuously monitoring acid gas emissions. The decision on which reagent to use is normally economic. Lime produces a lower leaching solid residue in the APC residues than sodium bicarbonate and the reaction temperature is well suited to bag filters, it tends to be lower cost, but it is a corrosive material and can generate a greater volume of solid waste residues than sodium bicarbonate. Either reagent is BAT, and the use of one over the other is not significant in environmental terms in this case.

In this case, the Applicant proposes to use a dry scrubbing system with lime dosing. The Environment Agency is satisfied that this is BAT

6.2.4 Carbon monoxide and volatile organic compounds (VOCs)

The prevention and minimisation of emissions of carbon monoxide and volatile organic compounds is through the optimisation of combustion controls, where all measures will increase the oxidation of these species.

Carbon monoxide and volatile organic compounds (VOCs)				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Optimise combustion control	All measures will increase oxidation of these species.		Covered in section on furnace selection	All plants

6.2.5 Dioxins and furans (and Other POPs)

Dioxins and furans				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Optimise combustion control	All measures will increase oxidation of these species.		Covered in section on furnace selection	All plants
Avoid <i>de novo</i> synthesis			Covered in boiler design	All plant
Effective Particulate matter removal			Covered in section on particulate matter	All plant
Activated Carbon injection	Can be combined with acid gas absorber or fed separately.	Combined feed rate usually controlled by acid gas content.		All plant. Separate feed normally BAT unless feed is constant and acid gas control also controls dioxin release.

The prevention and minimisation of emissions of dioxins and furans is achieved through:

- optimisation of combustion control including the maintenance of permit conditions on combustion temperature and residence time, which has been considered in 6.1.1 above;
- avoidance of de novo synthesis, which has been covered in the consideration of boiler design;
- the effective removal of particulate matter, which has been considered in 6.2.1 above;

- injection of activated carbon. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant. Effective control of acid gas emissions also assists in the control of dioxin releases.

In this case the Applicant proposes a separate feed and we are satisfied their proposals are BAT.

6.2.6 Metals

Metals				
Technique	Advantages	Disadvantages	Optimisation	Defined as BAT in BREF or TGN for:
Effective Particulate matter removal			Covered in section on particulate matter	All plant
Activated Carbon injection for mercury recovery	Can be combined with acid gas absorber or fed separately.	Combined feed rate usually controlled by acid gas content.		All plant. Separate feed normally BAT unless feed is constant and acid gas control also controls dioxin release.

The prevention and minimisation of metal emissions is achieved through the effective removal of particulate matter, and this has been considered in 6.2.1 above.

Unlike other metals however, mercury if present will be in the vapour phase. BAT for mercury removal is also dosing of activated carbon into the exhaust gas stream. This can be combined with the acid gas reagent or dosed separately. Where the feed is combined, the combined feed rate will be controlled by the acid gas concentration in the exhaust. Therefore, separate feed of activated carbon would normally be considered BAT unless the feed was relatively constant.

In this case the Applicant proposes separate feed and we are satisfied their proposals are BAT.

6.3 BAT and global warming potential

This section summarises the assessment of greenhouse gas impacts which has been made in the determination of this Permit. Emissions of carbon dioxide (CO₂) and other greenhouse gases differ from those of other pollutants in that, except at gross levels, they have no localised environmental impact. Their impact is at a global level and in terms of climate change. Nonetheless, CO₂ is clearly a pollutant for IED purposes.

The principal greenhouse gas emitted is CO₂, but the plant also emits small amounts of N₂O arising from the operation of secondary NO_x abatement. N₂O has a global warming potential 310 times that of CO₂. The Applicant will therefore be required to optimise the performance of the secondary NO_x abatement system to ensure its GWP impact is minimised.

The major source of greenhouse gas emissions from the Installation is however CO₂ from the combustion of waste. There will also be CO₂ emissions from the burning of support fuels at start-up, shut-down and should it be necessary to maintain combustion temperatures. This equates to 10,240 tonnes of CO₂ per annum from Line 1 (biomass) and 123,240 tonnes of CO₂ per annum from Line 2 (SRF). BAT for greenhouse gas emissions is to maximise energy recovery and efficiency.

The electricity that is generated by the Installation will displace emissions of CO₂ elsewhere in the UK, as virgin fossil fuels will not be burnt to create the same electricity. The Applicant has therefore included within its GWP calculations a CO₂ offset for the net amount of electricity exported from the Installation.

Taking this into account, the net emissions of CO₂ from the Installation are estimated at -131,760 tonnes per annum from Line 1 (biomass) and -18,760 tonnes per annum from Line 2 (SRF). The Installation is not subject to the Greenhouse Gas Emissions Trading Scheme Regulations 2003; therefore it is a requirement of IED to investigate how emissions of greenhouse gases emitted from the Installation might be prevented or minimised.

The Applicant has considered GWP as part of its BAT options appraisal. There are a number of areas in which a difference can be made to the GWP of the Installation, e.g. The Applicant's BAT options appraisal compared SCR and SNCR methods of secondary NO_x abatement. In summary: the following factors influence the GWP of the facility:-

On the debit side

- CO₂ emissions from the burning of the waste;
- CO₂ emissions from burning auxiliary or supplementary fuels;
- CO₂ emissions associated with electrical energy used;
- N₂O from the de-NO_x process.

On the credit side

- CO₂ saved from the export of electricity to the public supply by displacement of burning of virgin fuels;
- CO₂ saved from the use of waste heat by displacement of burning of virgin fuels.

Note: avoidance of methane which would be formed if the waste was landfilled has not been included in this assessment. If it were included due to its avoidance it would be included on the credit side. Ammonia has no direct GWP effect.

The Applicant's assessment shows that the GWP of the plant is offset by the displacement of emissions from the production of electricity.

The differences in the GWP of the options in the BAT appraisal arise from small differences in energy recovery and in the amount of N₂O emitted.

Taking all these factors into account, the Applicant's assessment shows their preferred option is best in terms of GWP.

The Environment Agency agrees with this assessment and that the chosen option is BAT for the installation.

6.4 BAT and POPs

International action on Persistent Organic pollutants (POPs) is required under the UN's Stockholm Convention, which entered into force in 2004. The EU implemented the Convention through the POPs Regulation (850/2004), which is directly applicable in UK law. The Environment Agency is required by national POPs Regulations (SI 2007 No 3106) to give effect to Article 6(3) of the EC POPs Regulation when determining applications for environmental Permits.

However, it needs to be borne in mind that this application is for a particular type of installation, namely a waste incinerator. The Stockholm Convention distinguishes between intentionally-produced and unintentionally-produced POPs. Intentionally-produced POPs are those used deliberately (mainly in the past) in agriculture (primarily as pesticides) and industry. Those intentionally-produced POPs are not relevant where waste incineration is concerned, as in fact high-temperature incineration is one of the prescribed methods for destroying POPs.

The unintentionally-produced POPs addressed by the Convention are:

- dioxins and furans;
- HCB (hexachlorobenzene)
- PCBs (polychlorobiphenyls) and
- PeCB (pentachlorobenzene)

The UK's national implementation plan for the Stockholm Convention, published in 2007, makes explicit that the relevant controls for unintentionally-produced POPs, such as might be produced by waste incineration, are delivered through the requirements of IED. That would include an examination of BAT, including potential alternative techniques, with a view to preventing or minimising harmful emissions. These have been applied as explained in this document, which explicitly addresses alternative techniques and BAT for the minimisation of emissions of dioxins.

Our legal obligation, under regulation 4(b) of the POPs Regulations, is, when considering an application for an environmental permit, to comply with article 6(3) of the POPs Regulation:

“Member States shall, when considering proposals to construct new facilities or significantly to modify existing facilities using processes that release chemicals listed in Annex III, without prejudice to Council Directive 1996/61/EC, give priority consideration to alternative processes, techniques or practices that have similar usefulness but which avoid the formation and release of substances listed in Annex III.”

The 1998 Protocol to the Convention recommended that unintentionally produced should be controlled by imposing emission limits (e.g. 0.1 ng/m³ for MWIs) and using BAT for incineration. UN Economic Commission for Europe (Executive Body for the Convention) (ECE-EB) produced BAT guidance for the parties to the Convention in 2009. This document considers various control techniques and concludes that primary measures involving management of feed material by reducing halogenated substances are not technically effective. This is not surprising because halogenated wastes still need to be disposed of and because POPs can be generated from relatively low concentrations of halogens. In summary, the successful control techniques for waste incinerators listed in the ECE-EB BAT are:

- maintaining furnace temperature of 850°C and a combustion gas residence time of at least 2 seconds
- rapid cooling of flue gases to avoid the *de novo* reformation temperature range of 250-450°C
- use of bag filters and the injection of activated carbon or coke to adsorb residual POPs components.

Using the methods listed above, the UN-ECE BAT document concludes that incinerators can achieve an emission concentration of 0.1 ng TEQ/m³.

We believe that the Permit ensures that the formation and release of POPs will be prevented or minimised. As we explain above, high-temperature incineration is one of the prescribed methods for destroying POPs. Permit conditions are based on the use of BAT and Chapter IV of IED and incorporate all the above requirements of the UN-ECE BAT guidance and deliver the requirements of the Stockholm Convention in relation to unintentionally produced POPs.

The release of **dioxins and furans** to air is required by the IED to be assessed against the I-TEQ (International Toxic Equivalence) limit of 0.1 ng/m³. Further development of the understanding of the harm caused by dioxins has resulted in the World Health Organisation (WHO) producing updated factors to calculate the WHO-TEQ value. Certain **PCBs** have structures which make them behave like dioxins (dioxin-like PCBs), and these also have toxic equivalence factors defined by WHO to make them capable of being considered together with dioxins. The UK's independent health advisory committee, the Committee on Toxicity of Chemicals in Food, Consumer Products and the Environment (COT) has adopted WHO-TEQ values for both dioxins and dioxin-like PCBs in their review of Tolerable Daily Intake (TDI) criteria. In support of the requirements of the IED, the WHO-TEQ values for both dioxins and dioxin-like PCBs have been specified for monitoring and reporting purposes, to enable an evaluation of exposure to dioxins and dioxin-like PCBs to be made using the revised TDI recommended by COT. The release of dioxin-like PCBs and PAHs is expected to be low where measures have been taken to control dioxin releases. We specify monitoring of a range of PAHs and dioxin-like PCBs in waste incineration Permits at the same frequency as dioxins are monitored. We have included a requirement to monitor and report against these WHO-TEQ values for dioxins and dioxin-like PCBs and the range of PAHs identified by Defra in their previous Environmental Permitting Guidance on the WID. We are confident that the measures taken to control the release of dioxins will also control the releases of dioxin-like PCBs and PAHs. Section 5 of this document details the assessment of emissions to air, which includes dioxins and concludes that there will be no adverse effect on human health from either normal or abnormal operation.

Hexachlorobenzene (HCB) is released into the atmosphere as an accidental product from the combustion of coal, waste incineration and certain metal processes. It has also been used as a fungicide, especially for seed treatment although this use has been banned in the UK since 1975. Natural fires and volcanoes may serve as natural sources. Releases of (HCB) are addressed by the European Environment Agency (EEA), which advises that:

"due to comparatively low levels in emissions from most (combustion) processes special measures for HCB control are usually not proposed. HCB emissions can be controlled generally like other chlorinated organic compounds in emissions, for instance dioxins/furans and PCBs: regulation of time of combustion, combustion temperature, temperature in cleaning devices, sorbents application for waste gases cleaning etc." [reference

http://www.eea.europa.eu/publications/EMEPCORINAIR4/sources_of_HCB.pdf]

Pentachlorobenzene (PeCB) is another of the POPs list to be considered under incineration. PeCB has been used as a fungicide or flame retardant, there is no data available however on production, recent or past, outside the UN-ECE region. PeCBs can be emitted from the same sources as for PCDD/F: waste incineration, thermal metallurgic processes and combustion

plants providing energy. As discussed above, the control techniques described in the UN-ECE BAT guidance and included in the permit, are effective in controlling the emissions of all relevant POPs including PeCB.

We have assessed the control techniques proposed for dioxins by the Applicant and have concluded that they are appropriate for dioxin control. We are confident that these controls are in line with the UN-ECE BAT guidance and will minimise the release of HCB, PCB and PeCB.

We are therefore satisfied that the substantive requirements of the Convention and the POPs Regulation have been addressed and complied with.

6.5 Other Emissions to the Environment

6.5.1 Emissions to water

Uncontaminated surface water run-off will be collected in the surface water drainage system. Where possible it will be harvested for domestic use with the remainder being discharged off site.

Based upon the information in the Application we are satisfied that appropriate measures will be in place to prevent and /or minimise emissions to water.

6.5.2 Emissions to sewer

Process effluents will be generated from boiler blow down losses, water treatment facilities and run-off from the ash quench and will be collected and treated in the sedimentation basin. Treatment will provide acid dosing for pH adjustment and settlement of waste waters prior to discharge to sewer under a trade effluent consent.

Based upon the information in the Application we are satisfied that appropriate measures will be in place to prevent and /or minimise emissions to sewer.

6.5.3 Fugitive emissions

The IED specifies that plants must be able to demonstrate that the plant is designed in such a way as to prevent the unauthorised and accidental release of polluting substances into soil, surface water and groundwater. In addition storage requirements for waste and for contaminated water of Article 46(5) must be arranged.

The facility will be supplied with gas-oil and chemicals which will be stored in an appropriate manner incorporating the use of bunding and other measures to ensure appropriate containment. The potential for accidents, and associated environmental impacts, is therefore limited.

Tanker off-loading of will take place within areas of concrete hard standing. The storage tanks will be bunded at 110% of the tank capacity and the

offloading point will be fully contained with the appropriate capacity to contain any spills during delivery.

All external areas of hard standing will be provided with curbed containment, to prevent any potential spills from causing pollution of the ground / groundwater.

In the event of a fire, the fire fighting water will be collected in the firewater pits. Site drainage for external areas will be fitted with a shut-off alarm, linked to the fire detection systems to contain any fire fighting water from external areas. Additional storage will be available from site kerbing.

Ash processing will take place within an enclosed building equipped with concrete hardstanding.

Biomass will be stored externally prior to processing. Processing will take place within an enclosed building with internal storage in place for the processed biomass. A pre-operational condition requires the Operator to confirm the specific details of the storage arrangements for processed and unprocessed biomass at the site with specific regard to TGN 7.01 for the storage of combustible materials. We have also specified that the Applicant must operate the Installation in accordance with this guidance in Table S1.2 of the Permit. Specific details of the dust control measures to be implemented are also required prior to commissioning of Line 1 (biomass).

Based upon the information in the application and conditions in the Permit, we are satisfied that appropriate measures will be in place to prevent and /or minimise fugitive emissions.

6.5.4 Odour

The Applicant did not consider that the storage and combustion of biomass at Line 1 would give rise to emissions of odour; however Line 2 has the potential to give rise to odour. They confirmed that the facility will be designed in accordance with the requirements of our H4 Guidance on odour and that the following principles would be applied:

- Air from waste storage and processing will be used as combustion air within Line 2;
- Air from less odorous areas will be contained within the building;
- All waste storage areas will be maintained under a negative pressure;
- Fast acting roller shutter doors.

Having considered the information submitted in the Application, we are satisfied that the appropriate measures will be in place to prevent or where that is not practicable to minimise odour and to prevent pollution from odour. Pre-operational conditions require the Operator to submit details of the odour controls to be implemented for each line.

6.5.5 Noise and vibration

The Applicant concludes that an assessment using the principles of BS 4142 (*Method for rating industrial noise affecting mixed residential and industrial areas*) found predicted Rating Levels to be such that complaints will be unlikely representing an impact of less than marginal significance.

The Application contains a noise impact assessment identifying local noise sensitive receptors, potential sources of noise at the proposed plant and noise attenuation measures. Measurements were taken of the prevailing ambient noise levels to produce a baseline noise survey and a BS4142 assessment was carried out to compare the predicted plant rating noise levels with the established background levels.

We have carried out an assessment of the Noise Report provided with the Application (Ref: AQMAU_C1106_RP01) and have concluded that it cannot be used as the basis for permit determination. We have concluded that there is a difference of 10 dB or greater between the Applicant's noise contribution and the background. This falls within the BS4142 assessment criteria of 'an indication that complaints are likely' and this is applicable to both day and night time.

We asked for an amended noise assessment to address the following areas:

- Background data
- 5 dB noise feature penalty
- On-site traffic
- Noise levels at Curzon Drive
- Noise Barrier
- HGV deliveries

The Applicant provided additional information in reports dated 25 February, 12 March and 1 April 2014. The key areas to be addressed were the noise penalty and background data. The February report included a justification for the 5dB noise penalty with the April report including additional baseline noise data.

Although we did not agree technically with all aspects of the assessments, we agreed that the predicted noise levels at sensitive receptors due to day and night time operations was unlikely to exceed greater than marginal significance, in accordance with BS:4142. Our findings are detailed in our report ref AQMAU_C1106_RP01 and our email from AQMAU sent 11 April 2014 which are available on the public register.

Based upon the information in the Application we are satisfied that the appropriate measures (which include adequate maintenance of plant and equipment) will be in place to prevent or where that is not practicable to minimise noise and vibration and to prevent pollution from noise and vibration outside the site.

6.6 Setting ELVs and other Permit conditions

6.6.1 Translating BAT into Permit conditions

Article 14(3) of IED states that BAT conclusions shall be the reference for permit conditions. Article 15(3) further requires that under normal operating conditions; emissions do not exceed the emission levels associated with the best available techniques as laid down in the decisions on BAT conclusions.

At the time of writing of this document, no BAT conclusions have been published for waste incineration or co-incineration.

The use of IED Chapter IV emission limits for air dispersion modelling sets the worst case scenario. If this shows emissions are insignificant then we have accepted that the Applicant's proposals are BAT, and that there is no justification to reduce ELVs below the Chapter IV limits in these circumstances.

Below we consider whether, for those emission not screened out as insignificant, different conditions are required as a result of consideration of local or other factors, so that no significant pollution is caused (Article 11(c)) or to comply with environmental quality standards (Article 18).

(i) Local factors

We have considered the impact on the AQMAs as detailed in section 5.2.4 of this document. We did not consider it necessary in this instance to include further assessment of the Northfleet Industrial Area AQMA due to the marginal exceedance of the insignificance criteria (1.1%) and that the area of maximum impact is over the Thames.

We would not consider it practical or reasonable to expect the Applicant to go beyond what is considered BAT for the control of NO₂, HF, As, Ni, TOC, PAH.

(ii) National and European EQSs

We do not expect emissions from the Installation to cause an exceedance of an EQS. In view of this, Article 18 of IED does not require any tighter conditions than we have already applied.

(iii) Global Warming

CO₂ is an inevitable product of the combustion of waste. The amount of CO₂ emitted will be essentially determined by the quantity and characteristics of waste being incinerated, which are already subject to conditions in the Permit. It is therefore inappropriate to set an emission limit value for CO₂, which could do no more than recognise what is going to be emitted. The gas is not therefore targeted as a key pollutant under Annex II of IED, which lists the main polluting substances that are to be considered when setting emission limit values (ELVs) in Permits.

We have therefore considered setting equivalent parameters or technical measures for CO₂. However, provided energy is recovered efficiently (see section 4.3.7 above), there are no additional equivalent technical measures (beyond those relating to the quantity and characteristics of the waste) that can be imposed that do not run counter to the primary purpose of the plant, which is the destruction of waste/recovery of energy from waste. Controls in the form of restrictions on the volume and type of waste that can be accepted at the Installation and permit conditions relating to energy efficiency effectively apply equivalent technical measures to limit CO₂ emissions.

(iv) Commissioning

The Application refers to commissioning and the validation of combustion conditions for the incineration plant. We have secured this by setting a pre-operational condition.

We have also set a pre-operational condition requiring a commissioning plan including timelines for completion. The commissioning plan will include the expected actual emissions (rather than the permitted emissions) to the environment during the different stages of commissioning, the expected durations of commissioning activities and the actions to be taken to protect the environment and report to the Environment Agency in the event that actual emissions exceed expected emissions. Commissioning shall be carried out in accordance with the commissioning plan as approved.

6.7 Monitoring

6.7.1 Monitoring during normal operations

We have decided that monitoring should be carried out for the parameters listed in Schedule 3 using the methods and to the frequencies specified in those tables. These monitoring requirements have been imposed in order to demonstrate compliance with emission limit values and to enable correction of measured concentration of substances to the appropriate reference conditions; to gather information about the performance of the SNCR system; to deliver the EPR requirement that dioxin-like PCBs and PAHs should be monitored and to deliver the requirements of Chapter IV of IED for monitoring of residues and temperature in the combustion chamber.

For emissions to air, the methods for continuous and periodic monitoring are in accordance with the Environment Agency's Guidance M2 for monitoring of stack emissions to air.

Based on the information in the Application and the requirements set in the conditions of the permit we are satisfied that the Operator's techniques, personnel and equipment will have either MCERTS certification or MCERTS accreditation as appropriate.

6.7.2 Monitoring under abnormal operations arising from the failure of the installed CEMs

The Operator has stated that they will provide back-up CEMS working in parallel to the operating CEMS. These will be switched into full operation immediately in the event that there is any failure in the regular monitoring equipment. The back-up CEMS measure the same parameters as the operating CEMS. In the unlikely event that the back-up CEMS also fail Condition 2.3.10 of the permit requires that the abnormal operating conditions apply.

6.7.3 Continuous emissions monitoring for dioxins and heavy metals

Chapter IV of IED specifies manual extractive sampling for heavy metals and dioxin monitoring. However, Article 48(5) of the IED enables The Commission to act through delegated, authority to set the date from which continuous measurements of the air emission limit values for heavy metals, dioxins and furans shall be carried out, as soon as appropriate measurement techniques are available within the Community. No such decision has yet been made by the Commission.

The Environment Agency has reviewed the applicability of continuous sampling and monitoring techniques to the installation.

Recent advances in mercury monitoring techniques have allowed standards to be developed for continuous mercury monitoring, including both vapour-phase and particulate mercury. There is a standard which can apply to CEMs which measure mercury (EN 15267-3) and standards to certify CEMs for mercury, which are EN 15267-1 and EN 15267-3. Furthermore, there is an MCERTS-certified CEM which has been used in trials in the UK and which has been verified on-site using many parallel reference tests as specified using the steps outlined in EN 14181.

In the case of dioxins, equipment is available for taking a sample for an extended period (several weeks), but the sample must then be analysed in the conventional way. However, the continuous sampling systems do not meet the requirements of BS EN 1948 which is the standard for dioxin analysis. BS EN 1948 requires traversing the sampler across the duct and collecting parts of the sample at various points across the duct to ensure that all of the gas phase is sampled proportionately, in case there are variations in gas flow rate or composition resulting in a non-homogeneous gas flow. This requirement is particularly important where suspended solids are present in the gas, and dioxins are often associated with suspended solid particles. Continuous samplers are currently designed for operation at one or two fixed sampling points within the duct, and traverses are not carried out automatically. Using such samplers, more information could be obtained about the variation with time of the dioxin measurement, but the measured results could be systematically higher or lower than those obtained by the approved standard method which is the reference technique required to demonstrate compliance with the limit specified in the IED. The lack of a primary reference method

(e.g. involving a reference gas of known concentration of dioxin) prohibits any one approach being considered more accurate than another. Because compliance with the IED's requirements is an essential element of EPR regulation, we have set emission limits for dioxins in the permit based on the use of BS EN 1948 and the manual sampling method remains the only acceptable way to monitor dioxins for the purpose of regulation.

For either continuous monitoring of mercury or continuous sampling of dioxins to be used for regulatory purposes, an emission limit value would need to be devised which is applicable to continuous monitoring. Such limits for mercury and dioxins have not been set by the European Commission. Use of a manual sample train is the only technique which fulfils the requirements of the IED. At the present time, it is considered that in view of the predicted low levels of mercury and dioxin emission it is not justifiable to require the Operator to install additionally continuous monitoring or sampling devices for these substances.

In accordance with its legal requirement to do so, the Environment Agency reviews the development of new methods and standards and their performance in industrial applications. In particular the Environment Agency considers continuous sampling systems for dioxins to have promise as a potential means of improving process control and obtaining more accurate mass emission estimates.

6.8 Reporting

We have specified the reporting requirements in Schedule 4 of the Permit either to meet the reporting requirements set out in the IED, or to ensure data is reported to enable timely review by the Environment Agency to ensure compliance with permit conditions and to monitor the efficiency of material use and energy recovery at the Installation.

7 Other legal requirements

In this section we explain how we have addressed other relevant legal requirements, to the extent that we have not addressed them elsewhere in this document.

7.1 The EPR 2010 and related Directives

The EPR delivers the requirements of a number of European and national laws.

7.1.1 Schedules 1 and 7 to the EPR 2010 – IED Directive

We address the requirements of the IED in the body of this document above and the specific requirements of Chapter IV in Annex 1 of this document.

There is one requirement not addressed above, which is that contained in Article 5(3) IED. Article 5(3) requires that “In the case of a new installation or a substantial change where Article 4 of Directive 85/337/EC (the EIA Directive) applies, any relevant information obtained or conclusion arrived at pursuant to articles 5, 6 and 7 of that Directive shall be examined and used for the purposes of granting the permit.”

- Article 5 of EIA Directive relates to the obligation on developers to supply the information set out in Annex IV of the Directive when making an application for development consent.
- Article 6(1) requires Member States to ensure that the authorities likely to be concerned by a development by reason of their specific environmental responsibilities are consulted on the Environmental Statement and the request for development consent.
- Article 6(2)-6(6) makes provision for public consultation on applications for development consent.
- Article 7 relates to projects with transboundary effects and consequential obligations to consult with affected Member States.

The grant or refusal of development consent is a matter for the relevant local planning authority. The Environment Agency’s obligation is therefore to examine and use any relevant information obtained or conclusion arrived at by the local planning authorities pursuant to those EIA Directive articles.

In determining the Application we have considered the following documents: -

- The Environmental Statement submitted with the planning application (which also formed part of the Environmental Permit Application).
- The decision of Thurrock Thames Gateway Development Corporation (as local planning authority) to grant planning permission on 12 January 2012.
- The report and decision notice of the local planning authority accompanying the grant of planning permission.
- The response of the Environment Agency to the local planning authority in its role as consultee to the planning process.

From consideration of all the documents above, the Environment Agency considers that no additional or different conditions are necessary.

The Environment Agency has also carried out its own consultation on the Environmental Permitting Application which includes the Environmental Statement submitted to the local planning authority. The results of our consultation are described elsewhere in this decision document.

7.1.2 Schedule 9 to the EPR 2010 – Waste Framework Directive

As the Installation involves the treatment of waste, it is carrying out a *waste operation* for the purposes of the EPR 2010, and the requirements of Schedule 9 therefore apply. This means that we must exercise our functions so as to ensure implementation of certain articles of the WFD.

We must exercise our relevant functions for the purposes of ensuring that the waste hierarchy referred to in Article 4 of the Waste Framework Directive is applied to the generation of waste and that any waste generated is treated in accordance with Article 4 of the Waste Framework Directive. (See also section 4.3.9)

The conditions of the permit ensure that waste generation from the facility is minimised. Where the production of waste cannot be prevented it will be recovered wherever possible or otherwise disposed of in a manner that minimises its impact on the environment. This is in accordance with Article 4.

We must also exercise our relevant functions for the purposes of implementing Article 13 of the Waste Framework Directive; ensuring that the requirements in the second paragraph of Article 23(1) of the Waste Framework Directive are met; and ensuring compliance with Articles 18(2)(b), 18(2)(c), 23(3), 23(4) and 35(1) of the Waste Framework Directive.

Article 13 relates to the protection of human health and the environment. These objectives are addressed elsewhere in this document.

Article 23(1) requires the permit to specify:

- (a) the types and quantities of waste that may be treated;
- (b) for each type of operation permitted, the technical and any other requirements relevant to the site concerned;
- (c) the safety and precautionary measures to be taken;
- (d) the method to be used for each type of operation;
- (e) such monitoring and control operations as may be necessary;
- (f) such closure and after-care provisions as may be necessary.

These are all covered by permit conditions.

We consider that the intended method of waste treatment is acceptable from the point of view of environmental protection so Article 23(3) does not apply.

Energy efficiency is dealt with elsewhere in this document but we consider the conditions of the permit ensure that the recovery of energy take place with a high level of energy efficiency in accordance with Article 23(4).

Article 35(1) relates to record keeping and its requirements are delivered through permit conditions.

7.1.3 Schedule 22 to the EPR 2010 – Groundwater, Water Framework and Groundwater Daughter Directives

To the extent that it might lead to a discharge of pollutants to groundwater (a “groundwater activity” under the EPR 2010), the Permit is subject to the requirements of Schedule 22, which delivers the requirements of EU Directives relating to pollution of groundwater. The Permit will require the taking of all necessary measures to prevent the input of any hazardous substances to groundwater, and to limit the input of non-hazardous pollutants into groundwater so as to ensure such pollutants do not cause pollution, and satisfies the requirements of Schedule 22.

No releases to groundwater from the Installation are permitted. The Permit also requires material storage areas to be designed and maintained to a high standard to prevent accidental releases.

7.1.4 Directive 2003/35/EC – The Public Participation Directive

Regulation 59 of the EPR 2010 requires the Environment Agency to prepare and publish a statement of its policies for complying with its public participation duties. We have published our public participation statement.

This Application has been consulted upon in line with this statement, as well as with our guidance RGS6 on Sites of High Public Interest, which addresses specifically extended consultation arrangements for determinations where public interest is particularly high. This satisfies the requirements of the Public Participation Directive.

Our final decision in this case has been reached following a programme of extended public consultation, both on the original application and later, separately, on the draft permit and a draft decision document. The way in which this has been done is set out in Section 2. A summary of the responses received to our consultations and our consideration of them is set out in Annex 4.

7.2 National primary legislation

7.2.1 **Environment Act 1995**

(i) Section 4 (Pursuit of Sustainable Development)

We are required to contribute towards achieving sustainable development, as considered appropriate by Ministers and set out in guidance issued to us. The

Secretary of State for Environment, Food and Rural Affairs has issued *The Environment Agency's Objectives and Contribution to Sustainable Development: Statutory Guidance (December 2002)*. This document:

“provides guidance to the Agency on such matters as the formulation of approaches that the Agency should take to its work, decisions about priorities for the Agency and the allocation of resources. It is not directly applicable to individual regulatory decisions of the Agency”.

In respect of regulation of industrial pollution through the EPR, the Guidance refers in particular to the objective of setting permit conditions *“in a consistent and proportionate fashion based on Best Available Techniques and taking into account all relevant matters...”*. The Environment Agency considers that it has pursued the objectives set out in the Government's guidance, where relevant, and that there are no additional conditions that should be included in this Permit to take account of the Section 4 duty.

(ii) Section 7 (Pursuit of Conservation Objectives)

We considered whether we should impose any additional or different requirements in terms of our duty to have regard to the various conservation objectives set out in Section 7, but concluded that we should not.

We have considered the impact of the installation on local wildlife sites within 2Km which are not designated as either European Sites or SSSIs. We are satisfied that no additional conditions are required.

(iii) Section 81 (National Air Quality Strategy)

We have had regard to the National Air Quality Strategy and consider that our decision complies with the Strategy, and that no additional or different conditions are appropriate for this Permit.

7.2.2 Human Rights Act 1998

We have considered potential interference with rights addressed by the European Convention on Human Rights in reaching our decision and consider that our decision is compatible with our duties under the Human Rights Act 1998. In particular, we have considered the right to life (Article 2), the right to a fair trial (Article 6), the right to respect for private and family life (Article 8) and the right to protection of property (Article 1, First Protocol). We do not believe that Convention rights are engaged in relation to this determination.

7.2.3 Countryside and Rights of Way Act 2000 (CROW 2000)

Section 85 of this Act imposes a duty on Environment Agency to have regard to the purpose of conserving and enhancing the natural beauty of the area of outstanding natural beauty (AONB). There is no AONB which could be affected by the Installation.

7.2.4 Wildlife and Countryside Act 1981

Under section 28G of the Wildlife and Countryside Act 1981 the Environment Agency has a duty to take reasonable steps to further the conservation and enhancement of the flora, fauna or geological or physiographical features by reason of which a site is of special scientific interest. Under section 28I the Environment Agency has a duty to consult Natural England in relation to any permit that is likely to damage SSSIs.

We assessed the Application and concluded that the Installation will not damage the special features of any SSSI. This was recorded on a CROW Appendix 4 form, which we used to consult Natural England, who agreed with our conclusion. This is set out in their letter dated 3 March 2014, ref 112132 from Land Use Operations.

The CROW assessment is summarised in greater detail in section 5.4.3 of this document. A copy of the full Appendix 4 Assessment can be found on the public register.

7.2.5 Natural Environment and Rural Communities Act 2006

Section 40 of this Act requires us to have regard, so far as is consistent with the proper exercise of our functions, to the purpose of conserving biodiversity. We have done so and consider that no different or additional conditions in the Permit are required.

7.3 National secondary legislation

7.3.1 The Conservation of Natural Habitats and Species Regulations 2010

We have assessed the Application in accordance with guidance agreed jointly with Natural England and concluded that there will be no likely significant effect on any European Site.

An Appendix 11 assessment was sent to Natural England for information purposes.

The habitat assessment is summarised in greater detail in section 5.4.2 of this document. A copy of the full Appendix 11 Assessment can be found on the public register.

7.3.2 Water Framework Directive Regulations 2003

Consideration has been given to whether any additional requirements should be imposed in terms of the Environment Agency's duty under regulation 3 to secure the requirements of the Water Framework Directive through (inter alia) EP permits, but it is felt that existing conditions are sufficient in this regard and no other appropriate requirements have been identified.

7.3.3 The Persistent Organic Pollutants Regulations 2007

We have explained our approach to these Regulations, which give effect to the Stockholm Convention on POPs and the EU's POPs Regulation, above.

7.5 Other relevant legal requirements

7.5.1 Duty to Involve

S23 of the Local Democracy, Economic Development and Construction Act 2009 require us where we consider it appropriate to take such steps as we consider appropriate to secure the involvement of interested persons in the exercise of our functions by providing them with information, consulting them or involving them in any other way. S24 requires us to have regard to any Secretary of State guidance as to how we should do that.

The way in which the Environment Agency has consulted with the public and other interested parties is set out in section 2 of this document. The way in which we have taken account of the representations we have received is set out in Annex 4. Our public consultation duties are also set out in the EP Regulations, and our statutory Public Participation Statement, which implement the requirements of the Public Participation Directive. In addition to meeting our consultation responsibilities, we have also taken account of our guidance in Environment Agency Guidance Note RGS6 and the Environment Agency's Building Trust with Communities toolkit.

ANNEX 1: APPLICATION OF CHAPTER IV OF THE INDUSTRIAL EMISSIONS DIRECTIVE

IED Article	Requirement	Delivered by
45(1)(a)	The permit shall include a list of all types of waste which may be treated using at least the types of waste set out in the European Waste List established by Decision 2000/532/EC, if possible, and containing information on the quantity of each type of waste, where appropriate.	Condition 2.3.3 and Tables S2.2 and S2.3 in Schedule 2.
45(1)(b)	The permit shall include the total waste incinerating or co-incinerating capacity of the plant.	Condition 2.3.3 and Tables S2.2 and S2.3 in Schedule 2.
45(1)(c)	The permit shall include the limit values for emissions into air and water.	Conditions 3.1.1 and 3.1.2 and Tables S3.1 and S3.1(a) in Schedule 3.
45(1)(e)	The permit shall include the sampling and measurement procedures and frequencies to be used to comply with the conditions set for emissions monitoring.	Conditions 3.5.1 and Tables S3.1, S3.1(a), S3.2, S3.3 and S3.4, also compliance with Articles 10 and 11.
45(1)(f)	The permit shall include the maximum permissible period of unavoidable stoppages, disturbances or failures of the purification devices or the measurement devices, during which the emissions into the air and the discharges of waste water may exceed the prescribed emission limit values.	Conditions 2.3.6 to 2.3.11.
46(1)	Waste gases shall be discharged in a controlled way by means of a stack the height of which is calculated in such a way as to safeguard human health and the environment.	Emissions and their ground-level impacts are discussed in the body of this document.
46(2)	Emission into air shall not exceed the emission limit values set out in part of Annex VI.	Conditions 3.1.1 and 3.1.2 and Tables S3.1 and S3.1a.
46(3)	Relates to conditions for water discharges from the cleaning of exhaust gases.	There are no such discharges as condition 3.1.1 prohibits this.
46(4)	Relates to conditions for water	There are no such

IED Article	Requirement	Delivered by
	discharges from the cleaning of exhaust gases.	discharges as condition 3.1.1 prohibits this.
46(5)	Prevention of unauthorised and accidental release of any polluting substances into soil, surface water or groundwater. Adequate storage capacity for contaminated rainwater run-off from the site or for contaminated water from spillage or fire-fighting.	The application explains the measures to be in place for achieving the directive requirements
46(6)	Limits the maximum period of operation when an ELV is exceeded to 4 hours uninterrupted duration in any one instance, and with a maximum cumulative limit of 60 hours per year. Limits on dust (150 mg/m ³), CO and TOC not to be exceeded during this period.	Conditions 2.3.6 and 2.3.10 and Table S3.1(a)
47	In the event of breakdown, reduce or close down operations as soon as practicable. Limits on dust (150 mg/m ³), CO and TOC not to be exceeded during this period.	Conditions 2.3.6, 2.3.9, 2.3.10
48(1)	Monitoring of emissions is carried out in accordance with Parts 6 and 7 of Annex VI.	Schedule 6 details this standardisation requirement
48(2)	Installation and functioning of the automated measurement systems shall be subject to control and to annual surveillance tests as set out in point 1 of Part 6 of Annex VI.	Condition 3.5.3, and tables S3.1, S3.1(a), and S3.4
48(3)	The competent authority shall determine the location of sampling or measurement points to be used for monitoring of emissions.	Tables S3.1, S3.1(a) and S3.4
48(4)	All monitoring results shall be recorded, processed and presented in such a way as to enable the competent authority to verify compliance with the operating conditions and emission limit values which are included in the permit.	Conditions 4.1.1 and 4.1.2
49	The emission limit values for air and water shall be regarded as being complied with if the conditions described in Part 8 of Annex VI are	Condition 3.5.5 (b) to (e)

IED Article	Requirement	Delivered by
	fulfilled.	
50(1)	Slag and bottom ash to have Total Organic Carbon (TOC) < 3% or loss on ignition (LOI) < 5%.	Condition 3.5.1 and Table S3.5
50(2)	Flue gas to be raised to a temperature of 850°C for two seconds, as measured at representative point of the combustion chamber.	Condition 2.3.6 and Pre-operational condition PO7. The application specifies measurement point
50(3)	At least one auxiliary burner which must not be fed with fuels which can cause higher emissions than those resulting from the burning of gas oil liquefied gas or natural gas.	Condition 2.3.7
50(4)(a)	Automatic shut to prevent waste feed if at start up until the specified temperature has been reached.	Condition 2.3.6
50(4)(b)	Automatic shut to prevent waste feed if the combustion temperature is not maintained.	Condition 2.3.6
50(4)(c)	Automatic shut to prevent waste feed if the CEMs show that ELVs are exceeded due to disturbances or failure of waste cleaning devices.	Condition 2.3.6
50(5)	Any heat generated from the process shall be recovered as far as practicable.	The plant will generate electricity Operator to review the available heat recovery options prior to commissioning (Pre-operational condition PO2)
50(7)	Management of the Installation to be in the hands of a natural person who is competent to manage it.	Conditions 1.1.1 to 1.1.3 and 2.3.1 fulfil this requirement
51(1)	Different conditions than those laid down in Article 50(1), (2) and (3) and, as regards the temperature Article 50(4) may be authorised, provided the other requirements of this chapter are met.	No such conditions Have been allowed
51(2)	Changes in operating conditions do not cause more residues or residues with a higher content of organic polluting substances compared to those residues which could be expected under the conditions laid	No such conditions Have been included.

IED Article	Requirement	Delivered by
	down in Articles 50(1), (2) and (3).	
52(1)	Take all necessary precautions concerning delivery and reception of Wastes, to prevent or minimise pollution.	EPR require prevent or minimise pollution. The Supporting Information of the Application defines how this will be carried out. Conditions 2.3.1, 2.3.3, 3.2, 3.3 and 3.4
52(2)	Determine the mass of each category of wastes, if possible according to the EWC, prior to accepting the waste.	The Supporting Information of the Application describes procedures for the reception and monitoring of incoming waste
53(1)	Residues to be minimised in their amount and harmfulness, and recycled where appropriate.	Conditions 1.4.1 and 3.5.1
53(2)	Prevent dispersal of dry residues and dust during transport and storage.	Conditions 2.3.1 and 3.2.1
53(3)	Test residues for their physical and chemical characteristics and polluting potential including heavy metal content (soluble fraction).	Condition 3.5.1 and pre-operational condition PO3.
55(1)	Application, decision and permit to be publicly available.	All documents are accessible from the Environment Agency Public Register.
55(2)	An annual report on plant operation and monitoring for all plants burning more than 2 tonne/hour waste.	Condition 4.2.2

ANNEX 2: Pre-Operational Conditions

Based on the information on the Application, we consider that we do need to impose pre-operational conditions. These conditions are set out below and referred to, where applicable, in the text of the decision document. We are using these conditions to require the Operator to confirm that the details and measures proposed in the Application have been adopted or implemented prior to the operation of the Installation.

Ref.	Pre-operational measures
PO1	Prior to the commencement of commissioning, the Operator shall send a summary of the site Environment Management System (EMS) to the Environment Agency and make available for inspection all documents and procedures which form part of the EMS. The EMS shall be developed in line with the requirements set out in Section 1 of How to comply with your environmental permit. The documents and procedures set out in the EMS shall form the written management system referenced in condition 1.1.1 (a) of the permit.
PO2	Prior to the commencement of commissioning, the Operator shall send a report to the Environment Agency which will contain a comprehensive review of the options available for utilising the heat generated by the waste incineration process in order to ensure that it is recovered as far as practicable. The review shall detail any identified proposals for improving the recovery and utilisation of waste heat and shall provide a timetable for their implementation.
PO3	Prior to the commencement of commissioning, the Operator shall submit to the Environment Agency for approval a protocol for the sampling and testing of incinerator bottom ash for the purposes of assessing its hazard status. Sampling and testing shall be carried out in accordance with the protocol as approved.
PO4	Prior to the commencement of commissioning of each line; the Operator shall provide a written commissioning plan, including timelines for completion, for approval by the Environment Agency. The commissioning plan shall include the expected emissions to the environment during the different stages of commissioning, the expected durations of commissioning activities and the actions to be taken to protect the environment and report to the Environment Agency in the event that actual emissions exceed expected emissions. Commissioning shall be carried out in accordance with the commissioning plan as approved.
PO5	Prior to the commencement of commissioning, the Operator shall submit a written report to the Agency detailing the waste acceptance procedure to be used at the site. The waste acceptance procedure shall include the process and systems by which wastes unsuitable for incineration at the site will be controlled. The procedure shall be implemented in accordance with the written approval from the Agency.

PO6	<p>Prior to the commencement of commissioning of Line 1 (biomass), the Operator shall submit a written report for approval by the Environment Agency detailing the storage arrangements for processed and unprocessed biomass at the site. The storage arrangements shall have specific regard to TGN 7.01, or other such appropriate guidance as is adopted, for the storage of combustible materials and include specific details of the odour and dust control measures to be implemented.</p> <p>The storage arrangements and control measures shall be implemented in accordance with the written approval from the Environment Agency.</p>
PO7	<p>After completion of furnace design and at least three calendar months before any furnace operation; the operator shall submit a written report to the Agency of the details of the computational fluid dynamic (CFD) modelling. The report shall demonstrate whether the design combustion conditions comply with the residence time and temperature requirements as defined by Article 50(2) of the IED.</p>
PO8	<p>The Operator shall submit the written protocol referenced in condition 2.3.4 for the monitoring of soil and groundwater for approval by the Environment Agency. The protocol shall demonstrate how the Operator will meet the requirements of Articles 14(1)(b), 14(1)(e) and 16(2) of the IED.</p> <p>The procedure shall be implemented in accordance with the written approval from the Agency.</p>
PO9	<p>Prior to the commencement of construction of Line 2 (SRF) the Operator shall submit a report for approval by the Environment Agency detailing the design specification of the Line. The report shall include specific details of waste storage arrangements and the dust and odour control measures to be implemented (e.g. air-lock system). If there have been changes to the design which require a variation to the permit, an application for a variation shall be submitted to the Environment Agency prior to the commencement of construction of the Line.</p>

ANNEX 3: Improvement Conditions

Based in the information in the Application we consider that we need to set improvement conditions. These conditions are set out below - justifications for these is provided at the relevant section of the decision document. We are using these conditions to require the Operator to provide the Environment Agency with details that need to be established or confirmed during and/or after commissioning.

Ref.	Improvement measure	Completion date
IC1	The Operator shall submit a written report to the Environment Agency on the implementation of its Environmental Management System and the progress made in the certification of the system by an external body or if appropriate submit a schedule by which the EMS will be certified.	Within 12 months of the date on which waste is first burnt.
IC2	The Operator shall submit a written proposal to the Environment Agency to carry out tests to determine the size distribution of the particulate matter in the exhaust gas emissions to air from emission points A1 and A2, identifying the fractions within the PM ₁₀ , and PM _{2.5} ranges. The proposal shall include a timetable for approval by the Environment Agency to carry out such tests and produce a report on the results. On receipt of written agreement by the Environment Agency to the proposal and the timetable, the Operator shall carry out the tests and submit to the Environment Agency a report on the results.	Within 6 months of the completion of commissioning of each line.
IC3	The Operator shall submit a written report to the Environment Agency on the commissioning of the installation. The report shall summarise the environmental performance of the plant as installed against the design parameters set out in the Application. The report shall also include a review of the performance of the facility against the conditions of this permit and details of procedures developed during commissioning for achieving and demonstrating compliance with permit conditions.	Within 4 months of the completion of commissioning of each line.
IC4	The Operator shall carry out checks to verify the residence time, minimum temperature and oxygen content of the exhaust gases in the furnace whilst operating under the anticipated most unfavourable operating conditions. The results shall be submitted in writing to the Environment Agency.	Within 4 months of the completion of commissioning of each line.

Ref.	Improvement measure	Completion date
IC5	<p>The Operator shall submit a written report to the Environment Agency describing the performance and optimisation of the Selective Non Catalytic Reduction (SNCR) system and combustion settings to minimise oxides of nitrogen (NO_x) emissions within the emission limit values described in this permit with the minimisation of nitrous oxide emissions. The report shall include an assessment of the level of NO_x and N₂O emissions that can be achieved under optimum operating conditions.</p> <p>The report shall also provide details of the optimisation (including dosing rates) for the control of acid gases and dioxins</p>	<p>Within 4 months of the completion of commissioning of each line.</p>
IC6	<p>The Operator shall carry out an assessment of the impact of emissions to air of the following component metals subject to emission limit values, i.e. As, Cr, and Ni. A report on the assessment shall be made to the Environment Agency.</p> <p>Emissions monitoring data obtained during the first year of operation shall be used to compare the actual emissions with those assumed in the impact assessment submitted with the Application. An assessment shall be made of the impact of each metal against the relevant EQS/EAL. In the event that the assessment shows that an EQS/EAL can be exceeded, the report shall include proposals for further investigative work.</p>	<p>15 months from commencement of operations of each line.</p>
IC7	<p>The Operator shall submit a written summary report to the Agency to confirm by the results of calibration and verification testing that the performance of Continuous Emission Monitors for parameters as specified in Table S3.1 and Table S3.1(a) complies with the requirements of BS EN 14181, specifically the requirements of QAL1, QAL2 and QAL3.</p>	<p>Initial calibration report to be submitted to the Agency within 3 months of completion of commissioning of each line.</p> <p>Full summary evidence compliance report to be submitted within 18 months of commissioning of each line.</p>

ANNEX 4: Consultation Responses

A) Advertising and Consultation on the Application

The Application has been advertised and consulted upon in accordance with the Environment Agency's Public Participation Statement. The way in which this has been carried out along with the results of our consultation and how we have taken consultation responses into account in reaching our decision is summarised in this Annex. Copies of all consultation responses have been placed on the Environment Agency and Local Authority public registers.

The Application was advertised on the Environment Agency website from 19 December 2013 to 3 February 2014 and in the Thurrock Gazette on 19 December 2013. Copies of the Application were placed in the Environment Public Register at Icen House, Cobham Road, Ipswich, IP3 9JD and Thurrock Council Public Register at Civic Offices, New Road, Grays, RM17 6SL.

The following statutory and non-statutory bodies were consulted: -

- Local council (Thurrock) Planning Department
- Local council (Thurrock) Environmental Health
- Gravesham Council
- Public Health England (PHE)
- Director of Public Health
- Food Standards Agency (FSA)
- Health & Safety Executive (HSE)
- Local Fire & Rescue Service
- National Grid
- Thames Water
- Port of London Authority
- Port of Tilbury
- Civil Aviation Authority

1) Consultation Responses from Statutory and Non-Statutory Bodies

Response received from Thurrock Council , Environmental Health Officer (response dated 17 December 2013)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
<p>Planning conditions 29 to 32 relating to noise are applicable at the facility. These conditions include the following:</p> <ul style="list-style-type: none"> • provision of a noise and vibration management plan to include for monitoring; • arrangements in place for exceptionally noisy events e.g. emergencies, emergency pressure valve testing/operation. 	<p>We have undertaken a detailed assessment of the noise impact assessment as detailed in Section 6.5.5 of this document. We are satisfied that the appropriate measures will be in place. We do not expect noise to be an issue; however permit condition 3.4.2 requires submission and implementation of a noise management plan should it be required.</p>
<p>Specific points that would require attention are air quality, odours, particulates (timber handling) and operational noise.</p>	<p>We have undertaken detailed assessments as described in this document and we are satisfied that impacts will not be significant.</p> <p>These points are addressed by specific permit conditions:</p> <p>Air Quality: conditions 3.1.1 and 3.1.2 (ELVs set in Schedule 3)</p> <p>Odours: conditions 3.3.1 and 3.3.2</p> <p>Fugitives (particulate): conditions 3.2.1 and 3.2.2 and pre-operational condition P06</p> <p>Noise: conditions 3.4.1 and 3.4.2</p>

Response received from **Gravesham Borough Council**, Senior Environmental Health Officer, Environmental Protection Team, Regulatory Services (response received electronically 03 January 2014) and Service Manager, Development Control Planning and Regeneration Services, dated 14 January 2014

Brief summary of issues raised:	Summary of action taken / how this has been covered
That the site is located on the opposite side of the River Thames to Gravesham Borough and they would not wish to see any increase in existing background noise levels to properties in this area as a result of the development.	We have undertaken a detailed audit of the noise impact assessment as detailed in Section 6.5.5 of this document. We are satisfied that the appropriate measures will be in place.

Response received from **Civil Aviation Authority (CAA)**, CAA Airspace, ATM and Aerodromes, Safety and Airspace Regulation Group (response dated 02 January 2014)

Brief summary of issues raised:	Summary of action taken / how this has been covered
This response indicated they were not required to respond to planning applications; however it then clarified situations when it was necessary to consult which included a development with structures of a height of 90 metres or more.	It is proposed that the facility will have 2 x 100 metres exhaust stacks so we sent an additional consultation to the address indicated in this response.

Response received from **Civil Aviation Authority (CAA)**, Airspace Regulator, Safety and Airspace Regulation Group (response received electronically 09 January 2014)

Brief summary of issues raised:	Summary of action taken / how this has been covered
Some of the points raised were applicable to the planning process which included the requirement to check any aerodrome safeguarding maps, aviation issues and the requirement for aviation warning lights on the stacks.	It is the responsibility of the Local Planning Authority to consider matters applicable to the planning process. The lighting of the flue stacks has been included as a planning condition.
It is assumed that the CHP plant is not intended to vent or flare gas either routinely or as an emergency procedure such as to cause danger to overlying aircraft.	There are no proposals to vent or flare gas in the Application.

Response received from **Public Health England (PHE)**, Environmental Public Health Scientist, Environmental Hazards and Emergencies Department (EHE) (response dated 15 January 2014)

Brief summary of issues raised:	Summary of action taken / how this has been covered
Requested that we consider reporting any significant and/or prolonged breaches of authorised limits of atmospheric emissions.	<p>If a Permit is issued we will start a continued assessment of the plant operations and its environmental performance in a number of ways:</p> <ul style="list-style-type: none"> - Operators must monitor emissions at given times and report the results to us. - We regularly inspect Installations (announced and unannounced), review monitoring techniques and assess monitoring results to measure the performance of the plant. - We undertake auditing of operator monitoring. - Operators must inform us immediately of any breach of the emissions limits, followed by a fuller report of the size of the release, its impact and how they propose to avoid this happening in the future. - Operators monitoring results are placed on the public registers. -We will take appropriate enforcement action and/or prosecute depending on the seriousness of any breach.
That we may wish to ensure that the time periods used for the measurement of background concentrations represent a typical worst case scenario relevant to current air quality in the vicinity of the Installation. (the Applicant has reviewed older data)	We have audited the Applicant's Air Quality modelling and carried out our own check modelling. The Applicant has used older data; however this background data is more conservative and represents a worst case scenario.
That the Installation will contribute to air quality (nitrogen dioxide) within the AQMAs, independent of the background concentrations; therefore the proposals should be to the satisfaction of the relevant local authorities who are responsible for local air quality management.	We have consulted with the relevant local authorities (see above) and they have not raised any issues with respect to this matter.
That the local authority is consulted on potential impacts from noise on nearby residential properties.	We have consulted with the relevant local authorities (see above) who have raised concerns about increases

	<p>in noise levels.</p> <p>We have also carried out our own assessment (see above).</p>
<p>That the local authority is consulted on matters relating to contaminated land, odour, dust and other nuisance emissions.</p>	<p>We have consulted with the relevant local authorities (see above) who have raised concerns. We have addressed these above.</p>
<p>That little information is provided on the recovery, storage and transport of bottom ash or fly ash and that we may like to ensure that any measures taken are adequate and will not result in any off-site impact to public health.</p>	<p>If a permit it issued it will require an Environmental Management System (EMS) to be in place. The EMS covers the design and installation of suitable equipment, operation and maintenance, accidents, training of staff and operating instructions. A pre-operational condition is included requiring the Operator to provide a summary of the EMS prior to commissioning of the plant and to make available for inspection all EMS documentation.</p> <p>The Application confirms that bottom ash from the grate will be transported by the grate to the bottom of the hearth and into a water filled quench pit. A conveyor will then transport the wet ash to the ash storage bunker.</p> <p>Loading of bottom ash into vehicles will be undertaken in areas of hardstanding. Bottom ash will be transferred off-site in covered vehicles.</p>
<p>PHE is aware of incidents of odour complaints associated with natural degradation of wood chip that is stored for prolonged periods. It was noted that the storage areas will be indoors but it is not clear how long the pellets could potentially be stored.</p> <p>That we may like to ensure that the Operator is aware of this potential issue and takes steps to mitigate any potential odour risk.</p>	<p>Our assessment is detailed in Sections 6.5.3 and 6.5.4 of this document. We have set a pre-operational condition requiring the submission of biomass storage details for approval.</p> <p>We are satisfied that the appropriate measures will be in place to prevent/minimise odour.</p>
<p>That as the Installation will store and process waste wood we may wish to ensure that appropriate consideration is given to the implementation of fire</p>	<p>An accident management plan will be required as part of the site's EMS. The Applicant will also consult with local fire officers (Section 2.1.4.5 of</p>

<p>prevention measures, and measures to minimise the public health impacts in the event of a fire incident, such as fire breaks and adequate access for fire fighting.</p>	<p>the Application Supporting information) to ensure that fire fighting measures are designed with particular attention paid to the fuel reception and storage building.</p> <p>We have also incorporated TGN 7.01 into the Permit operating techniques as detailed in Section 4.3.6 of this document.</p>
<p>That the FSA is consulted on the potential for deposition of pollutants on land used for the growing of food crops or animal rearing.</p>	<p>We have consulted with the FSA in our letter dated 13 December 2013. We sent a reminder 22 April 2014 to remind them that comments were overdue.</p>
<p>That the Director of Public Health is consulted on matters relating to wider public health impacts.</p>	<p>We have consulted with the Director of Public Health and have received a response, see below.</p>

Response received from Director of Public Health , Adults Health and Commissioning, Thurrock Council (response dated 26 January 2014)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
That they support the recommendations made by Public Health England that:	
Requested that we consider reporting any significant and/or prolonged breaches of authorised limits of atmospheric emissions.	See Public Health England comments above.
That we may wish to ensure that appropriate methodology has been followed in determining background concentrations of chemicals in the vicinity of the Installation.	See Public Health England comments above.
That we may wish to confirm that on-site procedures are sufficient to prevent any emissions off-site of bottom ash or fly ash particles.	See Public Health England comments above.
That we may wish to ensure that the Applicant has considered the potential for odour from the storage of wood chippings and has measures in place to mitigate this.	See Public Health England comments above.
That we should ensure that the Applicant has an accident management plan that: <ul style="list-style-type: none"> • identifies all potential hazards in relation to all of the proposed operations; • assesses the risk associated with the hazards (e.g. fire) including an assessment of the potential impact on human health (e.g. on local residents); and • identifies the measures to prevent or mitigate the risks. 	An accident management plan will be required as part of the site's EMS, see above.
That they are not aware of any local health issues that are relevant in relation to this process.	

Response received from Essex County Fire & Rescue Service , Fire Safety Officer (response dated 13 February 2014)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
That the Applicant has been in consultation with the Fire and Rescue Service with regard to fire-fighting measures. That they are following the	The Permit requires the Applicant to follow the TGN 7.01 for 'Reducing fire risk at sites storing combustible materials.' This will be included in the

<p>Wood Recycling Industry Guidance on the Safe Storage of Combustible Material. It was stated that this guidance has been produced with assistance from the Chief Fire Officers Association (CFOA) and other agencies. The Applicant has agreed to include the following:</p> <ul style="list-style-type: none"> • Water supplies for fire-fighting; • Extensions to the dock fire water main; • Fire pumps and fire fighting equipment; • Fire water run-off interceptors and collection for re-cycling and removal; • Provision of access for emergency vehicles; • Fire fighting monitors for early intervention in a fire; • Mobile water mist cannon which can be employed to provide a water curtain to help suppress sparks and radiated heat. 	<p>accident management plan which will form part of the EMS and must be in place prior to commissioning as required by a pre-operational condition.</p>
---	---

<p>Response received from Port of London Authority (response received electronically 18 February 2014)</p>	
<p>Brief summary of issues raised:</p>	<p>Summary of action taken / how this has been covered</p>
<p>That it is disappointing that delivery by river has not been utilised. If there were future opportunities to increase this then they would be encouraging discussions.</p>	<p>Delivery of materials to the Installation are relevant considerations for the grant of planning permission. They do not form part of the Environmental Permit decision making process.</p>

2) Consultation Responses from Members of the Public and Community Organisations

A total of two consultation responses were received. A number of the issues raised were outside the Environment Agency’s remit in reaching its permitting decisions. Specifically questions were raised which fall within the jurisdiction of the planning system, both on the development of planning policy and the grant of planning permission.

Guidance on the interaction between planning and pollution control is given in PPS23. It says that the planning and pollution control systems are separate but complementary. We are only able to take into account those issues, which fall within the scope of the Environmental Permitting Regulations.

a) Representations from Community and Other Organisations

A representation was received from Allied Mills as follows:

Response received from Allied Mills – Tilbury Flour Mill, Environmental Coordinator	
Brief summary of issues raised:	Summary of action taken / how this has been covered
That the mill is an immediate neighbour and concerned that fugitive emissions such as wood, dust and waste are adequately controlled and will cause no food safety, health and safety or environmental issues on site. e.g. waste or wood chippings do not enter their process. Concerned that wood storage/shredding located near to wheat intake, also fugitive emissions from raw material delivery or waste collection activities.	We have addressed this in section 6.5.3 of this document. Also refer to response from PHE above.
Concerned that the flood risk has been adequately addressed and controlled and that the proposed facility has not increased their own flood risk.	The Environment Agency provides advice and guidance to the local Planning Authority on flood risk in our consultation response to the local planning authority. Our advice on these matters is normally accepted by both Applicant and Planning Authority. When making permitting decisions, flood risk is still a relevant consideration, but only in so far as it is taken into account in the accident management plan and that appropriate measures are in place to

	prevent pollution in the event of a credible flooding incident.
Concerned that fire/dust explosion risk has been adequately assessed and controlled. Main concerns are the wood storage and shredding area, located near to the grain terminal conveyor and their wheat intake, mill and warehousing buildings	<p>We have consulted with Essex County Fire & Rescue Service, see comments above.</p> <p>An accident management plan will also be required as part of the site's EMS.</p> <p>We have also set a pre-operational condition requiring specific details of the dust control measures to be implemented.</p>
That in 2013 issues were raised with Tilbury Green Power Limited about dust emissions from current chipping operations on site.	<p>Biomass processing will take place inside an enclosed building.</p> <p>Permit conditions 3.2.1 and 3.2.2 for fugitives (particulate) ensure that the necessary controls will be in place.</p>
<p>That it is not clear whether the Tilbury Flour Mill (immediate neighbour) has been adequately considered. As a food factory they are concerned that the facility especially wood storage/shredding area does not pose an increased risk to flooding, fire/dust explosion, health and safety or food safety.</p> <p>Also concerned that the facility will not pose an increased risk of pest infestation.</p>	<p>These points are addressed by specific permit conditions:</p> <p>Wood storage: condition 2.3.1 (incorporation of TGN7.01 in Table S1.2)</p> <p>Fugitives (particulate): conditions 3.2.1 and 3.2.2</p> <p>Fire/dust: a pre-operational condition requires specific details of the storage arrangements for combustible materials and dust control measures to be implemented.</p> <p>Pest infestation: conditions 3.6.1 and 3.6.2</p>
Concerned about the increased traffic movements on an already busy dock and adequate signage at entrance to ensure vehicles do not miss the facility and enter their site by mistake.	Vehicle access to the Installation and traffic movements are relevant considerations for the grant of planning permission. They do not form part of the Environmental Permit decision making process except where there are established high background concentrations contributing to poor air quality and the increased level of traffic might be significant in these limited circumstances.

b) Representations from Individual Members of the Public

One response was received from an individual member of the public. This was in favour of the facility because it produces energy from waste which may benefit the community by producing cheaper electricity and reducing the cost of waste removal.

A drop-in event was attended by nine people, who were a mixture of local councillors and representatives from local businesses that may potentially be impacted by the proposed facility.

B) Advertising and Consultation on the Draft Decision

This section reports on the outcome of the public consultation on our draft decision carried out between 12 June and 10 July 2014.

Where the issues raised in the consultation are the same as those raised previously (and already reported in section A of this Annex) we do not repeat our response and reference should be made to section A for an explanation of the particular concerns or issues.

Where consultation responses are on matters which are outside the scope of the Environment Agency's powers under the Environmental Permitting Regulations, our position on these matters is as described previously.

a) Consultation Responses from Statutory and Non-Statutory Bodies

We sent our draft decision documents to the statutory and non-statutory bodies listed in Section A) of this Annex. Further comments were received from the following bodies:-

Response received from Civil Aviation Authority (CAA) , Airspace Regulator, Safety and Airspace Regulation Group (response received electronically 11 June 2014)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
Stated that the CAA's response remains as previously described in the email dated 9 January 2014.	Refer to the response in section A of this Annex.

Response received from Gravesham Borough Council , Senior Environmental Health Officer, Environmental Protection Team, Regulatory Services (response received electronically 8 July 2014)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
Confirmed that they had no comments to make.	No action required.

Response received from Public Health England , Environmental Public Health Scientist, Centre for Radiation, Chemical and Environmental Hazards (response dated 4 July 2014)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
Confirmed that the recommendations in their original response had been addressed appropriately and that they had no further comments to make.	No action required.

Response received from Port of London Authority , Environment Officer, (response received electronically 14 July 2014)	
Brief summary of issues raised:	Summary of action taken / how this has been covered
That it was not clear how the waste was being stored on receipt at site and whether there is any potential for litter generation (and hence litter blowing onto the river). Suggested that a condition is added to cover litter management.	<p>These points are addressed by specific permit conditions:</p> <p>Fugitives (includes litter): conditions 3.2.1 and 3.2.2</p> <p>Waste wood storage: condition 2.3.1 (incorporation of TGN7.01 in Table S1.2) and a pre-operational condition</p> <p>SRF storage: a pre-operational condition</p>

b) Representations from others, e.g. Local MP, Councillors, Parish / Town / Community Councils, Community Organisations, Individual Members of the Public

We did not receive any responses from other groups or individuals.