

Environment Agency

Review of an Environmental Permit under the Environmental Permitting (England & Wales) Regulations 2010 (as amended)

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/AP3139LE
The Operator is: National Grid Gas PLC
The Installation is: Aylesbury Compressor Station
This Variation Notice number is: EPR/AP3139LE/V003

What this document is about

All Environmental permits which permit the operation of large combustion plant (LCP), as defined by articles 28 and 29 of the Industrial Emissions Directive (IED), need to be varied to implement the special provisions for LCP given in the IED, by the 1 January 2016 (Article 82(3)). The IED makes special provisions for LCP under Chapter III, introducing new Emission Limit Values (ELVs) applicable to LCP, referred to in Article 30(2) and set out in Annex V.

The IED provides a period of transition towards the new ELVs via Article 32, the Transitional National Plan (TNP). It also makes provision for plant that wish to be exempted from compliance with the new ELVs in Article 33, the Limited Life Derogation (LLD). Other derogations include limited operating hour regimes for sites using 500 hr or 1500 hr derogations. There are also options for exemption from emission limits based on operating hours.

The operator has submitted a response to our notice requiring information, issued under regulation 60(1) of the Environmental Permitting Regulations (EPR), which has provided us with information on which compliance route they wish to follow for each LCP. The response also includes specific details relating to each LCP, necessary for accurate implementation the IED requirements. A copy of the regulation 60 notice and the operator's response is available on the public register.

We have reviewed the permit for this installation, including all variations since the last permit consolidation, and referred to the operator's response to the regulation 60 notice requiring information. This is our decision document, which explains the reasoning for the consolidated variation notice that we have issued.

It explains how we have reviewed and considered the compliance routes and, where relevant, the emissions limits proposed by the operator for each LCP on the installation. This review has been undertaken with reference to the:

- Chapter III and annex V of the IED
- “IED BAT ESI Review Paper, 28 October 2014” produced by the Environment Agency (referred to as the “2014 ESI BAT review paper” in this document)
- “Electricity Supply Industry – IED compliance protocol for Utility Boilers and Gas Turbines”, published by the Joint Environmental Programme.

It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

As well as implementing the chapter III IED compliance of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issue. It also modernises the entire permit to reflect the conditions contained in our current generic permit template. The notice also incorporates changes made by the operator to meet the IED emission limits by the installation of catalytic oxidation and two further improvement conditions related to this.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been deleted because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to chapter III review and the changes to the operation of the installation to comply with the IED emission limits.

How this document is structured

Glossary

1. Our decision
2. How we reached our decision
3. The legal framework
4. Key Issues

Annex 1 – Review and assessment of changes that are not part of the Chapter III IED derived permit review.

GLOSSARY

Baseload	means: (i) as a mode of operation, operating for >4000hrs per annum; and (ii) as a load, the maximum load under ISO conditions that can be sustained continuously, i.e. maximum continuous rating
BAT	best available techniques
BREF	best available techniques reference document
CCGT	combined cycle gas turbine
Derogation	as set out in Article 15(4) of the IED
Emergency use	<500 operating hours per annum
ELV	emission limit value set out in either IED or LCPD
GT	gas turbine
IED	Industrial Emissions Directive 2010/75/EC
LCP	large combustion plant – combustion plant subject to Chapter III of IED
LCPD	Large Combustion Plant Directive 2001/80/EC
LLD	Limited Life Derogation
MCR	Maximum Continuous Rating
MSUL/MSDL	Minimum start up load/minimum shut-down load
OCGT	Open Cycle Gas Turbine
Part load operation	operation during a 24 hr period that includes loads between MSUL/MSDL and maximum continuous rating (MCR)
TNP	Transitional National Plan

1 Our decision

We have decided to issue the Variation Notice to the operator. This will allow it to continue to operate the Installation, subject to the conditions in the Consolidated Variation Notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The Consolidated Variation Notice contains many conditions taken from our standard Environmental Permit template including the relevant annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information relating to the requirements of Chapter III of and Annex V to the IED

We issued a Notice under Regulation 60(1) of the Environmental Permitting (England and Wales) Regulations 2010 (a Regulation 60 Notice) on 31/10/14 requiring the operator to provide information for each LCP they operate, including:

- The type of plant, size and configuration.
- The proposed compliance routes.
- Minimum start up and shut down loads.
- The proposed emission limits and how they accord with the 2014 BAT review paper.
- For gas turbines, proposed emission limits for each unit between the MSUL/MSDL and 70% load, with a justification.

The Regulation 60 Notice response from the operator was received on 26/03/15

We considered that the response did not contain sufficient information for us to commence determination of the permit review. We therefore issued a further information request to the operator. Suitable further information was provided by the operator on 30/07/15.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that determination.

The operator made no claim for commercial confidentiality. We have not received any information in relation to the Regulation 60 Notice response that appears to be confidential in relation to any party.

The Secretary of State has given notice that aspects of the original application shall not be placed on the public register or consulted upon for reasons of national security.

2.2 Requests for Further Information during determination

Although we were able to consider the Regulation 60 Notice response generally satisfactory at receipt, we did in fact need more information in order to complete our permit review assessment, and issued a further information

request on 16/10/15. A copy of the further information request was placed on our public register.

In addition to the responses to our further information requests, we received additional information during the determination from National Grid Gas PLC which included a description of the new abatement system to be installed at the installation and an assessment of its impact on 28/09/15. We made a copy of this information available to the public in the same way as the response to our information request.

2.3 Alternative compliance routes

In their Regulation 60 Notice response, the operator initially requested multiple compliance routes be considered for their LCP because at that point they had not decided which route they wanted to apply. The routes requested were: ELV's, 500 hour emergency operation and Limited Life Derogation.

We were only able to issue the variation notice for single compliance routes per LCP (other than TNP which can apply by pollutant), and the operator confirmed which routes they wanted in the variation notice by email dated 20/08/15. The confirmed routes were:

LCP231 – 500 hour emergency operation

LCP232 - ELV

This is what is considered in this decision document.

3 The legal framework

The Consolidated Variation Notice will be issued under Regulations 18 and 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that, in issuing the Consolidated Variation Notice, it will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

Meeting the requirements of the IED

The table below shows how each requirement of the IED has been addressed by the permit conditions.

IED Article Reference	IED requirement	Permit condition
30(6)	If there is an interruption in the supply of gas, an alternative fuel may be used and the permit emission limits deferred for a period of up to 10 days, except where there is an overriding need to maintain energy supplies. The EA shall be notified immediately.	Not applicable
32(4)	For installations that have applied to derogate from the IED Annex V emission limits by means of the transitional national plan, the monitoring and reporting requirements set by UK Government shall be complied with.	Not applicable
33(1)b	For installations that have applied to derogate from the IED Annex V emission limits by means of the Limited Life Derogation, the operator shall submit annually a record of the number of operating hours since 1 January 2016;	Not applicable
37	Provisions for malfunction and breakdown of abatement equipment including notifying the EA.	2.3.7, 3.1.3, 4.2.2e, 4.2.5, 4.3.1d, 4.3.2
38	Monitoring of air emissions in accordance with Ann V Pt 3	3.5, 3.6
40	Multi-fuel firing	Not applicable
41(a)	Determination of start-up and shut-down periods	4
72b	For combustion plants which do not operate more than 1500 operating hours per year as a rolling average over a period of 5 years, the number of operating hours per year.	Not applicable
Ann V Pt 1(1)	All emission limit values shall be calculated at a temperature of 273,15 K, a pressure of 101,3 kPa and after correction for the water vapour content of the waste gases and at a standardised O ₂ content of 6 % for solid fuels, 3 % for combustion plants, other than gas turbines and gas engines using liquid and gaseous fuels and 15 % for gas turbines and gas engines.	Schedule 6, Interpretation
Ann V Pt 1	Emission limit values	3.1.2 Schedule 3, Table S3.1
Ann V Pt 1	For plants operating less than 500 hours per year, record the used operating hours	2.3.5, 4.2.2d
Ann V Pt 1(6(1))	Definition of natural gas	Schedule 6, Interpretation
Ann V Pt 2	Emission limit values	3.1.2 Schedule 3, Table S3.1
AnnV Pt 3(1)	Continuous monitoring for >100MWth for specified substances	3.5, 3.6 Schedule 3, Table S3.1

IED Article Reference	IED requirement	Permit condition
AnnV Pt 3(2, 3, 5)	Monitoring derogations	3.5.1 Schedule 3, Table S3.1
AnnV Pt3(4)	Measurement of total mercury	Not applicable
AnnV Pt3(6)	EA informed of significant changes in fuel type or in mode of operation so can check Pt3 (1-4) still apply	2.3.1 Schedule 1, Table S1.2
AnnV Pt3(7)	Monitoring requirements	3.5.1 Schedule 3, Table S3.1
AnnV Part 3(8,9,10)	Monitoring methods	3.5, 3.6
AnnV Pt 4	Monthly, daily, 95%ile hourly emission limit value compliance	3.5.1 Schedule 3, Table S3.1
AnnV Pt7	Refinery multi-fuel firing SO2 derogation	Not applicable

4. Key Issues

The operator has carried out tests to justify the Net Rated Thermal Input to each LCP. These tests were based on the maximum flow of fuel (gas) into the turbine multiplied by the net calorific value (ncv) of the fuel, carried out at the maximum fuel flow. Fuel flow rates and the ncv were subject to testing to ISO standard. As these tests are repeatable and provide an absolute measure of the thermal input to the plant, we accept these figures.

As the plant is a mechanical drive gas turbine, no electricity is produced so precluding using electrical output to determine when the plant is in Start-up/Shut-down. In place of this the operator has proposed using three measured operational criteria in place of electrical output and has provided evidence of the trigger values for each of these criteria. We accept these criteria in place of an electrical output

The operator has selected to apply the 500hr/y derogation to LCP231 (Unit A). Whilst the derogation allows for no emission limits nor monitoring of the plant, the existing permit includes both monitoring and emission limit; these have been applied to the permit under the 'no adverse change' principal.

The operator has selected to comply with the Annex V ELV's for LCP232 (Unit B) and is retro-fitting catalytic oxidation abatement for carbon monoxide to the unit in order to comply with the ELV's. This has been subject to a BAT assessment and air dispersion modelling (see Annex 1). The operator has proposed an emission limit for carbon monoxide of 1250mg/m³ for low load operation. The air dispersion modelling indicates there will be no significant effect from this emission and it is a decrease from the existing 2000mg/m³ ELV. However the permit imposes further controls including:

- monitoring the number operational hours at low-load
- an improvement condition to assess the performance of the abatement plant with a view to further reducing the low-load carbon monoxide limit.
- an improvement condition to assess the possible generation of formaldehyde within the exhaust gas

Unless the decision document specifies otherwise we have accepted the applicant's proposals.

Where relevant and appropriate, we have incorporated the techniques described by the operator in their Regulation 60 Notice response as specific operating techniques required by the permit, through their inclusion in Table S1.2 of the Consolidated Variation Notice.

The variation notice uses updated LCP numbers in accordance with the most recent DEFRA reference numbers. The LCP references have changed as follows:

- **LCP 214** is changed to **LCP 231**
- **LCP 215** is changed to **LCP 232**

LCP231

This LCP consists of a single 50.5 MWth OCGT which vents via a single windshield at emission point A1. The unit burns natural gas.

Compliance Route:

The operator has proposed to operate this LCP under the 500 hour emergency plant compliance route. No ELVs are therefore applicable for LCP231, but the monitoring arrangements as previously permitted have been retained under the 'no adverse changes' principle.

Net Rated Thermal Input:

The Applicant has stated that the Net Thermal Input is 50.5MWth. They have justified this figure by providing details of a test carried out on 10/12/2009 which used the maximum fuel flow (measured to ISO 5167:2003) and net calorific value of the fuel (measured to ISO 6976:1995) to obtain the Net Thermal Input when fuel flow is at its maximum.

Minimum start up load and Minimum shut-down load:

The operator has defined the "minimum start up load" and "minimum shut-down load" for the LCP in their response to question 6 of the Reg 60, in terms of three discrete processes or thresholds for operational parameters that suit the technical characteristics of the plant, which can be met at the end of start-up or start of shut-down.

We agree with all of these definitions and have set these thresholds in table S1.4 of the permit accordingly. Standard permit condition 2.3.6 has been set to define the period of start up and shut down, referring to the thresholds in this table.

Emission limits:

Annex V of the IED does not include any emission limits for plant operating under the 500 hour emergency plant derogation. The existing emission limits have therefore been removed from the permit.

Sulphur dioxide emissions from natural gas firing will be reported on the basis of the fuel sulphur content without continuous or periodic monitoring since only trace quantities of sulphur are present in UK natural gas. Likewise, dust emissions from natural gas firing will be reported on the basis of emission factors without continuous or periodic monitoring. Natural gas is an ash-free fuel and high efficiency combustion does not generate additional particulate matter. The fuel gas is always filtered and, in the case of gas turbines, the inlet air is also filtered resulting in a lower dust concentration in the flue than in the surrounding air.

LCP232

This LCP consists of a single 52.6 MWth OCGT which vents via a single windshield at emission point A2. The unit burns natural gas.

Compliance Route:

The operator has proposed to operate this LCP under the ELV compliance route.

Net Rated Thermal Input:

The Applicant has stated that the Net Thermal Input is 52.6MWth. They have justified this figure by providing details of a test carried out on 26/01/2010 which used the maximum fuel flow (measured to ISO 5167:2003) and net calorific value of the fuel (measured to ISO 6976:1995) to obtain the Net Thermal Input when fuel flow is at its maximum.

Minimum start up load and Minimum shut-down load:

The operator has defined the “minimum start up load” and “minimum shut-down load” for the LCP in their response to question 6 of the Reg 60, in terms of three discrete processes or thresholds for operational parameters that suit the technical characteristics of the plant, which can be met at the end of start-up or start of shut-down.

We agree with all of these definitions and have set these thresholds in table S1.4 of the permit accordingly. Standard permit condition 2.3.6 has been set to define the period of start up and shut down, referring to the thresholds in this table.

Emission limits:

The operator has proposed limits in line with annex V of the IED and the 2014 BAT review paper although they have used the Daily Limit where the Monthly one should apply. Consequently we have applied the annex V limits and incorporated them into table S3.1 of the permit.

LCP	Parameter	Period	Existing ELV	Reg60 ELV	New ELV
232	NOx	Monthly	-	68	75
		Daily	100	75	82
		Hourly	200	150	150
		Low Load	-	75	82
	CO	Monthly	-	91	100
		Daily	2000	100	110
		Hourly	2000	100	200
		Low Load	-	1250	1250

Sulphur dioxide emissions from natural gas firing will be reported on the basis of the fuel sulphur content without continuous or periodic monitoring since only trace quantities of sulphur are present in UK natural gas. Likewise, dust emissions from natural gas firing will be reported on the basis of emission factors without continuous or periodic monitoring. Natural gas is an ash-free fuel and high efficiency combustion does not generate additional particulate matter. The fuel gas is always filtered and, in the case of gas turbines, the inlet air is also filtered resulting in a lower dust concentration in the flue than in the surrounding air.

The IED Annex V ELVs for oxides of nitrogen and carbon monoxide apply to OCGTs, CCGTs and mechanical drive gas turbines when the load is >70%. This has been interpreted as 70% of the rated output load. The rated output load used here is the same as that used for calculating the percentage load when specifying the end of start-up and beginning of shut-down.

“Low Load” Gas Turbine Emission Limits set when the load varies between MSUL/MSDL and base load during the daily reference period: IED Annex V ELVs for GTs apply when the load is >70%. The operator has proposed the following limits:

- Oxides of nitrogen – 82mg/m^3
- Carbon Monoxide – 1250mg/m^3

when the load varies between MSUL/MSDL and base load during the daily reference period.

They have provided air dispersion modelling data demonstrating that these emissions will not cause significant pollution. We have reviewed the operator's assessment of the environmental risk and consider it to be satisfactory for the substances specified. IED Annex V ELVs still apply for operation at >70% load.

However, a report, due to be issued shortly by the Joint Environmental Programme, indicates that emissions at or above levels of 440mg/Nm^3 carbon monoxide, there may be implications for ambient air quality to do with levels of formaldehyde. Because of this Improvement Condition IC8 requires the operator to undertake an air quality assessment for formaldehyde.

Installation

Energy efficiency:

The installation does not have CHP. In line with the DEFRA Part A guidance, to report on the scope for further improvement, a condition has been included for the operator to carry out a 4-yearly efficiency review.

Reporting efficiency:

In order to ensure the efficiency of plant using fossil fuels or biomass is maximised and regularly recorded, condition 1.2.1(c), condition 4.2.2(b) and table S4.2 have been added to the permit.

Notifications:

Schedule 5, Part C, takes account of the malfunction and breakdown requirements. A breach of permit condition is NOT implicit in notification under Part C.

Monitoring & standards:

Standards for assessment of the monitoring location and for measurement of oxygen, water vapour, temperature and pressure have been added to the permit template for clarity.

Resource efficiency metrics:

A more comprehensive suite of reporting metrics has been added to the permit template for ESI plant. Table S4.2 "Resource Efficiency Metrics" has been added requiring the reporting of various resource parameters, as this is an Electrical Supply Industry (ESI) power plant. This table is being used for all ESI plant.

Additional IED Chapter II requirements:

Condition 3.1.6 relating to protection of soil, groundwater and groundwater monitoring, has been added in compliance with IED requirements.

Conditions 4.3.1 and 4.3.2 relating to notifications have been amended in compliance with IED requirements.

Annex 1: Review and assessment of changes that are not part of the Chapter III IED derived permit review.

This annex should be read in conjunction with the Regulation 60 Notice response received on 26/03/15, the additional information received on 28/09/15 and the variation notice.

The existing permit includes emission limits for carbon monoxide (CO) of 2000mg/m³ as a daily average for both Units. Daily averages reported over the last two years are in the range 800 to 1100 mg/m³. The operator has carried out an assessment of the Best Available Technologies (BAT) available to meet the equivalent 110 mg/m³ IED emission limit, together with an assessment of the environmental impact of the proposed changes.

BAT Assessment

National Grid Gas PLC has developed a BAT Assessment Tool that fits with the company's business strategy and principles. It looks at the whole-life cost of a project and its approach is supported by OFGEN and the Environment Agency.

This tool has been used to screen six different options to reduce CO emissions from the installation, including fitting of abatement plant and replacement of one or more of the existing gas turbine with modern equivalents. Four different operating hour requirements were included in the screening to account for the sporadic nature of the operation of Aylesbury compressor station.

The screening tool identified fitting of catalytic oxidation to the existing gas turbines as BAT for the installation. This is a technique identified as being suitable within the Combustion Sector Guidance Note and we agree with this assessment.

The engineering work will include the installation of a new exhaust stack for each gas turbine, incorporating beds of platinum-based catalyst within multiple replaceable modules. Each stack also includes a diffuser to ensure uniform distribution of exhaust gas over the catalyst, a new monitoring platform, a silencer and a rain-cowl. Stack height is increased from 19m to 21.5m and there is a new associated support structure.

In addition, a Continuous Emission Monitoring System (CEMS) will be installed to demonstrate compliance with the CO emission limit and monitor the performance of the catalyst. This will work alongside the Company's existing Predictive Emission Monitoring System.

Environmental Impact Assessment

The design of the new stack has possible adverse impact on the dispersion of exhaust gases and air quality dispersion modelling has been used to assess this. The modelling was also used to identify the best height for the new stack.

Summary results from the modelling are shown below, using worse case scenarios for both NO_x and CO in short and long terms. The modelling indicates that the relevant environmental quality standards will not be

exceeded. We have reviewed the modelling and verified that it has been carried out to the required standard.

Pollutant	Averaging period	Environmental Quality Standard (EQS) ($\mu\text{g}/\text{m}^3$)	Background conc. ($\mu\text{g}/\text{m}^3$)	Scenario							
				1c (2x Avon, Max NOx)				2c (2x Avon CC, Max NOx)			
				PC ($\mu\text{g}/\text{m}^3$)	PEC ($\mu\text{g}/\text{m}^3$)	PC / EQS (%)	PEC / EQS (%)	PC ($\mu\text{g}/\text{m}^3$)	PEC ($\mu\text{g}/\text{m}^3$)	PC / EQS (%)	PEC / EQS (%)
Nitrogen dioxide	1 hour mean (99.79 th %ile)	200	19.5	17.7	37.2	8.8%	18.6%	9.7	29.2	4.8%	14.6%
Carbon monoxide	Maximum 8 hour running mean	10,000	208.1	288.9	497.0	2.9%	5.0%	9.6	217.7	0.1%	2.2%
				1d (2x Avon, Max CO)				2d (2x Avon CC, Max CO)			
Nitrogen dioxide	1 hour mean (99.79 th %ile)	200	19.5	8.3	27.8	4.1%	13.9%	3.7	23.3	1.9%	11.6%
Carbon monoxide	Maximum 8 hour running mean	10,000	208.1	1872.1	2080.2	18.7%	20.8%	61.3	269.4	0.6%	2.7%

Improvement Conditions

In order to verify that the new abatement plant and CEMS are operated correctly, and to confirm details of the air dispersion modelling, the operator proposed five new Improvement Conditions. These have been reviewed and incorporated into IC7 as required.

Recent research has identified that formaldehyde may be formed in exhaust gases where CO levels are above $440\text{mg}/\text{m}^3$. Where emission limits are proposed above this concentration, a standard Improvement Condition is being imposed across the combustion sector to assess this.

Implementation

Due to lead-times for the installation of the new abatement plant, it is only possible for the operator to complete the installation of the new abatement plant on one of the two LCPs at Aylesbury before the 01/01/16 IED deadline. They have therefore proposed to complete this on LCP 232 during 2015, thereafter the unit will be subject to the IED emission limits for mechanical drive gas turbines. LCP 231 will take the 500 hour emergency plant derogation until fitted with the new abatement plant, probably during 2016, and the operator will then apply to vary the permit accordingly.

Annex 1: decision checklist

Aspect considered	Justification / Detail	Criteria met
		Yes
Consultation		
Scope of consultation	As an existing operation with proposed decreases in emissions, no advertising or consultation is required.	✓
Environmental Risk Assessment and operating techniques		
Environmental risk	We have reviewed the operator's assessment of the environmental risk from the facility. The operator's risk assessment is satisfactory.	✓

Aspect considered	Justification / Detail	Criteria met
		Yes
	The assessment shows that, applying the conservative criteria in our guidance on Environmental Risk Assessment or similar methodology supplied by the operator and reviewed by ourselves, all emissions may be categorised as environmentally insignificant	
Operating techniques	<p>We have reviewed the techniques used by the operator and compared these with the relevant guidance notes. The proposed techniques/ emission levels for priorities for control are in line with the benchmark levels contained in the TGN and we consider them to represent appropriate techniques for the facility.</p> <p>We consider that the emission limits included in the permit reflect the BAT for the installation.</p>	✓
The permit conditions		
Improvement conditions	<p>We consider that we need to impose improvement conditions.</p> <p>We have imposed improvement conditions to ensure that the operator assesses and verifies the performance of the new abatement system to ensure continued compliance with the emission limits.</p>	✓
Operating techniques	<p>We have specified that the operator must operate the permit in accordance with referenced operating techniques.</p> <p>This includes installation of catalytic abatement for carbon monoxide within the flue and associated changes to the continuous monitoring system.</p> <p>These are specified in the Operating Techniques table in the permit.</p>	✓
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>The emission limits are those proposed by Annex V of the Industrial Emissions Directive.</p>	✓