



Marine  
Management  
Organisation

**MARINE AND COASTAL ACCESS ACT 2009  
SECTION 72**

**DEEMED MARINE LICENCE - NOTICE OF VARIATION**

**THE GALLOPER WIND FARM ORDER 2013 (SI 2013/1203) SCHEDULE 2**

**VARIATION NUMBER:**

2

**AUTHORISED DEVELOPMENT:**

Galloper Offshore Wind Farm

**LICENCE HOLDER:**

Galloper Wind Farm Ltd  
RWE Innogy UK Limited  
Windmill Hill Business Park  
Whitehall Way  
Swindon  
Wiltshire  
SN5 6PB

**DATE:**

17 September 2015

**COMPANY REGISTRATION NUMBER:**

7320597

**PREVIOUS VARIATIONS:**

1

The Marine Management Organisation (“MMO”) received a request on 3 February 2015 from Galloper Wind Farm Ltd for a variation to the deemed marine licence (“DML”) contained within Schedule 2 of the Galloper Wind Farm Order 2013 (“the Order”).

NOTICE IS HEREBY GIVEN that the MMO varies the DML in relation to each of the provisions of the DML specified in the first column of the table in the Annex to this notice, by replacing the words set out in the second column of that table with the words set out in the third column of that table, in accordance with section 72(3)(d) of the Marine and Coastal Access Act 2009.

This variation has immediate effect from the date of this notice.



Marine  
Management  
Organisation

In accordance with regulation 3 of The Marine Licensing (Notices Appeals) Regulations 2011, you may appeal the notice of variation to the First-tier Tribunal. If you wish to appeal then in accordance with Rule 22(1)(b) of the Tribunal Procedure (First-tier Tribunal)(General Regulatory Chamber) Rules 2009 (SI 2009/1976) you have 28 days from the date of the sending of this notice to send or deliver a notice of appeal to the First-tier Tribunal.

Signed:

Name and Position: Kathleen Mongan, Marine Licensing Case Officer

Date: 17 September 2015

Annex 1

<i>Provision</i>	<i>Previous text</i>	<i>Replacement text</i>
Schedule 2, Part 2, Condition 6(1)	Each monopile foundation forming part of the authorised scheme shall not have a diameter greater than 7 metres.	Each monopile foundation forming part of the authorised scheme shall not have a diameter greater than 7.5 metres.