

EC Type Examination Certificate Number: 0120/SGS0163

Holley Metering Ltd

No. 181 Wuchang Avenue Yuhang District Hangzhou 310023 China

Instrument Identification:

Instrument Traceable Number 0120/SGS0163

Single Phase, Active Import/Export, Indoor, Electricity Meter

has been assessed and certified as meeting the requirements of

EC Directive 2004/22/EC

Measuring Instruments Annex B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F

> This certificate is valid from 23rd January 2015 to 22nd January 2025 Issue 1

Certification is based on report number(s) SHES1312005106MI dated 14th January 2015

Authorised Signature

Jan Saunders

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



EC-Type Examination Certificate Number:

0120/ SGS0163

Issue Number: 1

Dated: 23rd January 2015

1. Technical Data	
Manufacturer	Holley Metering Ltd
Meter Types	AES1100, AES1120, AES1220
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	0,4-10(100)A
Starting current Ist	0.04ltr (0.04A)
l _{tr}	0.1Iref (1)A
Frequency <i>(Fn)</i>	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Ambient Humidity	95% non-condensing
Software Version No. Software Checksum	EH1BC10
Identification Location	Nameplate
Mechanical Environment	M1
Electromagnetic environment	E2
Bill Of Materials No.'s	AES1100_BOM V1.1 AES1120_BOM V1.1 AES1220_BOM V1.1
IP Rating	IP53
Insulation Protective Class	Class II
Pulse Output	1000imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	2x Wire & Crimp
Terminal Cover Sealing Type	1x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	BS



2. Photograph of Meter and Sealing Plan





EC-Type Examination Certificate Number:

0120/ SGS0163

Issue Number: 1

Dated: 23rd January 2015

Photograph of Meter and Sealing Plan (cont)

Example of damaged seals





Dated: 23rd January 2015

4. Influence factors for temperature, frequency and voltage

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

$\delta e(T, I, \cos \phi) =$	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos \phi) =$	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos \phi) =$	Additional error due to variation of the frequency at the same load

		Influence Factors for Temperature, Voltage & Frequency										
Current	PF Cos	-25	-10	5	30	40	55					
Imin	1.0	0.08	0.06	0.06	0.16	0.14	0.09					
ltr	1.0	0.11	0.09	0.04	0.09	0.09	0.05					
10ltr	1.0	0.10	0.15	0.08	0.10	0.10	0.08					
Imax	1.0	0.17	0.17	0.10	0.10	0.10	0.10					
ltr	0.5ind	0.07	0.02	0.02	0.16	0.11	0.05					
10ltr	0.5ind	0.11	0.13	0.09	0.11	0.09	0.06					
Imax	0.5ind	0.13	0.13	0.10	0.21	0.16	0.10					
ltr	0.8cap	0.12	0.10	0.06	0.12	0.09	0.10					
10ltr	0.8cap	0.18	0.14	0.10	0.12	0.09	0.09					
Imax	0.8cap	0.17	0.11	0.13	0.23	0.15	0.13					



5. Reproducibility of metrological performance

The application of the same measurement in a different location or by a different user, all other conditions being the same, shall result in the close agreement of successive measurements. The difference between the measurement results shall be small when compared with the MPE.

		Intrinsic error														
		COSφ=1.0					COSφ =0.5ind				COSφ=0.8cap					
Current	Imax	Iref	0.5Irf	0.2Iref	0.1Iref	0.05Iref	Imax	Iref	0.5Iref	0.2Iref	0.1Iref	Imax	Iref	0.5 Iref	0.2 Iref	0.1Iref
Pulse output	16	4	4	4	1	1	16	4	4	4	1	16	4	4	4	1



EC-Type Examination Certificate Number:

0120/ SGS0163

Issue Number: 1

Dated: 23rd January 2015

5. **Product Variant Identification Details**

AES 1100 – Single measuring element, import/export (kWh), import/export (kvarh) single auxiliary relay

AES 1120 – Single measuring element, import/export (kWh), import/export (kvarh), two auxiliary relays

AES 1220 – Two measuring elements, import/export (kWh), import/export (kvarh), two auxiliary relays

Modifications to the meter(s) described according to approval No.**0120/ SGS0163** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

6. Document Revision History

Issue	Date	Comments
1	23/01/2015	Initial Issue