

Notice of variation and consolidation with introductory note

The Environmental Permitting (England & Wales) Regulations 2010

Magnox Limited

Effluent treatment facility serving Bradwell Site
Bradwell-on-Sea
Southminster
Essex
CM0 7HP

Variation application number

PR2TS/E10760C/V003

Permit number

PR2TS/E10760C

Effluent treatment facility serving Bradwell Site

Permit number PR2TS/E10760C

Introductory note

This introductory note does not form a part of the notice.

Under the Environmental Permitting (England & Wales) Regulations 2010 (schedule 5, part 1, paragraph 19) a variation may comprise a consolidated permit reflecting the variations and a notice specifying the variations included in that consolidated permit.

Schedule 1 of the notice specifies the conditions that have been varied and schedule 2 comprises a consolidated permit which reflects the variations being made. Only the variations specified in schedule 1 are subject to a right of appeal.

This variation makes changes to the existing permit for a discharge of mixed effluents in a carrier flow of up to 504,900 cubic meters per day of circulating seawater from the Bradwell Site to the Blackwater Estuary. The changes are necessary to prepare for the predicted eventuality that the existing outlet for the discharge may become inoperable at an unknown date in the future due to siltation. This will necessitate the effluents being pumped through a new outlet structure at the same location. It will also necessitate the separation out of the mix of one of the effluents and its discharge out of a different outlet on the new structure. Because the effluents are to be pumped there will also be no need to add large volumes of seawater as a carrier flow when the new outlets are used. Although the primary purpose of the added volumes of seawater was to provide a head pressure to force the mixed effluents out into the estuary, they did provide pre-dilution for the effluents. This variation therefore includes conditions that will protect the receiving environment from the existing discharge of mixed effluents through the existing outlet and also conditions that will afford the same protection when the effluents are divided and there will be no dilution prior to discharge. The variation also includes conditions requiring the package sewage treatment plant serving the workforce on site to have tertiary UV disinfection facilities for the effluent to meet the appropriate standard for the protection of shellfish for human consumption in the receiving waters when the new outlet is used. The total residual oxidant (TRO) limit has been removed from the permit as is no longer applicable.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit		
Description	Date	Comments
Permit determined PR2TS/E10760	21/12/1960	Permit issued
Variation determined PR2TS/E10760A	04/03/1993	
Variation determined PR2TS/E10760B	02/08/1993	
Variation determined PR2TS/E10760C	07/07/2006	Full re-write
Transfer determined PR2TS/E10760C/T001	05/01/2011	Notice issued to Magnox Limited.
Variation determined PR2TS/E10760C/V002	29/11/2013	Varied and consolidated permit issued in modern condition format. Added non-radioactive aqueous effluent to the existing permit.

Status log of the permit		
Description	Date	Comments
Application PR2TS/E10760C/V003 (variation and consolidation)	Duly made 24/07/2015	Application to vary and update the permit to modern conditions.
Additional information received	01/09/2015	Clarification of discharge arrangements
Additional information received	08/10/2015	Supplementary modelling reports
Additional information received	15/11/2015	Revised H1 assessments
Additional information received	18/11/2015	Further clarification of H1 assessments
Additional information received	21/04/2016	Clarification of sizing of package sewage treatment plant
Additional information received	02/08/2016	Revised site plan and map references for operating techniques
Additional information received	08/08/2016	Operating technique - new outlet design specification for activity A2
Additional information received	08/08/2016	Operating technique - flow measurement specification
Additional information received	11/08/2016	Operating technique - site drainage sampling programme
Additional information received	15/08/2016	Operating technique – maximum daily volume of the sewage treatment plant
Additional information received	16/08/2016	Operating technique – new outlet design specification for activity A3
Additional information received	16/08/2016	Operating technique – maximum capacity of treatment plant for non-radioactive site drainage
Additional information received	17/08/2016	Revised operating technique –site drainage sampling programme
Additional information received	17/08/2016	Operating technique – Pumping arrangements for activity A3
Additional information received	18/08/2016	Operating techniques – Laboratory methods for analysing the treated site drainage effluents. Revised operating technique for the sewage treatment plant. Change to sampling location.
Additional information received	01/09/2016	Notification of change of registered company address
Additional information received	07/09/2016	Revised operating techniques and supplementary documents - Laboratory method for effluent analysis
Additional information received	13/09/2016	Revised site plan
Variation determined PR2TS/E10760C	DD/MM/YY	Varied and consolidated permit issued in modern condition format.

End of introductory note

Notice of variation and consolidation

The Environmental Permitting (England and Wales) Regulations 2010

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 varies and consolidates

Permit number

PR2TS/E10760C

Issued to

Magnox Limited (“the operator”)

whose registered office is

Oldbury Technical Centre

Oldbury Naite

South Gloucestershire

BS35 1RQ

company registration number **02264251**

to operate water discharge activities at

Effluent treatment facility serving Bradwell Site

Bradwell-on-Sea

Southminster

Essex

CM0 7HP

to the extent set out in the schedules.

The notice shall take effect from **[DD/MM/YYYY]**

Name	Date
[name of authorised person] Type name, signature not needed	[DD/MM/YYYY]

Authorised on behalf of the Environment Agency

Schedule 1

All conditions other than 1.1.2, 3.1.1, 4.2.1, 4.3.3 and 4.4.1 have been varied by the consolidated permit PR2TS/E10760C

The following conditions were varied as a result of an Environment Agency initiated variation:

3.3.4 and Schedule 5

The following conditions were varied as a result of the application made by the operator:

All other conditions.

Schedule 2 – consolidated permit

Consolidated permit issued as a separate document.

Permit

The Environmental Permitting (England and Wales) Regulations 2010

Permit number

PR2TS/E10760C

This is the consolidated permit referred to in the variation and consolidation notice for application PR2TS/E10760C/V003 authorising,

Magnox Limited (“the operator”)

whose registered office is

Oldbury Technical Centre

Oldbury Naite

South Gloucestershire

BS35 1RQ

company registration number **02264251**

to operate water discharge activities at

Effluent treatment facility serving Bradwell Site

Bradwell-on-Sea

Southminster

Essex

CM0 7HP

to the extent authorised by and subject to the conditions of this permit.

Name	Date
[name of authorised person]	[DD/MM/YYYY]

Authorised on behalf of the Environment Agency

Conditions

1 Management

1.1 General management

- 1.1.1 The operator shall manage and operate the activities:
- (a) in accordance with a written management system that identifies and minimises risks of pollution so far as is reasonably practicable, including those risks arising from operations, maintenance, accidents, incidents, non-conformances and those drawn to the attention of the operator as a result of complaints; and
 - (b) using sufficient competent persons and resources.
- 1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.
- 1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of the permit.

2 Operations

2.1 Permitted activities

- 2.1.1 The only activities authorised by the permit are the activities specified in schedule 1 table S1.1.

2.2 The site

- 2.2.1 The discharge activities shall take place at the discharge points marked on the site plan at schedule 7 to this permit, and as listed in table S3.2; and, the operating techniques that are the subject of conditions prefixed by 2.3 shall be applied at the locations shown, or otherwise described, in schedule 7.

2.3 Operating techniques

- 2.3.1 For the activities A2 & A3 referenced in schedule 1, table S1.1 the activities shall, subject to the conditions of this permit, be operated using the techniques and in the manner described in the documentation specified in schedule 1, table S1.2, unless otherwise agreed in writing by the Environment Agency.
- 2.3.2 If notified by the Environment Agency that the activities are giving rise to pollution, the operator shall submit to the Environment Agency for approval within the period specified, a revision of any plan or other documentation ("plan") specified in schedule 1, table S1.2 which identifies and minimises the risks of pollution relevant to that plan, and shall implement the approved revised plan in place of the original from the date of approval, unless otherwise agreed in writing by the Environment Agency.
- 2.3.3 For the activity A4 referenced in schedule 1, table S1.1 the discharge in schedule 3 table S3.3 shall consist solely of secondary treated sewage effluent which has been disinfected by means of ultra violet (UV) radiation as specified in that table.

2.4 Pre-operational conditions

- 2.4.1 For the activities A2, A3 and A4 referenced in schedule 1, table S1.1 the activities shall not be brought into operation until the measures specified in schedule 1 table S1.3 have been completed.

3 Emissions and monitoring

3.1 Emissions to water

3.1.1 The limits given in schedule 3 table S3.1 shall not be exceeded.

3.2 Emissions of substances not controlled by emission limits

3.2.1 The operator shall take appropriate measures to minimise so far as reasonably practicable the polluting effects of the emissions of substances in the discharge not controlled by emission limits (excluding odour).

3.3 Monitoring

3.3.1 The operator shall, unless otherwise agreed in writing by the Environment Agency, undertake the monitoring specified in the following tables in schedule 3 to this permit:

(a) point source emissions specified in tables S3.1 and S3.4.

3.3.2 The operator shall maintain records of all monitoring required by this permit.

3.3.3 Monitoring equipment, techniques, personnel and organisations employed for the emissions monitoring programme specified in condition 3.3.1 shall have either MCERTS certification or MCERTS accreditation (as appropriate), where available, unless otherwise agreed in writing by the Environment Agency.

3.3.4 Accessible monitoring points shall be provided and maintained to enable the emissions monitoring programme and/or other monitoring to be carried out at the monitoring points specified in table S3.4 of schedule 3 and shown marked on the site plan in schedule 7.

4 Information

4.1 Records

4.1.1 All records required to be made by schedule 3, 4 and 5 to this permit shall:

(a) be legible;

(b) be made as soon as reasonably practicable;

(c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and

(d) be retained, unless otherwise agreed in writing by the Environment Agency, for at least 6 years from the date when the records were made.

4.1.2 The operator shall maintain convenient access, in either electronic or hard copy, to the records, plan and management system required to be maintained by this permit.

4.2 Reporting

4.2.1 The operator shall send all reports and notifications required by the permit to the Environment Agency using the contact details supplied in writing by the Environment Agency.

4.2.2 Within the time period after the end of the reporting period specified in schedule 4 table S4.1 the operator shall, unless otherwise agreed in writing by the Environment Agency, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:

(a) in respect of the parameters and monitoring points specified in schedule 4 table S4.1;

- (b) for the reporting periods specified in schedule 4 table S4.1 and using the forms specified in schedule 4 table S4.2; and
- (c) giving the information from such results and assessments as may be required by the forms specified in those tables.

4.3 Notifications

4.3.1 The Environment Agency shall be notified as soon as reasonably practicable following detection, within the site of the regulated facility of:

- (a) any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution; and
- (b) any breach of a limit specified in schedule 3 table S3.1.

Any other significant adverse environmental effects, which may have been caused by the activity, shall also be notified to the Environment Agency as soon as reasonably practicable following detection.

4.3.2 The information provided under condition 4.3.1 shall be supported by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.

4.3.3 The Environment Agency shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:

Where the operator is a registered company:

- (a) any change in the operator's trading name, registered name or registered office address; and
- (b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.

Where the operator is a corporate body other than a registered company:

- (a) any change in the operator's name or address; and
- (b) any steps taken with a view to the dissolution of the operator.

4.3.4 Where the operator proposes to make a change in the nature of the activity by increasing the concentration of, or the addition of, or allowing the introduction of, a substance to the activity to an extent that the operator considers could have a significant adverse environmental effect on the receiving waters, and the change is not permitted by emission limits specified within schedule 3 table S3.1 or the subject of an application for approval under the EP Regulations or under the terms of this permit:

- (a) the Environment Agency shall be notified in writing at least 14 days before the increase or addition or allowing the introduction; and
- (b) the notification shall contain a description of the proposed change.

4.4 Interpretation

4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.

4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made "as soon as reasonably practicable", in which case it may be provided by telephone.

Schedule 1 – Operations

Activity reference	Description of activity	Limits of specified activity
A1	Discharge of secondary treated sewage effluent and trade effluent consisting of treated radioactive site drainage, treated non-radioactive site drainage, uncontaminated site drainage, waste waters from the reverse osmosis treatment of mains water and a carrier flow of circulating seawaters via Outlet 1	Effective until PO1 and PO2 are completed
A2	Discharge of trade effluent consisting of treated radioactive site drainage via Outlet 2	The discharge will take place over 45 minutes each day on the ebb tide between 1 and 2.5 hours after high water.
A3	Discharge of trade effluent consisting of treated non-radioactive site drainage, uncontaminated site drainage and waste waters from the reverse osmosis treatment of mains water via Outlet 3	N/A
A4	Discharge of secondary treated sewage effluent subject to disinfection by ultra violet irradiation via Outlet 3	N/A

Activity reference	Description of documentation	Parts	Date Received
A2	OT1: Effluent Sampling (AE A2 OT1) BRAD/EN/REP/196	All	11/08/2016
	OT2: New Outlet Design Specification (Mixed Effluent A2 OT2) BRAD/ENREP/188	All	08/08/2016
	OT3: Mixed Effluent : Analytical Techniques (A2:OT3) BRAD/EN/REP/203	All	07/09/2016
	OT4: Flow Monitoring (AE A2 OT4) BRAD/EN/REP/191	All	09/08/2016
A3	OT5: New Outlet Design Specification for the Non-Radioactive constituents (Mixed Effluent A3 OT5) BRAD/EN/REP/200	All	16/08/2016
	OT6: Siltbuster Capacity (ME A3 OT6) BRAD/EN/REP/199	All	16/08/2016
	OT7: Sewage Treatment Plant Maximum Capacity (Mixed Effluent A3 OT7) BRAD/EN/REP/197	All	18/08/2016
	OT8: Effluent sampling (Mixed Effluent A3 OT8) BRAD/EN/REP/193	All	17/08/2016
	OT9: Analytical Techniques (A3 OT9) BRAD/EN/REP/206	All	07/09/2016

Table S1.2 Operating techniques			
Activity reference	Description of documentation	Parts	Date Received
	OT10: Pumping Arrangement for the Main Drains Pit (ME A3 OT10) BRAD/EN/REP/201	All	17/08/2016

Table S1.3 Pre-operational measures	
Reference	Pre-operational measures
PO1	Install equipment to disinfect the secondary treated sewage effluent by means of ultra violet (UV) radiation.
PO2	The Operator shall notify the Environment Agency in writing when Outlet 1 becomes inoperable and the date that Outlets 2 and 3 are to be brought into operation. The Operator will not begin discharging via Outlets 2 and 3 without written agreement from the Environment Agency.

Schedule 2 – Waste types, raw materials and fuels

Schedule 2 not in use.

Schedule 3 – Emissions and monitoring

Table S3.1 Point Source emissions to water (other than sewer) – emission limits and monitoring requirements						
Effluent(s) and discharge point(s)	Parameter	Limit (including unit)	Reference Period	Limit of effective range	Monitoring frequency	Compliance Statistic
A1: Secondary treated sewage effluent and trade effluent consisting of treated radioactive site drainage, treated non-radioactive site drainage, uncontaminated site drainage, waste waters from the reverse osmosis treatment of mains water and a carrier flow of circulating seawaters via Outlet 1	Maximum daily discharge volume	504,900 m ³ /day	Total daily volume	N/A	N/A	Maximum
	pH	6 to 9	Instantaneous (spot sample)	N/A	N/A	Minimum and maximum
	Visible oil or grease	No significant trace present so far as is reasonably practicable	Instantaneous (visual examination)	N/A	N/A	No significant trace
A2: Trade effluent consisting of treated radioactive site drainage via Outlet 2	Maximum daily discharge volume	30 m ³ /day	Total daily volume	N/A	Every time a discharge occurs	Maximum
	pH	6 to 9	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	Minimum and maximum
	Cadmium as Cd	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A
	Chromium as Cr	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A
	Copper as Cu	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A
	Lead as Pb	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A
	Mercury as Hg	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A
	Nickel as Ni	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A
Zinc as Zn	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT1 table S1.2	N/A	

Table S3.1 Point Source emissions to water (other than sewer) – emission limits and monitoring requirements						
Effluent(s) and discharge point(s)	Parameter	Limit (including unit)	Reference Period	Limit of effective range	Monitoring frequency	Compliance Statistic
A3: Trade effluent consisting of treated non-radioactive site drainage, uncontaminated site drainage and waste waters from the reverse osmosis treatment of mains water via Outlet 3	Maximum	50,000 m ³ /day	Total daily volume	Condition 3.3.3 does not apply	Every time a discharge occurs	Maximum
	pH	6 to 9	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT8 table S1.2	Minimum and maximum
	Visible oil or grease	No significant trace present so far as is reasonably practicable	Instantaneous (visual examination)	N/A	N/A	No significant trace
	Chromium as Cr (in treated non-radioactive site drainage as monitored at monitoring point SP4)	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT8 table S1.2	N/A
	Copper as Cu (in treated non-radioactive site drainage as monitored at monitoring point SP4)	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT8 table S1.2	N/A
	Lead as Pb (in treated non-radioactive site drainage as monitored at monitoring point SP4)	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT8 table S1.2	N/A

Table S3.1 Point Source emissions to water (other than sewer) – emission limits and monitoring requirements						
Effluent(s) and discharge point(s)	Parameter	Limit (including unit)	Reference Period	Limit of effective range	Monitoring frequency	Compliance Statistic
	Nickel as Ni (in treated non-radioactive site drainage as monitored at monitoring point SP4)	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT8 table S1.2	N/A
	Zinc as Zn (in treated non-radioactive site drainage as monitored at monitoring point SP4)	No limit set Record as ug/l	Instantaneous (spot sample)	Condition 3.3.3 does not apply	As specified in OT8 table S1.2	N/A
A4: Secondary treated sewage effluent subject to disinfection by ultra violet irradiation via Outlet 3	Maximum	45 m ³ /day	Total daily volume	N/A	N/A	Maximum
	ATU-BOD as O ₂	40 mg/l	Instantaneous (spot sample)	N/A	N/A	Maximum
	Suspended solids (measured after drying at 105°C)	60 mg/l	Instantaneous (spot sample)	N/A	N/A	Maximum
	Visible oil or grease	No significant trace present so far as is reasonably practicable	Instantaneous (visual examination)	N/A	N/A	No significant trace

Effluent Name	Discharge Point	Discharge point NGR	Receiving water/ Environment
A1: Secondary treated sewage effluent and trade effluent consisting of treated radioactive site drainage, treated non-radioactive site drainage, uncontaminated site drainage, waste waters from the reverse osmosis treatment of mains water and a carrier flow of circulating seawaters	Outlet 1	TL 99680 09162	The Blackwater Estuary
A2: Trade effluent consisting of treated radioactive site drainage	Outlet 2	TL 99680 09162	The Blackwater Estuary
A3: Trade effluent consisting of treated non-radioactive site drainage, uncontaminated site drainage and waste waters from the reverse osmosis treatment of mains water	Outlet 3	TL 99680 09162	The Blackwater Estuary
A4: Secondary treated sewage effluent subject to disinfection by ultra violet irradiation	Outlet 3	TL 99680 09162	The Blackwater Estuary

Effluent(s) and discharge point(s)	Dose type	Design minimum dose mJ/cm2	Effective dates	Assumed transmittance to be used in dose calculations
A4: Secondary treated sewage effluent subject to disinfection by ultra violet irradiation via Outlet 3	Applied	32	1st Jan - 31st Dec	45%

Effluent(s) and discharge point(s)	Monitoring type	Monitoring point NGR	Monitoring point reference
A1: Secondary treated sewage effluent and trade effluent consisting of treated radioactive site drainage, treated non-radioactive site drainage, uncontaminated site drainage, waste waters from the reverse osmosis treatment of mains water and a carrier flow of circulating seawaters via Outlet 1	Effluent sampling	TM 00065 08890	SP1
A2: Trade effluent consisting of treated radioactive site drainage via Outlet 2	Effluent sampling	TM 00288 08797	SP2
	Flow Monitoring	TM 00288 08797	SP2
A3: secondary treated sewage effluent and trade effluent consisting of treated non-radioactive site drainage, uncontaminated site drainage and waste waters from the reverse osmosis treatment of mains water via Outlet 3	Effluent sampling	TM 00006 08822	SP3
	Effluent sampling (of treated non-radioactive site drainage)	TM 00026 08836	SP4
	Flow Monitoring	TM 00026 08836	SP4
A4: Secondary treated sewage effluent subject to disinfection by ultra violet irradiation via Outlet 3	Effluent sampling	TM 00003 08830	SP5

Schedule 4 – Reporting

Parameters, for which reports shall be made, in accordance with conditions of this permit, are listed below.

Table S4.1 Reporting of monitoring data			
Parameter	Monitoring point reference	Reporting period	Period begins
A2: Total daily volume	SP2	Annually Report to be submitted within 1 month of the end of the calendar year	1 January
A2: Cadmium as Cd, Chromium as Cr, Copper as Cu, Lead as Pb, Mercury as Hg, Nickel as Ni, Zinc as Zn and pH.	SP2	Quarterly Report to be submitted within 28 days	1st of month
A3: Total daily volume	SP4	Annually Report to be submitted within 1 month of the end of the calendar year	1 January
A3: Chromium as Cr, Copper as Cu, Lead as Pb, Nickel as Ni, Zinc as Zn and pH.	SP4	Quarterly Report to be submitted within 28 days	1st of month

Table S4.2 Reporting forms	
Parameter	Reporting format
A2 and A3: Total daily volume	Electronic format as agreed with the Environment Agency
A2: Cadmium as Cd, Chromium as Cr, Copper as Cu, Lead as Pb, Mercury as Hg, Nickel as Ni, Zinc as Zn and pH.	Electronic format as agreed with the Environment Agency
A3: Chromium as Cr, Copper as Cu, Lead as Pb, Nickel as Ni, Zinc as Zn and pH.	Electronic format as agreed with the Environment Agency

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	
Name of operator	
Location of Facility	
Time and date of the detection	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection unless otherwise agreed in writing by the Environment Agency	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released/type or nature of sewage released	
Best estimate of the quantity or rate of release of substances and/or duration of discharge	
Best estimate of the environmental impact of the discharge	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit specified in schedule 3 table S3.1	
The information specified below is to be notified to the Environment Agency as soon as reasonably practicable following detection.	
Monitoring point reference/ source	
Self monitoring regime (where relevant)	
Type of failure	e.g. Maximum/minimum /other
Date of sample/event	
Parameter	
Result and units	
Limit and units	

Part B – to be submitted as soon as reasonably practicable unless otherwise agreed in writing by the Environment Agency

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident/breach/exceedance	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	

Name*	
Post	
Signature	
Date	

* authorised to sign on behalf of the operator

Schedule 6 – Interpretation

“accident” means an accident that may result in pollution.

"annually" means once every year.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“appropriate measures” for the purposes of the emission of substances not controlled by emission limits condition (condition 3.2.1) do not require the operator to undertake treatment to a level beyond that specified in schedule 1 table S1.1, or to carry out routine monitoring for substances not controlled by emission limits.

“ATU-BOD as O₂” means the biochemical oxygen demand (measured after 5 days at 20°C with nitrification suppressed by the addition of allylthiourea).

“disinfection” means the use of a process designed specifically to reduce the number of viable, potentially infectious micro organisms in the effluent.

“emissions of substances not controlled by emission limits” means emissions of substances to air, water or land from the permitted activities, which are not controlled by an emission limit.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2010 No.675 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.


“MCERTS” means the Environment Agency’s Monitoring Certification Scheme.

"quarter" means a calendar year quarter commencing on 1 January, 1 April, 1 July or 1 October.

“significant pollution” means a category 1 or category 2 incident indicated by the Common Incident Classification Scheme (CICS).

“year” means calendar year ending 31 December.

Schedule 7 – Site plan



END OF PERMIT