

BSUID	Record ID	Floor	Room ID	Room Description	Elements	Material Description	Approximate Amount of Material	Unit of Measure	Asbestos Type
1863656	2203954	First	12	Bedroom	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203911	Ground	5	UnderStaircase	Ceiling	Insulating Board (IB)	0	N/A	No Asbestos Detected
1863656	2203917	Ground	5	UnderStaircase	Floor	Thermoplastic Tile	0	N/A	No Asbestos Detected

1863656	2203897	Ground	3	Lounge	Walls	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203937	First	9	Bathroom	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203929	First	7	Staircase	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203950	First	11	Bedroom	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected

1863656	2203907	Ground	4	Kitchen	Sink Pads	Bituminous Product	0	N/A	No Asbestos Detected
1863656	2203973	External	14	External	External	not recorded	0	N/A	No sample required
1863656	2203945	First	10	Bedroom	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203885	Ground	2	Hall		Meter Cupboa Insulating Board (IB)	0	N/A	No Asbestos Detected
1863656	2203879	Ground	2	Hall	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected

1863656	2203903	Ground	4	Kitchen	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203935	First	8	Toilet	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203875	Ground	1	Entrance Hall	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203958	Roof Void	13	Roof Void		not recorded	0	N/A	No sample required
1863656	2203921	Ground	6	Rear Hall	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected

1863656	2203901	Ground	3	Lounge	Ceiling	Semi Rigid Paint (Textured Coating)	0	N/A	No Asbestos Detected
1863656	2203891	Ground	3	Lounge	Floor	Thermoplastic Tile	15	m2	Chrysotile Trace
1863656	2203886	Ground	2	Hall	Floor	Thermoplastic Tile	2	m2	Chrysotile Trace
1863656	2203969	Roof	15	Roof	Fillet	Cement Product	2	m2	Chrysotile