

EC Type Examination Certificate Number: 0120/SGS0162

Europa Component & Equipment plc

Europa House, Airport Way, Luton, Bedfordshire, LU2 9NH

Instrument Identification: SDM120*

Instrument Traceable Number 0120/SGS0162

Single Phase, Active Import (kWh) Indoor, Electricity Meter

has been assessed and certified as meeting the requirements of

EC Directive 2004/22/EC

Measuring Instruments Annex B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F

This certificate is valid from 1st June 2014 to 17th February 2024 Issue 1

Certification is based on report number(s) SHES130800321401 dated 18th February 2014

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sqs.com



0120/ SGS0162

Issue Number: 1 Dated: 1st June 2014

1. Technical Data

Manufacturer	Europa Component & Equipment plc				
Meter Type	SDM120A, SDM120D, SDM120DB				
Voltage Rating (Un)	230V				
Current Rating (Imin – Iref (Imax))	0.25-5(45)A				
Frequency (Fn)	50Hz				
Active Accuracy Class (kWh)	A or B (kWh)				
Type of circuit	1p2w				
Temperature Range	-25°C to +55°C				
Software Version No.	SWV1.2				
Identification Location	Name Plate				
Bill Of Materials No.'s	SDM120-Measure-V2.1 SDM120-Power-V2.1 SDM120-Pulse-V2.0				
IP Rating	IP51				
Insulation Protective Class	Class II				
LED Pulse Constant	1000imp/ kWh				
Impulse Voltage Rating	6kV				
AC Voltage Rating	4kV				
Main Cover Sealing Type	4 x Wire & Crimp				
Integrity of meter	Inaccessible without breaking seals				
Intended Location of the Meter	Indoor				
Type of Register	LCD (SDM120D & SDM120DB), Mechanical (SDM120A)				



0120/ SGS0162

Issue Number: 1 Dated: 1st June 2014

2. Photographs of Meters

SDM120D







0120/SGS0162

Dated: 1st June 2014 Issue Number: 1

Photographs of Meters (cont)

SDM120DB







0120/ SGS0162

Issue Number: 1 Dated: 1st June 2014

Photographs of Meters (cont)

SDM120A







0120/SGS0162

Issue Number: 1 Dated: 1st June 2014

3. Influence factors for temperature, frequency and voltage

	Influence Factors for temperature, frequency and voltage					l voltage	
Current	PF Cos	-25	-10	5	30	40	55
lmin	1.0	0.12	0.12	0.12	0.13	0.12	0.12
ltr	1.0	0.16	0.16	0.16	0.16	0.16	0.16
10ltr	1.0	0.17	0.16	0.16	0.16	0.16	0.16
lmax	1.0	0.13	0.13	0.13	0.13	0.13	0.13
ltr	0.5ind	0.29	0.29	0.29	0.29	0.29	0.29
10ltr	0.5ind	0.40	0.40	0.40	0.40	0.40	0.40
lmax	0.5ind	0.16	0.16	0.16	0.16	0.16	0.16
ltr	0.8cap	0.24	0.24	0.24	0.24	0.24	0.24
10ltr	0.8cap	0.31	0.31	0.31	0.31	0.31	0.31
Imax	0.8cap	0.09	0.09	0.09	0.09	0.09	0.09

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta e (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$$

where

 $\delta e(T, I, \cos \varphi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \varphi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load



0120/SGS0162

Issue Number: 1 Dated: 1st June 2014

4. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter		
SDM120D	Single Phase 230V, 0.25-5(45)A LCD register		
SDM120DB	Single Phase 230V, 0.25-5(45)A LCD register with backlight		
SDM120A	Single Phase 230V, 0.25-5(45)A Mechanical register		

Modifications to the meter(s) described according to approval No.0120/SGS0162 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).

5. Document Revision History

Issue	Date	Comments
1	01/06/2014	Initial Issue