

EU Type Examination Certificate Number: 0120/SGS0249

Tyco Electronics UK Ltd

Freebournes Road Witham Essex CM83AH UK

Instrument Identification: DRS-100-1P

Instrument Traceable Number 0120/SGS0249

Single Phase, Active Import/ Export (kWh), Indoor, Electricity Meter

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

Measuring Instruments Annex B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II Module F

This certificate is valid until 29th September 2025 Issue 1

Certification is based on report number(s) SHES141200649301 issued 16th April 2015 EMA207767 EMA226287

Authorised Signature

St. 8

SGS United Kingdom Limited, Notified Body 0120
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA_□UK
t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK
t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of the Bocker Reverous is that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole respondingly light 7 its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGSPAPER 17071974



0120/ SGS0249

Issue Number: 1

19th January 2017

1. Technical Data

Manufacturer	Tyco Electronics UK Ltd			
Meter Type(s)	DRS-100-Modbus, DRS-100-1P BI, DRS-100-1P DR, DRS-100-1P Pulse			
Voltage Rating (Un)	230V			
Current Rating (Imin – Iref (Imax))	0.5-10(100)A			
Frequency (Fn)	50Hz			
Active Accuracy Class (kWh)	A or B (kWh)			
Type of circuit	1p2w			
Temperature Range	-25°C to +55°C			
Software Version No.	V1.2			
Identification Location	Nameplate			
Bill Of Materials No.'s	SDM230MODBUS-20150929			
IP Rating	IP51			
Insulation Protective Class	Class II			
LED Pulse Constant	1000imp/ kWh			
Impulse Voltage Rating	6kV			
AC Voltage Rating	4kV			
Terminal Cover Sealing Type	4 x Wire & Crimp			
Integrity of meter	Inaccessible without breaking seals			
Intended Location of the Meter	Indoor			
Type of Register	LCD			
Location of Manufacture Address	Associated documents installation manual			



0120/ SGS0249

Issue Number: 1

19th January 2017

2. Photograph of Meter and Sealing Plan






0120/SGS0249

Issue Number: 1

19th January 2017

3. Name plates and Markings





Example of name plate and markings



0120/SGS0249

Issue Number: 1

19th January 2017

3. Influence factors for temperature, frequency and voltage

Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.45	0.33	0.23	0.15	0.17	0.23
ltr	1.0	0.44	0.31	0.19	0.07	0.10	0.18
10ltr	1.0	0.42	0.29	0.18	0.03	0.08	0.16
Imax	1.0	0.27	0.19	0.12	0.03	0.06	0.12
ltr	0.5ind	0.48	0.36	0.27	0.17	0.18	0.22
10ltr	0.5ind	0.41	0.28	0.17	0.03	0.08	0.17
Imax	0.5ind	0.27	0.18	0.12	0.04	0.07	0.13
ltr	0.8cap	0.45	0.31	0.20	0.09	0.12	0.18
10ltr	0.8cap	0.40	0.27	0.16	0.04	0.10	0.19
Imax	0.8cap	0.26	0.19	0.11	0.05	0.08	0.15

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta e (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$$
 where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load$

 $\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load$

 $\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$



0120/SGS0249

Issue Number: 1

19th January 2017

4. Annex of Variants

Product Variant Identification Details:

Type Designation Description of meter

DRS-100-1P-Modbus: Single tariff, total active energy, resettable active energy, import active energy,

export active energy, total reactive energy, import reactive energy,

export reactive energy, active power, reactive power, voltage, current, frequency,

power factor, power demand, RS485 Modbus.

DRS-100-1P- Pulse: Single tariff, total active energy, resettable active energy, import active energy,

export active energy total reactive energy import reactive energy export reactive energy active, power reactive, power, voltage, current, frequency, power factor,

power demand.

DRS-100-1P-DR: Single tariff, total active energy, resettable energy, active power

DRS-100-1P-Bi: Single tariff, import active energy, export active energy, import active power, export

active power, total active energy, total active power

Modifications to the meter(s) described according to approval No.0120/SGS0249 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0249

Issue Number: 1

19th January 2017

5. Document Revision History

Issue	Date	Comments
1	09/01/2017	Initial Issue