

EU Type Examination Certificate Number: 0120/SGS0227

# **Controlin BV**

Glasblazerstraat 1, Ridderkirk. 2984 BL The Netherlands,

Instrument Identification: SKD-100-M

Instrument Traceable Number 0120/SGS0227

Single Phase, Active Import/ Export (kWh), Indoor, Electricity Meter

has been assessed and certified as meeting the requirements of

# EU Directive 2014/32/EU

#### **Measuring Instruments Annex B**

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of

Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in

Annex II, Module D or Annex II, Module F

This certificate is valid until 29<sup>th</sup> September 2025 Issue 2

Certification is based on report number(s) SHES141200649301 issued 16<sup>th</sup> April 2015, EMA207767 issued 9<sup>th</sup> October 2015 EMA224035/1 issued 14<sup>th</sup> June 2016

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



EU-Type Examination Certificate Number:


# 0120/ SGS0227

Issue Number: 2

Dated: 9<sup>th</sup> November 2016

### 1. Technical Data

Manufacturer	Controlin BV
Meter Type(s)	SKD-100-M
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	0.5-10(100)A
Frequency <i>(Fn)</i>	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software Version No.	V1.2
Identification Location	Nameplate
Bill Of Materials No.'s	SDM230MODBUS-20150929
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Terminal Cover Sealing Type	4 x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Location of Distributers Name & Address	Accompanying documentation



### 1. Photograph of Meter and Sealing Plan





EU-Type Examination Certificate Number:

# 0120/ SGS0227

Issue Number: 2

Dated: 9<sup>th</sup> November 2016

### 2. Influence factors for temperature, frequency and voltage

Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.45	0.33	0.23	0.15	0.17	0.23
ltr	1.0	0.44	0.31	0.19	0.07	0.10	0.18
10ltr	1.0	0.42	0.29	0.18	0.03	0.08	0.16
Imax	1.0	0.27	0.19	0.12	0.03	0.06	0.12
ltr	0.5ind	0.48	0.36	0.27	0.17	0.18	0.22
10ltr	0.5ind	0.41	0.28	0.17	0.03	0.08	0.17
Imax	0.5ind	0.27	0.18	0.12	0.04	0.07	0.13
ltr	0.8cap	0.45	0.31	0.20	0.09	0.12	0.18
10ltr	0.8cap	0.40	0.27	0.16	0.04	0.10	0.19
Imax	0.8cap	0.26	0.19	0.11	0.05	0.08	0.15

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta \in (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$$

where

$\delta e(T, I, \cos \phi) =$	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos \phi) =$	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos \phi) =$	Additional error due to variation of the frequency at the same load



EU-Type Examination Certificate Number:

# 0120/ SGS0227

Issue Number: 2

Dated: 9<sup>th</sup> November 2016

#### 3. Annex of Variants

Product Variant Identification Details:

#### Type Designation Description of meter

SKD-100-M: Single tariff, total active energy, resettable active energy, import active energy, export active energy, total reactive energy, import reactive energy, export reactive energy, active power, reactive power, voltage, current, frequency, power factor, power demand, RS485 Modbus.

Modifications to the meter(s) described according to approval No.**0120/SGS0227** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



# 0120/ SGS0227

Issue Number: 2

Dated: 9<sup>th</sup> November 2016

### 4. Document Revision History

Issue	Date	Comments
1	14/06/2016	Initial Issue
2	09/11/2016	Change of directive referencefrom EC 2004/22/EC to EU 2014/32/EU. Location of distributers name and address added to technical data

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at <a href="http://www.sgs.com/en/Terms-and-Conditions.aspx">http://www.sgs.com/en/Terms-and-Conditions.aspx</a> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/en/terms-edocument.htm">www.sgs.com/en/terms-edocument.htm</a>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law." "Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days only."

\*\* End of Document \*\*