

EU Type Examination Certificate Number: 0120/SGS0311

Zhejiang Risesun Science and Technology Co., Ltd.

No. 4 Small Zone High & New Park Economic & Technical Development Zone Wenzhou City Zhejiang Province China

Instrument Identification:

WSZ12D-32A & WSZ12D-65A

Single phase, Active Import (kWh), Electricity Meter

Instrument Traceable Number 0120/SGS0311

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 4th September 2027

Certification is based on report number(s) SHES170500381501 5th September 2017 EMA243848/1 EMM244840/1

Authorised Signature

Jan 19

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sqs.com

DU_CST-ME-002 Rev 1 EU Type Examination Cert.



0120/SGS0311

Issue Number: 1 Dated: 26th September 2017

1. Technical Data

Manufacturer	Zhejiang Risesun Science and Technology Co., Ltd		
Meter Type	WSZ12D-32A & WSZ12D-65A		
Voltage Rating (Un)	230V		
Current Rating (Imin – Iref (Imax))	0.25-5(32)A, 0.5-10(65)A		
Frequency (Fn)	50Hz		
Active Accuracy Class (kWh)	B(kWh)		
Type of circuit	1p2w		
Temperature Range	-25°C to +55°C		
Software/ Firmware Version No	RS217DR4-1MB-V10		
CRC Checksum	0x1723		
Identification Location	LCD		
Bill Of Materials Number	5(32)A: RS2B-217DR4-1-001 10(65)A: RS2B-217DR4-1-002		
IP Rating	The meter casing is only IP50 complaint. The meter MUST always be fitted into an IP51 approved enclosure.		
Insulation Protective Class	Class II		
LED Pulse Constant	2000imp/kWh		
Impulse Voltage Rating	6kV		
AC Voltage Rating	4kV		
Main Cover Sealing Type	Main cover clipped in place and sealed with tamper proof sealing tape		
Integrity of meter	Inaccessible without breaking seals		
Intended Location of the Meter	Indoor		
Type of Register	LCD		
Terminal Arrangement(s)	DIN		
Location of Manufacturers Address	Nameplate		



0120/SGS0311

Issue Number: 1 Dated: 26th September 2017

2. Photograph of Meter and Sealing Plan





Photograph of WSZ12D-32A






Photograph of WSZ12D-65A





0120/SGS0311


Issue Number: 1 Dated: 26th September 2017

3. Examples of Nameplates











0120/SGS0311

Issue Number: 1 Dated: 26th September 2017

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \varphi) =$ Additional error due to variation of the voltage at the same load $\delta e(f, I, \cos \varphi) =$ Additional error due to variation of the frequency at the same load

		Influenc	e Factors	for Tempe	rature, Vo	tage & Fre	equency
Current	PF Cos	-25℃	-10℃	5℃	30℃	40℃	55℃
lmin	1.0	1.00	0.69	0.31	0.06	0.08	0.13
ltr	1.0	0.96	0.57	0.35	0.03	0.09	0.14
10ltr	1.0	0.78	0.49	0.18	0.06	0.09	0.14
lmax	1.0	0.80	0.46	0.21	0.04	0.07	0.13
ltr	0.5ind	0.95	0.64	0.38	0.03	0.08	0.13
10ltr	0.5ind	0.86	0.52	0.25	0.05	0.09	0.12
Imax	0.5ind	0.63	0.38	0.18	0.10	0.12	0.12
II .	0.0	4.00	0.70	0.00	0.00	0.00	0.44
ltr	0.8cap	1.02	0.73	0.39	0.03	0.08	0.14
10ltr	0.8cap	0.92	0.59	0.28	0.04	0.09	0.13
Imax	0.8cap	0.60	0.38	0.12	0.13	0.09	0.11



0120/SGS0311

Issue Number: 1 Dated: 26th September 2017

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
WSZ12D-32A	230V, 0.25-5(32)A,
WSZ12D-65A	230V, 0.5-10(65)A

Modifications to the meter(s) described according to approval No.0120/SGS0311 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0311

Issue Number: 1 Dated: 26th September 2017

6. Document Revision History

Issue	Date	Comments
1	26/09/2017	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE