

EC Type Examination Certificate Number: 0120/SGS0132

# Janz-Contadores De Energia, SA

Av.Infante D. Henrique 328 1800-223 Lisboa Portugal

Instrument Identification: B2801\*\*\*\*\*\*

Instrument Traceable Number 0120/SGS0132 Polyphase, Credit, Active Import/ Export, Multi-rate, Indoor, Electricity Meter

has been assessed and certified as meeting the requirements of

# EC Directive 2004/22/EC

#### Measuring Instruments Annex B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of MI-003 of EC Directive 2004/22/EC

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex D or Annex F.

This certificate is valid until 1<sup>st</sup> October 2023 Issue 12

Certification is based on report number(s) EMA101440 dated 2<sup>nd</sup> August 2006, EMA179642 dated 2<sup>nd</sup> October 2013 EMA179642/CB dated 28<sup>th</sup> January 2014, EMA179642/1 dated 21<sup>st</sup> July 2015, EMA179642/1/iss2 dated 9th September 2016

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Ltd, Unit 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



Issue Number: 12

Dated: 20<sup>th</sup> August 2018

#### 1. Technical Data

Manufacturer	Janz-Contadores de Energia, SA.
Meter Types	B2801******
Voltage Rating (Un)	3x220/380V – 3x240/415V
Current Rating (Imin – Iref (Imax))	0,5-10(80)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	3p4w
Temperature Range	-25°C to +55°C
Firmware Version No's.	FW V01.06, FW V01.08
Software Version No's.	SW V00.03, SW V00.04, SW V00.05, SW V00.09,SWV01.03, V01.05, V01.06 (B2801###PLC) V01.07 (B2801###GPRS), V2.17 (B2801###GPRS V01.04(B2801###-IP) V02.05 (B2801##NBIoT) V02.01(B2801##UMTS)
	LCD
Bill Of Materials No.'s	917809502f1d Mechanical BOM 917809502f3f Mechanical BOM 917809502f1e Mechanical BOM 917809502f4e Electronic BOM
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	1000 imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp or tamper proof sealing tape
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN



Issue Number: 12

Dated: 20<sup>th</sup> August 2018

### 2. Example of Meter and Sealing Plan




Terminal Cover Seals





Issue Number: 12

Dated: 20th August 2018

#### 3. Namplates










Issue Number: 12

Dated: 20<sup>th</sup> August 2018



NBIoT	[A  I00  T   C  ₁ѯ₃ Q ]	R 1000imp/kWia
B2801R2R4LRFNBIOT 3x230/400V S0Hz 0,5-10(80)A Classe B 3K5 E2 M1 □ - ↓ L <sup>1</sup> 2 =	JANZ LISBOA - PORTUGAL	Classe 2 IECR22053-23 CCE M170120 0120/8030132



Issue Number: 12

Dated: 20<sup>th</sup> August 2018

### 4. Influence factors for temperature, frequency and voltage

Influence factors for temperature, frequency and voltage							
Current	PF Cos	-25℃	-10℃	5°C	30 <i>°</i> C	40 <i>°</i> C	55 <i>°</i> C
Imin	1.0	0.65	0.42	0.19	0.05	0.04	0.19
ltr	1.0	0.71	0.45	0.21	0.04	0.04	0.20
10ltr	1.0	0.72	0.43	0.21	0.05	0.04	0.17
Imax	1.0	0.72	0.43	0.19	0.04	0.03	0.16
ltr	0.5ind	0.76	0.46	0.22	0.02	0.03	0.20
10ltr	0.5ind	0.76	0.46	0.22	0.04	0.03	0.16
Imax	0.5ind	0.76	0.45	0.19	0.04	0.03	0.16
ltr	0.8cap 0.74 0.43 0.22 0.05 0.05		0.05	0.22			
10ltr	0.8cap	0.75	0.44	0.22	0.05	0.05	0.19
Imax	0.8cap	0.75	0.43	0.20	0.04	0.03	0.17
L1							
ltr	1.0	0.76	0.43	0.22	0.04	0.07	0.25
10ltr	1.0	0.76	0.44	0.21	0.03	0.06	0.22
Imax	1.0	0.76	0.44	0.21	0.04	0.05	0.22
ltr	0.5ind	0.79	0.46	0.25	0.06	0.08	0.27
10ltr	0.5ind	0.78	0.46	0.24	0.02	0.04	0.20
Imax	0.5ind	0.79	0.47	0.24	0.04	0.04	0.20
L2							
ltr	1.0	0.76	0.41	0.20	0.06	0.05	0.20
10ltr	1.0	0.76	0.43	0.20	0.07	0.07	0.17
Imax	1.0	0.76	0.42	0.19	0.06	0.05	0.16
ltr	0.5ind	0.76	0.42	0.19	0.07	0.04	0.15
10ltr	10ltr 0.5ind		0.45	0.23	0.07	0.05	0.14
Imax	0.5ind	0.78	0.46	0.22	0.04	0.05	0.16
L3							
ltr	1.0	0.81	0.44	0.22	0.04	0.03	0.17
10ltr	1.0	0.80	0.45	0.22	0.05	0.04	0.15
Imax	1.0	0.79	0.44	0.21	0.07	0.04	0.15
ltr	0.5ind	0.83	0.47	0.25	0.03	0.03	0.18
10ltr	0.5ind	0.82	0.47	0.22	0.04	0.03	0.12
Imax	0.5ind	0.80	0.45	0.14	0.04	0.04	0.23

000	EC-Type Examination Certificate Number:		
SGS	0120/ SGS0132		
	Issue Number: 12	Dated: 20 <sup>th</sup> August 2018	

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

 $\delta \in (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$ 

where

$\delta e(T, I, \cos \phi) =$	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos \phi) =$	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos \phi) =$	Additional error due to variation of the frequency at the same load



**Description of meter** 

Issue Number: 12

Dated: 20th August 2018

#### 5. Annex of Variants

Product Variant Identification Details:

#### Type Designation

CONNECTION В Polyphase meter for direct connection (4 wires) MODE The concept of series is related with the physical aspect of meter (meter case), seven series remain SERIES 2 available TARIFF SCHEME 80 Programmable Multirate, kWh/kvarh import/export (demand registration and load profile) Without push buttons (LCD scrolls the programmed data) INTERFACE TO THE USER 1 With one push button (to accelerate LCD scrolling and navigate through menus) No pulse output PULSE OUTPUT E1 One pulse output (through terminal 21) E2 Two pulse outputs (through terminals 21 & 22) No pulse input for tariff switch \_ PULSE INPUT 11 One pulse input (through terminal 23) 12 Two pulse inputs (through terminals 23 & 24 ) No auxiliary devices AUXILIARY DEVICES LR Latching relay for local or remote power control Without external cover opening detection device ANTI-TAMPER F With external cover opening detection device No auxiliary communications R2 RS232 port RS485 port R4 PSTN Internal PSTN MODEM AUXILIARY PLC Internal PLC MODEM COMMUNICATIONS GPRS Internal GSM/GPRS MODEM UMTS Internal UMTS MODEM NBIoT Internal NBIoT MODEM (others, to be identified always by alphanumeric characters) The initial version is not identified The concept of version is related to hardware changes or significant firmware modifications, but .Α VERSION always within the same "series" (see above) .В ...

Modifications to the meter(s) described according to approval No.**0120**/ **SGS0132** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



### EC-Type Examination Certificate Number:

### 0120/ SGS0132

Issue Number: 12

Dated: 20th August 2018

#### 6. Document Revision History

Issue	Date	Comments
1	02/10/2013	Initial Issue
2	05/12/2013	Minor software update from V0003 to V0004. Firmware unchanged.
3	31/01/2014	New software and firmware versions for circuit breaker type.
4	10/04/2014	Software update to V0007. Firmware unchanged.
5	27/05/2014	Software update to V0009. Firmware unchanged.
6	24/04/2015	Software update to V01.03. Firmware unchanged. Minor HW changes due to the introduction of a new memory chip
7	21/07/2015	Minor hardware modification due to repositioning of the RS232 & RS485 comms ports. Additional capacitors to improve radiated emissions. New opto coupler due to terminal lid presence sensor was being isolated. Minor software update.
8	09/10/2015	New SW01.06 version (meters intended for PLC communications) and SW01.07 version (meters intended for GPRS communications), due to debugging. Firmware unchanged.
9	09/09/2016	Auxiliary PCB modification due to the requirement of voltage free contacts. New SW 01.04 version (meters intended for public lighting measurement and command only). New mechanical BOM. Nameplates added to certificate.
10	26/10/2016	Certificate update due to PSU transformer's change and other minor component modifications, documented in electronic BOM doc. number 917809502f4d.
11	07/06/2017	New SW version V02.05 (NBIoT) and V02.01(UMTS) intended for UMTS and Narrow band IOT communications New mechanical BOM and Electronic BOM and Nameplates added to certificate.
12	20/08/2018	New software version V02.17 for GPRS

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at <a href="http://www.sgs.com/en/Terms-and-Conditions.aspx">http://www.sgs.com/en/Terms-and-Conditions.aspx</a> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/terms\_e-document.htm">www.sgs.com/terms\_e-document.htm</a>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days only."

#### \*\* End of Document \*\*