

EU Type Examination Certificate Number: 0120/ SGS0182

Ningbo Sanxing Smart Electric Co., Ltd

No 16, Fengwan Road Cicheng Town Jiangbei District Ningbo China

Instrument Identification:

SX1A1-SELS-05

Single Phase, Active Import/Export, Multi-Tariff, Indoor, Electricity Meter

Instrument Traceable Number 0120/ SGS0182

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 31st May 2025

Issue 4

Certification is based on report number(s) SHES141200650501 dated 1st June 2015

SHES150900528201 dated 9th October 2015

SHES150900528201/iss2 dated 10th November 2015

SHES141200650501/iss2 dated 10th November 2015

SHES150900528201/iss3 dated 19th December 2016

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sqs.com



0120/ SGS0182

Issue Number: 4 Dated: 19th December 2016

1. Technical Data


Manufacturer	Ningbo Sanxing Smart Electric Co., Ltd.
Meter Type	SX1A1-SELS-05
Voltage Rating (Un)	220V- 240V
Current Rating (Imin – Iref (Imax))	0,25-5(40)A 0,25-5(50)A 0,25-5(60)A 0,5-10(50)A 0,5-10(60)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No.	SX1A1-SELS-05.V1.0 SX1A1-SELS-05.V1.1
Identification Location	LCD
Bill Of Materials Numbers	201611295872 201503270004 SX3.417.000214
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	500 imp/kWh 1000 imp/kWh 2000 imp/kWh 10000 imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN or BS



0120/ SGS0182

Issue Number: 4 Dated: 19th December 2016


2. Photograph of Meter and Sealing Plan





0120/ SGS0182

Issue Number: 4 Dated: 19th December 2016





0120/SGS0182

Issue Number: 4 Dated: 19th December 2016

3. Influence factors for temperature, frequency and voltage

		Influence Factors for temperature, frequency and voltage								
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C	
Imin	1.0	1.04	0.72	0.46	0.16	0.12	0.21	0.23	0.17	
ltr	1.0	1.01	0.70	0.38	0.13	0.15	0.25	0.33	0.19	
10ltr	1.0	1.08	0.75	0.48	0.17	0.13	0.23	0.26	0.14	
Imax	1.0	0.84	0.57	0.31	0.08	0.13	0.24	0.25	0.14	
ltr	0.5ind	0.99	0.71	0.36	0.06	0.20	0.29	0.34	0.16	
10ltr	0.5ind	0.98	0.67	0.37	0.11	0.21	0.33	0.32	0.23	
Imax	0.5ind	0.87	0.61	0.36	0.11	0.12	0.19	0.18	0.07	
ltr	0.8cap	0.95	0.66	0.36	0.11	0.19	0.26	0.29	0.22	
10ltr	0.8cap	1.02	0.74	0.41	0.17	0.12	0.20	0.26	0.16	
Imax	0.8cap	0.85	0.61	0.37	0.17	0.10	0.14	0.16	0.09	

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta \; \mathsf{e} \; (\textit{T}, \; \textit{U}, \; \textit{f}) \; = \; \forall \; (\delta \; \mathsf{e}^2 \; (\textit{T}, \; \textit{I} \; , \mathsf{cos} \varphi) \; , \; \delta \; \mathsf{e}^2 \; (\textit{U}, \; \textit{I} \; , \mathsf{cos} \varphi) \; , \; \delta \; \mathsf{e}^2 \; (\; \textit{f} \; , \; \textit{I} \; , \mathsf{cos} \varphi))$$

where

 $\delta e(T, I, \cos \varphi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \varphi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load



0120/SGS0182

Issue Number: 4 Dated: 19th December 2016

4. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
SX1A1-SELS-05	220V, 230V, 240V 0,25-5(40)A, 0,25-5(50)A, 0,25-5(60)A, 0,5-10(50)A, 0,5-10(60)A 500imp/kWh, 1000imp/kWh, 2000imp/kWh, 10000imp/kWh Barrier or spring auxiliary terminal block

Modifications to the meter(s) described according to approval No.0120/ SGS0182 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0182

Issue Number: 4 Dated: 19th December 2016

5. Document Revision History

Issue	Date	Comments
1	01/06/2015	Initial Issue
2	09/10/2015	Minor pcb change and component relocation, minor software revision, additional pulse constant 1000imp/kWh
3	10/11/2015	Company name change from Ningbo Sanxing Electric Co., Ltd to Ningbo Sanxing Smart Electric Co., Ltd
4	19/12/2016	Change of directive reference from EC 2004/22/EC to EU 2014/32/EU. New BOM number due to component change

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."

"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days