

EC Type Examination Certificate Number: 0120/SGS0204

Shenzhen Chuangren Technology Co Ltd

Building 33, No. 3 Industrial Area Mashantou, Gongming Street, New Guangming District, Shenzhen City Guangdong Province, 518106, China

Instrument Identification:

DSZ12E-3x80A, DSZ12D-3x80A, DSZ12A-3x80A, DSZ15D-3x80A, DSZ14DRS-3x80A, DSZ12DM-3x80A, DSZ15DM-3x80A

Instrument Traceable Number 0120/SGS0204

Poly phase, Active Import/Export (kWh), Electricity Meter

has been assessed and certified as meeting the requirements of

EC Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EC Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 28th April 2026

Issue 7

Certification is based on report number(s) SHES150800499601 dated 29th April 2016, SHES171201220501 dated 24th January 2018, SHES180300313101 dated 8th May 2018, EMA222994

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



0120/ SGS0204

Issue Number: 7 Dated: 2nd November 2018

1. Technical Data

1. Technical Data	
Manufacturer	Shenzhen Chuangren Technology Co Ltd
Meter Type(s)	DSZ12E-3X80A, DSZ12D-3X80A, DSZ12A-3X80A, DSZ15D-3x80A, DSZ14DRS-3x80A, DSZ12DM-3x80A, DSZ15DM-3x80A
Voltage Rating (Un)	3 x 230/400 V
Current Rating (Imin – Iref (Imax))	DSZ12E: 0.25-5(80) A, DSZ12D: 0.5-10(80) A, DSZ12A: 0.5-10(80 A, DSZ15D: 0.5-10(80) A, DSZ14DRS: 0.5-10(80) A,DSZ12DM: 0.5-10(80) A DSZ15DM: 0.5-10(80) A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B (kWh)
Type of circuit	3p4w
Temperature Range	-25° C to +55° C
Software/ Firmware Version No	DSZ12D: V1.1, DSZ12E: V1.1, DSZ12A: V1.1, DSZ15D: V1.1, DSZ12DM: V1.1, DSZ15DM: V1.1
Identification Location	LCD
Bill Of Materials Number	DSZ12D V0, DSZ12E V0, DSZ12A V0, DSZ15D V0, DSZ14DRS: V0, DSZ12DM: V0, DSZ15DM: V0
IP Rating	The meter casing is only IP50 complaint. Therefore the meter MUST always be fitted into an IP51 approved enclosure.
Insulation Protective Class	Class II
LED Pulse Constant	DSZ12E: 800 imp/kWh DSZ12D LED tariff: 100 imp/kWh, S0-output: 1000imp/kWh DSZ12A LED tariff:100 imp/kWh, S0-output –1000imp/kWh DSZ15D LED tariff – 100imp/kWh, SO-output – 1000imp/kWh DSZ14DRS LED tariff:1000imp/kWh DSZ12DM LED tariff:1000 imp/kWh DSZ15DM LED tariff:1000 imp/kWh
Impulse Voltage Rating	6 kV
AC Voltage Rating	4 kV
Main Cover Sealing Type	Terminal covers are wire & crimp Main cover clipped in place and sealed with tamper proof sealing tape
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN




0120/ SGS0204

Issue Number: 7 Dated: 2nd November 2018

2. Photographs of Meter and Sealing Plan

DSZ12D







0120/ SGS0204

Issue Number: 7 Dated: 2nd November 2018



Terminal cover sealing points




0120/ SGS0204

Issue Number: 7

Dated: 2nd November 2018

DSZ12E





Main cover sealing points



0120/ SGS0204






0120/ SGS0204

Issue Number: 7

Dated: 2nd November 2018

DSZ12A






Main cover sealing points



0120/ SGS0204








0120/SGS0204


Issue Number: 7 Dated: 2nd November 2018

3. Nameplates















0120/SGS0204















0120/ SGS0204











0120/ SGS0204

Issue Number: 7 Dated: 2nd November 2018

4. Calculation of the composite error/ MPE

Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.30	0.29	0.32	0.37	0.64	0.45
Itr	1.0	0.42	0.61	0.69	0.26	0.28	0.33
10ltr	1.0	0.35	0.22	0.24	0.21	0.61	0.54
Imax	1.0	0.16	0.14	0.15	0.15	0.16	0.22
Itr	0.5ind	0.32	0.48	0.59	0.63	0.65	0.71
10ltr	0.5ind	0.43	0.49	0.51	0.57	0.57	0.48
Imax	0.5ind	0.95	0.99	0.69	0.74	0.68	0.94
Itr	0.8cap	0.38	0.41	0.30	0.30	0.68	0.37
10ltr	0.8cap	0.57	0.59	0.43	0.54	0.41	0.42
Imax	0.8cap	0.65	0.56	0.72	0.75	0.52	0.64
L1							
Itr	1.0	0.42	0.38	0.30	0.18	0.14	0.07
10ltr	1.0	0.62	0.65	0.66	0.46	0.52	0.31
Imax	1.0	0.58	0.73	0.72	0.63	0.68	0.54
Itr	0.5ind	0.52	0.37	0.26	0.09	0.06	0.15
10ltr	0.5ind	0.51	0.62	0.53	0.39	0.38	0.11
Imax	0.5ind	0.57	1.06	1.06	0.86	0.98	0.81
L2							
Itr	1.0	0.27	0.22	0.15	0.04	0.03	0.09
10ltr	1.0	0.21	0.16	0.09	0.07	0.09	0.12
Imax	1.0	0.27	0.24	0.19	0.14	0.12	0.09
Itr	0.5ind	030	0.24	0.14	0.02	0.07	0.17
10ltr	0.5ind	0.27	0.20	0.12	0.02	0.05	0.15
Imax	0.5ind	0.21	0.18	0.15	0.09	0.08	0.10
L3							
Itr	1.0	0.21	0.16	0.09	0.03	0.07	0.12
10ltr	1.0	0.20	0.16	0.12	0.06	0.08	0.12
Imax	1.0	0.28	0.26	0.24	0.20	0.19	0.18
Itr	0.5ind	0.28	0.18	0.12	0.02	0.07	0.16
10ltr	0.5ind	0.25	0.20	0.13	0.02	0.05	0.12
Imax	0.5ind	0.20	0.27	0.16	0.03	0.11	0.14



0120/SGS0204

Issue Number: 7 Dated: 2nd November 2018

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$$

where

 $\delta e(T, I, \cos \varphi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \varphi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load



0120/SGS0204

Issue Number: 7 Dated: 2nd November 2018

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
DSZ12E	3 x 230/400V 0.25-5(80) A, 800 imp/kWh
DSZ12D	3 x 230/400V 0.5-10(80) A, LED tariff - 100 imp/kWh, S0-output - 1000imp/kWh
DSZ12A	3 x 230/400V 0.5-10(80) A, LED tariff - 100 imp/kWh, S0-output - 1000imp/kWh
DSZ15D	3 x 230/400V 0.5-10(80) A, LED tariff - 100 imp/kWh, S0-output - 1000imp/kWh
DSZ14DRS	3 x 230/400V 0.5-10(80) A, LED tariff - 1000 imp/kWh, RS485 communication
DSZ12DM	3 x 230/400V 0.5-10(80) A, LED tariff - 1000 imp/kWh, M-Bus communication, grey face and terminal covers
DSZ15DM	3 x 230/400V 0.5-10(80) A, LED tariff - 1000 imp/kWh, M-Bus communication Blue face and terminal covers

Modifications to the meter(s) described according to approval No.0120/ SGS0204 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0204

Issue Number: 7 Dated: 2nd November 2018

6. Document Revision History

Issue	Date	Comments
1	29/04/2016	Initial Issue
2	20/05/2016	Model DSZ12A added to approval
3	26/10/2016	Software versions rename
4	08/09/2017	Model DSZ15D added to approval
5	24/01/2018	Model DSZ14DRS added to approval
6	08/05/2018	Models DSZ12DM & DSZ15DM added to approval
7	02/11/2018	DSZ14DRS-3x80A nameplate modified due to removal of S0 output and change of meter constant from 100imp/kWh to 1000imp/kWh

** End of Document **

[&]quot;This document is issued by the Company subject to its General Conditions of Service available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."

"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days



0120/ SGS0204

Issue Number: 7

Dated: 2nd November 2018