

EC Type Examination Certificate Number: 0120/ SGS0218

Zhejiang Yongtailong Electronic Co., Ltd.

No. 320 Tongsheng Road, Tongxiang, Jiaxing, Zhejiang P.R., China.

Instrument Identification: DDS353G

Instrument Traceable Number 0120/ SGS0218

Single phase, Active Import (kWh), Electricity Meter, Mechanical Display

has been assessed and certified as meeting the requirements of

EC Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of

Annex V of EC Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 7th June 2016 until 6th June 2026 Issue 2

Certification is based on report number(s) SHES151200784001 dated 3rd June 2016

Authorised Signature

Jan Saunders

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



0120/ SGS0218

Issue Number: 2 Dated: 25th July 2016

1. Technical Data

Manufacturer	Zhejiang Yongtailong Electronic Co., Ltd.
Meter Type	DDS353G
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	0.25-5(30)A, 0.25-5(32)A, 0.25-5(40)A, 0.25- 5(45)A, 0.25-5(50)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No's	F+R Version(2000imp/kWh):V1.0 F+R Version(1000imp/kWh):V1.1 F+R Version(100imp/kWh): V1.2 F Version(2000imp/kWh):V1.0.1
Identification Location	Nameplate
Bill Of Materials Numbers	1000imp/kWh, V1.1: D111042; 100imp/kWh, V1.2: D111042-01; 2000imp/kWh, V1.0, F+R: D111042-02 2000imp/kWh, V1.0.1, F version: D111031
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	2000imp/kWh, 1000imp/kWh, 100imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	Mechanical
Terminal Arrangement(s)	DIN




0120/SGS0218

Issue Number: 2 Dated: 25th July 2016

2. Photograph of Meter and Sealing Plan












0120/SGS0218


Issue Number: 2 Dated: 25th July 2016

3. Nameplates














0120/SGS0218

Issue Number: 2 Dated: 25th July 2016











0120/SGS0218

Issue Number: 2 Dated: 25th July 2016

4. Calculation of Composite Error/MPE

Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C	
Imin	1.0	0.64	0.57	0.48	0.29	0.34	0.40	
ltr	1.0	0.57	0.39	0.28	0.20	0.25	0.37	
10ltr	1.0	0.49	0.36	0.22	0.14	0.24	0.38	
Imax	1.0	0.49	0.40	0.29	0.14	0.18	0.29	
ltr	0.5ind	0.48	0.44	0.43	0.43	0.50	0.57	
10ltr	0.5ind	0.34	0.26	0.21	0.26	0.32	0.45	
lmax	0.5ind	0.41	0.34	0.28	0.19	0.19	0.25	
ltr	0.8cap	0.69	0.55	0.39	0.23	0.27	0.38	
10ltr	0.8cap	0.58	0.45	0.27	0.13	0.22	0.38	
Imax	0.8cap	0.60	0.50	0.35	0.13	0.15	0.26	

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta e (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$$

where

 $\delta e(T, I, \cos \varphi) = \Delta ditional error due to variation of the temperature at the same load <math>\delta e(U, I, \cos \varphi) = \Delta ditional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load$



0120/SGS0218

Issue Number: 2 Dated: 25th July 2016

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of	of meter	
DDS353G	0.25-5(30)A 0.25-5(32)A 0.25-5(40)A 0.25-5(45)A 0.25-5(50)A	100imp/kWh 1000imp/kWh 2000imp/kWh	Hardware the same for all currents and impulse constants. The only differences are in software.

Modifications to the meter(s) described according to approval No.0120/ SGS0218 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0218

Issue Number: 2 Dated: 25th July 2016

6. Document Revision History

Issue	Date	Comments
1	07/06/2016	Initial Issue
2	25/07/2016	MCU replacement. Import only type F Version included in approval