

EU Type Examination Certificate Number: 0120/ SGS0253

Ningbo Sanxing Smart Electric Co., Ltd.

No 16 Fengwan Road Cicheng Town Jiangbei District Ningbo China

Instrument Identification:

M12U02 Series & SX300 Series

Single Phase, Active Import/Export, Outdoor, Electricity Meter

Instrument Traceable Number 0120/ SGS0253

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EC Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 3rd August 2026 Issue 5

Certification is based on report number(s) SHES160700553301 dated 4^{th} August 2016, SHES171201208801 dated 26^{th} January 2018, SHES180700758201 dated 9^{th} August 2018

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



0120/ SGS0253

Issue Number: 5 Dated: 30th August 2018

1. Technical Data


1. Technical Data	1							
Manufacturer	Ningbo Sanxing Smart Electric Co., Ltd.							
Meter Types	M12U02 Series & SX300 Series							
Voltage Rating (Un)	220V, 230V, 240V							
Current Rating (Imin – Iref (Imax))	0.25-5(60)A, 0.25-5(40)A, 0.25-5(30)A, 0.5-10(40)A, 0.5-10(30)A, 0.5-10(60)A, 0.25-5(80)A, 0.5-10(80)A							
Frequency (Fn)		501	Hz					
Active Accuracy Class (kWh)		A or B	(kWh)					
Type of circuit		1p2w						
Temperature Range		-40°C to +70°C						
Software/ Firmware Version No's	V1.00.01	V1.00.02	V1.00.03	V1.00.04				
CRC Checksum No's.			1B76	D0B9				
Identification Location	LCD	LCD	LCD	LCD				
Bill Of Materials Numbers	SX0.354.000284.QJ SX3.417.000275.JG, 24419023893, 242003010089							
IP Rating	IP54							
Insulation Protective Class	Class II							
LED Pulse Constant	1000 imp/kWh, 1600 imp/kWh, 2000 imp/kWh, 3200imp/kWh							
Impulse Voltage Rating	6kV (1.2/50μs)							
AC Voltage Rating	4kV (50Hz)							
Main Cover Sealing Types	Screw with seal, Screw with plastic plug Ultrasonic welding, Ultrasonic welding with holographic sticker, Ultrasonic welding with screw + seal Ultrasonic welding with screw + plastic plug, Glue + Screw + Holographic Sticker							
Integrity of meter	In	accessible witho	out breaking seal	S				
Intended Location of the Meter		Outo	door					
Type of Register		LC	CD					
Terminal Arrangement(s)	DIN or BS							
Mechanical Environment	M2							
Electromagnetic Environment	E2							



0120/ SGS0253

Issue Number: 5 Dated: 30th August 2018

2. Photograph of Meter and Sealing Points





Anti-counterfeiting labeling. Meter with ultrasonic welding




0120/SGS0253


Issue Number: 5 Dated: 30th August 2018

3. Terminal Block Dimensions

DIN standard



BS standard



For M12U02 Series and SX300 Series connecting wires with a cross-section in range between $2.5 \text{mm}^2 \sim 25 \text{mm}^2$





0120/ SGS0253

Issue Number: 5

Dated: 30th August 2018

Crimp Type Terminal Cage Type Terminal








0120/SGS0253

Issue Number: 5 Dated: 30th August 2018


4. Examples of Nameplates

M12U02



The contents are changeable depending on the meter variant

SX300



The contents are changeable depending on the meter variant



0120/SGS0253

Issue Number: 5 Dated: 30th August 2018

5. The description given on the meter must include at least the following information:

- 1) Manufacturer's name, registered trade name or registered trade mark
- 2) Conformity marking supplementary metrology marking and notified body number
- 3) Number of the EU-type examination certificate or the EU design examination certificate;
- 4) Serial number
- 5) Year of manufacture
- 6) Meter's type designation
- 7) Accuracy class
- 8) The type of distribution network (graphic symbol or description)
- 9) Nominal voltage and frequency
- 10) Nominal, Minimal and Maximal currents
- 11) Operating temperatures range
- 12) Meter's constant
- 13) Connection diagram or its number
- 14) Graphic symbol of protection class
- 15) CE marking



0120/SGS0253

Issue Number: 5 Dated: 30th August 2018

6. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \varphi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load

	Influence Factors for Temperature. Frequency & Voltage							
PF Cos	-40℃	-25℃	-10℃	5℃	30℃	40℃	55℃	70℃
1.0	0.28	0.27	0.27	0.27	0.27	0.27	0.28	0.31
1.0	0.19	0.17	0.17	0.16	0.17	0.17	0.17	0.17
1.0	0.13	0.10	0.07	0.07	0.07	0.07	0.07	0.08
1.0	0.17	0.17	0.18	0.18	0.17	0.16	0.17	0.17
0.5ind	0.41	0.41	0.42	0.42	0.42	0.42	0.42	0.45
0.5ind	0.11	0.09	0.07	0.07	0.07	0.07	0.07	0.09
0.5ind	0.18	0.19	0.19	0.19	0.18	0.18	0.18	0.18
0.8cap	0.20	0.19	0.20	0.20	0.20	0.20	0.20	0.24
0.8cap	0.09	0.05	0.05	0.05	0.05	0.05	0.06	0.07
0.8cap	0.10	0.11	0.12	0.11	0.10	0.10	0.10	0.11
	1.0 1.0 1.0 1.0 0.5ind 0.5ind 0.5ind 0.8cap 0.8cap	1.0	PF Cos -40 °C -25 °C 1.0 0.28 0.27 1.0 0.19 0.17 1.0 0.13 0.10 1.0 0.17 0.17 0.5ind 0.41 0.41 0.5ind 0.11 0.09 0.5ind 0.18 0.19 0.8cap 0.20 0.19 0.8cap 0.09 0.05	PF Cos -40 °C -25 °C -10 °C 1.0 0.28 0.27 0.27 1.0 0.19 0.17 0.17 1.0 0.13 0.10 0.07 1.0 0.17 0.17 0.18 0.5ind 0.41 0.41 0.42 0.5ind 0.11 0.09 0.07 0.5ind 0.18 0.19 0.19 0.8cap 0.20 0.19 0.20 0.8cap 0.09 0.05 0.05	PF Cos -40 °C -25 °C -10 °C 5 °C 1.0 0.28 0.27 0.27 0.27 1.0 0.19 0.17 0.17 0.16 1.0 0.13 0.10 0.07 0.07 1.0 0.17 0.17 0.18 0.18 0.5ind 0.41 0.41 0.42 0.42 0.5ind 0.11 0.09 0.07 0.07 0.5ind 0.18 0.19 0.19 0.19 0.8cap 0.20 0.19 0.20 0.20 0.8cap 0.09 0.05 0.05 0.05	PF Cos -40 °C -25 °C -10 °C 5 °C 30 °C 1.0 0.28 0.27 0.27 0.27 0.27 1.0 0.19 0.17 0.17 0.16 0.17 1.0 0.13 0.10 0.07 0.07 0.07 1.0 0.17 0.18 0.18 0.17 0.5ind 0.41 0.41 0.42 0.42 0.42 0.5ind 0.11 0.09 0.07 0.07 0.07 0.5ind 0.18 0.19 0.19 0.19 0.19 0.8cap 0.20 0.19 0.20 0.20 0.20 0.8cap 0.09 0.05 0.05 0.05 0.05	PF Cos -40 °C -25 °C -10 °C 5 °C 30 °C 40 °C 1.0 0.28 0.27 0.27 0.27 0.27 0.27 1.0 0.19 0.17 0.17 0.16 0.17 0.17 1.0 0.13 0.10 0.07 0.07 0.07 0.07 1.0 0.17 0.17 0.18 0.18 0.17 0.16 0.5ind 0.41 0.41 0.42 0.42 0.42 0.42 0.5ind 0.11 0.09 0.07 0.07 0.07 0.07 0.5ind 0.18 0.19 0.19 0.19 0.18 0.18 0.8cap 0.20 0.19 0.20 0.20 0.20 0.20 0.8cap 0.09 0.05 0.05 0.05 0.05 0.05	PF Cos -40 °C -25 °C -10 °C 5 °C 30 °C 40 °C 55 °C 1.0 0.28 0.27 0.27 0.27 0.27 0.27 0.28 1.0 0.19 0.17 0.17 0.16 0.17 0.17 0.17 1.0 0.13 0.10 0.07 0.07 0.07 0.07 0.07 1.0 0.17 0.17 0.18 0.18 0.17 0.16 0.17 0.5ind 0.41 0.41 0.42 0.42 0.42 0.42 0.42 0.5ind 0.11 0.09 0.07 0.07 0.07 0.07 0.07 0.5ind 0.18 0.19 0.19 0.19 0.19 0.18 0.18 0.18 0.8cap 0.20 0.09 0.05 0.05 0.05 0.05 0.05 0.05 0.05



0120/ SGS0253

Issue Number: 5 Dated: 30th August 2018

7. Product Variant Identification Details

M12U02/SX300	-	D	7	D	3	2	-	Т	I	F	0	Р	4
Connection standard													
DIN standard		D				-		-				-	
BS standard		В											
Current range													
230V,0.25-5 (60) A			1			-						-	
230V,0.25-5 (40) A			2										
230V,0.25-5 (30) A			3										
230V,0.5-10 (60) A			4			-						-	
230V,0.5-10 (40) A			5										
230V,0.5-10 (30) A			6										
230V,0.25-5 (80) A			7										
230V,0.5-10 (80) A			8										
220V,0.25-5 (60) A			Α										
220V,0.25-5 (40) A			В									-	
220V,0.25-5 (30) A			C										
220V,0.5-10 (60) A			D										
220V,0.5-10 (40) A			Ε									-	
220V,0.5-10 (30) A			F										
240V,0.25-5 (60) A			J										
240V,0.25-5 (40) A			Κ										
240V,0.25-5 (30) A			L									-	
240V,0.5-10 (60) A			М										
240V,0.5-10 (40) A			Ν										
240V,0.5-10 (30) A			0										
Reserved													
Accuracy													
Active Class A				Α									
Active Class B				В									
Active Calss A. Rective Class 2				C									
Active Calss B. Rective Class 2				D									
Reserved													



0120/SGS0253

Issue Number: 5 Dated: 30th August 2018 Reserved **Const** Reserved Reserved 1000 3 1600 4 2000 5 3200 6 Reserved **Mechanical(Terminal cover)** Long transparent terminal cover 1 Long none transparent terminal cover 2 Short transparent terminal cover 3 Short none transparent terminal cover 4 Reserved **Power Supply and Neutral measurement** Transformer power supply Transformer, Neutral measurement Υ Reserved Reserved **Auxiliary Power** Ι **Interal Battery** Ε **External Battery** S Super-capacitor Internal + External battery 1 Internal Battery + Supercap 2 Externall Battery + Supercap 3 Internal Battery + External Battery + F Supercap No Auxiliary Power Ν Reserved **Backlight and Flash** Backlight + No Flash В Backlight + Flash 2



0120/SGS0253

Issue Number: 5 Dated: 30th August 2018

No Backlight + Flash	F		1	
No Backlight + No Flash	Ν			
Optical interface				
Optical interface		0		
Infrared interface		I		
None		Ν		
Reserved				
Buttons				
0 button			Ν	
1 button			М	
2 buttons			Р	
Reserved				
Inputs and outputs				
1 S0 output				1
2 S0 ouptut				2
reserved				3
RS485				4
1 S0 output + RS485				5
2 S0 ouptut + RS485				6
None				Ν

Modifications to the meter(s) described according to approval No.0120/ SGS0253 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0253

Issue Number: 5 Dated: 30th August 2018

8. Document Revision History

Issue	Date	Comments
1	04/08/2016	Initial Issue
2	15/03/2017	Minor pcb and non metrology component change. New software version added.
3	14/02/2018	Minor pcb and non metrology component change.
4	14/08/2018	MCU, transformer, FET replaced. PCB layout changed, Software update.
5	30/08/2018	Additional software version V1.00.04 & CRC number D0B9

"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days only."

** E J -£ D	
** End of Document **	

[&]quot;This document is issued by the Company subject to its General Conditions of Service available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms-e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawfull and offenders may be prosecuted to the fullest extent of the law."