

EU Type Examination Certificate Number: 0120/ SGS0260

RDL Meters Ltd

Unit E2
Westfield Business Park
Long Road
Paignton
Devon
TQ4 7AU

Instrument Identification:

M-101

Single Phase, Multi-rate, Active Import (kWh), Prepayment Electricity Meter
Instrument Traceable Number
0120/ SGS0260

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 5th September 2016 until 4th September 2026 Issue 2

Certification is based on report number(s) EMA225073/1 1st September 2016

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD UK

t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



0120/ SGS0260

Issue Number: 2 Dated: 30th June 2017

1. Technical Data

Manufacturer	RDL Meters Ltd
Meter Type	M-101
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	1-20(100)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1P2W
Temperature Range	-25°C to +55°C
Software/ Firmware Version No	V6.2
Identification Location	LCD
Bill Of Materials Number	Rev E
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD & Nameplate
Terminal Arrangement(s)	BS



0120/ SGS0260

Issue Number: 2 Dated: 30th June 2017

2. Photograph of Meter and Sealing Plan



Main Cover Seals


Terminal Cover Seal



0120/SGS0260

Issue Number: 2 Dated: 30th June 2017

3. Name plate and Markings







0120/SGS0260

Issue Number: 2 Dated: 30th June 2017

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta \; \mathsf{e} \; (\textit{T}, \; \textit{U}, \; \textit{f}) \; = \; \forall \; (\delta \; \mathsf{e}^2 \; (\textit{T}, \; \textit{I} \; , \mathsf{cos} \varphi) \; , \; \delta \; \mathsf{e}^2 \; (\textit{U}, \; \textit{I} \; , \mathsf{cos} \varphi) \; , \; \delta \; \mathsf{e}^2 \; (\; \textit{f} \; , \; \textit{I} \; , \mathsf{cos} \varphi))$$

where

 $\delta e(T, I, \cos \phi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \phi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load

		Influence Factors for Temperature, Voltage & Frequency				equency	
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.11	0.22	0.07	0.07	0.10	0.18
Itr	1.0	0.05	0.21	0.06	0.05	0.08	0.18
10Itr	1.0	0.07	0.18	0.07	0.06	0.09	0.18
Imax	1.0	0.26	0.07	0.14	0.07	0.12	0.20
ltr	0.5ind	0.12	0.19	0.08	0.07	0.12	0.18
10ltr	0.5ind	0.16	0.21	0.09	0.06	0.11	0.19
Imax	0.5ind	0.37	0.36	0.18	0.07	0.10	0.18
Itr	0.8cap	0.05	0.37	0.05	0.05	0.09	0.51
10Itr	0.8cap	0.06	0.32	0.07	0.08	0.14	0.22
Imax	0.8cap	0.18	0.17	0.12	0.09	0.18	0.50



0120/SGS0260

Issue Number: 2 Dated: 30th June 2017

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter		
M-101	230V, 1-20(100)A Dual coin operated electronic meter & timer		

Modifications to the meter(s) described according to approval No.0120/ SGS0260 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0260

Issue Number: 2 Dated: 30th June 2017

6. Document Revision History

Issue	Date	Comments	
1	05/09/2016	Initial Issue	
2	30/06/2017	BOM revision number update from Rev D to Rev E	

This document is issued by the Company subject to its General Conditions of Service available on request of accessible at
http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic
Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues
defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its
intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does
not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot
be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content
or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days
only."

**	End of Document	**