

EU Type Examination Certificate Number: 0120/ SGS0265

Itron Indonesia

PT Mecoindo EJIP Plot 6B-2 Lemah Abang Bekasi 17550 Jawa Barat Indonesia

Instrument Identification: EM512 Type 900 Single Phase, Active, Import/ Export, Prepayment, Electricity Meter

> Instrument Traceable Number 0120/ SGS0265

has been assessed and certified as meeting the requirements of



on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 5th December 2016 until 4th December 2026 Issue 2

Certification is based on report number(s) EMA229359/1/MID Issued 7th December 2016

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK

t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



EU-Type Examination Certificate Number:

0120/ SGS0265

Issue Number: 2

Dated: 29th June 2017

1. Technical Data

Manufactura	
Manufacturer	
Meter Type	EM512 Type 900
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	0.25-5(100)A
Frequency <i>(Fn)</i>	50Hz
Active Accuracy Class (kWh)	A or B(kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No	V1.02
CRC Checksum	5C815367
Identification Location	LCD
Bill Of Materials Number	A5004427 PCBA EM512 Type 900 Centian 1
IP Rating	IP51 & IP54
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of manufacturers address	Nameplate





0120/ SGS0265

Issue Number: 2


Dated: 29th June 2017


2. Photograph of Meter and Sealing Plan





3. Nameplate





4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta \in (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$

where

$\delta e(T, I, \cos \phi) =$	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos \phi) =$	Additional error due to variation of the voltage at the same load
δe(f , I ,cosφ) =	Additional error due to variation of the frequency at the same load

		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40	-25	-10	5	30	40	55	70
Imin	1.0	0.52	0.49	0.43	0.28	0.22	0.33	0.44	0.61
ltr	1.0	0.52	0.49	0.40	0.26	0.12	0.26	0.39	0.56
10ltr	1.0	0.49	0.49	0.38	0.24	0.17	0.27	0.44	0.63
Imax	1.0	0.47	0.52	0.43	0.29	0.08	0.11	0.26	0.40
ltr	0.5ind	0.59	0.57	0.44	0.29	0.03	0.14	0.31	0.44
10ltr	0.5ind	0.55	0.49	0.45	0.28	0.07	0.20	0.31	0.53
Imax	0.5ind	0.59	0.57	0.50	0.33	0.11	0.09	0.18	0.34
ltr	0.8cap	0.51	0.49	0.44	0.28	0.07	0.19	0.33	0.53
10ltr	0.8cap	0.49	0.51	0.42	0.24	0.10	0.20	0.36	0.55
Imax	0.8cap	0.41	0.48	0.42	0.29	0.11	0.17	0.29	0.45

000	EU-Type Examination Certificate N			
SGS	0120/ SGS0265			
	Issue Number: 2	Dated: 29 th June 2017		

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
EM512	Single Phase, 1p2w, 230V, 0,25-5(100)A, Active Import (kWh), Prepayment

Modifications to the meter(s) described according to approval No.**0120/ SGS0265** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0265

Issue Number: 2

Dated: 29th June 2017

6. Document Revision History

Issue	Date	Comments
1	05/12/2016	Initial Issue
2	29/06/2017	Minor firmware change from V1.01 to V1.02 and CRC number change from C11AECE3 to 5C815367

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at http://www.sqs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sqs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sqs.com/en/Terms-end-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sqs.com/en/Terms-end-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sqs.com/en/Terms-end-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sqs.com/en/Terms-end-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sqs.com/en/Terms-end-Conditions.aspx and, for electronic format documents, subject to Terms and Condition and jurisdiction is sues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document connot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the

** End of Document **