

EU Type Examination Certificate Number: 0120/SGS0286

#### SmartProcess & Control Ltd.

Unit 11 Totman Close Brook Road Rayleigh SS6 7UZ United Kingdom

Instrument Identification: Smartpanel X835-MID

Polyphase, Active Import/Export (kWh), Indoor, Transformer Operated, Multi-function, Electricity Meter

Instrument Traceable Number 0120/SGS0286

has been assessed and certified as meeting the requirements of

# EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 23<sup>rd</sup> April 2027 Issue 3

Certification is based on report number(s) EMA234440/2 dated 24<sup>th</sup> April 2017, EMA250027/1 dated 27th April 2018 EMA240491/1

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



# 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

#### 1. Technical Data

1. Technical Data	
Manufacturer	Smartprocess & Control Ltd.
Meter Type(s)	Smartpanel X835-MID Smartpanel X835RJ-MID
Voltage Rating (Un)	1P2W: 230V 3P3W: 3x230V 3P4W: 3 x 230/400V
Wiring Configurations	1P2W, 3P3W,3P4W
Current Rating (Imin – Iref (Imax))	0.25-5(6)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B or C (kWh)
Type of circuit	1p2w, 3p3w, 3p4w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No's	Smartpanel X835-MID: V1.3 Smartpanel X835RJ-MID: V1.5
CRC Checksum No's	Smartpanel X835-MID: 0x0059DD5E Smartpanel X835RJ-MID: 0x005C2B34
Identification Location	LCD
Bill Of Materials No's	Smartpanel X835-MID::DH-JS-160010-1.3 Smartpanel X835RJ-MID: DH-JS-180013-1.0
IP Rating	IP51 Front Display Meter body not rated. Must be installed in a suitable IP rated enclosure
Insulation Protective Class	Class I / Class II
LED Pulse Constant	3200imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Terminal Cover Sealing Type	Wire & Crimp
Main Cover Sealing Type	Laser Welded
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Location of Manufacturers Address	Associated Documents




### 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

#### 2. Photograph of Meter and Sealing Plan







## 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018



RJ45 Terminal cover sealing point


Voltage terminal cover sealing point



### 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

#### 3. Example of Nameplates









### 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018







### 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

#### 4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$ 

#### where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$ 



# 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

		Influenc	e Factors	for Tempe	rature. Fre	quency &	Voltage
Current	PF Cos	-25℃	-10℃	5℃	30℃	40℃	55℃
Imin	1.0	0.21	0.20	0.14	0.07	0.19	0.39
ltr	1.0	0.25	0.24	0.20	0.10	0.17	0.37
10ltr	1.0	0.24	0.23	0.19	0.10	0.20	0.39
Imax	1.0	0.24	0.24	0.18	0.10	0.18	0.39
ltr	0.5ind	0.25	0.25	0.21	0.10	0.19	0.44
10ltr	0.5ind	0.20	0.06	0.11	0.31	0.56	0.70
Imax	0.5ind	0.23	0.19	0.10	0.36	0.51	0.51
ltr	0.8cap	0.25	0.25	0.20	0.12	0.18	0.37
10ltr	0.8cap	0.35	0.30	0.23	0.09	0.11	0.33
Imax	0.8cap	0.33	0.29	0.27	0.16	0.18	0.30
L1							
ltr	1.0	0.19	0.17	0.11	0.08	0.19	0.40
10ltr	1.0	0.18	0.17	0.11	0.10	0.20	0.41
Imax	1.0	0.18	0.16	0.10	0.10	0.20	0.40
ltr	0.5ind	0.21	0.19	0.13	0.07	0.20	0.45
10ltr	0.5ind	0.23	0.22	0.17	0.12	0.18	0.39
Imax	0.5ind	0.19	0.17	0.13	0.09	0.19	0.41
L2							
ltr	1.0	0.35	0.35	0.31	0.19	0.21	0.40
10ltr	1.0	0.29	0.30	0.25	0.16	0.22	0.47
lmax	1.0	0.30	0.30	0.27	0.15	0.20	0.43
ltr	0.5ind	0.31	0.32	0.28	0.16	0.16	0.35
10ltr	0.5ind	0.74	0.14	0.33	0.77	0.46	0.92
Imax	0.5ind	0.33	0.34	0.37	0.63	0.47	1.19
L3							
ltr	1.0	0.16	0.15	0.10	0.08	0.19	0.40
10ltr	1.0	0.18	0.16	0.10	0.10	0.20	0.41
lmax	1.0	0.17	0.16	0.10	0.11	0.21	0.41
ltr	0.5ind	0.17	0.20	0.17	0.12	0.26	0.58
10ltr	0.5ind	0.18	0.18	0.11	0.36	0.40	0.62
Imax	0.5ind		0.15	0.08	0.62	0.37	0.57



## 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

#### 5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
Smartpanel X835-MID	Active Import/Export (kWh), 3x230/400V, 5(6)A, Transformer operated, Multifunction, RS485 Modbus RTU
Smartpanel X835 RJ-MID	Active Import/Export (kWh), 3x230/400V, 100mA/5(6)A, Transformer operated, Multifunction, RS485 Modbus RTU, RJ12 Pluggable CT Input

Modifications to the meter(s) described according to approval No.0120/SGS0286 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



### 0120/SGS0286

Issue Number: 3 Dated: 24<sup>th</sup> May 2018

#### 6. Document Revision History

Issue	Date	Comments
1	08/09/2017	Initial Issue
2	27/04/2018	Model X835 RJ – MID added to approval
3	24/05/2018	Photo of rear of X835RJ-MID showing RJ45 terminal cover added.

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <a href="http://www.sgs.com/en/Terms-and-Conditions.aspx">http://www.sgs.com/en/Terms-and-Conditions.aspx</a>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE