

EU Type Examination Certificate Number: 0120/SGS0354

Perry Electric srl

Via Milanese 11 22070 Veniano (CO) Italia

Instrument Identification: 1SDSD05CEM2MID

Single Phase, Active Import/ Export (kWh), Indoor, Electricity Meter

Instrument Traceable Number 0120/SGS0354

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 29th September 2025 Issue 1

Certification is based on report number(s) SHES141200649301 issued 16th April 2015 EMA207767 issued 9th October 2015 EMA251464

Authorised Signature



SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



EU-Type Examination Certificate Number:


0120/SGS0354

Issue Number: 1


Dated: 6th June 2018


1. Technical Data

Manufacturer	Perry Electric srl
Meter Type	1SDSD05CEM2MID
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	0.5-10(100)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No	V1.2
CRC Checksum	0x000052F2
Identification Location	Nameplate
Bill Of Materials Number	20150929
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	4 x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Nameplate and associated documents




2. Photograph of Meter and Sealing Plan





3. Examples of Nameplates



Prodotto non fabbricato in Italia

Nameplate

Right side laser

SW:V1.2 SN:xxxxxxx LOT NO.: xxxxxxx

Top side laser



EU-Type Examination Certificate Number:

0120/SGS0354

Issue Number: 1

Dated: 6th June 2018

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta \in (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$

where

δe(<i>T</i> , <i>I</i> ,cosφ)	=	Additional error due to variation of the temperature at the same load
δe(<i>U</i> , <i>I</i> ,cosφ)	=	Additional error due to variation of the voltage at the same load
δe(f , I ,cosφ)	=	Additional error due to variation of the frequency at the same load

		Influenc	e Factors	for Tempe	rature, Vo	Itage & Fre	equency
Current	PF Cos	-25℃	-10℃	5℃	30 <i>°</i> C	40 <i>°</i> C	55 <i>°</i> C
Imin	1.0	0.45	0.33	0.23	0.15	0.17	0.23
ltr	1.0	0.44	0.31	0.19	0.07	0.10	0.18
10ltr	1.0	0.42	0.29	0.18	0.03	0.08	0.16
Imax	1.0	0.27	0.19	0.12	0.03	0.06	0.12
ltr	0.5ind	0.48	0.36	0.27	0.17	0.18	0.22
10ltr	0.5ind	0.41	0.28	0.17	0.03	0.08	0.17
Imax	0.5ind	0.27	0.18	0.12	0.04	0.07	0.13
ltr	0.8cap	0.45	0.31	0.20	0.09	0.12	0.18
10ltr	0.8cap	0.40	0.27	0.16	0.04	0.10	0.19
Imax	0.8cap	0.26	0.19	0.11	0.05	0.08	0.15

000	EU-Type Examination Certificate Number:		
SGS	0120/SGS0354		
	Issue Number: 1	Dated: 6 th June 2018	

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
1SDSD05CEM2MID	Single tariff, total active energy, resettable energy, active power

Modifications to the meter(s) described according to approval No.0120/SGS0354 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0354

Issue Number: 1

Dated: 6th June 2018

6. Document Revision History

Issue	Date	Comments
1	06/06/2018	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE