

EU Type Examination Certificate Number: 0120/SGS0355

# **BTICINO Spa**

Viale Borri, 231 21100 Varese Italy

Instrument Identification:

**CE6DMID52, CE6DMID56, F41DM125** 

Polyphase, Active Import kWh, DIN Rail, Electricity Meter

Instrument Traceable Number 0120/SGS0355

has been assessed and certified as meeting the requirements of

# EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 14<sup>th</sup> June 2018 until 13<sup>th</sup> June 2028 Issue 2

Certification is based on report number(s) EMA248086/1 dated 14<sup>th</sup> June 2018 EMA248086/1/TR50579 14<sup>th</sup> June 2018

**Authorised Signature** 

H

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 <a href="https://www.sgs.com">www.sgs.com</a>

DU\_CST-ME-002 Rev 2 EU Type Examination Cert.



# 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018

#### 1. Technical Data


| Manufacturer                        | BTICINO Spa  |  |  |
|-------------------------------------|--|--|--|
| Meter Type's                        | CE6DMID52<br>CE6DMID56<br>F41DM125   |  |  |
| Voltage Rating (Un)                 | 3 x 230/400V   |  |  |
| Current Rating (Imin – Iref (Imax)) | 0.5-10(125)A,  |  |  |
| Frequency (Fn)                      | 50Hz   |  |  |
| Active Accuracy Class (kWh)         | B (kWh)  |  |  |
| Type of circuit                     | 3p4w   |  |  |
| Temperature Range                   | -25℃ to +55℃   |  |  |
| Software/ Firmware Version No's     | CE6DMID52: <b>MID 1.101</b><br>CE6DMID56: <b>MID 1.101</b><br>F41DM125: <b>MID 1.101</b>   |  |  |
| CRC Checksum No's                   | CE6DMID52: <b>60922</b><br>CE6DMID56: <b>36085</b><br>F41DM125: <b>36085</b>               |  |  |
| Identification Location             | LCD  |  |  |
| Bill Of Materials No's              | CE6DMID52: IM-CE6DMID52<br>CE6DMID56: IM-CE6DMID56<br>F41DM125: BT-F41DM125                |  |  |
| IP Rating                           | Meter to be installed in a suitable IP rated enclosure as described in installation manual |  |  |
| Insulation Protective Class         | Class II   |  |  |
| LED Pulse Constant                  | 5Wh/imp  |  |  |
| Impulse Voltage Rating              | 6kV  |  |  |
| AC Voltage Rating                   | 4kV  |  |  |
| Main Cover Sealing Type             | 4 x ultrasonic welded plastic plugs.   |  |  |
| Integrity of meter                  | Inaccessible without breaking seals  |  |  |
| Intended Location of the Meter      | Indoor   |  |  |
| Type of Register                    | LCD  |  |  |
| Terminal Arrangement(s)             | DIN  |  |  |
| Location of Manufacturers Address   | Nameplate & Documentation  |  |  |




# 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018

### 2. Photographs of Meter and Sealing Plan








## 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018


#### 3. Nameplates & Markings






## 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018









## 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018

#### 4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$ 

#### where

 $\delta e(T, I, \cos \varphi) =$  Additional error due to variation of the temperature at the same load  $\delta e(U, I, \cos \varphi) =$  Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load



# 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018

|         |        | Influenc | e Factors | for Tempe | rature. Fre | quency & | Voltage |
|---------|--------|----------|-----------|-----------|-------------|----------|---------|
| Current | PF Cos | -25℃     | -10℃      | 5℃        | 30℃         | 40℃      | 55℃     |
| Imin    | 1.0    | 0.72     | 0.50      | 0.27      | 0.07        | 0.08     | 0.10    |
| ltr     | 1.0    | 0.55     | 0.34      | 0.19      | 0.06        | 0.05     | 0.18    |
| 10ltr   | 1.0    | 0.55     | 0.33      | 0.18      | 0.06        | 0.11     | 0.17    |
| Imax    | 1.0    | 0.65     | 0.41      | 0.22      | 0.08        | 0.12     | 0.18    |
| ltr     | 0.5ind | 0.45     | 0.42      | 0.49      | 0.41        | 0.45     | 0.60    |
| 10ltr   | 0.5ind | 0.49     | 0.31      | 0.28      | 0.35        | 0.43     | 0.57    |
| Imax    | 0.5ind | 0.36     | 0.37      | 0.44      | 0.35        | 0.37     | 0.50    |
| ltr     | 0.8cap | 0.61     | 0.44      | 0.30      | 0.10        | 0.15     | 0.14    |
| 10ltr   | 0.8cap | 0.58     | 0.40      | 0.27      | 0.18        | 0.33     | 0.50    |
| Imax    | 0.8cap | 0.92     | 0.68      | 0.48      | 0.18        | 0.19     | 0.19    |
| L1      |        |          |           |           |             |          |         |
| Itr     | 1.0    | 0.52     | 0.34      | 0.20      | 0.10        | 0.12     | 0.15    |
| 10ltr   | 1.0    | 0.40     | 0.24      | 0.17      | 0.21        | 0.25     | 0.28    |
| Imax    | 1.0    | 0.53     | 0.32      | 0.15      | 0.06        | 0.11     | 0.16    |
| ltr     | 0.5ind | 0.39     | 0.30      | 0.32      | 0.32        | 0.30     | 0.38    |
| 10ltr   | 0.5ind | 0.47     | 0.30      | 0.24      | 0.41        | 0.51     | 0.67    |
| Imax    | 0.5ind | 0.69     | 0.75      | 0.84      | 0.72        | 0.76     | 0.87    |
| L2      |        |          |           |           |             |          |         |
| ltr     | 1.0    | 0.44     | 0.27      | 0.17      | 0.09        | 0.10     | 0.14    |
| 10ltr   | 1.0    | 0.46     | 0.27      | 0.14      | 0.05        | 0.09     | 0.13    |
| Imax    | 1.0    | 0.56     | 0.35      | 0.21      | 0.06        | 0.10     | 0.19    |
| ltr     | 0.5ind | 0.36     | 0.42      | 0.49      | 0.36        | 0.37     | 0.47    |
| 10ltr   | 0.5ind | 0.41     | 0.28      | 0.29      | 0.38        | 0.51     | 0.69    |
| Imax    | 0.5ind | 0.56     | 0.60      | 0.65      | 0.55        | 0.60     | 0.71    |
| L3      |        |          |           |           |             |          |         |
| Itr     | 1.0    | 0.69     | 0.49      | 0.37      | 0.31        | 0.33     | 0.38    |
| 10ltr   | 1.0    | 0.66     | 0.39      | 0.19      | 0.07        | 0.17     | 0.26    |
| Imax    | 1.0    | 0.73     | 0.46      | 0.26      | 0.09        | 0.15     | 0.23    |
| ltr     | 0.5ind | 0.50     | 0.39      | 0.40      | 0.37        | 0.40     | 0.56    |
| 10ltr   | 0.5ind | 0.61     | 0.38      | 0.28      | 0.33        | 0.42     | 0.53    |
| Imax    | 0.5ind | 0.78     | 0.84      | 0.89      | 0.39        | 0.89     | 0.96    |



## 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018

#### 5. Annex of Variants

Product Variant Identification Details:

| Type Designation | Description of meter   |
|------------------|--|
| CE6DMID52        | Polyphase, 3x230/400V, 5(125)A, 50Hz, pulse output             |
| CE6DMID56        | Polyphase 3x230/400V, 5(125)A, 50Hz,RS485 Modbus communication |
| F41DM125         | Polyphase 3x230/400V, 5(125)A, 50Hz,RS485 Modbus communication |

Modifications to the meter(s) described according to approval No.0120/SGS0355 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



## 0120/SGS0355

Issue Number: 2 Dated: 2<sup>nd</sup> October 2018

#### 6. Document Revision History

| Issue | Date       | Comments                  |
|-------|------------|---------------------------|
| 1     | 14/06/2018 | Initial Issue             |
| 2     | 02/10/2018 | Influence factors updated |

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <a href="http://www.sgs.com/en/Terms-and-Conditions.aspx">http://www.sgs.com/en/Terms-and-Conditions.aspx</a>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE