

EU Type Examination Certificate Number: 0120/SGS0356

Zhejiang CHINT Instrument & Meter Co., Ltd

Wenzhou Bridge Industrial Zone Yueqing Zhejiang P. R. China

Instrument Identification:

DDSID666

Single Phase, Active Import kWh, Smart, Electricity Meter

Instrument Traceable Number 0120/SGS0356

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 29th September 2018 until 28th September 2028 Issue 1

Certification is based on report number(s) SHES170800838701 dated 20th August 2018 EMA254463/1/TR50579 20th August 2018 EMA254463/1

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

DU_CST-ME-002 Rev 2 EU Type Examination Cert.



0120/SGS0356

Issue Number: 1 Dated: 29th September 2018

1. Technical Data

Manufacturer	Zhejiang CHINT Instrument & Meter Co., Ltd			
Meter Type's	DDSID666			
Voltage Rating (Un)	230V			
Current Rating (Imin – Iref (Imax))	0.5-10(60)A,			
Frequency (Fn)	50Hz			
Active Accuracy Class (kWh)	B (kWh)			
Type of circuit	1p2w			
Temperature Range	-25 ℃ to +55 ℃			
Software/ Firmware Version No.	ZTYMID.0.01.01			
CRC Checksum No.	FA1B6329			
Identification Location	Nameplate			
Bill Of Materials No's	1887V5.1_0001_230_10(60) ZTY0.051.835.1(20170613)			
IP Rating	IP51			
Insulation Protective Class	Class II			
LED Pulse Constant	1000 imp/kWh			
Impulse Voltage Rating	6kV			
AC Voltage Rating	4kV			
Main Cover Sealing Type	3 x Ultrasonically welded and sealed plastic stakes			
Integrity of meter	Inaccessible without breaking seals			
Intended Location of the Meter	Indoor			
Type of Register	LCD			
Terminal Arrangement(s)	BS			
Location of Manufacturers Address	Associated Documentation			



0120/SGS0356

Issue Number: 1 Dated: 29th September 2018

2. Photographs of Meter and Sealing Plan






0120/SGS0356

Issue Number: 1 Dated: 29th September 2018

3. Example of Nameplate





0120/SGS0356

Issue Number: 1 Dated: 29th September 2018

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$

		Influenc	e Factors	for Tempe	rature. Fre	equency &	Voltage
Current	PF Cos	-25℃	-10℃	5℃	30℃	40℃	55℃
lmin	1.0	0.02	0.02	0.03	0.03	0.06	0.13
ltr	1.0	0.05	0.06	0.05	0.02	0.02	0.14
10ltr	1.0	0.04	0.00	0.01	0.02	0.05	0.12
Imax	1.0	0.01	0.01	0.01	0.04	0.10	0.16
ltr	0.5ind	0.07	0.05	0.05	0.05	0.04	0.09
10ltr	0.5ind	0.05	0.01	0.01	0.03	0.05	0.12
Imax	0.5ind	0.02	0.01	0.01	0.05	0.09	0.16
ltr	0.8cap	0.03	0.06	0.04	0.05	0.03	0.12
10ltr	0.8cap	0.03	0.00	0.02	0.02	0.05	0.14
lmax	0.8cap	0.01	0.02	0.02	0.04	0.08	0.17



0120/SGS0356

Issue Number: 1 Dated: 29th September 2018

5. Description of Meter

Product Identification Details:

- Single Phase Smart Meter
- Complies with IEC 62056 and EN50470 standards.
- Voltage and current ratings:0,5-10(60)A 230V
- Unidirectional or Bi-directional active energy /reactive measurement, including forward active energy/reverse active energy/four-quadrant reactive energy measurement, Instantaneous value measurement.
- Multi-tariff function: supply contract and grid contract.
 - a) Supply contract: With 12 season tables, 8 week profile tables, 10 day profile table and 11 switch-time tables; With 30 special days, 3 peak days, 20 special actions.
 - b) Grid contract: With 4 season tables, 4 week profile tables, 4 day profile tables and 11 switch-time tables; With 30 special days.
- Independent RTC with accuracy 0.5s /day at full temperature range, and leap year auto switch.
- Three communication modes: G3-PLC supported IPV6 communications; Euridis 2 (IEC62056-31 with DLMS) communications; TIC with IHD(In home Display).
- G3-PLC with IPV6 protocol and Euridis 2 protocol, Support AES128-GCM, MD5, GMAC and other encryption communication methods of DLMS/COSEM, ensures an open and secure communication system, has excellent compatibility.
- Effectively suppress magnetic interference.
- Tamper Cheat detection and strong magnetic field detection function, while ensuring PLC communication at 500mT field.
- Remote communication control load switch on/off function; and automatically detect (user breaker status) to close and open load switch.
- Relay control water heater and virtual relay control function.
- Multiple event logs and load profile record function.
- Local or remote firmware upgrades, the function of the meter can be extended.
- Long life dot matrix LCD display which can display 3 lines of 16 characters.
- LCD backlight can increase readability under low light condition.
- 20-year lifetime.
- Support three-point screw fixation and DIN rail fixation.

Modifications to the meter(s) described according to approval No.0120/SGS0356 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0356

Issue Number: 1 Dated: 29th September 2018

6. Document Revision History

Issue	Date	Comments
1	26/09/2018	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE