

EU Type Examination Certificate Number: 0120/SGS0360

Qonnex byba

Hollestraat 12 9310 Aalst Belguim

Instrument Identification:

EMM.220

Single Phase, Active Import/ Export (kWh), Multifunction, Indoor, Electricity Meter

Instrument Traceable Number 0120/SGS0360

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 15th April 2025 Issue 1

Certification is based on report number(s) SHES141200649301 16th April 2015 EMA255538

Authorised Signature

HC.

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

DU_CST-ME-002 Rev 2 EU Type Examination Cert.



0120/SGS0360

Issue Number: 1 Dated: 19th July 2018

1. Technical Data

NA	0
Manufacturer	Qonnex bvba
Meter Type	EMM.220
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	0.25-5(100)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No	V1.2
Identification Location	Nameplate
Bill Of Materials Number	V1.5
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	2 x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Nameplate and associated documents



0120/SGS0360

Issue Number: 1 Dated: 19th July 2018

2. Photograph of Meter and Sealing Plan







0120/SGS0360

Issue Number: 1 Dated: 19th July 2018

3. Examples of Nameplates







0120/SGS0360

Issue Number: 1 Dated: 19th July 2018

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(J, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$

Influence Factors for Temperature, Voltage & Frequenc						equency	
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.30	0.28	0.25	0.23	0.24	0.23
Itr	1.0	0.17	0.15	0.16	0.13	0.13	0.13
10ltr	1.0	0.07	0.08	0.08	0.05	0.07	0.10
Imax	1.0	0.13	0.11	0.05	0.04	0.04	0.04
Itr	0.5ind	0.27	0.24	0.24	0.21	0.21	0.23
10ltr	0.5ind	0.16	0.16	0.17	0.16	0.16	0.17
Imax	0.5ind	0.06	0.04	0.05	0.11	0.11	0.09
Itr	0.8cap	0.24	0.24	0.22	0.19	0.19	0.19
10ltr	0.8cap	0.06	0.07	0.07	0.05	0.07	0.08
Imax	0.8cap	0.13	0.09	0.04	0.03	0.03	0.03



0120/SGS0360

Issue Number: 1 Dated: 19th July 2018

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
EMM.220	Single tariff, single phase, multi-function, RS485 Modbus

Modifications to the meter(s) described according to approval No.0120/SGS0360 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0360

Issue Number: 1 Dated: 19th July 2018

6. Document Revision History

Issue	Date	Comments
1	19/07/2018	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE