

EU Type Examination Certificate Number: 0120/ SGS0382

Secure Meters (UK) Ltd

Secure House Moorside Road Winnall Winchester SO23 7RX

Instrument Identification: Liberty 101

Single Phase, Active Import/Export (kWh), Smart, Electricity Meter

Instrument Traceable Number 0120/ SGS0382

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 23rd August 2018 until 22nd August 2028 Issue 1

Certification is based on report number(s) EMA257329/1 dated 21st August 2018, EMA257329/1/TR50579 dated 21st August 2018, EMA257329/1/iss2 dated 23rd August 2018

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com



0120/ SGS0382

Issue Number: 1

Dated: 23rd August 2018

1. Technical Data

Manufacturer	Secure Meters (UK)Ltd
Meter Type(s)	Liberty 101
Voltage Rating (Un)	
Current Rating (Imin – Iref (Imax))	
Frequency (Fn)	50 Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25° C to +55° C
Software/ Firmware Version No	B92C010102
CRC Checksum	F6CE
Software Identification Location	LCD
Bill Of Materials Number	E1S0B1-Z30
Mechanical Environment	M1
Electromagnetic Environment	E2
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	3200 imp / kWh
Impulse Voltage Rating	6 kV
AC Voltage Rating	4 kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	BS
Location of Manufacturers Address	Associated Documents



0120/ SGS0382


Issue Number: 1

Dated: 23rd August 2018


2. Photograph of Meter and Sealing Plan



Main cover seal



3. Nameplate





0120/ SGS0382

Issue Number: 1

Dated: 23rd August 2018

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta \in (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$

where

$\delta e(T, I, \cos \varphi) =$	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos \phi) =$	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos \phi) =$	Additional error due to variation of the frequency at the same load

		Influence Factors for Temperature. Frequency & Voltage					
Current	PF Cos	-25 <i>°</i> C	-10℃	5℃	30°C	40 <i>°</i> C	55℃
Imin	1.0	0.19	0.14	0.12	0.12	0.19	0.29
ltr	1.0	0.20	0.15	0.11	0.11	0.18	0.30
10ltr	1.0	0.20	0.12	0.08	0.10	0.16	0.32
Imax	1.0	0.17	0.14	0.13	0.17	0.25	0.41
ltr	0.5ind	0.09	0.09	0.09	0.09	0.11	0.30
10ltr	0.5ind	0.59	0.54	0.51	0.54	0.70	0.77
Imax	0.5ind	0.09	0.06	0.06	0.13	0.06	0.46
ltr	0.8cap	0.16	0.05	0.03	0.08	0.17	0.34
10ltr	0.8cap	0.18	0.11	0.06	0.09	0.19	0.39
Imax	0.8cap	0.14	0.10	0.07	0.16	0.25	0.47



0120/ SGS0382


Issue Number: 1

Dated: 23rd August 2018

5. Annex of Variants

Product Variant Identification Details:

<u>Codification For Single Phase Liberty 101 Pre-Payment Meter</u>



XXXXXXX-Factory configurable features

Factory Configuration Features		
ICHIS COMPATIBLE TOP HAT	Refer table below	
COMMUNICATION MODULE		
SWITCH VENDOR	GRUNER/JOHNSON	
AUXILIARY OUTPUT	Present/Absent	

Table:1

Feature	Options
ICHIS compatible top hat Communication Module	Not present from factory (field installed) Toshiba EDMI WNC

Modifications to the meter(s) described according to approval No.**0120**/ **SGS0382** must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0382

Issue Number: 1

Dated: 23rd August 2018

6. Document Revision History

Issue	Date	Comments
1	23/08/2018	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE