

EU Type Examination Certificate Number: 0120/SGS0391

Eastron Zhejiang Electronic Co. Ltd

No. 1369. Chengnan Road Jiaxing Zhejiang China

Instrument Identification:

SDM320Y Series

Single Phase, Active, Import/ Export (kWh), Pre-payment, Electricity Meter

Instrument Traceable Number 0120/SGS0391

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 5th November 2018 until 4th November 2028 Issue 1

Certification is based on report number(s) EMA255473/1dated 20th November 2018, EMA255473/1/TR50579 dated 14th August 2018 Authorised Signature



SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

DU_CST-ME-002 Rev 2 EU Type Examination Cert.



0120/SGS0391

Issue Number: 1 Dated: 5th December 2018

1. Technical Data

Manufacturer	Zhejiang Eastron Electronic Co., Ltd
Meter Type's	SDM320Y-RF SDM320Y-D
Voltage Rating (Un)	2201/
Current Rating (Imin – Iref (Imax))	0,5-10(80)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No's	SDM320Y-RF: V1.1 SDM320Y-D: V1.2
CRC Checksum No's	SDM320Y-RF: 0x0000C70D SDM320Y-D: 0x0000F401
Identification Location	LCD & Nameplate
Bill Of Materials No's	SDM320Y-RF: DH-JS-180004-1.0 SDM320Y-D: DH-JS-180030-1.0
IP Rating	IP51 Must be installed in a suitable IP rated enclosure
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	4 x screws. 1 sealed with plastic plug
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Nameplate




0120/SGS0391

Issue Number: 1 Dated: 5th December 2018

2. Photograph of Meter and Sealing Plan








0120/SGS0391

Issue Number: 1 Dated: 5th December 2018

3. Example of Nameplate







0120/SGS0391

Issue Number: 1 Dated: 5th December 2018

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \varphi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load

Current	PF Cos	-25℃	-10℃	5℃	30℃	40℃	55℃
Imin	1.0	0.74	0.49	0.32	0.19	0.22	0.32
ltr	1.0	0.74	0.49	0.29	0.09	0.15	0.25
10ltr	1.0	0.76	0.51	0.32	0.03	0.07	0.19
Imax	1.0	0.48	0.33	0.23	0.09	0.10	0.15
ltr	0.5ind	0.82	0.59	0.38	0.18	0.21	0.28
10ltr	0.5ind	0.79	0.53	0.33	0.04	0.11	0.22
Imax	0.5ind	0.59	0.44	0.31	0.10	0.07	0.10
ltr	0.8cap	0.71	0.48	0.30	0.11	0.14	0.22
10ltr	0.8cap	0.68	0.44	0.28	0.06	0.12	0.22
Imax	0.8cap	0.46	0.32	0.23	0.07	0.06	0.10



0120/SGS0391

Issue Number: 1 Dated: 5th December 2018

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter		
SDM320Y-D	230V, 0.5A-10(80)A, pulse output		
SDM320Y-RF	230V, 0.5A-10(80)A, RS485 Modbus communication		

Modifications to the meter(s) described according to approval No.0120/SGS0391 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0391

Issue Number: 1 Dated: 5th December 2018

6. Document Revision History

Issue	Date	Comments
1	05/12/2018	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE