

EU Type Examination Certificate Number: 0120/SGS0400

# Caravan Park Electrical Services Ltd

Vale Industrial Estate
Spilsby
Lincolnshire
PE23 5HE
United Kingdom

Instrument Identification:

033006-RFID

Single Phase, Active, Import/ Export (kWh), Pre-payment, Electricity Meter

Instrument Traceable Number 0120/SGS0400

has been assessed and certified as meeting the requirements of

# EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 19<sup>th</sup> November 2028 Issue 1

Certification is based on report number(s) EMA255473/1 dated 20th November 2018 EMA255473/1/TR50579 dated 14<sup>th</sup> August 2018 EMA262256

**Authorised Signature** 

\*\*

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 <a href="https://www.sgs.com">www.sgs.com</a>

DU\_CST-ME-002 Rev 2 EU Type Examination Cert.



# 0120/SGS0400

Issue Number: 1 Dated: 3<sup>rd</sup> January 2019

#### 1. Technical Data

Manufacturer	Caravan Park Electrical Services Ltd		
Meter Type	033006-RFID		
Voltage Rating (Un)	230V		
Current Rating (Imin – Iref (Imax))	0,5-10(80)A		
Frequency (Fn)	50Hz		
Active Accuracy Class (kWh)	A or B (kWh)		
Type of circuit	1p2w		
Temperature Range	-25°C to +55°C		
Software/ Firmware Version No's	V1.1		
CRC Checksum No's	0x0000C70D		
Identification Location	LCD & Nameplate		
Bill Of Materials No's	DH-JS-180004-1.0		
IP Rating	IP51 Must be installed in a suitable IP rated enclosure		
Insulation Protective Class	Class II		
LED Pulse Constant	1000imp/kWh		
Impulse Voltage Rating	6kV		
AC Voltage Rating	4kV		
Main Cover Sealing Type	4 x screws. 1 sealed with plastic plug		
Integrity of meter	Inaccessible without breaking seals		
Intended Location of the Meter	Indoor		
Type of Register	LCD		
Terminal Arrangement(s)	DIN		
Location of Manufacturers Address	Associated documents		




# 0120/SGS0400

Issue Number: 1 Dated: 3<sup>rd</sup> January 2019

### 2. Photograph of Meter and Sealing Plan








## 0120/SGS0400

Issue Number: 1 Dated: 3<sup>rd</sup> January 2019

#### 3. Example of Nameplate




Caravan Park Electrical Services Limited

033006-RFID 0120/SGS0400 M19 g

Single Phase Energy Meter

230V AC 0,5-10(80)A AC 50Hz 2019 1000imp/kWh EN50470-1/3







## 0120/SGS0400

Issue Number: 1 Dated: 3<sup>rd</sup> January 2019

#### 4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$ 

#### where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$ 

Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.74	0.49	0.32	0.19	0.22	0.32
Itr	1.0	0.74	0.49	0.29	0.09	0.15	0.25
10ltr	1.0	0.76	0.51	0.32	0.03	0.07	0.19
Imax	1.0	0.48	0.33	0.23	0.09	0.10	0.15
Itr	0.5ind	0.82	0.59	0.38	0.18	0.21	0.28
10ltr	0.5ind	0.79	0.53	0.33	0.04	0.11	0.22
Imax	0.5ind	0.59	0.44	0.31	0.10	0.07	0.10
Itr	0.8cap	0.71	0.48	0.30	0.11	0.14	0.22
10ltr	0.8cap	0.68	0.44	0.28	0.06	0.12	0.22
Imax	0.8cap	0.46	0.32	0.23	0.07	0.06	0.10



# 0120/SGS0400

Issue Number: 1 Dated: 3<sup>rd</sup> January 2019

#### 5. Annex of Variants

**Product Variant Identification Details:** 

Type Designation	Description of meter
033006-RFID	230V, 0.5A-10(80)A, RS485 Modbus communication

Modifications to the meter(s) described according to approval No.0120/SGS0400 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



## 0120/SGS0400

Issue Number: 1 Dated: 3<sup>rd</sup> January 2019

#### 6. Document Revision History

Issue	Date	Comments
1	03/01/2019	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <a href="http://www.sgs.com/en/Terms-and-Conditions.aspx">http://www.sgs.com/en/Terms-and-Conditions.aspx</a>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE