

EU Type Examination Certificate Number: 0120/SGS0276

Rayleigh Instruments Limited

Raytel House Cutlers Road South Woodham Ferrers Essex CM3 5WA

Instrument Identification:

RI-D140-C HGR45

Poly phase, Active Import / Export (kWh), Transformer Operated, Auxiliary Power Supply

Instrument Traceable Number 0120/SGS0276

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 6th April 2017 until 5th April 2027 Issue 3

Certification is based on report number(s) EMA231682/1 Dated 17th February 2017

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

DU_CST-ME-002 Rev 2 EU Type Examination Cert.



0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

1. Technical Data

Manufacturer	Rayleigh Instruments Ltd
Meter Type	RI-D140-C and HGR45C
Voltage Rating (Un)	3 x 85/147 – 240/415V
Auxiliary Supply Voltage	85 - 270V
Current Rating (Imin – Iref (Imax))	0.05-5(6)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B (kWh)
Type of circuit	3P4W, 1P2W
Temperature Range	-25°C to +55°C
Software/ Firmware Version No	V1.0
CRC Checksum	10841
Identification Location	LCD
Bill Of Materials Number	DDCAD RID140-G-C
IP Rating	IP51 Front Display Meter body not rated. Must be installed in a suitable IP rated enclosure
Insulation Protective Class	Class II
LED Pulse Constant	Dependant on CT Ratio
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Self destructive label across the joint between base and side of case.
Terminal Cover Sealing Type	4 x wire & crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Location of Manufacturers Address	Nameplate & Documentation




0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

2. Photograph of Meter and Sealing Plan








0120/SGS0276

Issue Number: 3 Dated: 29th March 2019



Sealing is via a self-destructive seal applied across the meter casing joint, as shown below







0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

3. Examples of Nameplates









0120/SGS0276

Issue Number: 3 Dated: 29th March 2019







0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\begin{array}{lll} \delta \mathrm{e}(T,I,\cos \varphi) & = & \quad \text{Additional error due to variation of the temperature at the same load} \\ \delta \mathrm{e}(U,I,\cos \varphi) & = & \quad \text{Additional error due to variation of the voltage at the same load} \\ \delta \mathrm{e}(f,I,\cos \varphi) & = & \quad \text{Additional error due to variation of the frequency at the same load} \\ \end{array}$



0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

		Influence Factors for Temperature. Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.23	0.15	0.13	0.13	0.20	0.32
Itr	1.0	0.47	0.22	0.22	0.20	0.26	0.36
10ltr	1.0	0.25	0.25	0.25	0.25	0.34	0.34
Imax	1.0	0.41	0.41	0.41	0.42	0.42	0.53
Itr	0.5ind	0.24	0.21	0.22	0.22	0.33	0.48
10ltr	0.5ind	0.41	0.54	0.54	0.50	0.78	0.78
Imax	0.5ind	0.33	0.33	0.34	0.53	0.79	0.59
Itr	0.8cap	0.64	0.35	0.32	0.33	0.36	0.43
10ltr	0.8cap	0.36	0.35	0.44	0.36	0.36	0.59
Imax	0.8cap	0.39	0.43	0.40	0.43	0.40	0.40
 L1					0.00	0.00	0.00
L Itr	1.0	0.58	0.25	0.14	0.08	0.11	0.27
10ltr	1.0	0.21	0.21	0.21	0.21	0.30	0.30
Imax	1.0	0.35	0.35	0.35	0.35	0.37	0.37
Imax	1.0	0.00	0.00	0.00	0.00	0.07	0.07
Itr	0.5ind	0.61	0.48	0.55	0.45	0.36	0.32
10ltr	0.5ind	0.43	0.43	0.43	0.23	0.22	0.25
Imax	0.5ind	0.44	0.43	0.53	0.46	0.25	0.34
L2							
Itr	1.0	0.43	0.29	0.25	0.29	0.31	0.46
10ltr	1.0	0.46	0.39	0.38	0.44	0.46	0.46
Imax	1.0	0.26	0.26	0.26	0.28	0.25	0.29
 Itr	0.5ind	0.18	0.10	0.10	0.16	0.24	0.35
10ltr	0.5ind	0.52	0.51	0.48	0.48	0.49	0.63
Imax	0.5ind	0.36	0.36	0.36	0.33	0.38	0.39
L3							
Itr	1.0	0.44	0.26	0.23	0.26	0.33	0.47
10ltr	1.0	0.47	0.47	0.51	0.50	0.51	0.67
Imax	1.0	0.41	0.38	0.38	0.38	0.39	0.71
 Itr	0.5ind	0.34	0.37	0.31	0.45	0.54	0.72
10ltr	0.5ind	1.05	0.81	1.01	1.06	1.01	1.24
Imax	0.5ind	0.77	0.59	0.60	1.08	0.94	0.97



0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
RI-D140-C HGR45C	Poly phase, Active Import/ Export (kWh), Transformer Operated with RS485 Modbus communications

Modifications to the meter(s) described according to approval No.0120/SGS0276 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0276

Issue Number: 3 Dated: 29th March 2019

6. Document Revision History

Issue	Date	Comments
1	06/04/2017	Initial Issue
2	08/08/2017	0.02-1(6)A variant and RI-D140-B-MB removed from approval. New sealing method.
3	29/03/2019	Addition of HGR45C variant

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE