

EU Type Examination Certificate Number: 0120/SGS0404

# **Wasion Group Limited**

No.468 WestTongzipo Road High-Tech Industrial Development Zone 410205 Changsha City HuNanProvince P.R China

Instrument Identification:

Hymeter 100

Single Phase, Import/Export (KWh), Multi-rate, Smart, Electricity Meter

Instrument Traceable Number 0120/SGS0404

has been assessed and certified as meeting the requirements of

# EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 14<sup>th</sup> February 2019 until 13<sup>th</sup> February 2029

Certification is based on report number(s) SHES181101376501 dated 14<sup>th</sup> February 2019 EMA264209/1/TR50579 dated 13<sup>th</sup> February 2019, EMA264209/1

**Authorised Signature** 

#P

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 <a href="https://www.sgs.com">www.sgs.com</a>

DU\_CST-ME-002 Rev 2 EU Type Examination Cert.



# 0120/SGS0404

Issue Number: 1 Dated: 14<sup>th</sup> February 2019

#### 1. Technical Data

Manufacturer	Wasion Group Limited
Meter Type	Hymeter 100
Voltage Rating (Un)	115 - 276V
Current Rating (Imin – Iref (Imax))	0.25-5(60)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No.	A0401010
CRC Checksum No.	9B46D685
Identification Location	LCD
Bill Of Materials Number	20190115
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	1600imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Nameplate



# 0120/SGS0404

Issue Number: 1 Dated: 14<sup>th</sup> February 2019

## 2. Photograph of Meter and Sealing Plan




Main Cover Sealing Points



## 0120/SGS0404

Issue Number: 1 Dated: 14<sup>th</sup> February 2019

### 3. Example of Nameplate





## 0120/SGS0404

Issue Number: 1 Dated: 14<sup>th</sup> February 2019

## 4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$ 

#### where

 $\delta e(T, I, \cos \phi) =$  Additional error due to variation of the temperature at the same load  $\delta e(U, I, \cos \phi) =$  Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load

		Influence Factors for Temperature, Voltage & Frequency							
Current	PF Cos	-40℃	-25℃	-10℃	5℃	30℃	40℃	55℃	70℃
lmin	1.0	0.52	0.41	0.28	0.16	0.03	0.08	0.19	0.26
ltr	1.0	0.51	0.38	0.25	0.13	0.04	0.11	0.21	0.31
10ltr	1.0	0.52	0.39	0.25	0.14	0.04	0.11	0.22	0.30
Imax	1.0	0.29	0.22	0.15	0.09	0.02	0.07	0.15	0.21
ltr	0.5ind	0.34	0.34	0.23	0.13	0.06	0.12	0.21	0.31
10ltr	0.5ind	0.35	0.35	0.24	0.13	0.04	0.12	0.23	0.33
Imax	0.5ind	0.20	0.20	0.13	0.08	0.04	0.08	0.16	0.24
ltr	0.8cap	0.38	0.38	0.26	0.16	0.05	0.10	0.19	0.26
10ltr	0.8cap	0.38	0.38	0.25	0.13	0.05	0.12	0.21	0.30
lmax	0.8cap	0.23	0.23	0.14	0.08	0.04	0.08	0.14	0.18



# 0120/SGS0404

Issue Number: 1 Dated: 14<sup>th</sup> February 2019

#### 5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
Hymeter 100	Single Phase, 115 - 276V, 0.25-5(60)A, 50Hz

Modifications to the meter(s) described according to approval No.0120/SGS0404 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



## 0120/SGS0404

Issue Number: 1 Dated: 14<sup>th</sup> February 2019

### 6. Document Revision History

Issue	Date	Comments
1	14/02/2019	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <a href="http://www.sgs.com/en/Terms-and-Conditions.aspx">http://www.sgs.com/en/Terms-and-Conditions.aspx</a>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE