

WEST HORSLEY PLACE

Existing c1940 to present Sewage Works Capacity Combined System Maximum Sewage Outflow per Day

A	Estate Accommodation etc	People	Litres/Day	Total	Notes
1	Accommodation No 1 - 2 bedrooms (possibly 3 in 1940)	3	150	450	
2	Accommodation No 2 - 3 bedrooms (possibly 4 in 1940)	5	150	750	
3	Accommodation No 3 - 4 bedrooms (possibly 5 in 1940)	7	150	1050	
4	Lodge - 3 bedrooms	5	150	750	
B	Main House c1940				
1	Butlers, maids, liverymen, stablehands etc - 5 attic bedrooms etc	10	150	1500	
2	Cooks, scullery maids etc accommodation over kitchen - 4 bedrooms	6	150	900	
3	Lord and Lady Crewe's room	2	150	300	
4	Pink bedroom	2	150	300	
5	Old library bedroom	2	150	300	
6	Goldsmiths bedroom	2	150	300	
7	Buff bedroom	2	150	300	
8	Mulberry bedroom	2	150	300	
9	Blue bedroom	2	150	300	
10	Weston bedroom	2	150	300	
11	Bedroom adjacent to Weston bedroom	2	150	300	
12	Raleigh bedroom	2	150	300	
13	Bedroom adjacent to Raleigh bedroom	2	150	300	
14	Bedrooms to ground floor north west corner covered c1960 - 2no bedrooms	2	150	300	
C	Foul surface water from farmyard and stables and Rainwater from House and roofs etc				
1	Rainwater heavy storm allowed 1 year frequency and foul surface water from farmyard, and foul surface water and effluent from stables internally and externally	1	23622	23622	
TOTAL MAXIMUM DISCHARGE PER DAY				32622	litres per day