

## Environment Agency

# Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

## Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/EP3533RY  
The Operator is: Uniper UK Limited  
The Installation is: Grain Power Station  
This Variation Notice number is: EPR/EP3533RY/V006

### What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Additional IED Chapter II requirements
- 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2010 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 01/05/18 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 31/10/18.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review. We therefore issued further information requests to the Operator on 11/03/19 and 26/03/19. Suitable further information was provided by the Operator on 26/04/19.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

In relation to BAT Conclusion 9, we consider that improvements are required in respect to current capability stated by the operator as recorded in their Regulation 61 Notice response.

We have therefore included an improvement condition IC11 in the consolidated variation notice, which requires them to upgrade their operational techniques so that the requirements of the BAT Conclusion are delivered by 17 August 2021.

### 3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## 4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- The review and assessment of the availability of BAT for gas turbines operating <500 hours per year
- BATc 9 characterisation of fuel

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### 4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding: if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.
- For gas turbines operating less than 500 hours per year, we have referred to the following publications that reflect the work carried out by Joint Environmental Programme (JEP) research group and agreed in principle by the Environment Agency:
  - JEP report JEP17EMG02 / UTG/18/ERG/CT/773/R 'Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018;
  - JEP report JEP19AIB08 / UTG/18/PMP/774/R, 'BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year', October 2018.



The site consists four LCPs, namely LCP 102, LCP 103, LCP 104 and LCP 105.

LCP 102 consists of two open cycle gas turbines (OCGTs) fired on gas oil for generation of electricity for balancing services as a non-emergency plant, for up to 500 hours per year. These are Rolls Royce Avon gas turbines installed in the 1970-ies.

LCP 103, LCP 104 and LCP105 consist each of a combined cycle gas turbine (CCGT) fired on natural gas.

All the LCPs within the installation were put into operation before IED came into force and therefore the existing limits in the permit are either from Part 1 of Annex V applicable to existing plant, or more stringent due to application of the no-backsliding principle at the time of implementation of the IED and associated permit review.

The ELVs and AELs are based on the following operating regime:

- <500 hours non-emergency plant for LCP 102
- Unlimited hours operation for LCP 103, LCP 104 and LCP 105.

The following table outlines the limits that have been incorporated into the permit for LCP 102, LCP 103, LCP 104 and LCP 105, where these were derived from, where the backsliding principle has been followed, and the reference periods at which they apply. The emission limits and monitoring tables have been incorporated into Schedule 3.

## LCP 102

<b>Plant type</b>	Open Cycle Gas Turbine
<b>Age</b>	Permitted <b>before</b> publication of the LCP BREF and <b>before</b> IED
<b>Operating Hours</b>	Less than 500 hours/year non-emergency
<b>Fuel</b>	Gas oil

Under Chapter III gas turbines and gas engines operating for less than 500 hours per year are considered to be emergency plant and therefore are not covered by the emission limits set out in IED Annex V. However, for the purposes of the LCP BAT review, plants operated for emergency use may only be defined as plants which operate for the sole purpose of providing power at a site during an onsite emergency and/or during a black start and which do not provide balancing services or demand side response services. As LCP 102 within this site runs commercially on an intermittent basis to support the Grid (fast start contract), it is not considered emergency plant for the purposes of the LCP BAT review and therefore indicative BAT apply.

We have set the indicative limits requiring validation through emission factors based on the principle that we will not require plant to fire up with the sole purpose of performing an emission measurement, as set out the UK Regulators Interpretation Document.

NOx limits (mg/Nm <sup>3</sup> ) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	Continuous <sup>Note 2</sup>	None	None
Monthly	None	None	None	NA	NA		None	None

NOx limits (mg/Nm <sup>3</sup> ) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Daily average or average over the sampling period	None	None <sup>Note 1</sup>	None	BREF	70% to baseload		None	<b>300</b>
95 <sup>th</sup> %ile of hr means	None	None	None	NA	NA		None	None
<p><b>Note 1:</b> BATc 38 provides an indicative emission level of 250 mg/Nm<sup>3</sup> for combustion of gas oil in <u>dual fuel</u> gas turbines operating less than 500 hours per year. However this indicative figure is not applicable to LCP 102, because gas turbines within LCP 102 are not dual fuel.</p> <p><b>Note 2:</b> Footnote 2 to BAT conclusion 4 specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.</p>								

The indicative emission level for combustion of gas oil in dual fuel gas turbines operating less than 500 hours per year is reported in Note 1 of table above for reference. This indicative emission level is not applicable to LCP 102, because gas turbines within LCP 102 are not dual fuel. We have therefore set a benchmark emission level in the revised and consolidated permit notice at 300 mg/Nm<sup>3</sup> based on the emissions reported by the operator for the type of machines installed within LCP 102. The figure reported by the operator is based on industry benchmark emission level from reported industry performance, documented in JEP report JEP17EMG02 / UTG/18/ERG/CT/773/R 'Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018, for the specific gas turbines installed at Grain Power Station.

CO limits (mg/Nm <sup>3</sup> )								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	NA	None	None
Monthly	None	None	None	NA	NA		None	None
Daily	None	None	None	NA	NA		None	None
95 <sup>th</sup> %ile of hr means	None	None	None	NA	NA		None	None

SO <sub>2</sub> limits (mg/Nm <sup>3</sup> ) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None <sup>Note 1</sup>	NA	NA	Continuous or Periodic <sup>Notes 2, 3</sup>	None	None
Monthly	None	None	None	NA	NA		None	None
Daily or average over the sampling period	None	<i>66</i>	<i>66</i>	BREF	70% to baseload		None	<i>66</i>
95 <sup>th</sup> %ile of hr means	None	None	None	NA	NA		None	None

**Note 1:** Footnote 1 to Table 22 of BATc specifies that the annual AELs are not applicable to plants operating <1500 hours.

**Note 2:** Footnote 2 to BAT conclusion 4 specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.

**Note 3:** Footnote 8 to BAT conclusion 4 specifies that, as an alternative to the continuous measurement, in the case of plants combusting oil with a known sulphur content and where there is no flue- gas desulphurisation system, periodic measurements at least once every three months and/or other procedures ensuring the provision of data of an equivalent scientific quality may be used to determine the SO<sub>2</sub> emissions.

Dust limits (mg/Nm <sup>3</sup> ) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	None	None	NA	NA	Continuous or Periodic <sup>Note 1</sup>	None	None
Monthly	None	None	None	NA	NA		None	None
Daily or average over the sampling period	None	<i>10</i>	<i>10</i>	BREF	70% to baseload		None	<i>10</i>
95 <sup>th</sup> %ile of hr means	None	None	None	NA	NA		None	None
<b>Note 2:</b> Footnote 2 to BAT conclusion 4 specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement.								

LCP 102 is used only for balancing services operations for less than 500 hours per year. Therefore we consider applicable and relevant footnote 2 to BAT conclusion 4 that specifies that the monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement. The operator has explained that the schedule for running LCP 102 is unknown, making not feasible to plan monitoring. We agree with the operator's assessment because, according to the UK Regulators Interpretation Document on the BAT conclusions on Large Combustion Plants, we don't consider BAT running a large combustion plant for the sole purpose of testing emissions.

We have specified in the revised permit monitoring and reporting requirements for LCP 102 based on calculation of emissions according to the agreed protocol established in JEP Report JEP17EMG02 / UTG/18/ERG/CT/773/R 'Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018.

**LCP 103, LCP 104, 105**

<b>Type</b>	Combined Cycle Gas Turbine
<b>Age</b>	Permitted <b>before</b> publication of the LCP BREF
<b>Operating Hours</b>	Unlimited
<b>Fuel</b>	Natural gas

Summary of relevant technical features:

Electrical Generating Efficiency (EE) > 55%. Thermal input > 600 MWth. Respectively:

LCP 103 (Unit 6) = 737MWth input, EE = 58.57%, 431.69MW net electrical power output

LCP 104 (Unit 7) = 746MWth input, EE = 58.44%, 436.027MW net electrical power output

LCP 105 (Unit 8) = 744MWth input, EE = 58.36%, 434.244MW net electrical power output

Low load design concept as per BATc 42 (d.) is implemented on LCP103 and LCP104.

NOx limits (mg/Nm <sup>3</sup> )								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	40 ( $\geq 600 \text{ MW}_{\text{th}}$ , $\eta < 75\%$ ) <sup>1,2</sup>	40 ( $\geq 600 \text{ MW}_{\text{th}}$ , $\eta < 75\%$ ) <sup>1,2</sup>	BREF	E-DLN	Continuous	None	42.5 <sup>3</sup>

NOx limits (mg/Nm <sup>3</sup> )								
Averaging	IED (Annex V Part 1) - Existing	LCP BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Monthly	50 <i>(75 if EE&gt;55% or η&gt;75%)</i>	None	75	IED	E-DLN		50	50 <sup>5</sup>
Daily	55 <i>(82.5 if EE&gt;55% or η&gt;75%)</i>	50 (≥600 MW <sub>th</sub> , η <75%) <sup>1,2</sup>	50 (≥600 MW <sub>th</sub> , η <75%) <sup>1,2</sup>	BREF - IED compliance.	E-DLN		50 <b>(83 MSUL/MSDL to base load)</b>	50 <sup>5</sup> <b>(75 MSUL/MSDL to base load)<sup>4</sup></b>
95 <sup>th</sup> %ile of hr means	100 <i>(150 if EE&gt;55% or η&gt;75%)</i>	None	100 <i>(150 if EE&gt;55% or η&gt;75%)</i>	IED	E-DLN		75	75 <sup>5</sup>
1 - If electrical generating efficiency (EE) > 55% then limit is [limit] x EE/55 2 - Overall plant efficiency, η, based on 'net total fuel utilisation' 3 - Considering uplift for EE higher than 55%, calculated as 40 x EE/55 4 - Revised, reduced limit proposed by operator in response to Regulation 61(1) Notice. 5 - Current limit retained based on no-backsliding principle								

CO limits (mg/Nm <sup>3</sup> ) – indicative in <i>italics</i>								
Averaging	IED (Annex V Part 1) - Existing	BREF	Expected permit limits	Basis	Limits apply	Monitoring	Current Permit Limit	Revised Permit Limit
Annual	None	<i>30</i> <i>(50 for plant operating at low load)</i>	<i>30</i> <i>(50 for plant operating at low load)</i>	BREF	E-DLN	Continuous	None	50
Monthly	100	None	100	IED	E-DLN		50	50
Daily	110	None	110	IED	E-DLN		50 <i>(110 MSUL/MSDL to base load)</i>	50 <i>(110 MSUL/MSDL to base load)</i>
95 <sup>th</sup> %ile of hr means	200	None	200	IED	E-DLN		100	100

For LCP 103, LCP 104 and LCP 105, the operator has requested an emission limit for emissions of CO of 50 mg/m<sup>3</sup>, higher than the indicative BAT-AEL of 30 mg/m<sup>3</sup>.

The operator has provided a justification based on the technical characteristics of the installed Alstom GT26 gas turbines as described in the following paragraphs.

The emission limit requested by the operator is to align this parameter with the commercial guarantee provided by the equipment manufacturer. The operator has declared that the commercial guarantee is based on maintaining CO emissions below 50 mg/m<sup>3</sup> when operating above 60% of ISO base load (i.e. the proposed E-DLN point for these machines) and that this is the equipment manufacturer's assessment of achievable emissions performance, taking into account the technical characteristics of the gas turbines.

The operator has provided information showing that, under normal circumstances, when the gas turbines operate above the E-DLN point, CO emissions are below the indicative BAT-AEL of 30 mg/m<sup>3</sup> range for most of the time.



However, the operator has explained that these machines are sensitive to degradation of the gas turbine components across three-yearly major outage cycles and this degradation leads to increase CO emissions over time, especially around the 60% ISO base load point. According to the technical explanation provided, this is because the GT26 annular combustors are manufactured in two halves and the seals along the split-line are prone to degradation and in-leakage of compressed air into the combustor. The combustors are also segmented, due to their physical size, and the seals between the segments and at various other hardware interfaces are also prone to compressed air in-leakage. The introduction of relatively cool compressor discharge air, by in-leakage, into the flame zone or the hot combustion products leads to quenching and survival of CO within the hot gases.

The operator has confirmed that the gas turbines of LCP 103, LCP 104 and LCP 105 are maintained according to the manufacturer's recommendations. These include preventing air in-leakage by regular borescope inspections of the combustion system internals to identify unanticipated component damage. Typically, major outages are at three-yearly intervals with the exact time-scale dictated by the number of operating hours and the number of starts. During a major outage, the gas turbine is stripped down, repaired and re-built with new seals.

In conclusion, although CO emissions are generally below the indicative BAT-AEL of 30 mg/m<sup>3</sup> at high loads above the E-DLN point, the possibility of components degradation causing CO emissions up to 50 mg/m<sup>3</sup>, cannot be ruled out and this figure has therefore been proposed as the ELV by the operator.

We consider the technical justification provided by the operator is adequate and we have set the annual emission limits for CO at 50 mg/m<sup>3</sup> in the revised and consolidated permit.

## 4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

For LCP 102, Table 21 of the BAT Conclusions specifies that the AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year. We have therefore not assessed this operational aspect of the plant for LCP 102. We have however included a process monitoring requirement in table S3.3 of the consolidated variation notice. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2.

For LCP 103, LCP 104 and LCP 105, the table below sets out the AEELs specified in Table 23 the BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was based on the determination, according to equipment manufacturer's standards, of the Net Heat Rate (kJ/kWh) and net power output, corrected to ISO base load conditions (ambient temperature 15degC, ambient pressure 1.013 bar(a) and relative humidity of 60% consistent with ISO Standard 3977 Part 2). We consider these plants are BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
<b>LCP 103: CCGT &gt;= 600 MWth – existing unit</b>					
50 - 60	None	None	58.57	NA	NA
<b>LCP 104: CCGT &gt;= 600 MWth – existing unit</b>					
50 - 60	None	None	58.44	NA	NA
<b>LCP 105: CCGT &gt;= 600 MWth – existing unit</b>					
50 - 60	None	None	58.36	NA	NA

LCP 103, 104 and 105 are designed (and operated) as CHP units by provision of exporting hot water to a nearby LNG regasification plant. Footnote 2 to Table 23 of the LCP BAT Conclusions states that in case of CHP units only one between the Net Total Fuel Utilisation and the Net Electrical Efficiency should apply depending on the CHP unit design (i.e. either more oriented towards electricity generation or heat generation).

Therefore, since the operation of LCP 103, 104 and 105 can be considered more oriented towards electricity generation than heating generation, we have assessed the plant efficiency against BAT-AEEL for Net Electrical Efficiency. Nevertheless, the operator has stated for completeness that the Net Fuel Utilisation, when operating in CHP mode, is 73%. This figure is within the range of 65-95% BAT-AEEL Net Fuel Utilisation for CCGT combustion plants ( $\geq 600$  MWth).

#### **4.3 Availability of NO<sub>x</sub> reduction techniques for existing gas turbines operating <500 hours per year**

Joint Environmental Programme (JEP) produced a document '*BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*' dated October 2018. The content of this document has been agreed in principle by the Environment Agency and we have therefore taken the document into account during our determination of this variation.

For the gas turbines of LCP 102, the operator has provided BAT assessment for emissions of NO<sub>x</sub> that follows the approach described in this JEP report.

The techniques considered in the BAT assessment submitted by the operator, are those potentially applicable to gas turbines firing gas oil and operating less than 500 hours per year, according to BAT conclusion 37, namely:

- a. Water/Steam injection;
- b. Use of Dry Low NO<sub>x</sub> burners.

The technical information on the two Avon gas turbines installed in LCP 102, provided in support of this assessment, can be found in the JEP report JEP19AIB08 / UTG/18/PMP/774/R, '*BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*'.

According to this report, endorsed by us, the original equipment manufacturer and third-party service organisations advise that there are no commercially available options for NO<sub>x</sub> reduction for Avon gas turbines when firing on gas oil.

Based on this supporting information, and in line with the methodology set out in the JEP report '*BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating <500 Hours Per Year*', the Operator has concluded that techniques a. and b. of BATc 37 are not available for LCP 102 and that the currently permitted performance, along with continued appropriate maintenance, are BAT to prevent or reduce emissions of NO<sub>x</sub> from these gas turbines.

In all cases, the minimum BAT requirements are considered to be: i) the continued compliance with any permit requirements already in place to protect air quality and ii) the demonstration of an appropriate maintenance regime to maintain plant emissions performance.

We agree with the conclusions of the assessment provided by the operator and we consider accordingly that the techniques reported under BATc 37 are not applicable to LCP 102.

#### **4.4 BAT 9 - Fuel Characterisation**

BATc 9 requires the operator to carry out fuel characterisation.

LCP 103, 104 and 105 burn natural gas. We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid.

For LCP 102, the operator tests a sample of gas oil every 6 months including sulphur content and calorific value. The operator also tests a composite of a batch of deliveries for the same parameters. The operator has stated that, at the present, samples are not tested for N, C and Ash, which are required parameters for gas oil according to BATc 9.

We have therefore included an improvement condition in the consolidated variation notice (IC11) requiring the operator to submit for approval a plan outlining how the gas oil characterisation will be carried out in order to fully meet the requirements of BATc 9, prior to the implementation date for the BAT Conclusions.

## 5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
<b>General</b>			
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> </ul>	CC	<p>The site operates according to an environmental management system (EMS) accredited to ISO Standard 14001:2015.</p> <p>Sites within the UK operated by the same operator have a shared corporate EMS that sets central system procedures. This is complemented by site specific procedures.</p> <p>The operator has confirmed that their corporate EMS addresses all the features described in BATc 1 (i. to xiii.), with site specific procedures and systems in place at Grain Power Station to address topics listed in BATc 1 x. to xvi., where relevant to the operations of the site and the associated environmental aspects and risk assessment.</p> <p>The permit does not include activities that require a dust management plan, since only natural gas and gas oil with low content of ashes are permitted to be burned. Conditions 3.2.1 and 3.2.2 of the variation and consolidation notice regulate fugitive emissions (emissions of substances not controlled by emission limits), including fugitive emissions of dust, should this become a relevant aspect.</p> <p>The permit does not include activities requiring an odour management plan, since the combustion of malodorous substances is not permitted. However, conditions 3.3.1 and 3.3.2 of the variation and consolidation notice regulate odorous emissions, should this become a relevant aspect.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p>ix. application of sectoral benchmarking on a regular basis. Etc - see BAT Conclusions</p> <p><b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>		
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>The operator carried out performance tests on the CCGTs of LCP 103 (Unit 6), LCP 104 (Unit 7) and LCP 105 (Unit 8) after commissioning the units in 2011. The results of these performance tests are referred in Table S1.1 'Operating Techniques' of the variation and consolidation notice (document dated 30/06/15).</p> <p>The calculation provided by the operator was based on the determination, according to equipment manufacturer's standards, of the Net Heat Rate (kJ/kWh) and net power output, corrected to ISO base load conditions (ambient temperature 15degC, ambient pressure 1.013 bar(a) and relative humidity of 60% consistent with ISO Standard 3977 Part 2).</p> <p>According to this document, the following figures corrected to ISO base load conditions are declared by the operator:</p> <p>LCP 103 (Unit 6) = 737MWth input, 58.57% net electrical efficiency, 431.69MW net electrical power output</p> <p>LCP 104 (Unit 7) = 746MWth input, 58.44% net electrical efficiency, 436.027MW net electrical power output</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
			<p>LCP 105 (Unit 8) = 744MWth input, 58.36% net electrical efficiency, 434.244MW net electrical power output</p> <p>The operator has also reported that, under the long term maintenance agreement contract between the operator and the equipment manufacturer, a performance test is also completed pre and post outage for maintenance.</p> <p>The OCGTs of LCP 102 operate for &lt;500 hours per year. For these gas turbines, the operator has referred to efficiency data reported within the Joint Environmental Programme (JEP) Report, 'BAT Assessment for Existing Gas and Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50MWth or Greater Operating &lt;500 Hours Per Year'. According to this report, endorsed by us, the reported net electrical efficiency for the Rolls Royce Avon gas turbines of LCP 102 (installed circa 1978), running on gas oil, is 26.5%.</p> <p>We consider the information provided is of equivalent scientific quality of EN standards and demonstrates current compliance with this BAT conclusion.</p> <p>A process monitoring requirement has been set in table S3.3 which requires energy efficiency monitoring after an overhaul.</p>						
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1" data-bbox="338 1262 1382 1358"> <thead> <tr> <th data-bbox="338 1262 663 1297">Stream</th> <th data-bbox="663 1262 1050 1297">Parameter(s)</th> <th data-bbox="1050 1262 1382 1297">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1297 663 1358">Flue-gas</td> <td data-bbox="663 1297 1050 1358">Flow</td> <td data-bbox="1050 1297 1382 1358">Periodic or continuous determination</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	CC	<p>Process parameters for oxygen, stack gas temperature, and stack gas pressure are all continuously monitored on CCGT Units 6, 7 &amp; 8 at Grain Power Station.</p> <p>Water vapour is not monitored because the stack gas is dried before entering CEMS. Stack gas flow rate is</p>
Stream	Parameter(s)	Monitoring							
Flue-gas	Flow	Periodic or continuous determination							



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
		Oxygen content, temperature, and pressure	Periodic or continuous measurement		<p>determined from the metered unit fuel consumption and this has been verified by the operator according to EN ISO 16911-2.</p> <p>The OCGTs of LCP 102 operate for less than 500 hours per year, therefore emissions monitoring and reporting requirements are based on calculation, as opposed to direct measurement of flue gas parameters (refer to BATc 4). As specified in Note 2 to BATc 4, the specified monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement. We therefore consider the flue-gas monitoring requirements of BATc 3 not applicable to LCP 102.</p> <p>Process parameters for emissions to water: BATc 3 specifies monitoring of process water only applicable to waste water from flue gas treatment which does not apply at Grain Power Station.</p>	
	Waste water from flue-gas treatment	Water vapour content <sup>(1)</sup> Flow, pH, and temperature	Continuous measurement			
	(1) The continuous measurement of the water vapour content of the flue-gas is not necessary if the sampled flue-gas is dried before analysis					
4	BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.			CC	<p>The installation meets the monitoring requirements that are relevant to natural gas fired turbines as set out in BATc 4, these being NO<sub>x</sub>, CO, and O<sub>2</sub> for correction purposes, as set out in the current environmental permit. Continuous emissions monitoring is specified according to standard BS EN 14181.</p> <p>The OCGTs of LCP 102 are operated for less than 500 hours per year and the schedule for running is unknown, making not feasible to plan monitoring. As specified in Note 2 to BATc 4, the specified monitoring frequency does not apply where plant operation would be for the sole purpose of performing an emission measurement. Concentrations of NO<sub>x</sub>,</p>	
	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(6)</sup> <sup>(7)</sup>	Monitoring associated with
	NH <sub>3</sub>	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(7)</sup>	BAT 7
	NO <sub>x</sub>	— Coal and/or lignite including waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(8)</sup>	BAT 20 BAT 24 BAT 28 BAT 32

BAT Concn. Number	Summary of BAT Conclusion requirement						Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>				BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	CO, dust and SO <sub>2</sub> are calculated every 4380 operational hours or 2 years, whichever is sooner, based on fuel usage and emissions factors, according to the agreed protocol described in JEP Report JEP17EMG02 / UTG/18/ERG/CT/773/R 'Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018.	
	<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 14792	Once every year <sup>(9)</sup>	BAT 53			
N <sub>2</sub> O	<ul style="list-style-type: none"> <li>— Coal and/or lignite in circulating fluidised bed boilers</li> <li>— Solid biomass and/or peat in circulating fluidised bed boilers</li> </ul>	All sizes	EN 21258	Once every year <sup>(10)</sup>	BAT 20 BAT 24			
CO	<ul style="list-style-type: none"> <li>— Coal and/or lignite including waste co-incineration</li> </ul>	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sub>(8)</sub>	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38			

BAT Concn. Number	Summary of BAT Conclusion requirement						Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>				BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73		
		<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54		
SO <sub>2</sub>		<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sup>(11)</sup> <sub>(12)</sub>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74		

BAT Concn. Number	Summary of BAT Conclusion requirement						Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>						
SO <sub>3</sub>	—	When SCR is used	All sizes	No EN standard available	Once every year	—		
Gaseous chlorides, expressed as HCl	—	Coal and/or lignite	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
	—	Solid biomass and/or peat	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>	BAT 25		
	—	Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
HF	—	Coal and/or lignite	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57		
	—	Solid biomass and/or peat	All sizes	No EN standard available	Once every year	BAT 25		
	—	Waste co-incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67		
Dust	—	Coal and/or lignite	All sizes	Generic EN standards and	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26		

BAT Concn. Number	Summary of BAT Conclusion requirement						Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>		EN 13284-1 and EN 13284-2		BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75		
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Ti, V, Zn)	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> </ul>	All sizes	EN 14385	Once every year <sup>(18)</sup>	BAT 22 BAT 26 BAT 30		
		— Waste co-incineration	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sup>(13)</sup>	BAT 68 BAT 69		
			≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sup>(19)</sup> <sup>(13)</sup>			
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sup>(18)</sup>	BAT 75		
	Hg		< 300 MW <sub>th</sub>	EN 13211	Once every three months <sup>(13)</sup> <sup>(20)</sup>	BAT 23		

BAT Concn. Number	Summary of BAT Conclusion requirement					Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		— Coal and/or lignite including waste co-incineration	≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sub>(16)</sub> <sub>(21)</sub>		
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year <sub>(22)</sub>	BAT 27	
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sub>(13)</sub>	BAT 70	
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sub>(23)</sub>	BAT 75	
	TVOC	— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months <sub>(13)</sub>	BAT 33 BAT 59	
		— Process fuels from chemical industry in boilers					
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71	
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45	
	CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sub>(24)</sub>	BAT 45	
	PCDD/F	— Process fuels from chemical industry in boilers	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sub>(13)</sub> <sub>(25)</sub>	BAT 59 BAT 71	
		— Waste co-incineration					

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																									
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="349 528 1377 1353"> <thead> <tr> <th data-bbox="349 528 674 612">Substance/Parameter</th> <th data-bbox="674 528 965 612">Standard(s)</th> <th data-bbox="965 528 1178 612">Minimum monitoring frequency</th> <th data-bbox="1178 528 1377 612">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 612 674 647">Total organic carbon (TOC)<sub>(26)</sub></td> <td data-bbox="674 612 965 647">EN 1484</td> <td data-bbox="965 612 1178 647" rowspan="8">Once every month</td> <td data-bbox="1178 612 1377 647" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="349 647 674 708">Chemical oxygen demand (COD)<sub>(26)</sub></td> <td data-bbox="674 647 965 708">No EN standard available</td> </tr> <tr> <td data-bbox="349 708 674 743">Total suspended solids (TSS)</td> <td data-bbox="674 708 965 743">EN 872</td> </tr> <tr> <td data-bbox="349 743 674 778">Fluoride (F<sup>-</sup>)</td> <td data-bbox="674 743 965 778">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="349 778 674 813">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="674 778 965 813">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="349 813 674 849">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="674 813 965 849">No EN standard available</td> </tr> <tr> <td data-bbox="349 849 674 884">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="674 849 965 884">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="349 884 674 1209"> <table border="1" data-bbox="349 884 584 1209"> <tr><td data-bbox="349 884 584 919">Metals and metalloids</td></tr> <tr><td data-bbox="349 919 584 954">As</td></tr> <tr><td data-bbox="349 954 584 989">Cd</td></tr> <tr><td data-bbox="349 989 584 1024">Cr</td></tr> <tr><td data-bbox="349 1024 584 1059">Cu</td></tr> <tr><td data-bbox="349 1059 584 1094">Ni</td></tr> <tr><td data-bbox="349 1094 584 1129">Pb</td></tr> <tr><td data-bbox="349 1129 584 1165">Zn</td></tr> <tr><td data-bbox="349 1165 584 1209">Hg</td></tr> </table> </td> <td data-bbox="674 884 965 1209">           Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)         </td> <td data-bbox="965 884 1178 1209"></td> <td data-bbox="1178 884 1377 1209"></td> </tr> <tr> <td data-bbox="349 1209 674 1318">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="674 1209 965 1318">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="965 1209 1178 1318"></td> <td data-bbox="1178 1209 1377 1318">—</td> </tr> <tr> <td data-bbox="349 1318 674 1353">Total nitrogen</td> <td data-bbox="674 1318 965 1353">EN 12260</td> <td data-bbox="965 1318 1178 1353"></td> <td data-bbox="1178 1318 1377 1353">—</td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	<table border="1" data-bbox="349 884 584 1209"> <tr><td data-bbox="349 884 584 919">Metals and metalloids</td></tr> <tr><td data-bbox="349 919 584 954">As</td></tr> <tr><td data-bbox="349 954 584 989">Cd</td></tr> <tr><td data-bbox="349 989 584 1024">Cr</td></tr> <tr><td data-bbox="349 1024 584 1059">Cu</td></tr> <tr><td data-bbox="349 1059 584 1094">Ni</td></tr> <tr><td data-bbox="349 1094 584 1129">Pb</td></tr> <tr><td data-bbox="349 1129 584 1165">Zn</td></tr> <tr><td data-bbox="349 1165 584 1209">Hg</td></tr> </table>	Metals and metalloids	As	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)			Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen	EN 12260		—	NA	Not applicable to Grain Power Station - no FGD is installed at Grain Power Station
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																									
Total organic carbon (TOC) <sub>(26)</sub>	EN 1484	Once every month	BAT 15																																									
Chemical oxygen demand (COD) <sub>(26)</sub>	No EN standard available																																											
Total suspended solids (TSS)	EN 872																																											
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																											
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																											
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																											
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																											
<table border="1" data-bbox="349 884 584 1209"> <tr><td data-bbox="349 884 584 919">Metals and metalloids</td></tr> <tr><td data-bbox="349 919 584 954">As</td></tr> <tr><td data-bbox="349 954 584 989">Cd</td></tr> <tr><td data-bbox="349 989 584 1024">Cr</td></tr> <tr><td data-bbox="349 1024 584 1059">Cu</td></tr> <tr><td data-bbox="349 1059 584 1094">Ni</td></tr> <tr><td data-bbox="349 1094 584 1129">Pb</td></tr> <tr><td data-bbox="349 1129 584 1165">Zn</td></tr> <tr><td data-bbox="349 1165 584 1209">Hg</td></tr> </table>	Metals and metalloids			As	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																
Metals and metalloids																																												
As																																												
Cd																																												
Cr																																												
Cu																																												
Ni																																												
Pb																																												
Zn																																												
Hg																																												
Chloride (Cl <sup>-</sup> )	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																									
Total nitrogen	EN 12260		—																																									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="349 501 1375 1177"> <thead> <tr> <th data-bbox="349 501 551 536">Technique</th> <th data-bbox="551 501 943 536">Description</th> <th data-bbox="943 501 1375 536">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 536 551 644">a. Fuel blending and mixing</td> <td data-bbox="551 536 943 644">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="943 536 1375 644" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="349 644 551 727">b. Maintenance of the combustion system</td> <td data-bbox="551 644 943 727">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="349 727 551 836">c. Advanced control system</td> <td data-bbox="551 727 943 836">See description in Section 8.1</td> <td data-bbox="943 727 1375 836">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="349 836 551 919">d. Good design of the combustion equipment</td> <td data-bbox="551 836 943 919">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="943 836 1375 919">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="349 919 551 1177">e. Fuel choice</td> <td data-bbox="551 919 943 1177">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="943 919 1375 1177">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p><u>LCP 103, LCP 104 and LCP 105</u>  The operator has confirmed that they undertake regular maintenance of the combustion equipment in accordance with the suppliers' recommendations and that good design of the equipment ensures combustion optimisation (EV and SEV are designed to optimise combustion) (b &amp; d for BATc 6). The operator has also confirmed that engine mapping is also carried out as part of the Return to Service procedure after every outage for maintenance and periodically as part of ongoing maintenance when this is required.  Sequential low NOx burners are in use at Grain and the plant operates with an advanced control system (c for BATc 6) which is currently controlled through advanced computer system (DCS). This includes the monitoring of acoustic pulsations and the uniformity of circumferential gas temperature profiles in order to maintain the health of the lean premix combustion system.  Fuel blending and mixing and the potential for alternative fuels to reduce emissions to air (a and e for BATc 6) are not applied for the CCGTs at Grain.</p> <p><u>LCP 102</u>  The operator provided an assessment of compliance against this BATc in response to the Regulation 61(1) notice responded on 31/10/18 and subsequent additional information [document titled: "Follow-up Response (April 2019 v2) to the Environmental Permitting (England and Wales) Regulations 2016 Regulation 61(1) request for further information on compliance with BREF requirements for Large Combustion Plant"].</p>
Technique	Description	Applicability																		
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																		
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																			
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																		
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																		



BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>The operator has confirmed that, in order to improve the general environmental performance of the OCGTs, regular planned maintenance (b) is carried out according to the equipment manufacturer recommendations. Low sulphur fuel (e) (to meet legal requirements) is also utilised.</p> <p>Due to the nature and age of the plant and the fuels used on the OCGTs at Grain, the following techniques are not carried out: fuel blending and mixing (a), it does not have an advanced control system (c) and good design of the combustion equipment (d) is generally only applicable to new plant. The OCGTs of LCP 102 have been in operation since around 1979. The operator has confirmed that LCP 102 had a programmable logic controller (PLC) upgrade in 1990s to allow remote control to the central control room.</p>
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	Not applicable to Grain Power Station – no SCR / SNCR installed.
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	CC	The operator provided an assessment of compliance against this BATc in response to the Regulation 61(1) notice responded on 31/10/18 and subsequent additional information [document titled: "Follow-up Response (April 2019 v2) to the Environmental Permitting (England and Wales) Regulations 2016

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
			<p>Regulation 61(1) request for further information on compliance with BREF requirements for Large Combustion Plant”].</p> <p>The operator confirmed that the installation meets the requirements of this BAT conclusion as follows:</p> <ul style="list-style-type: none"> <li>- The operator undertakes regular maintenance of the combustion equipment in accordance with the suppliers’ recommendations for LCP 102, LCP 103, LCP 104 and LCP 105;</li> <li>- The performance of the CCGTs of LCP 103, LCP 104 and LCP 105 is monitored and DLN technology is in operation.</li> </ul>				
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <p>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</p> <p>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 1297 1382 1374"> <thead> <tr> <th data-bbox="338 1297 687 1334">Fuel(s)</th> <th data-bbox="687 1297 1382 1334">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1334 687 1374">Biomass/peat</td> <td data-bbox="687 1334 1382 1374">— LHV</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	FC	<p>The CCGTs of LCP 103, LCP 104 and LCP 105 at the installation meet the requirements of BATc 9 and the corresponding table.</p> <p>Natural gas is the only fuel used on the CCGTs and is supplied from the National Grid. This gas has to meet a nationally agreed specification for all the parameters listed. In addition to this, gas chromatographs are installed at the installation to measure the calorific value and other gas constituents of the incoming fuel. All of the parameters specified for natural gas in BATc 9 are therefore measured or calculated semi-continuously.</p> <p>In addition, the GT26 control system makes allowance for the instantaneous level of higher hydrocarbons (C2+) within the fuel and this is additionally measured, as a separate parameter, using a fast-response infra-red measurement system. There is a maintenance strategy in place to ensure the gas chromatograph is calibrated and functioning as per design. There is also a quality assurance</p>
Fuel(s)	Substances/Parameters subject to characterisation						
Biomass/peat	— LHV						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/CC/FC/NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																
	<table border="1"> <tr> <td data-bbox="338 411 689 579"></td> <td data-bbox="689 411 1382 579"> <ul style="list-style-type: none"> <li>— Moisture</li> <li>— Ash</li> <li>— C, Cl, F, N, S, K, Na</li> <li>— Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</li> </ul> </td> </tr> <tr> <td data-bbox="338 579 689 815">Coal/lignite</td> <td data-bbox="689 579 1382 815"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, fixed carbon, C, H, N, O, S</li> <li>— Br, Cl, F</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul> </td> </tr> <tr> <td data-bbox="338 815 689 903">HFO</td> <td data-bbox="689 815 1382 903"> <ul style="list-style-type: none"> <li>— Ash</li> <li>— C, S, N, Ni, V</li> </ul> </td> </tr> <tr> <td data-bbox="338 903 689 986">Gas oil</td> <td data-bbox="689 903 1382 986"> <ul style="list-style-type: none"> <li>— Ash</li> <li>— N, C, S</li> </ul> </td> </tr> <tr> <td data-bbox="338 986 689 1069">Natural gas</td> <td data-bbox="689 986 1382 1069"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</li> </ul> </td> </tr> <tr> <td data-bbox="338 1069 689 1177">Process fuels from the chemical industry<sup>(27)</sup></td> <td data-bbox="689 1069 1382 1177"> <ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul> </td> </tr> <tr> <td data-bbox="338 1177 689 1249">Iron and steel process gases</td> <td data-bbox="689 1177 1382 1249"> <ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul> </td> </tr> <tr> <td data-bbox="338 1249 689 1369">Waste<sup>(28)</sup></td> <td data-bbox="689 1249 1382 1369"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> </ul> </td> </tr> </table>		<ul style="list-style-type: none"> <li>— Moisture</li> <li>— Ash</li> <li>— C, Cl, F, N, S, K, Na</li> <li>— Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</li> </ul>	Coal/lignite	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, fixed carbon, C, H, N, O, S</li> <li>— Br, Cl, F</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>	HFO	<ul style="list-style-type: none"> <li>— Ash</li> <li>— C, S, N, Ni, V</li> </ul>	Gas oil	<ul style="list-style-type: none"> <li>— Ash</li> <li>— N, C, S</li> </ul>	Natural gas	<ul style="list-style-type: none"> <li>— LHV</li> <li>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</li> </ul>	Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>	Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>	Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> </ul>		<p>check on the gas chromatograph which is carried out annually by a 3<sup>rd</sup> party.</p> <p>For LCP 102, the operator has confirmed that they test a sample of gas oil every 6 months for sulphur content and calorific value. The operator also tests a composite of a batch of deliveries for the same parameters. Currently, samples are not tested for N, C and Ash.</p> <p>An improvement conditions has been included requiring the operator to submit a plan outlining how the fuel characterisation will be carried out in order to fully meet the requirements of BATc 9 for gas oil.</p>
	<ul style="list-style-type: none"> <li>— Moisture</li> <li>— Ash</li> <li>— C, Cl, F, N, S, K, Na</li> <li>— Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</li> </ul>																		
Coal/lignite	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, fixed carbon, C, H, N, O, S</li> <li>— Br, Cl, F</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>																		
HFO	<ul style="list-style-type: none"> <li>— Ash</li> <li>— C, S, N, Ni, V</li> </ul>																		
Gas oil	<ul style="list-style-type: none"> <li>— Ash</li> <li>— N, C, S</li> </ul>																		
Natural gas	<ul style="list-style-type: none"> <li>— LHV</li> <li>— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</li> </ul>																		
Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</li> </ul>																		
Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>																		
Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> </ul>																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
	<table border="1"> <tr> <td data-bbox="338 411 689 483"></td> <td data-bbox="689 411 1382 483">— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)</td> </tr> </table>		— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)		
	— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn)				
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	<p>The installation EMS incorporates the key aspects of BATc 10 as follows:</p> <ul style="list-style-type: none"> <li>- The site operates a risk based review within the EMS (aspects and impacts) which includes a review of potential impacts of OTNOC.</li> <li>- The power station was designed to minimise environmental impact during operational / non-operational conditions. This includes primary, secondary and tertiary containment measures to prevent emissions to soil or water from incidents.</li> <li>- Emissions to air and water are continually monitored with early warning alarms set on all notable parameters to bring instant notification of potential issue to plant operators.</li> <li>- Start up and shut down times are minimised as much as possible to reduce emissions and inefficient use of fuel.</li> <li>- Control systems are designed to ensure if the plant is operating in low load then emission limits are still met. Gas turbine starts are optimised based on plant condition to minimise emissions during start-up.</li> <li>- The power station is maintained in accordance with a full and active</li> </ul>		

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement								
			preventative maintenance program operated via computer software. All plant components are included within the site specific preventative maintenance programmes. The frequency of maintenance is dependent on component duty and manufacturers requirements. This programme is supported by risk assessment to identify environmentally critical plant (ECP), and emergency procedures for plant failure.								
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	Emissions are continuously recorded during potential periods of OTNOC for CCGTs of LCP 103, LCP 104, LCP 105. There is no requirement for continuous monitoring of emissions of LCP 102 that is permitted to operate for less than 500 hours per year. In the event of an accident or environmental incident, the operator's EMS requires that a review the emissions, causes, etc. is carried out as part of an incident investigation process and ensure any relevant corrective and / or preventive actions are implemented.								
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 1082 1382 1385"> <thead> <tr> <th data-bbox="338 1082 566 1118">Technique</th> <th data-bbox="566 1082 994 1118">Description</th> <th data-bbox="994 1082 1382 1118">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1118 566 1225">a. Combustion optimisation</td> <td data-bbox="566 1118 994 1225">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="994 1118 1382 1225" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="338 1225 566 1385">b. Optimisation of the working medium conditions</td> <td data-bbox="566 1225 994 1385">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	CC	<p>The operator provided an assessment of compliance against this BATc in response to the Regulation 61(1) notice responded on 31/10/18 and subsequent additional information [document titled: "Follow-up Response (April 2019 v2) to the Environmental Permitting (England and Wales) Regulations 2016 Regulation 61(1) request for further information on compliance with BREF requirements for Large Combustion Plant"].</p> <p>Not applicable to the OCGTs (LCP 102) at Grain Power Station because the plant operates for &lt;500 hrs/yr.</p>
Technique	Description	Applicability									
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable									
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded										

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions		<p>For LCPs 103,104 &amp; 105 the operator has confirmed that compliance is achieved by use of the following combination of techniques:</p> <ul style="list-style-type: none"> <li>- Combustion optimisation and advanced control systems (a. and g.);</li> <li>- Optimisation of the working medium conditions (b.);</li> <li>- Optimisation of the steam cycle (c.);</li> <li>- Minimisation of energy consumption (d.);</li> <li>- Fuel preheating (f.);</li> <li>- Feed-water preheating using recovered heat (h.);</li> <li>- Heat recovery by cogeneration (CHP) consisting of exporting hot water to the nearby LNG re-gasification terminal operated by the National Grid (i.);</li> <li>- Use of advanced materials (q.).</li> </ul>
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> <li>— flue-gas</li> <li>— grate cooling</li> <li>— circulating fluidised bed</li> </ul>	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		

BAT Concn. Number	Summary of BAT Conclusion requirement				Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations		
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units		
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to	Only applicable to new plants		

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
			achieve increased steam/combustion process efficiencies															
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime														
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses														
13	In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.			CC	<p>The operator has confirmed that, in addition to reducing water as far as possible, Grain employs a system whereby the Heat Recovery Steam Generators blow-down is recycled to the water treatment plant for reuse. This represents BAT for water usage (water recycling, BATc 13 a.).</p> <p>BATc 13 b. is not applicable to the installation CCGTs as this applies only to plants using solid fuel.</p> <p>BATc 13 is not applicable to the OCGTs of LCP 102 at the installation as there is no steam or cooling circuit for this plant and therefore no use of water in the process.</p>													
	<table border="1"> <thead> <tr> <th data-bbox="322 1010 387 1042">Technique</th> <th data-bbox="387 1010 521 1042"></th> <th data-bbox="521 1010 994 1042">Description</th> <th data-bbox="994 1010 1397 1042">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1042 387 1177">a.</td> <td data-bbox="387 1042 521 1177">Water recycling</td> <td data-bbox="521 1042 994 1177">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="994 1042 1397 1177">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="322 1177 387 1348">b.</td> <td data-bbox="387 1177 521 1348">Dry bottom ash handling</td> <td data-bbox="521 1177 994 1348">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="994 1177 1397 1348">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>		Technique		Description	Applicability	a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants				
Technique		Description	Applicability															
a.	Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present															
b.	Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants															



BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement						
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p><b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	<p>The operator provided an assessment of compliance against this BATc in response to the Regulation 61(1) notice responded on 31/10/18 and subsequent additional information [document titled: "Follow-up Response (April 2019 v2) to the Environmental Permitting (England and Wales) Regulations 2016 Regulation 61(1) request for further information on compliance with BREF requirements for Large Combustion Plant"].</p> <p>In line with the requirements of this BAT conclusion, the operator has confirmed that segregation of water streams is carried out at the site into the following streams:</p> <ul style="list-style-type: none"> <li>• Precipitation waste water</li> <li>• Sanitary waste water</li> <li>• Process waste water</li> <li>• Oily/contaminated waste water</li> </ul> <p>Cooling water flow is discharged separately to the combined monitoring basin (CMB) wastewater.</p> <p>Each of the above mentioned streams undertakes different treatment stages that depend on the likely contaminants and final disposal route. Treatment include oil separation on oily/contaminated streams, grit and oil filtration on surface (precipitation) streams, neutralisation on process waste water streams.</p>						
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="338 1262 1382 1353"> <thead> <tr> <th data-bbox="338 1262 687 1321">Technique</th> <th data-bbox="687 1262 965 1321">Typical pollutants prevented/abated</th> <th data-bbox="965 1262 1382 1321">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="338 1321 1382 1353" style="text-align: center;"><b>Primary techniques</b></td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			NA	Not applicable to Grain Power Station - no FGD is installed at Grain Power Station
Technique	Typical pollutants prevented/abated	Applicability							
<b>Primary techniques</b>									

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable		
<b>Secondary techniques <sup>(29)</sup></b>					
	b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable		
	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)		
	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable		
	e. Coagulation and flocculation	Suspended solids	Generally applicable		
	f. Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable		
	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable		
	h. Flotation	Suspended solids, free oil	Generally applicable		
	i. Ion exchange	Metals	Generally applicable		
	j. Neutralisation	Acids, alkalis	Generally applicable		
	k. Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable		
	l. Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable		
	m. Sedimentation	Suspended solids	Generally applicable		
	n. Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable		
The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.					
<b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b>					

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																												
	<table border="1"> <thead> <tr> <th colspan="2" data-bbox="338 411 920 448">Substance/Parameter</th> <th data-bbox="920 411 1382 448">BAT-AELs</th> </tr> <tr> <th colspan="2"></th> <th data-bbox="920 448 1382 485">Daily average</th> </tr> </thead> <tbody> <tr> <td colspan="2" data-bbox="338 485 920 521">Total organic carbon (TOC)</td> <td data-bbox="920 485 1382 521">20–50 mg/l <sup>(30)</sup> <sub>(31)</sub> <sub>(32)</sub></td> </tr> <tr> <td colspan="2" data-bbox="338 521 920 558">Chemical oxygen demand (COD)</td> <td data-bbox="920 521 1382 558">60–150 mg/l <sup>(30)</sup> <sub>(31)</sub> <sub>(32)</sub></td> </tr> <tr> <td colspan="2" data-bbox="338 558 920 595">Total suspended solids (TSS)</td> <td data-bbox="920 558 1382 595">10–30 mg/l</td> </tr> <tr> <td colspan="2" data-bbox="338 595 920 632">Fluoride (F<sup>-</sup>)</td> <td data-bbox="920 595 1382 632">10–25 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="338 632 920 668">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="920 632 1382 668">1,3–2,0 g/l <sup>(32)</sup> <sub>(33)</sub> <sub>(34)</sub> <sub>(35)</sub></td> </tr> <tr> <td colspan="2" data-bbox="338 668 920 705">Sulphide (S<sup>2-</sup>), easily released</td> <td data-bbox="920 668 1382 705">0,1–0,2 mg/l <sup>(32)</sup></td> </tr> <tr> <td colspan="2" data-bbox="338 705 920 742">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="920 705 1382 742">1–20 mg/l <sup>(32)</sup></td> </tr> <tr> <td data-bbox="338 742 831 1005" rowspan="8">Metals and metalloids</td> <td data-bbox="831 742 920 778">As</td> <td data-bbox="920 742 1382 778">10–50 µg/l</td> </tr> <tr> <td data-bbox="831 778 920 815">Cd</td> <td data-bbox="920 778 1382 815">2–5 µg/l</td> </tr> <tr> <td data-bbox="831 815 920 852">Cr</td> <td data-bbox="920 815 1382 852">10–50 µg/l</td> </tr> <tr> <td data-bbox="831 852 920 888">Cu</td> <td data-bbox="920 852 1382 888">10–50 µg/l</td> </tr> <tr> <td data-bbox="831 888 920 925">Hg</td> <td data-bbox="920 888 1382 925">0,2–3 µg/l</td> </tr> <tr> <td data-bbox="831 925 920 962">Ni</td> <td data-bbox="920 925 1382 962">10–50 µg/l</td> </tr> <tr> <td data-bbox="831 962 920 999">Pb</td> <td data-bbox="920 962 1382 999">10–20 µg/l</td> </tr> <tr> <td data-bbox="831 999 920 1005">Zn</td> <td data-bbox="920 999 1382 1005">50–200 µg/l</td> </tr> </tbody> </table>	Substance/Parameter		BAT-AELs			Daily average	Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sub>(31)</sub> <sub>(32)</sub>	Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sub>(31)</sub> <sub>(32)</sub>	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>	Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sub>(33)</sub> <sub>(34)</sub> <sub>(35)</sub>	Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>	Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
Substance/Parameter		BAT-AELs																																													
		Daily average																																													
Total organic carbon (TOC)		20–50 mg/l <sup>(30)</sup> <sub>(31)</sub> <sub>(32)</sub>																																													
Chemical oxygen demand (COD)		60–150 mg/l <sup>(30)</sup> <sub>(31)</sub> <sub>(32)</sub>																																													
Total suspended solids (TSS)		10–30 mg/l																																													
Fluoride (F <sup>-</sup> )		10–25 mg/l <sup>(32)</sup>																																													
Sulphate (SO <sub>4</sub> <sup>2-</sup> )		1,3–2,0 g/l <sup>(32)</sup> <sub>(33)</sub> <sub>(34)</sub> <sub>(35)</sub>																																													
Sulphide (S <sup>2-</sup> ), easily released		0,1–0,2 mg/l <sup>(32)</sup>																																													
Sulphite (SO <sub>3</sub> <sup>2-</sup> )		1–20 mg/l <sup>(32)</sup>																																													
Metals and metalloids	As	10–50 µg/l																																													
	Cd	2–5 µg/l																																													
	Cr	10–50 µg/l																																													
	Cu	10–50 µg/l																																													
	Hg	0,2–3 µg/l																																													
	Ni	10–50 µg/l																																													
	Pb	10–20 µg/l																																													
	Zn	50–200 µg/l																																													
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <ul style="list-style-type: none"> <li>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</li> <li>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</li> <li>(c) waste recycling;</li> <li>(d) other waste recovery (e.g. energy recovery),</li> </ul> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th data-bbox="338 1294 568 1331">Technique</th> <th data-bbox="568 1294 1016 1331">Description</th> <th data-bbox="1016 1294 1382 1331">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	<p>In terms of general waste management at the installation, the operator has confirmed that their EMS considers life cycle thinking (this is considered within the environmental aspects for the site) and ensures the waste hierarchy is applied when disposing of other waste streams which arise as part of site operations. The operator waste management policy strives to achieve zero waste to landfill where possible.</p> <p>Specific techniques of BATc 16 are not applicable to the installation because there are no wastes arising from the combustion process and abatement techniques for the LCPs.</p>																																						
Technique	Description	Applicability																																													

BAT Concn. Number	Summary of BAT Conclusion requirement				Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement							
	a.	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions									
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions									
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber									
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO <sub>x</sub> and NH <sub>3</sub> emissions									
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.				CC	LCP 103, LCP 104 and LCP105 at Grain Power Station have been constructed relatively recently (commissioning in 2011) and their design has included noise abatement features. The operator has confirmed that the following appropriate combination of techniques is used in order to reduce noise emissions at the installation: - Operational measures (BATc 17 a.) which include inspection and maintenance of equipment, ensuring doors are closed on the							
	<table border="1"> <thead> <tr> <th data-bbox="322 1166 387 1201">Technique</th> <th data-bbox="387 1166 566 1201">Description</th> <th data-bbox="566 1166 1016 1201">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1201 387 1396">a.</td> <td data-bbox="387 1201 566 1396">Operational measures</td> <td data-bbox="566 1201 1016 1396">           These include:            — improved inspection and maintenance of equipment            — closing of doors and windows of enclosed areas, if possible         </td> <td data-bbox="1016 1201 1384 1396">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Operational measures	These include: — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible	Generally applicable					
Technique	Description	Applicability											
a.	Operational measures	These include: — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible	Generally applicable										

BAT Concn. Number	Summary of BAT Conclusion requirement				Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			<ul style="list-style-type: none"> <li>— equipment operated by experienced staff</li> <li>— avoidance of noisy activities at night, if possible</li> <li>— provisions for noise control during maintenance activities</li> </ul>			<p>plant, avoidance of noisy activities where possible and ensuring staff are appropriately trained to operate plant.</p> <ul style="list-style-type: none"> <li>- Low-noise equipment (BATc 17 b.) is considered and installed where plant and equipment may need to be replaced with new.</li> <li>- Noise attenuation (BATc 17 c.);</li> <li>- Noise-control equipment (BATc 17 d.)</li> <li>- Appropriate location of equipment and buildings (BATc 17 e.).</li> </ul> <p>The operator has confirmed that noise surveys are carried out yearly instead of bi-yearly required by regulations. Noise surveys cover both environmental and occupational health noise and help the site to identify potential areas for improvement and these are put into the Noise Action Plan for the site. In order to reduce noise emissions from the OCGTs of LCP 102, the following techniques are used:</p> <ul style="list-style-type: none"> <li>- Low-noise equipment (BATc 17 b.);</li> <li>- Noise attenuation (BATc 17 c.); and</li> <li>- Appropriate location of equipment and buildings (BATc 17 e.).</li> </ul>																		
3.1.1 Table 13	<p style="text-align: center;">BAT-associated energy efficiency levels (BAT-AEELs) for HFO and/or gas oil combustion in boilers</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="3" style="width: 30%;">Type of combustion unit</th> <th colspan="4" style="text-align: center;">BAT-AEELs <sub>(99)</sub> <sub>(100)</sub></th> </tr> <tr> <th colspan="2" style="text-align: center;">Net electrical efficiency (%)</th> <th colspan="2" style="text-align: center;">Net total fuel utilisation (%) <sub>(101)</sub></th> </tr> <tr> <th style="text-align: center;">New unit</th> <th style="text-align: center;">Existing unit</th> <th style="text-align: center;">New unit</th> <th style="text-align: center;">Existi ng unit</th> </tr> </thead> <tbody> <tr> <td style="height: 40px;"></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				Type of combustion unit	BAT-AEELs <sub>(99)</sub> <sub>(100)</sub>				Net electrical efficiency (%)		Net total fuel utilisation (%) <sub>(101)</sub>		New unit	Existing unit	New unit	Existi ng unit						NA	Not applicable to gas turbines.
Type of combustion unit	BAT-AEELs <sub>(99)</sub> <sub>(100)</sub>																							
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sub>(101)</sub>																					
	New unit	Existing unit	New unit	Existi ng unit																				

BAT Concn. Number	Summary of BAT Conclusion requirement					Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
	HFO- and/or gas-oil-fired boiler	> 36,4	35,6–37,4	80–96	80–96																																
28	In order to prevent or reduce NO <sub>x</sub> emissions to air while limiting CO emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given below.					NA	Not applicable to gas turbines.																														
<table border="1"> <thead> <tr> <th data-bbox="322 552 383 587"></th> <th data-bbox="383 552 577 587">Technique</th> <th data-bbox="577 552 763 587">Description</th> <th data-bbox="763 552 1391 587">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 587 383 624">a.</td> <td data-bbox="383 587 577 624">Air staging</td> <td data-bbox="577 587 763 1011" rowspan="4">See descriptions in Section 8.3</td> <td data-bbox="763 587 1391 799" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="322 624 383 660">b.</td> <td data-bbox="383 624 577 660">Fuel staging</td> </tr> <tr> <td data-bbox="322 660 383 730">c.</td> <td data-bbox="383 660 577 730">Flue-gas recirculation</td> </tr> <tr> <td data-bbox="322 730 383 799">d.</td> <td data-bbox="383 730 577 799">Low-NO<sub>x</sub> burners (LNB)</td> </tr> <tr> <td data-bbox="322 799 383 869">e.</td> <td data-bbox="383 799 577 869">Water/steam addition</td> <td data-bbox="577 799 763 869"></td> <td data-bbox="763 799 1391 869">Applicable within the constraints of water availability</td> </tr> <tr> <td data-bbox="322 869 383 1011">f.</td> <td data-bbox="383 869 577 1011">Selective non-catalytic reduction (SNCR)</td> <td data-bbox="577 869 763 1011"></td> <td data-bbox="763 869 1391 1011">Not applicable to combustion plants operated &lt; 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="322 1011 383 1190">g.</td> <td data-bbox="383 1011 577 1190">Selective catalytic reduction (SCR)</td> <td data-bbox="577 1011 763 1190">See descriptions in Section 8.3</td> <td data-bbox="763 1011 1391 1190">Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Not generally applicable to combustion plants of &lt; 100 MW<sub>th</sub></td> </tr> <tr> <td data-bbox="322 1190 383 1313">h.</td> <td data-bbox="383 1190 577 1313">Advanced control system</td> <td data-bbox="577 1190 763 1313"></td> <td data-bbox="763 1190 1391 1313">Generally applicable to new combustion plants. The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> </tbody> </table>									Technique	Description	Applicability	a.	Air staging	See descriptions in Section 8.3	Generally applicable	b.	Fuel staging	c.	Flue-gas recirculation	d.	Low-NO <sub>x</sub> burners (LNB)	e.	Water/steam addition		Applicable within the constraints of water availability	f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g.	Selective catalytic reduction (SCR)	See descriptions in Section 8.3	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub>	h.	Advanced control system		Generally applicable to new combustion plants. The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system
	Technique	Description	Applicability																																		
a.	Air staging	See descriptions in Section 8.3	Generally applicable																																		
b.	Fuel staging																																				
c.	Flue-gas recirculation																																				
d.	Low-NO <sub>x</sub> burners (LNB)																																				
e.	Water/steam addition		Applicable within the constraints of water availability																																		
f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																																		
g.	Selective catalytic reduction (SCR)	See descriptions in Section 8.3	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub>																																		
h.	Advanced control system		Generally applicable to new combustion plants. The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																																		

BAT Concn. Number	Summary of BAT Conclusion requirement				Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
	i.	Fuel choice		Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State				
	<b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of HFO and/or gas oil in boilers</b>							
	<b>Combustion plant total rated thermal input (MW<sub>th</sub>)</b>		<b>BAT-AELs (mg/Nm<sup>3</sup>)</b>					
			<b>Yearly average</b>		<b>Daily average or average over the sampling period</b>			
			<b>New plant</b>	<b>Existing plant <sup>(102)</sup></b>	<b>New plant</b>	<b>Existing plant <sup>(103)</sup></b>		
	< 100		75–200	150–270	100–215	210–330 <sup>(104)</sup>		
	≥ 100		45–75	45–100 <sup>(105)</sup>	85–100	85–110 <sup>(106)</sup> <sup>(107)</sup>		
	As an indication, the yearly average CO emission levels will generally be: — 10–30 mg/Nm <sup>3</sup> for existing combustion plants of < 100 MW <sub>th</sub> operated ≥ 1 500 h/yr, or new combustion plants of <100 MW <sub>th</sub> , — 10–20mg/Nm <sup>3</sup> for existing combustion plants of ≥ 100 MW <sub>th</sub> operated ≥ 1 500 h/yr, or new combustion plants of ≥ 100 MW <sub>th</sub> .							
29	In order to prevent or reduce SO <sub>x</sub> , HCl and HF emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given below.				NA	Not applicable to gas turbines.		
	<b>Technique</b>		<b>Description</b>	<b>Applicability</b>				
	a.	Duct sorbent injection (DSI)	See description in Section 8.4	Generally applicable				
	b.	Spray dry absorber (SDA)						
	c.	Flue-gas condenser						
	d.	Wet flue-gas desulphurisation (wet FGD)		There may be technical and economic restrictions for applying the technique to combustion plants of < 300 MW <sub>th</sub> .				

BAT Concn. Number	Summary of BAT Conclusion requirement				Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
			Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr					
	e.	Seawater FGD	There may be technical and economic restrictions for applying the technique to combustion plants of < 300 MW <sub>th</sub> . Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr					
	f.	Fuel choice	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State					
	<b>BAT-associated emission levels (BAT-AELs) for SO<sub>2</sub> emissions to air from the combustion of HFO and/or gas oil in boilers</b>							
	<b>Combustion plant total rated thermal input (MW<sub>th</sub>)</b>		<b>BAT-AELs for SO<sub>2</sub> (mg/Nm<sup>3</sup>)</b>					
			<b>Yearly average</b>		<b>Daily average or average over the sampling period</b>			
			<b>New plant</b>	<b>Existing plant <sup>(108)</sup></b>	<b>New plant</b>	<b>Existing plant <sup>(109)</sup></b>		
			< 300	50–175	50–175	150–200	150–200 <sup>(110)</sup>	
30	In order to reduce dust and particulate-bound metal emissions to air from the combustion of HFO and/or gas oil in boilers, BAT is to use one or a combination of the techniques given below.					NA	Not applicable to gas turbines.	
	<b>Technique</b>	<b>Description</b>	<b>Applicability</b>					



BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a. Electrostatic precipitator (ESP)	See description in Section 8.5	Generally applicable		
b. Bag filter					
c. Multicyclones	See description in Section 8.5. Multicyclones can be used in combination with other dedusting techniques				
d. Dry or semi-dry FGD system	See descriptions in Section 8.5. The technique is mainly used for SO <sub>x</sub> , HCl and/or HF control				
e. Wet flue-gas desulphurisation (wet FGD)	See description in Section 8.5. The technique is mainly used for SO <sub>x</sub> , HCl and/or HF control	See applicability in BAT 29			
f. Fuel choice	See description in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State			
<b>BAT-associated emission levels (BAT-AELs) for dust emissions to air from the combustion of HFO and/or gas oil in boilers</b>					
<b>Combustion plant total rated thermal input (MW<sub>th</sub>)</b>	<b>BAT-AELs for dust (mg/Nm<sup>3</sup>)</b>				
	Yearly average	Daily average or average over the sampling period			

BAT Concn. Number	Summary of BAT Conclusion requirement					Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
		New plant	Existing plant <sup>(113)</sup>	New plant	Existing plant <sup>(114)</sup>																					
	< 300	2–10	2–20	7–18	7–22 <sup>(115)</sup>																					
	≥ 300	2–5	2–10	7–10	7–11 <sup>(116)</sup>																					
31	<p>In order to increase the energy efficiency of HFO and/or gas oil combustion in reciprocating engines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 619 1229 810"> <thead> <tr> <th data-bbox="338 619 367 683">Technique</th> <th data-bbox="367 619 674 683">Description</th> <th data-bbox="674 619 1229 683">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 683 367 810">a.</td> <td data-bbox="367 683 674 810">Combined cycle See description in Section 8.2</td> <td data-bbox="674 683 1229 810">Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated &lt; 1 500 h/yr</td> </tr> </tbody> </table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of HFO and/or gas oil in reciprocating engines</b></p> <table border="1" data-bbox="338 895 1384 1098"> <thead> <tr> <th data-bbox="338 895 1032 1023" rowspan="3">Type of combustion unit</th> <th colspan="2" data-bbox="1032 895 1384 927">BAT-AEELs <sup>(119)</sup></th> </tr> <tr> <th colspan="2" data-bbox="1032 927 1384 991">Net electrical efficiency (%) <sup>(120)</sup></th> </tr> <tr> <th data-bbox="1032 991 1205 1023">New unit</th> <th data-bbox="1205 991 1384 1023">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1023 1032 1054">HFO- and/or gas-oil-fired reciprocating engine — single cycle</td> <td data-bbox="1032 1023 1205 1054">41,5–44,5 <sup>(121)</sup></td> <td data-bbox="1205 1023 1384 1054">38,3–44,5 <sup>(121)</sup></td> </tr> <tr> <td data-bbox="338 1054 1032 1098">HFO- and/or gas-oil-fired reciprocating engine — combined cycle</td> <td data-bbox="1032 1054 1205 1098">&gt; 48 <sup>(122)</sup></td> <td data-bbox="1205 1054 1384 1098">No BAT-AEEL</td> </tr> </tbody> </table>					Technique	Description	Applicability	a.	Combined cycle See description in Section 8.2	Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr	Type of combustion unit	BAT-AEELs <sup>(119)</sup>		Net electrical efficiency (%) <sup>(120)</sup>		New unit	Existing unit	HFO- and/or gas-oil-fired reciprocating engine — single cycle	41,5–44,5 <sup>(121)</sup>	38,3–44,5 <sup>(121)</sup>	HFO- and/or gas-oil-fired reciprocating engine — combined cycle	> 48 <sup>(122)</sup>	No BAT-AEEL	NA	Not applicable to gas turbines.
Technique	Description	Applicability																								
a.	Combined cycle See description in Section 8.2	Generally applicable to new units operated ≥ 1 500 h/yr. Applicable to existing units within the constraints associated with the steam cycle design and the space availability. Not applicable to existing units operated < 1 500 h/yr																								
Type of combustion unit	BAT-AEELs <sup>(119)</sup>																									
	Net electrical efficiency (%) <sup>(120)</sup>																									
	New unit	Existing unit																								
HFO- and/or gas-oil-fired reciprocating engine — single cycle	41,5–44,5 <sup>(121)</sup>	38,3–44,5 <sup>(121)</sup>																								
HFO- and/or gas-oil-fired reciprocating engine — combined cycle	> 48 <sup>(122)</sup>	No BAT-AEEL																								
32	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1166 1229 1351"> <thead> <tr> <th data-bbox="338 1166 367 1198">Technique</th> <th data-bbox="367 1166 757 1198">Description</th> <th data-bbox="757 1166 1229 1198">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1198 367 1286">a.</td> <td data-bbox="367 1198 757 1286">Low-NO<sub>x</sub> combustion concept in diesel engines See descriptions in Section 8.3</td> <td data-bbox="757 1198 1229 1286">Generally applicable</td> </tr> <tr> <td data-bbox="338 1286 367 1351">b.</td> <td data-bbox="367 1286 757 1351">Exhaust-gas recirculation (EGR)</td> <td data-bbox="757 1286 1229 1351">Not applicable to four-stroke engines</td> </tr> </tbody> </table>					Technique	Description	Applicability	a.	Low-NO <sub>x</sub> combustion concept in diesel engines See descriptions in Section 8.3	Generally applicable	b.	Exhaust-gas recirculation (EGR)	Not applicable to four-stroke engines	NA	Not applicable to gas turbines.										
Technique	Description	Applicability																								
a.	Low-NO <sub>x</sub> combustion concept in diesel engines See descriptions in Section 8.3	Generally applicable																								
b.	Exhaust-gas recirculation (EGR)	Not applicable to four-stroke engines																								

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	c. Water/steam addition		Applicable within the constraints of water availability. The applicability may be limited where no retrofit package is available																				
	d. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space																				
33	In order to prevent or reduce emissions of CO and volatile organic compounds to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or both of the techniques given below.			NA	Not applicable to gas turbines.																		
<table border="1"> <thead> <tr> <th data-bbox="322 805 387 842">Technique</th> <th data-bbox="387 805 600 842">Description</th> <th data-bbox="600 805 1397 842">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 842 387 901">a. Combustion optimisation</td> <td data-bbox="387 842 600 901"></td> <td data-bbox="600 842 1397 901">Generally applicable</td> </tr> <tr> <td data-bbox="322 901 387 1010">b. Oxidation catalysts</td> <td data-bbox="387 901 600 1010">See descriptions in Section 8.3</td> <td data-bbox="600 901 1397 1010">Not applicable to combustion plants operated &lt; 500 h/yr. The applicability may be limited by the sulphur content of the fuel</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Combustion optimisation		Generally applicable	b. Oxidation catalysts	See descriptions in Section 8.3	Not applicable to combustion plants operated < 500 h/yr. The applicability may be limited by the sulphur content of the fuel									
Technique	Description	Applicability																					
a. Combustion optimisation		Generally applicable																					
b. Oxidation catalysts	See descriptions in Section 8.3	Not applicable to combustion plants operated < 500 h/yr. The applicability may be limited by the sulphur content of the fuel																					
<p align="center"><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of HFO and/or gas oil in reciprocating engines</b></p>																							
<table border="1"> <thead> <tr> <th data-bbox="322 1093 680 1249" rowspan="3">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="4" data-bbox="680 1093 1397 1129">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2" data-bbox="680 1129 965 1189">Yearly average</th> <th colspan="2" data-bbox="965 1129 1397 1189">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="680 1189 792 1249">New plant</th> <th data-bbox="792 1189 965 1249">Existing plant <sup>(123)</sup></th> <th data-bbox="965 1189 1108 1249">New plant</th> <th data-bbox="1108 1189 1397 1249">Existing plant <sup>(124)</sup> <sup>(125)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1249 680 1305">≥ 50</td> <td data-bbox="680 1249 792 1305">115–190 <sup>(126)</sup></td> <td data-bbox="792 1249 965 1305">125–625</td> <td data-bbox="965 1249 1108 1305">145–300</td> <td data-bbox="1108 1249 1397 1305">150–750</td> </tr> </tbody> </table>						Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average		Daily average or average over the sampling period		New plant	Existing plant <sup>(123)</sup>	New plant	Existing plant <sup>(124)</sup> <sup>(125)</sup>	≥ 50	115–190 <sup>(126)</sup>	125–625	145–300	150–750
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																						
	Yearly average		Daily average or average over the sampling period																				
	New plant	Existing plant <sup>(123)</sup>	New plant	Existing plant <sup>(124)</sup> <sup>(125)</sup>																			
≥ 50	115–190 <sup>(126)</sup>	125–625	145–300	150–750																			
<p>As an indication, for existing combustion plants burning only HFO and operated ≥ 1 500 h/yr or new combustion plants burning only HFO,</p>																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
	<ul style="list-style-type: none"> <li>— the yearly average CO emission levels will generally be 50–175 mg/Nm<sup>3</sup>,</li> <li>— the average over the sampling period for TVOC emission levels will generally be 10–40 mg/Nm<sup>3</sup>.</li> </ul>																																
34	<p>In order to prevent or reduce SO<sub>x</sub>, HCl and HF emissions to air from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 592 1382 954"> <thead> <tr> <th data-bbox="338 592 387 624">Technique</th> <th data-bbox="387 592 613 624">Description</th> <th data-bbox="613 592 1382 624">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 624 387 711">a.</td> <td data-bbox="387 624 613 711">Fuel choice</td> <td data-bbox="613 624 1382 711">See descriptions in Section 8.4</td> </tr> <tr> <td data-bbox="338 711 387 794">b.</td> <td data-bbox="387 711 613 794">Duct sorbent injection (DSI)</td> <td data-bbox="613 711 1382 794">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> <tr> <td data-bbox="338 794 387 954">c.</td> <td data-bbox="387 794 613 954">Wet flue-gas desulphurisation (wet FGD)</td> <td data-bbox="613 794 1382 954">There may be technical restrictions in the case of existing combustion plants Not applicable to combustion plants operated &lt; 500 h/yr</td> </tr> </tbody> </table> <p><b>BAT-associated emission levels (BAT-AELs) for SO<sub>2</sub> emissions to air from the combustion of HFO and/or gas oil in reciprocating engines</b></p> <table border="1" data-bbox="338 1038 1382 1225"> <thead> <tr> <th data-bbox="338 1038 685 1190" rowspan="3">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="4" data-bbox="685 1038 1382 1070">BAT-AELs for SO<sub>2</sub> (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2" data-bbox="685 1070 972 1129">Yearly average</th> <th colspan="2" data-bbox="972 1070 1382 1129">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="685 1129 797 1190">New plant</th> <th data-bbox="797 1129 972 1190">Existing plant <sup>(127)</sup></th> <th data-bbox="972 1129 1133 1190">New plant</th> <th data-bbox="1133 1129 1382 1190">Existing plant <sup>(128)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1190 685 1225">All sizes</td> <td data-bbox="685 1190 797 1225">45–100</td> <td data-bbox="797 1190 972 1225">100–200 <sup>(129)</sup></td> <td data-bbox="972 1190 1133 1225">60–110</td> <td data-bbox="1133 1190 1382 1225">105–235 <sup>(129)</sup></td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Fuel choice	See descriptions in Section 8.4	b.	Duct sorbent injection (DSI)	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	c.	Wet flue-gas desulphurisation (wet FGD)	There may be technical restrictions in the case of existing combustion plants Not applicable to combustion plants operated < 500 h/yr	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs for SO <sub>2</sub> (mg/Nm <sup>3</sup> )				Yearly average		Daily average or average over the sampling period		New plant	Existing plant <sup>(127)</sup>	New plant	Existing plant <sup>(128)</sup>	All sizes	45–100	100–200 <sup>(129)</sup>	60–110	105–235 <sup>(129)</sup>	NA	Not applicable to gas turbines.
Technique	Description	Applicability																															
a.	Fuel choice	See descriptions in Section 8.4																															
b.	Duct sorbent injection (DSI)	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																															
c.	Wet flue-gas desulphurisation (wet FGD)	There may be technical restrictions in the case of existing combustion plants Not applicable to combustion plants operated < 500 h/yr																															
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs for SO <sub>2</sub> (mg/Nm <sup>3</sup> )																																
	Yearly average		Daily average or average over the sampling period																														
	New plant	Existing plant <sup>(127)</sup>	New plant	Existing plant <sup>(128)</sup>																													
All sizes	45–100	100–200 <sup>(129)</sup>	60–110	105–235 <sup>(129)</sup>																													
35	<p>In order to prevent or reduce dust and particulate-bound metal emissions from the combustion of HFO and/or gas oil in reciprocating engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1326 1382 1362"> <thead> <tr> <th data-bbox="338 1326 562 1362">Technique</th> <th data-bbox="562 1326 757 1362">Description</th> <th data-bbox="757 1326 1382 1362">Applicability</th> </tr> </thead> </table>	Technique	Description	Applicability	NA	Not applicable to gas turbines.																											
Technique	Description	Applicability																															

BAT Concn. Number	Summary of BAT Conclusion requirement				Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	a.	Fuel choice	See descriptions in Section 8.5	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																				
b.	Electrostatic precipitator (ESP)	Not applicable to combustion plants operated < 500 h/yr																						
c.	Bag filter																							
36	In order to increase the energy efficiency of gas oil combustion in gas turbines, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.				N/A	Not applicable to the OCGTs at Grain because the plant operates for <500 hrs/yr. Technique BATc 36 (a) only applies to plant operating for ≥1500 hrs/yr. BAT-AEELs do not apply to units operating < 1500 hrs/y.  Refer also to assessment of BATc 12.																		
a.	Combined cycle	See description in Section 8.2	<table border="1"> <thead> <tr> <th colspan="4">BAT-AEELs for dust (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2">Yearly average</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant <sup>(130)</sup></th> <th>New plant</th> <th>Existing plant <sup>(131)</sup></th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–10</td> <td>5–35</td> <td>10–20</td> <td>10–45</td> </tr> </tbody> </table>		BAT-AEELs for dust (mg/Nm <sup>3</sup> )				Combustion plant total rated thermal input (MW <sub>th</sub> )	Yearly average		Daily average or average over the sampling period		New plant	Existing plant <sup>(130)</sup>	New plant	Existing plant <sup>(131)</sup>	≥ 50	5–10	5–35	10–20	10–45		
BAT-AEELs for dust (mg/Nm <sup>3</sup> )																								
Combustion plant total rated thermal input (MW <sub>th</sub> )	Yearly average		Daily average or average over the sampling period																					
	New plant	Existing plant <sup>(130)</sup>	New plant	Existing plant <sup>(131)</sup>																				
	≥ 50	5–10	5–35	10–20	10–45																			
BAT-associated energy efficiency levels (BAT-AEELs) for gas-oil-fired gas turbines																								
Type of combustion unit		BAT-AEELs <sup>(132)</sup>																						
		Net electrical efficiency (%) <sup>(133)</sup>																						
		New unit	Existing unit																					
Gas-oil-fired open-cycle gas turbine		> 33	25–35,7																					
Gas-oil-fired combined cycle gas turbine		> 40	33–44																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
37	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 469 1382 778"> <thead> <tr> <th data-bbox="338 469 389 501"></th> <th data-bbox="389 469 584 501">Technique</th> <th data-bbox="584 469 786 501">Description</th> <th data-bbox="786 469 1382 501">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 501 389 560">a.</td> <td data-bbox="389 501 584 560">Water/steam addition</td> <td data-bbox="584 501 786 560" rowspan="3">See description in Section 8.3</td> <td data-bbox="786 501 1382 560">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="338 560 389 619">b.</td> <td data-bbox="389 560 584 619">Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="786 560 1382 619">Only applicable to turbine models for which low-NO<sub>x</sub> burners are available on the market</td> </tr> <tr> <td data-bbox="338 619 389 778">c.</td> <td data-bbox="389 619 584 778">Selective catalytic reduction (SCR)</td> <td data-bbox="786 619 1382 778">Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	b.	Low-NO <sub>x</sub> burners (LNB)	Only applicable to turbine models for which low-NO <sub>x</sub> burners are available on the market	c.	Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space	NA	<p>We consider that the techniques described by this BAT conclusion are not applicable to the OCGTs of LCP102 because:</p> <ul style="list-style-type: none"> <li>- They operate less than 500 hours per year;</li> <li>- There are currently no NO<sub>x</sub> emission reduction options available for the type of turbines installed within LCP102 (Rolls-Royce Avon)</li> </ul> <p>In making this assessment, we have considered the reference technical information available within the Joint Environmental Programme (JEP) report UTG/18/PMP/774/R, 'BAT Assessment for Existing Gas &amp; Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50 MWth or Greater Operating &lt;500 Hours Per Year'. Further details are discussed in the key issues section.</p>
	Technique	Description	Applicability														
a.	Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability														
b.	Low-NO <sub>x</sub> burners (LNB)		Only applicable to turbine models for which low-NO <sub>x</sub> burners are available on the market														
c.	Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space														
38	<p>In order to prevent or reduce CO emissions to air from the combustion of gas oil in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 963 1382 1145"> <thead> <tr> <th data-bbox="338 963 389 995"></th> <th data-bbox="389 963 584 995">Technique</th> <th data-bbox="584 963 786 995">Description</th> <th data-bbox="786 963 1382 995">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 995 389 1054">a.</td> <td data-bbox="389 995 584 1054">Combustion optimisation</td> <td data-bbox="584 995 786 1054" rowspan="2">See description in Section 8.3</td> <td data-bbox="786 995 1382 1054">Generally applicable</td> </tr> <tr> <td data-bbox="338 1054 389 1145">b.</td> <td data-bbox="389 1054 584 1145">Oxidation catalysts</td> <td data-bbox="786 1054 1382 1145">Not applicable to combustion plants operated &lt; 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </tbody> </table> <p>As an indication, the emission level for NO<sub>x</sub> emissions to air from the combustion of gas oil in dual fuel gas turbines for emergency use operated &lt; 500 h/yr will generally be 145–250 mg/Nm<sup>3</sup> as a daily average or average over the sampling period.</p>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.3	Generally applicable	b.	Oxidation catalysts	Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space	CC	<p>The operator provided an assessment of compliance against this BATc in response to a request for additional information [document titled: "Follow-up Response (April 2019 v2) to the Environmental Permitting (England and Wales) Regulations 2016 Regulation 61(1) request for further information on compliance with BREF requirements for Large Combustion Plant"].</p> <p>The operator has confirmed that combustion optimisation is implemented as a technique to prevent or reduce CO emissions air from the combustion of gas oil in gas turbines of LCP 102. Combustion optimisation is implemented by ensuring that an appropriate inspection and maintenance regime is followed for this combustion equipment, in line with the JEP report JEP17EMG02 /</p>			
	Technique	Description	Applicability														
a.	Combustion optimisation	See description in Section 8.3	Generally applicable														
b.	Oxidation catalysts		Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space														

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>UTG/18/ERG/CT/773/R 'Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018.</p> <p>The operator has confirmed that, once set-up, the diffusion flame combustion system of the Avon gas turbines installed within LCP 102 is robust and is expected to deliver good combustion performance subject to maintaining i) the mechanical integrity of the combustor and ii) the fuel injection nozzles which should remain clean (un-coked) and undamaged, in line, with the maintenance requirements outlined in the above mentioned JEP report. The operator has confirmed that Grain power station follows these maintenance guidelines.</p> <p>The indicative NOx BAT-AEL for oil firing on dual-fuel fired gas turbines does not apply to LCP102 because it does not consists of dual-fuel gas turbines. The operator has provided an assessment of their current NOx emission levels and available techniques for their reduction. The current emission level is 300 mg/m<sup>3</sup>.</p> <p>We consider that there are currently no NOx emission reduction options available for the type of turbines installed within LCP102 (Rolls-Royce Avon). In making this assessment, we have considered the reference technical information available within the Joint Environmental Programme (JEP) report UTG/18/PMP/774/R, 'BAT Assessment for Existing Gas &amp; Liquid Fuel Fired OCGTs, CCGTs and Dual-fuel GTs with a Thermal Input Rating of 50 MWth or Greater Operating &lt;500 Hours Per Year'.</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																								
			<p>We have therefore accepted that the currently NOx emission levels, along with appropriate maintenance of the gas turbines, is BAT for the installation. Accordingly, we have set an indicative emission level of 300 mg/m<sup>3</sup> in the varied and consolidated permit. It is noted that the indicative emission level set in the permit is an industry benchmark emission level from reported industry performance documented in JEP report JEP17EMG02 / UTG/18/ERG/CT/773/R 'Maintaining the Emissions Performance of Open Cycle Gas Turbines that operate for less than 500 hours per year', October 2018.</p> <p>Further details are discussed in the key issues section.</p>																								
39	<p>In order to prevent or reduce SO<sub>x</sub> and dust emissions to air from the combustion of gas oil in gas turbines, BAT is to use the technique given below.</p> <table border="1" data-bbox="338 916 1382 1034"> <thead> <tr> <th data-bbox="338 916 521 951">Technique</th> <th data-bbox="521 916 719 951">Description</th> <th data-bbox="719 916 1382 951">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 951 387 1034">a.</td> <td data-bbox="387 951 719 1034">Fuel choice See description in Section 8.4</td> <td data-bbox="719 951 1382 1034">Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State</td> </tr> </tbody> </table> <p><b>BAT-associated emission levels for SO<sub>2</sub> and dust emissions to air from the combustion of gas oil in gas turbines, including dual fuel gas turbines</b></p> <table border="1" data-bbox="338 1091 1382 1305"> <thead> <tr> <th data-bbox="338 1091 521 1246" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="521 1091 1382 1126">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2" data-bbox="521 1126 954 1161">SO<sub>2</sub></th> <th colspan="2" data-bbox="954 1126 1382 1161">Dust</th> </tr> <tr> <th data-bbox="521 1161 689 1246">Yearly average <sup>(134)</sup></th> <th data-bbox="689 1161 954 1246">Daily average or average over the sampling period <sup>(135)</sup></th> <th data-bbox="954 1161 1115 1246">Yearly average <sup>(134)</sup></th> <th data-bbox="1115 1161 1382 1246">Daily average or average over the sampling period <sup>(135)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1246 521 1305">New and existing plants</td> <td data-bbox="521 1246 689 1305">35–60</td> <td data-bbox="689 1246 954 1305">50–66</td> <td data-bbox="954 1246 1115 1305">2–5</td> <td data-bbox="1115 1246 1382 1305">2–10</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Fuel choice See description in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				SO <sub>2</sub>		Dust		Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>	Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>	New and existing plants	35–60	50–66	2–5	2–10	CC	<p>The operator has confirmed that the installation implements 'fuel choice' as a technique to prevent and reduce emissions of SO<sub>x</sub> and dust from combustion of liquid fuel in LCP 102. LCP 102 is permitted to operate for no more than 500 hours per year. The yearly BAT-AELs for SO<sub>2</sub> and dust are not applicable to existing plants operating for less than 1500 hours per year. The daily (or over sampling period) BAT-AELs for SO<sub>2</sub> and dust are indicative for existing plants operating for less than 500 hours per year. LCP 102 meets the indicative daily (or over sampling period) BAT-AEL as follows:</p> <ul style="list-style-type: none"> <li>- The indicative BAT-AEL requirement for SO<sub>2</sub> is satisfied for gas oil by restricting the sulphur content of the fuel to 0.1%, by mass, in line with the Sulphur Content of Liquid Fuels Regulations;</li> </ul>
Technique	Description	Applicability																									
a.	Fuel choice See description in Section 8.4	Applicable within the constraints associated with the availability of different types of fuel, which may be impacted by the energy policy of the Member State																									
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																										
	SO <sub>2</sub>		Dust																								
	Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>	Yearly average <sup>(134)</sup>	Daily average or average over the sampling period <sup>(135)</sup>																							
New and existing plants	35–60	50–66	2–5	2–10																							



BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																			
			<p>- The indicative BAT-AEL for dust is satisfied by restricting the maximum ash content of gas oil to 0.01% by mass. We have specified the indicative BAT-AELs in the permit.</p>																																																			
40	<p>In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 624 1382 943"> <thead> <tr> <th data-bbox="338 624 387 659">Technique</th> <th data-bbox="387 624 539 659">Description</th> <th data-bbox="539 624 1382 659">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 659 387 943">a. Combined cycle</td> <td data-bbox="387 659 539 943">See description in Section 8.2</td> <td data-bbox="539 659 1382 943">Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table> <p data-bbox="338 943 1382 970"><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b></p> <table border="1" data-bbox="338 970 1382 1262"> <thead> <tr> <th data-bbox="338 970 577 1129" rowspan="3">Type of combustion unit</th> <th colspan="5" data-bbox="577 970 1382 1007">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th colspan="2" data-bbox="577 1007 853 1066">Net electrical efficiency (%)</th> <th data-bbox="853 1007 1061 1066" rowspan="2">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th colspan="2" data-bbox="1061 1007 1382 1066">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> <tr> <th data-bbox="577 1066 719 1129">New unit</th> <th data-bbox="719 1066 853 1129">Existing unit</th> <th data-bbox="1061 1066 1202 1129">New unit</th> <th data-bbox="1202 1066 1382 1129">Existing unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1129 577 1166">Gas engine</td> <td data-bbox="577 1129 719 1166">39,5–44 <sup>(141)</sup></td> <td data-bbox="719 1129 853 1166">35–44 <sup>(141)</sup></td> <td data-bbox="853 1129 1061 1166">56–85 <sup>(141)</sup></td> <td colspan="2" data-bbox="1061 1129 1382 1166">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="338 1166 577 1203">Gas-fired boiler</td> <td data-bbox="577 1166 719 1203">39–42,5</td> <td data-bbox="719 1166 853 1203">38–40</td> <td data-bbox="853 1166 1061 1203">78–95</td> <td colspan="2" data-bbox="1061 1166 1382 1203">No BAT-AEEL.</td> </tr> <tr> <td data-bbox="338 1203 577 1262">Open cycle gas turbine, ≥ 50 MW<sub>th</sub></td> <td data-bbox="577 1203 719 1262">36–41,5</td> <td data-bbox="719 1203 853 1262">33–41,5</td> <td data-bbox="853 1203 1061 1262">No BAT-AEEL</td> <td data-bbox="1061 1203 1202 1262">36,5–41</td> <td data-bbox="1202 1203 1382 1262">33,5–41</td> </tr> </tbody> </table> <p data-bbox="338 1262 1382 1299"><b>Combined cycle gas turbine (CCGT)</b></p> <table border="1" data-bbox="338 1299 1382 1374"> <tbody> <tr> <td data-bbox="338 1299 577 1342">CCGT, 50–600 MW<sub>th</sub></td> <td data-bbox="577 1299 719 1342">53–58,5</td> <td data-bbox="719 1299 853 1342">46–54</td> <td data-bbox="853 1299 1061 1342">No BAT-AEEL</td> <td colspan="2" data-bbox="1061 1299 1382 1342">No BAT-AEEL</td> </tr> <tr> <td data-bbox="338 1342 577 1374">CCGT, ≥ 600 MW<sub>th</sub></td> <td data-bbox="577 1342 719 1374">57–60,5</td> <td data-bbox="719 1342 853 1374">50–60</td> <td data-bbox="853 1342 1061 1374">No BAT-AEEL</td> <td colspan="2" data-bbox="1061 1342 1382 1374">No BAT-AEEL</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers	Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>					Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CC	<p>LCP 103, LCP 104 and LCP105 at Grain Power Station operate in combined cycle mode in accordance with BATc 40. Refer also to the assessment provided for BATc 12 (energy efficiency techniques).</p> <p>The BAT AEEL range for net electrical efficiency applicable to the Grain CCGTs is 50-60% (based on a thermal input ranging between 737MW<sub>th</sub> and 746MW<sub>th</sub> input for the three LCPs). The CCGTs at Grain Power Station meet the BAT AEEL as follows:</p> <p>LCP 103 (Unit 6) = 737MW<sub>th</sub> input, 58.6% net electrical efficiency, 431.69MW net electrical power output</p> <p>LCP 104 (Unit 7) = 746MW<sub>th</sub> input, 58.44% net electrical efficiency, 436.027MW net electrical power output</p> <p>LCP 105 (Unit 8) = 744MW<sub>th</sub> input, 58.36% net electrical efficiency, 434.244MW net electrical power output</p>
Technique	Description	Applicability																																																				
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																																				
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																																																					
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																																																		
	New unit	Existing unit		New unit	Existing unit																																																	
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.																																																		
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																		
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																	
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																		
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																		

BAT Concn. Number	Summary of BAT Conclusion requirement					Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL		
	CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL		
41	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.					NA	Not applicable to gas turbines
<b>Technique</b>		<b>Description</b>			<b>Applicability</b>		
a.	Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners			Generally applicable		
b.	Flue-gas recirculation	See description in Section 8.3					
c.	Low-NO <sub>x</sub> burners (LNB)						
d.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr			The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
e.	Reduction of the combustion air temperature	See description in Section 8.3			Generally applicable within the constraints associated with the process needs		
f.	Selective non-catalytic reduction (SNCR)				Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads		
g.	Selective catalytic reduction (SCR)				Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> .		

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
			There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																				
42	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air, the following combination of techniques from BATc 42 Table are implemented in LCP 103, LCP 104 and LCP 105:</p> <ul style="list-style-type: none"> <li>- Advanced control system (BATc 42a),</li> <li>- Dry-low NO<sub>x</sub> (DLN) burners (BATc 42c),</li> <li>- Low NO<sub>x</sub> burners (BATc 42e) (a combination of both (c) and (e) as the site has sequential low NO<sub>x</sub> burners); and</li> <li>- Low load design concept (BATc 42d) which is installed on LCP 103 and LCP 104.</li> </ul>																		
<table border="1"> <thead> <tr> <th data-bbox="331 598 371 624">Technique</th> <th data-bbox="371 598 510 624">Description</th> <th data-bbox="510 598 927 624">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 624 371 786">a. Advanced control system</td> <td data-bbox="371 624 510 786">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="510 624 927 786">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="331 786 371 847">b. Water/steam addition</td> <td data-bbox="371 786 510 847">See description in Section 8.3</td> <td data-bbox="510 786 927 847">The applicability may be limited due to water availability</td> </tr> <tr> <td data-bbox="331 847 371 981">c. Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="371 847 510 981"></td> <td data-bbox="510 847 927 981">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="331 981 371 1163">d. Low-load design concept</td> <td data-bbox="371 981 510 1163">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td data-bbox="510 981 927 1163">The applicability may be limited by the gas turbine design</td> </tr> <tr> <td data-bbox="331 1163 371 1319">e. Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="371 1163 510 1319">See description in Section 8.3</td> <td data-bbox="510 1163 927 1319">Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants
Technique	Description	Applicability																					
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																					
c. Dry low-NO <sub>x</sub> burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																					
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																					
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	f.	Selective catalytic reduction (SCR)	<p>Not applicable in the case of combustion plants operated &lt; 500 h/yr.</p> <p>Not generally applicable to existing combustion plants of &lt; 100 MW<sub>th</sub>.</p> <p>Retrofitting existing combustion plants may be constrained by the availability of sufficient space.</p> <p>There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>																
43	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 866 1397 1366"> <thead> <tr> <th data-bbox="322 866 371 898">Technique</th> <th data-bbox="371 866 943 898">Description</th> <th data-bbox="943 866 1397 898">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 898 371 1034">a. Advanced control system</td> <td data-bbox="371 898 943 1034">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="943 898 1397 1034">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 1034 371 1098">b. Lean-burn concept</td> <td data-bbox="371 1034 943 1098">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="943 1034 1397 1098">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 1098 371 1177">c. Advanced lean-burn concept</td> <td data-bbox="371 1098 943 1177" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="943 1098 1397 1177">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 1177 371 1366">d. Selective catalytic reduction (SCR)</td> <td data-bbox="943 1177 1397 1366">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated &lt; 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion</td> </tr> </tbody> </table>			Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d. Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion	NA	Not applicable to gas turbines
Technique	Description	Applicability																	
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																	
b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																	
c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																	
d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion																	

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																		
	<table border="1"> <tr> <td data-bbox="338 411 528 472"></td> <td data-bbox="528 411 943 472"></td> <td data-bbox="943 411 1382 472">plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			plants operated between 500 h/yr and 1 500 h/yr																																																	
		plants operated between 500 h/yr and 1 500 h/yr																																																			
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1"> <thead> <tr> <th data-bbox="338 632 752 751" rowspan="2">Type of combustion plant</th> <th data-bbox="752 632 965 751" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2" data-bbox="965 632 1382 663">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th data-bbox="965 663 1167 751">Yearly average <sup>(144)</sup> <sup>(145)</sup></th> <th data-bbox="1167 663 1382 751">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="338 751 1382 783" style="text-align: center;"><b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b></td> </tr> <tr> <td data-bbox="338 791 752 823">New OCGT</td> <td data-bbox="752 791 965 823">≥ 50</td> <td data-bbox="965 791 1167 823">15–35</td> <td data-bbox="1167 791 1382 823">25–50</td> </tr> <tr> <td data-bbox="338 831 752 911">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td> <td data-bbox="752 831 965 911">≥ 50</td> <td data-bbox="965 831 1167 911">15–50</td> <td data-bbox="1167 831 1382 911">25–55 <sup>(148)</sup></td> </tr> <tr> <td colspan="4" data-bbox="338 911 1382 943" style="text-align: center;"><b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b></td> </tr> <tr> <td data-bbox="338 951 752 983">New CCGT</td> <td data-bbox="752 951 965 983">≥ 50</td> <td data-bbox="965 951 1167 983">10–30</td> <td data-bbox="1167 951 1382 983">15–40</td> </tr> <tr> <td data-bbox="338 991 752 1046">Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td data-bbox="752 991 965 1046">≥ 600</td> <td data-bbox="965 991 1167 1046">10–40</td> <td data-bbox="1167 991 1382 1046">18–50</td> </tr> <tr> <td data-bbox="338 1054 752 1110">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="752 1054 965 1110">≥ 600</td> <td data-bbox="965 1054 1167 1110">10–50</td> <td data-bbox="1167 1054 1382 1110">18–55 <sup>(150)</sup></td> </tr> <tr> <td data-bbox="338 1118 752 1174">Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td data-bbox="752 1118 965 1174">50–600</td> <td data-bbox="965 1118 1167 1174">10–45</td> <td data-bbox="1167 1118 1382 1174">35–55</td> </tr> <tr> <td data-bbox="338 1182 752 1238">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="752 1182 965 1238">50–600</td> <td data-bbox="965 1182 1167 1238">25–50 <sup>(151)</sup></td> <td data-bbox="1167 1182 1382 1238">35–55 <sup>(152)</sup></td> </tr> <tr> <td colspan="4" data-bbox="338 1238 1382 1270" style="text-align: center;"><b>Open- and combined-cycle gas turbines</b></td> </tr> <tr> <td data-bbox="338 1278 752 1382">Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated &lt; 500 h/yr</td> <td data-bbox="752 1278 965 1382">≥ 50</td> <td data-bbox="965 1278 1167 1382">No BAT-AEL</td> <td data-bbox="1167 1278 1382 1382">60–140 <sup>(153)</sup> <sup>(154)</sup></td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period	<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>	<b>Open- and combined-cycle gas turbines</b>				Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>	CC	<p>The operator provided an assessment of compliance against this BATc in response to the Regulation 61(1) notice responded on 31/10/18 and subsequent additional information [document titled: “Follow-up Response (April 2019 v2) to the Environmental Permitting (England and Wales) Regulations 2016 Regulation 61(1) request for further information on compliance with BREF requirements for Large Combustion Plant”].</p> <p>The operator has confirmed that BATc 44 is implemented for LCP 103, LCP 104 and LCP 105 by using optimised combustion.</p> <p>BAT AELs for emissions of NO<sub>x</sub> from LCP 103, LCP 104 and LCP 104 (existing CCGT with a net total fuel utilisation of &lt;75% for ≥600MW<sub>th</sub> input plant) are met as follows:</p> <ul style="list-style-type: none"> <li>- Yearly average NO<sub>x</sub> limit of 42.5 mg/Nm<sup>3</sup> (considering adjustment for energy efficiency EE &gt; 55%);</li> <li>- Daily average NO<sub>x</sub> limit of 50 mg/Nm<sup>3</sup>; in this case the adjustment for energy efficiency is not considered on the ground of no backsliding from the limits specified in the permit prior to this review</li> </ul> <p>These limits have been reflected in Table S3.1a of the varied and consolidated permit.</p>
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )			BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																																																	
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																																																		
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>																																																					
New OCGT	≥ 50	15–35	25–50																																																		
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																																																		
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>																																																					
New CCGT	≥ 50	10–30	15–40																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																																																		
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																		
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>																																																		
<b>Open- and combined-cycle gas turbines</b>																																																					
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>																																																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/CC/FC/NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																											
	<table border="1" data-bbox="338 411 1382 496"> <tr> <td data-bbox="338 411 748 496">Existing gas turbine for mechanical drive applications — All but plants operated &lt; 500 h/yr</td> <td data-bbox="748 411 965 496">≥ 50</td> <td data-bbox="965 411 1167 496">15–50 <sup>(155)</sup></td> <td data-bbox="1167 411 1382 496">25–55 <sup>(156)</sup></td> </tr> </table> <p data-bbox="338 496 1382 555">As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul data-bbox="338 555 1382 957" style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p data-bbox="338 957 1382 1016">In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p data-bbox="338 1016 1382 1075"><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="338 1075 1382 1294"> <thead> <tr> <th data-bbox="338 1075 600 1225" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="600 1075 1382 1106">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2" data-bbox="600 1106 911 1163">Yearly average <sup>(157)</sup></th> <th colspan="2" data-bbox="911 1106 1382 1163">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="600 1163 723 1225">New plant</th> <th data-bbox="723 1163 911 1225">Existing plant <sup>(158)</sup></th> <th data-bbox="911 1163 1099 1225">New plant</th> <th data-bbox="1099 1163 1382 1225">Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1225 600 1262">Boiler</td> <td data-bbox="600 1225 723 1262">10–60</td> <td data-bbox="723 1225 911 1262">50–100</td> <td data-bbox="911 1225 1099 1262">30–85</td> <td data-bbox="1099 1225 1382 1262">85–110</td> </tr> <tr> <td data-bbox="338 1262 600 1294">Engine <sup>(160)</sup></td> <td data-bbox="600 1262 723 1294">20–75</td> <td data-bbox="723 1262 911 1294">20–100</td> <td data-bbox="911 1262 1099 1294">55–85</td> <td data-bbox="1099 1262 1382 1294">55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p data-bbox="338 1294 1382 1324">As an indication, the yearly average CO emission levels will generally be:</p> <ul data-bbox="338 1324 1382 1367" style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> </ul>	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>		<p data-bbox="1473 403 2074 555">Refer to the key issues section for further details of how the limits for NO<sub>x</sub> have been worked out from the comparison and review of the LCP BAT conclusions, IED Chapter III limits and limits retained from the current permit based on the no-backsliding principle.</p> <p data-bbox="1473 555 2074 802">The operator has proposed a deviation from the upper end of the indicative BAT-AEL for CO emissions based on the technical characteristics of the turbines installed: the proposed ELV increases the indicative BAT-AEL to 50 mg/m<sup>3</sup> in order to allow for the combustion characteristics of this gas turbine and potential combustor degradation relating to combustor air in-leakage.</p> <p data-bbox="1473 802 2074 954">We consider the justification provided by the operator is satisfactory and we have set the annual emission limits for CO at 50 mg/m<sup>3</sup> in the revised and consolidated permit.</p> <p data-bbox="1473 954 2074 1000">Refer to the key issues section for further details.</p>
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>																											
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																													
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																											
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																										
Boiler	10–60	50–100	30–85	85–110																										
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																										

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<p>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers, — 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</p>																				
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH<sub>4</sub>) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description</b> See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p><b>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH<sub>4</sub> emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</b></p> <table border="1" data-bbox="338 730 1382 957"> <thead> <tr> <th rowspan="3">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="3">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th>Formaldehyde</th> <th colspan="2">CH<sub>4</sub></th> </tr> <tr> <th colspan="3">Average over the sampling period</th> </tr> <tr> <th></th> <th>New or existing plant</th> <th>New plant</th> <th>Existing plant</th> </tr> </thead> <tbody> <tr> <td>≥ 50</td> <td>5–15 <sup>(162)</sup></td> <td>215–500 <sup>(163)</sup></td> <td>215–560 <sup>(162)</sup>, <sup>(163)</sup></td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )			Formaldehyde	CH <sub>4</sub>		Average over the sampling period				New or existing plant	New plant	Existing plant	≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> , <sup>(163)</sup>	NA	Not applicable to gas turbines
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																				
	Formaldehyde		CH <sub>4</sub>																		
	Average over the sampling period																				
	New or existing plant	New plant	Existing plant																		
≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> , <sup>(163)</sup>																		
46	<p>In order to increase the energy efficiency of the combustion of iron and steel process gases, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.</p> <table border="1" data-bbox="338 1027 1382 1134"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Process gas management system</td> <td>See description in Section 8.2</td> <td>Only applicable to integrated steelworks</td> </tr> </tbody> </table> <p><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of iron and steel process gases in boilers</b></p> <table border="1" data-bbox="338 1214 1382 1380"> <thead> <tr> <th rowspan="2">Type of combustion unit</th> <th colspan="2">BAT-AEELs <sup>(164)</sup> <sup>(165)</sup></th> </tr> <tr> <th>Net electrical efficiency (%)</th> <th>Net total fuel utilisation (%) <sup>(166)</sup></th> </tr> </thead> <tbody> <tr> <td>Existing multi-fuel firing gas boiler</td> <td>30–40</td> <td>50–84</td> </tr> <tr> <td>New multi-fuel firing gas boiler <sup>(167)</sup></td> <td>36–42,5</td> <td>50–84</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Process gas management system	See description in Section 8.2	Only applicable to integrated steelworks	Type of combustion unit	BAT-AEELs <sup>(164)</sup> <sup>(165)</sup>		Net electrical efficiency (%)	Net total fuel utilisation (%) <sup>(166)</sup>	Existing multi-fuel firing gas boiler	30–40	50–84	New multi-fuel firing gas boiler <sup>(167)</sup>	36–42,5	50–84	NA	Not applicable to Grain Power Station	
Technique	Description	Applicability																			
a. Process gas management system	See description in Section 8.2	Only applicable to integrated steelworks																			
Type of combustion unit	BAT-AEELs <sup>(164)</sup> <sup>(165)</sup>																				
	Net electrical efficiency (%)	Net total fuel utilisation (%) <sup>(166)</sup>																			
Existing multi-fuel firing gas boiler	30–40	50–84																			
New multi-fuel firing gas boiler <sup>(167)</sup>	36–42,5	50–84																			

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	<p align="center"><b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of iron and steel process gases in CCGTs</b></p> <table border="1"> <thead> <tr> <th rowspan="3">Type of combustion unit</th> <th colspan="3">BAT-AEELs <sup>(168)</sup> <sup>(169)</sup></th> </tr> <tr> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%) <sup>(170)</sup></th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>CHP CCGT</td> <td>&gt; 47</td> <td>40–48</td> <td>60–82</td> </tr> <tr> <td>CCGT</td> <td>&gt; 47</td> <td>40–48</td> <td>No BAT-AEEL</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs <sup>(168)</sup> <sup>(169)</sup>			Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(170)</sup>	New unit	Existing unit	CHP CCGT	> 47	40–48	60–82	CCGT	> 47	40–48	No BAT-AEEL				
Type of combustion unit	BAT-AEELs <sup>(168)</sup> <sup>(169)</sup>																					
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(170)</sup>																			
	New unit	Existing unit																				
CHP CCGT	> 47	40–48	60–82																			
CCGT	> 47	40–48	No BAT-AEEL																			
47	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of iron and steel process gases in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Low-NO<sub>x</sub> burners (LNB)</td> <td>See description in Section 8.3. Specially designed low-NO<sub>x</sub> burners in multiple rows per type of fuel or including specific features for multi-fuel firing (e.g. multiple dedicated nozzles for burning different fuels, or including fuels premixing)</td> <td rowspan="4">Generally applicable</td> </tr> <tr> <td>b. Air staging</td> <td rowspan="3">See descriptions in Section 8.3</td> </tr> <tr> <td>c. Fuel staging</td> </tr> <tr> <td>d. Flue-gas recirculation</td> </tr> <tr> <td>e. Process gas management system</td> <td>See description in Section 8.2.</td> <td>Generally applicable within the constraints associated with the availability of different types of fuel</td> </tr> <tr> <td>f. Advanced control system</td> <td>See description in Section 8.3. This technique is used in combination with other techniques</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>g. Selective non-catalytic reduction (SNCR)</td> <td>See descriptions in Section 8.3</td> <td>Not applicable to combustion plants operated &lt; 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3. Specially designed low-NO <sub>x</sub> burners in multiple rows per type of fuel or including specific features for multi-fuel firing (e.g. multiple dedicated nozzles for burning different fuels, or including fuels premixing)	Generally applicable	b. Air staging	See descriptions in Section 8.3	c. Fuel staging	d. Flue-gas recirculation	e. Process gas management system	See description in Section 8.2.	Generally applicable within the constraints associated with the availability of different types of fuel	f. Advanced control system	See description in Section 8.3. This technique is used in combination with other techniques	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	g. Selective non-catalytic reduction (SNCR)	See descriptions in Section 8.3	Not applicable to combustion plants operated < 500 h/yr	NA	Not applicable to Grain Power Station
Technique	Description	Applicability																				
a. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3. Specially designed low-NO <sub>x</sub> burners in multiple rows per type of fuel or including specific features for multi-fuel firing (e.g. multiple dedicated nozzles for burning different fuels, or including fuels premixing)	Generally applicable																				
b. Air staging	See descriptions in Section 8.3																					
c. Fuel staging																						
d. Flue-gas recirculation																						
e. Process gas management system	See description in Section 8.2.	Generally applicable within the constraints associated with the availability of different types of fuel																				
f. Advanced control system	See description in Section 8.3. This technique is used in combination with other techniques	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																				
g. Selective non-catalytic reduction (SNCR)	See descriptions in Section 8.3	Not applicable to combustion plants operated < 500 h/yr																				



BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	h. Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . Retrofitting existing combustion plants may be constrained by the availability of sufficient space and by the combustion plant configuration																				
48	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of iron and steel process gases in CCGTs, BAT is to use one or a combination of the techniques given below.			NA	Not applicable to Grain Power Station																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Technique</th> <th style="width: 30%;">Description</th> <th style="width: 60%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Process gas management system</td> <td>See description in Section 8.2</td> <td>Generally applicable within the constraints associated with the availability of different types of fuel</td> </tr> <tr> <td>b. Advanced control system</td> <td>See description in Section 8.3. This technique is used in combination with other techniques</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>c. Water/steam addition</td> <td>See description in Section 8.3. In dual fuel gas turbines using DLN for the combustion of iron and steel process gases, water/steam addition is generally used when combusting natural gas</td> <td>The applicability may be limited due to water availability</td> </tr> <tr> <td>d. Dry low-NO<sub>x</sub> burners(DLN)</td> <td>See description in Section 8.3. DLN that combust iron and steel process gases differ from those that combust natural gas only</td> <td>Applicable within the constraints associated with the reactivity of iron and steel process gases such as coke oven gas. The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td>e. Low-NO<sub>x</sub> burners (LNB)</td> <td>See description in Section 8.3</td> <td>Only applicable to supplementary firing for heat recovery steam generators (HRSGs) of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Process gas management system	See description in Section 8.2	Generally applicable within the constraints associated with the availability of different types of fuel	b. Advanced control system	See description in Section 8.3. This technique is used in combination with other techniques	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	c. Water/steam addition	See description in Section 8.3. In dual fuel gas turbines using DLN for the combustion of iron and steel process gases, water/steam addition is generally used when combusting natural gas	The applicability may be limited due to water availability	d. Dry low-NO <sub>x</sub> burners(DLN)	See description in Section 8.3. DLN that combust iron and steel process gases differ from those that combust natural gas only	Applicable within the constraints associated with the reactivity of iron and steel process gases such as coke oven gas. The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Only applicable to supplementary firing for heat recovery steam generators (HRSGs) of combined-cycle gas turbine (CCGT) combustion plants
Technique	Description	Applicability																					
a. Process gas management system	See description in Section 8.2	Generally applicable within the constraints associated with the availability of different types of fuel																					
b. Advanced control system	See description in Section 8.3. This technique is used in combination with other techniques	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
c. Water/steam addition	See description in Section 8.3. In dual fuel gas turbines using DLN for the combustion of iron and steel process gases, water/steam addition is generally used when combusting natural gas	The applicability may be limited due to water availability																					
d. Dry low-NO <sub>x</sub> burners(DLN)	See description in Section 8.3. DLN that combust iron and steel process gases differ from those that combust natural gas only	Applicable within the constraints associated with the reactivity of iron and steel process gases such as coke oven gas. The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																					
e. Low-NO <sub>x</sub> burners (LNB)	See description in Section 8.3	Only applicable to supplementary firing for heat recovery steam generators (HRSGs) of combined-cycle gas turbine (CCGT) combustion plants																					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																														
	<table border="1"> <tr> <td data-bbox="338 411 546 499">f. Selective catalytic reduction (SCR)</td> <td data-bbox="546 411 972 499"></td> <td data-bbox="972 411 1379 499">Retrofitting existing combustion plants may be constrained by the availability of sufficient space</td> </tr> </table>	f. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space																													
f. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space																															
49	<p>In order to prevent or reduce CO emissions to air from the combustion of iron and steel process gases, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="338 571 573 603">Technique</th> <th data-bbox="573 571 813 603">Description</th> <th data-bbox="813 571 1379 603">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 603 573 667">a. Combustion optimisation</td> <td data-bbox="573 603 813 667" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="813 603 1379 667">Generally applicable</td> </tr> <tr> <td data-bbox="338 667 573 746">b. Oxidation catalysts</td> <td data-bbox="813 667 1379 746">Only applicable to CCGTs. The applicability may be limited by lack of space, the load requirements and the sulphur content of the fuel</td> </tr> </tbody> </table> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of 100 % iron and steel process gases</b></p> <table border="1"> <thead> <tr> <th data-bbox="338 834 573 930" rowspan="2">Type of combustion plant</th> <th data-bbox="573 834 813 930" rowspan="2">O<sub>2</sub> reference level (vol-%)</th> <th colspan="2" data-bbox="813 834 1379 866">BAT-AELs (mg/Nm<sup>3</sup>)<sup>(171)</sup></th> </tr> <tr> <th data-bbox="813 866 994 930">Yearly average</th> <th data-bbox="994 866 1379 930">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 930 573 962">New boiler</td> <td data-bbox="573 930 813 962">3</td> <td data-bbox="813 930 994 962">15–65</td> <td data-bbox="994 930 1379 962">22–100</td> </tr> <tr> <td data-bbox="338 962 573 994">Existing boiler</td> <td data-bbox="573 962 813 994">3</td> <td data-bbox="813 962 994 994">20–100<sub>(172)</sub> <sub>(173)</sub></td> <td data-bbox="994 962 1379 994">22–110<sub>(172)</sub> <sub>(174)</sub> <sub>(175)</sub></td> </tr> <tr> <td data-bbox="338 994 573 1026">New CCGT</td> <td data-bbox="573 994 813 1026">15</td> <td data-bbox="813 994 994 1026">20–35</td> <td data-bbox="994 994 1379 1026">30–50</td> </tr> <tr> <td data-bbox="338 1026 573 1058">Existing CCGT</td> <td data-bbox="573 1026 813 1058">15</td> <td data-bbox="813 1026 994 1058">20–50<sub>(172)</sub> <sub>(173)</sub></td> <td data-bbox="994 1026 1379 1058">30–55<sub>(175)</sub> <sub>(176)</sub></td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> <li>— &lt; 5–100 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–35 mg/Nm<sup>3</sup> for new boilers,</li> <li>— &lt; 5–20 mg/Nm<sup>3</sup> for existing CCGTs operated ≥ 1 500 h/yr or new CCGTs.</li> </ul>	Technique	Description	Applicability	a. Combustion optimisation	See descriptions in Section 8.3	Generally applicable	b. Oxidation catalysts	Only applicable to CCGTs. The applicability may be limited by lack of space, the load requirements and the sulphur content of the fuel	Type of combustion plant	O <sub>2</sub> reference level (vol-%)	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(171)</sup>		Yearly average	Daily average or average over the sampling period	New boiler	3	15–65	22–100	Existing boiler	3	20–100 <sub>(172)</sub> <sub>(173)</sub>	22–110 <sub>(172)</sub> <sub>(174)</sub> <sub>(175)</sub>	New CCGT	15	20–35	30–50	Existing CCGT	15	20–50 <sub>(172)</sub> <sub>(173)</sub>	30–55 <sub>(175)</sub> <sub>(176)</sub>	NA	Not applicable to Grain Power Station
Technique	Description	Applicability																															
a. Combustion optimisation	See descriptions in Section 8.3	Generally applicable																															
b. Oxidation catalysts		Only applicable to CCGTs. The applicability may be limited by lack of space, the load requirements and the sulphur content of the fuel																															
Type of combustion plant	O <sub>2</sub> reference level (vol-%)	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(171)</sup>																															
		Yearly average	Daily average or average over the sampling period																														
New boiler	3	15–65	22–100																														
Existing boiler	3	20–100 <sub>(172)</sub> <sub>(173)</sub>	22–110 <sub>(172)</sub> <sub>(174)</sub> <sub>(175)</sub>																														
New CCGT	15	20–35	30–50																														
Existing CCGT	15	20–50 <sub>(172)</sub> <sub>(173)</sub>	30–55 <sub>(175)</sub> <sub>(176)</sub>																														
50	<p>In order to prevent or reduce SO<sub>x</sub> emissions to air from the combustion of iron and steel process gases, BAT is to use a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="338 1289 589 1321">Technique</th> <th data-bbox="589 1289 1178 1321">Description</th> <th data-bbox="1178 1289 1379 1321">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1321 589 1385">a. Process gas management system</td> <td data-bbox="589 1321 1178 1385">See description in Section 8.2.</td> <td data-bbox="1178 1321 1379 1385">Generally applicable within</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Process gas management system	See description in Section 8.2.	Generally applicable within	NA	Not applicable to Grain Power Station																								
Technique	Description	Applicability																															
a. Process gas management system	See description in Section 8.2.	Generally applicable within																															

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	and auxiliary fuel choice	To the extent allowed by the iron- and steel-works, maximise the use of:	<ul style="list-style-type: none"> <li>— a majority of blast furnace gas with a low sulphur content in the fuel diet,</li> <li>— a combination of fuels with a low averaged sulphur content, e.g. individual process fuels with a very low S content such as:               <ul style="list-style-type: none"> <li>— Blast furnace gas with a sulphur content &lt; 10 mg/Nm<sup>3</sup>,</li> <li>— coke oven gas with a sulphur content &lt; 300 mg/Nm<sup>3</sup>,</li> </ul> </li> <li>— and auxiliary fuels such as:               <ul style="list-style-type: none"> <li>— natural gas,</li> <li>— liquid fuels with a sulphur content of ≤ 0,4 % (in boilers).</li> </ul> </li> </ul> Use of a limited amount of fuels with a higher sulphur content	the constraints associated with the availability of different types of fuel															
	b. Coke oven gas pretreatment at the iron- and steel-works	Use of one of the following techniques:	<ul style="list-style-type: none"> <li>— desulphurisation by absorption systems,</li> <li>— wet oxidative desulphurisation</li> </ul>	Only applicable to coke oven gas combustion plants															
	BAT-associated emission levels (BAT-AELs) for SO <sub>2</sub> emissions to air from the combustion of 100 % iron and steel process gases																		
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th data-bbox="338 1094 577 1190" rowspan="2">Type of combustion plant</th> <th data-bbox="577 1094 801 1190" rowspan="2">O<sub>2</sub> reference level (%)</th> <th colspan="2" data-bbox="801 1094 1384 1126">BAT-AELs for SO<sub>2</sub> (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th data-bbox="801 1126 1010 1190">Yearly average <sup>(177)</sup></th> <th data-bbox="1010 1126 1384 1190">Daily average or average over the sampling period <sup>(178)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1190 577 1222">New or existing boiler</td> <td data-bbox="577 1190 801 1222">3</td> <td data-bbox="801 1190 1010 1222">25–150</td> <td data-bbox="1010 1190 1384 1222">50–200 <sup>(179)</sup></td> </tr> <tr> <td data-bbox="338 1222 577 1270">New or existing CCGT</td> <td data-bbox="577 1222 801 1270">15</td> <td data-bbox="801 1222 1010 1270">10–45</td> <td data-bbox="1010 1222 1384 1270">20–70</td> </tr> </tbody> </table>					Type of combustion plant	O <sub>2</sub> reference level (%)	BAT-AELs for SO <sub>2</sub> (mg/Nm <sup>3</sup> )		Yearly average <sup>(177)</sup>	Daily average or average over the sampling period <sup>(178)</sup>	New or existing boiler	3	25–150	50–200 <sup>(179)</sup>	New or existing CCGT	15	10–45	20–70
Type of combustion plant	O <sub>2</sub> reference level (%)	BAT-AELs for SO <sub>2</sub> (mg/Nm <sup>3</sup> )																	
		Yearly average <sup>(177)</sup>	Daily average or average over the sampling period <sup>(178)</sup>																
New or existing boiler	3	25–150	50–200 <sup>(179)</sup>																
New or existing CCGT	15	10–45	20–70																
51	In order to reduce dust emissions to air from the combustion of iron and steel process gases, BAT is to use one or a combination of the techniques given below.			NA	Not applicable to Grain Power Station														
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th data-bbox="338 1334 651 1374">Technique</th> <th data-bbox="651 1334 1093 1374">Description</th> <th data-bbox="1093 1334 1384 1374">Applicability</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>			Technique	Description	Applicability													
Technique	Description	Applicability																	

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																		
	<table border="1"> <tr> <td data-bbox="338 411 371 520">a.</td> <td data-bbox="371 411 651 520">Fuel choice/management</td> <td data-bbox="651 411 1093 520">Use of a combination of process gases and auxiliary fuels with a low averaged dust or ash content</td> <td data-bbox="1093 411 1384 520">Generally applicable within the constraints associated with the availability of different types of fuel</td> </tr> <tr> <td data-bbox="338 520 371 703">b.</td> <td data-bbox="371 520 651 703">Blast furnace gas pretreatment at the iron- and steel-works</td> <td data-bbox="651 520 1093 703">Use of one or a combination of dry dedusting devices (e.g. deflectors, dust catchers, cyclones, electrostatic precipitators) and/or subsequent dust abatement (venturi scrubbers, hurdle-type scrubbers, annular gap scrubbers, wet electrostatic precipitators, disintegrators)</td> <td data-bbox="1093 520 1384 703">Only applicable if blast furnace gas is combusted</td> </tr> <tr> <td data-bbox="338 703 371 812">c.</td> <td data-bbox="371 703 651 812">Basic oxygen furnace gas pretreatment at the iron- and steel-works</td> <td data-bbox="651 703 1093 812">Use of dry (e.g. ESP or bag filter) or wet (e.g. wet ESP or scrubber) dedusting. Further descriptions are given in the Iron and Steel BREF</td> <td data-bbox="1093 703 1384 812">Only applicable if basic oxygen furnace gas is combusted</td> </tr> <tr> <td data-bbox="338 812 371 874">d.</td> <td data-bbox="371 812 651 874">Electrostatic precipitator (ESP)</td> <td data-bbox="651 812 1093 874" rowspan="2">See descriptions in Section 8.5</td> <td data-bbox="1093 812 1384 874" rowspan="2">Only applicable to combustion plants combusting a significant proportion of auxiliary fuels with a high ash content</td> </tr> <tr> <td data-bbox="338 874 371 948">e.</td> <td data-bbox="371 874 651 948">Bag filter</td> </tr> </table>	a.	Fuel choice/management	Use of a combination of process gases and auxiliary fuels with a low averaged dust or ash content	Generally applicable within the constraints associated with the availability of different types of fuel	b.	Blast furnace gas pretreatment at the iron- and steel-works	Use of one or a combination of dry dedusting devices (e.g. deflectors, dust catchers, cyclones, electrostatic precipitators) and/or subsequent dust abatement (venturi scrubbers, hurdle-type scrubbers, annular gap scrubbers, wet electrostatic precipitators, disintegrators)	Only applicable if blast furnace gas is combusted	c.	Basic oxygen furnace gas pretreatment at the iron- and steel-works	Use of dry (e.g. ESP or bag filter) or wet (e.g. wet ESP or scrubber) dedusting. Further descriptions are given in the Iron and Steel BREF	Only applicable if basic oxygen furnace gas is combusted	d.	Electrostatic precipitator (ESP)	See descriptions in Section 8.5	Only applicable to combustion plants combusting a significant proportion of auxiliary fuels with a high ash content	e.	Bag filter				
a.	Fuel choice/management	Use of a combination of process gases and auxiliary fuels with a low averaged dust or ash content	Generally applicable within the constraints associated with the availability of different types of fuel																				
b.	Blast furnace gas pretreatment at the iron- and steel-works	Use of one or a combination of dry dedusting devices (e.g. deflectors, dust catchers, cyclones, electrostatic precipitators) and/or subsequent dust abatement (venturi scrubbers, hurdle-type scrubbers, annular gap scrubbers, wet electrostatic precipitators, disintegrators)	Only applicable if blast furnace gas is combusted																				
c.	Basic oxygen furnace gas pretreatment at the iron- and steel-works	Use of dry (e.g. ESP or bag filter) or wet (e.g. wet ESP or scrubber) dedusting. Further descriptions are given in the Iron and Steel BREF	Only applicable if basic oxygen furnace gas is combusted																				
d.	Electrostatic precipitator (ESP)	See descriptions in Section 8.5	Only applicable to combustion plants combusting a significant proportion of auxiliary fuels with a high ash content																				
e.	Bag filter																						
	BAT-associated emission levels (BAT-AELs) for dust emissions to air from the combustion of 100 % iron and steel process gases																						
	<table border="1"> <thead> <tr> <th data-bbox="338 1010 622 1107" rowspan="2">Type of combustion plant</th> <th colspan="2" data-bbox="622 1010 1384 1042">BAT-AELs for dust (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th data-bbox="622 1042 853 1107">Yearly average <sup>(180)</sup></th> <th data-bbox="853 1042 1384 1107">Daily average or average over the sampling period <sup>(181)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1107 622 1147">New or existing boiler</td> <td data-bbox="622 1107 853 1147">2–7</td> <td data-bbox="853 1107 1384 1147">2–10</td> </tr> <tr> <td data-bbox="338 1147 622 1187">New or existing CCGT</td> <td data-bbox="622 1147 853 1187">2–5</td> <td data-bbox="853 1147 1384 1187">2–5</td> </tr> </tbody> </table>			Type of combustion plant	BAT-AELs for dust (mg/Nm <sup>3</sup> )		Yearly average <sup>(180)</sup>	Daily average or average over the sampling period <sup>(181)</sup>	New or existing boiler	2–7	2–10	New or existing CCGT	2–5	2–5									
Type of combustion plant	BAT-AELs for dust (mg/Nm <sup>3</sup> )																						
	Yearly average <sup>(180)</sup>	Daily average or average over the sampling period <sup>(181)</sup>																					
New or existing boiler	2–7	2–10																					
New or existing CCGT	2–5	2–5																					
52	In order to improve the general environmental performance of the combustion of gaseous and/or liquid fuels on offshore platforms, BAT is to use one or a combination of the techniques given below.			NA	Not applicable to Grain Power Station																		
	<table border="1"> <thead> <tr> <th data-bbox="338 1265 568 1297">Techniques</th> <th data-bbox="568 1265 994 1297">Description</th> <th data-bbox="994 1265 1384 1297">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1297 568 1353">a. Process optimisation</td> <td data-bbox="568 1297 994 1353">Optimise the process in order to minimise the mechanical power requirements</td> <td data-bbox="994 1297 1384 1353">Generally applicable</td> </tr> </tbody> </table>			Techniques	Description	Applicability	a. Process optimisation	Optimise the process in order to minimise the mechanical power requirements	Generally applicable														
Techniques	Description	Applicability																					
a. Process optimisation	Optimise the process in order to minimise the mechanical power requirements	Generally applicable																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	b.	Control pressure losses	Optimise and maintain inlet and exhaust systems in a way that keeps the pressure losses as low as possible		
	c.	Load control	Operate multiple generator or compressor sets at load points which minimise emissions		
	d.	Minimise the 'spinning reserve'	When running with spinning reserve for operational reliability reasons, the number of additional turbines is minimised, except in exceptional circumstances		
	e.	Fuel choice	Provide a fuel gas supply from a point in the topside oil and gas process which offers a minimum range of fuel gas combustion parameters, e.g. calorific value, and minimum concentrations of sulphurous compounds to minimise SO <sub>2</sub> formation. For liquid distillate fuels, preference is given to low-sulphur fuels		
	f.	Injection timing	Optimise injection timing in engines		
	g.	Heat recovery	Utilisation of gas turbine/engine exhaust heat for platform heating purposes		
	h.	Power integration of multiple gas fields/oilfields	Use of a central power source to supply a number of participating platforms located at different gas fields/oilfields		
53	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of gaseous and/or liquid fuels on offshore platforms, BAT is to use one or a combination of the techniques given below.			NA	Not applicable to Grain Power Station

BAT Concn. Number	Summary of BAT Conclusion requirement			Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	<table border="1"> <thead> <tr> <th data-bbox="338 411 371 435">Technique</th> <th data-bbox="371 411 562 435">Description</th> <th data-bbox="562 411 1384 435">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 435 371 531">a.</td> <td data-bbox="371 435 562 531">Advanced control system</td> <td data-bbox="562 435 1384 531">See descriptions in Section 8.3</td> </tr> <tr> <td data-bbox="338 531 371 667">b.</td> <td data-bbox="371 531 562 667">Dry low-NO<sub>x</sub> burners (DLN)</td> <td data-bbox="562 531 1384 667">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 667 371 722">c.</td> <td data-bbox="371 667 562 722">Lean-burn concept</td> <td data-bbox="562 667 1384 722">Applicable to new gas turbines (standard equipment) within the constraints associated with fuel quality variations. The applicability may be limited for existing gas turbines by: availability of a retrofit package (for low-load operation), complexity of the platform organisation and space availability</td> </tr> <tr> <td data-bbox="338 722 371 783">d.</td> <td data-bbox="371 722 562 783">Low-NO<sub>x</sub> burners (LNB)</td> <td data-bbox="562 722 1384 783">Only applicable to new gas-fired engines</td> </tr> <tr> <td colspan="2" data-bbox="338 783 562 799"></td> <td data-bbox="562 783 1384 799">Only applicable to boilers</td> </tr> </tbody> </table>			Technique	Description	Applicability	a.	Advanced control system	See descriptions in Section 8.3	b.	Dry low-NO <sub>x</sub> burners (DLN)	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	c.	Lean-burn concept	Applicable to new gas turbines (standard equipment) within the constraints associated with fuel quality variations. The applicability may be limited for existing gas turbines by: availability of a retrofit package (for low-load operation), complexity of the platform organisation and space availability	d.	Low-NO <sub>x</sub> burners (LNB)	Only applicable to new gas-fired engines			Only applicable to boilers			
Technique	Description	Applicability																						
a.	Advanced control system	See descriptions in Section 8.3																						
b.	Dry low-NO <sub>x</sub> burners (DLN)	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																						
c.	Lean-burn concept	Applicable to new gas turbines (standard equipment) within the constraints associated with fuel quality variations. The applicability may be limited for existing gas turbines by: availability of a retrofit package (for low-load operation), complexity of the platform organisation and space availability																						
d.	Low-NO <sub>x</sub> burners (LNB)	Only applicable to new gas-fired engines																						
		Only applicable to boilers																						
54	<p>In order to prevent or reduce CO emissions to air from the combustion of gaseous and/or liquid fuels in gas turbines on offshore platforms, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="338 882 371 906">Technique</th> <th data-bbox="371 882 562 906">Description</th> <th data-bbox="562 882 1384 906">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 906 371 978">a.</td> <td data-bbox="371 906 562 978">Combustion optimisation</td> <td data-bbox="562 906 1384 978">See descriptions in Section 8.3</td> </tr> <tr> <td data-bbox="338 978 371 1086">b.</td> <td data-bbox="371 978 562 1086">Oxidation catalysts</td> <td data-bbox="562 978 1384 1086">Generally applicable</td> </tr> <tr> <td colspan="2" data-bbox="338 1086 562 1102"></td> <td data-bbox="562 1086 1384 1102">Not applicable to combustion plants operated &lt; 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space and by weight restrictions</td> </tr> </tbody> </table> <p>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of gaseous fuels in open-cycle gas turbines on offshore platforms</p> <table border="1"> <thead> <tr> <th data-bbox="338 1174 931 1198" rowspan="2">Type of combustion plant</th> <th data-bbox="931 1174 1384 1198">BAT-AELs (mg/Nm<sup>3</sup>)<sub>(182)</sub></th> </tr> <tr> <th data-bbox="931 1198 1384 1238">Average over the sampling period</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1238 931 1278">New gas turbine combusting gaseous fuels<sub>(183)</sub></td> <td data-bbox="931 1238 1384 1278">15–50<sub>(184)</sub></td> </tr> <tr> <td data-bbox="338 1278 931 1318">Existing gas turbine combusting gaseous fuels<sub>(183)</sub></td> <td data-bbox="931 1278 1384 1318">&lt; 50–350<sub>(185)</sub></td> </tr> </tbody> </table> <p>As an indication, the average CO emission levels over the sampling period will generally be:</p>			Technique	Description	Applicability	a.	Combustion optimisation	See descriptions in Section 8.3	b.	Oxidation catalysts	Generally applicable			Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space and by weight restrictions	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> ) <sub>(182)</sub>	Average over the sampling period	New gas turbine combusting gaseous fuels <sub>(183)</sub>	15–50 <sub>(184)</sub>	Existing gas turbine combusting gaseous fuels <sub>(183)</sub>	< 50–350 <sub>(185)</sub>	NA	Not applicable to Grain Power Station
Technique	Description	Applicability																						
a.	Combustion optimisation	See descriptions in Section 8.3																						
b.	Oxidation catalysts	Generally applicable																						
		Not applicable to combustion plants operated < 500 h/yr. Retrofitting existing combustion plants may be constrained by the availability of sufficient space and by weight restrictions																						
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> ) <sub>(182)</sub>																							
	Average over the sampling period																							
New gas turbine combusting gaseous fuels <sub>(183)</sub>	15–50 <sub>(184)</sub>																							
Existing gas turbine combusting gaseous fuels <sub>(183)</sub>	< 50–350 <sub>(185)</sub>																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Stat us NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> <li>— &lt; 100 mg/Nm<sup>3</sup> for existing gas turbines combusting gaseous fuels on offshore platforms operated ≥ 1 500 h/yr,</li> <li>— &lt; 75 mg/Nm<sup>3</sup> for new gas turbines combusting gaseous fuels on offshore platforms.</li> </ul>		

## **6 Emissions to Water**

The consolidated permit incorporates the one current discharge to controlled waters (River Medway) identified as W1 that consists of cooling water and process water.

There are no BAT AELs specified in the BAT Conclusions for this type of plant.

There are also no additional treatment options identified as BAT for the installation.

We have therefore not carried out any additional assessment of the emissions to water as part of this review.



## **7 Additional IED Chapter II requirements:**

The BAT for balancing plant guidance (Draft V9, 2017) sets out additional restrictions on hours for <1500 hour non-emergency plant which are low efficiency. Table 1 of the guidance sets out categories for LCP peaking plant. LCP 102 at Grains Power Station falls into category B because its NOx emissions are below the threshold of 500 mg/m<sup>3</sup> (dry at 15% O<sub>2</sub>) and its efficiency at 26.5% is above that set out in table 2 of the guidance for OCGTs operating with liquid fuels. Table 1 of the guidance therefore confirms that there are no additional restrictions applied to the hours of operation below 500 hours per year.

## 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an	We have varied the permit as stated in the variation notice.

<b>Aspect considered</b>	<b>Decision</b>
Environment Agency initiated variation	
Improvement programme	<p>Based on the information on the application, we consider that we need to impose an improvement programme.</p> <p>We have imposed an improvement programme to ensure that the operator will have a plan in place to ensure that the gas oil is characterised in line with BATc 9.</p>
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.3 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BATc 2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> <li>• Sulphur dioxide</li> <li>• Dust</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
<b>Operator competence</b>	
Management system	<p>There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.</p>
<b>Growth Duty</b>	

Aspect considered	Decision
<p>Section 108 Deregulation Act 2015 – Growth duty</p>	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>