



SGS

EU Type Examination Certificate Number: 0120/SGS0156

## Itron Metering Solutions Ltd

Design Centre  
Langer Road  
Felixstowe  
IP11 2ER

Manufacturing Centre  
Itron-Ganz Meter Company Ltd  
Tancsics M. u.11  
P.O.B. 396  
H-2101 Gödöllő  
Hungary

Instrument Identification:  
**3.HZ-A**

Polyphase, Active, Import/ Export, Credit, Electricity Meter  
Instrument Traceable Number  
**0120/ SGS0156**

has been assessed and certified as meeting the requirements of

## EU Directive 2014/32/EU on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 27<sup>th</sup> November 2024  
Issue 8

Certification is based on report number(s) EMA194130/1 issued 28<sup>th</sup> November 2014

Authorised Signature

SGS United Kingdom Limited, Notified Body 0120  
Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK  
t +44 (0)1934 522917 f +44 (0)1934 522137 [www.sgs.com](http://www.sgs.com)

Contact Address

SGS United Kingdom Ltd, Unit 12, South Industrial Estate, Bowburn, Durham, DH6 5AD UK  
t +44 (0)191 377 2000 f +44 (0)191 377 2020 [www.sgs.com](http://www.sgs.com)



This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf.  
The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGS PAPER  
19356788

EU Type Examination Cert.





EU-Type Examination Certificate Number:


**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019

## 1. Technical Data

<b>Manufacturer</b>	Itron - Ganz Meter Company Ltd
<b>Meter Type's</b>	3.HZ-A*-D*-*1 3.HZ-A*-H*-*1
<b>Voltage Rating (Un)</b>	230V or 3x230/400V
<b>Current Rating (Imin – Iref (Imax))</b>	0,25-5(60)A - 3.HZ-A*-D*-B1 0,25-5(100)A - 3.HZ-A*-H*-B1
<b>Frequency (Fn)</b>	50Hz
<b>Active Accuracy Class (kWh)</b>	A or B (kWh)
<b>Type of circuit</b>	1p2w, 3p4w
<b>Temperature Range</b>	-25°C to +55°C
<b>Software No's.</b>	V01.01, V01.03, V01.04, V01.05
<b>CRC Checksum No's</b>	E8E2, 8F3B, B31D, 0AF8
<b>Identification Location</b>	Name Plate
<b>Bill Of Materials No's</b>	Main PCB – A50001201 LCD PCB – A5000623AB
<b>IP Rating</b>	IP51
<b>Insulation Protective Class</b>	Class II
<b>LED Pulse Constant</b>	3.HZ-A*-D*-B1:- 10000 imp/kWh 3.HZ-A*-H*-B1: - 5000 imp/kWh
<b>Impulse Voltage Rating</b>	6kV
<b>AC Voltage Rating</b>	4kV
<b>Main Cover Sealing Type</b>	Ultrasonically welded
<b>Integrity of meter</b>	Inaccessible without breaking seal
<b>Intended Location of the Meter</b>	Indoor
<b>Type of Register</b>	LCD
<b>Terminal Arrangement(s)</b>	DIN

**2. Photograph of Meter & Sealing Plan**


**SGS**

EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019



**SGS**



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019

### 3. Photographs of Name Plates





EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019

#### 4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\phi), \delta e^2(U, I, \cos\phi), \delta e^2(f, I, \cos\phi))}$$

where

$\delta e(T, I, \cos\phi) =$	Additional error due to variation of the temperature at the same load
$\delta e(U, I, \cos\phi) =$	Additional error due to variation of the voltage at the same load
$\delta e(f, I, \cos\phi) =$	Additional error due to variation of the frequency at the same load



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019**3.HZ-A\*-H\*-\*1: 0,25-5(100)A**

3P4W		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25	-10	5	30	40	55
Imin	1.0	0.44	0.31	0.21	0.12	0.12	0.13
Itr	1.0	0.39	0.23	0.12	0.06	0.10	0.13
10ltr	1.0	0.40	0.24	0.11	0.05	0.10	0.15
Imax	1.0	0.35	0.24	0.17	0.14	0.15	0.17
Itr	0.5ind	0.37	0.25	0.17	0.15	0.16	0.16
10ltr	0.5ind	0.34	0.22	0.09	0.03	0.09	0.11
Imax	0.5ind	0.24	0.16	0.07	0.05	0.10	0.05
Itr	0.8cap	0.41	0.11	0.12	0.09	0.13	0.15
10ltr	0.8cap	0.42	0.26	0.11	0.04	0.09	0.15
Imax	0.8cap	0.26	0.16	0.08	0.04	0.07	0.07
L1							
Itr	1.0	0.34	0.17	0.08	0.07	0.11	0.12
10ltr	1.0	0.42	0.26	0.12	0.06	0.10	0.19
Imax	1.0	0.37	0.25	0.13	0.08	0.13	0.15
Itr	0.5ind	0.35	0.24	0.15	0.14	0.15	0.17
10ltr	0.5ind	0.37	0.26	0.12	0.06	0.09	0.13
Imax	0.5ind	0.34	0.26	0.23	0.22	0.22	0.23
L2							
Itr	1.0	0.45	0.29	0.14	0.09	0.14	0.17
10ltr	1.0	0.49	0.32	0.17	0.12	0.15	0.21
Imax	1.0	0.44	0.36	0.30	0.27	0.29	0.29
Itr	0.5ind	0.48	0.34	0.21	0.18	0.18	0.21
10ltr	0.5ind	0.44	0.28	0.16	0.10	0.13	0.16
Imax	0.5ind	0.39	0.32	0.28	0.26	0.27	0.27
L3							
Itr	1.0	0.29	0.16	0.08	0.06	0.07	0.11
10ltr	1.0	0.30	0.19	0.10	0.03	0.06	0.08
Imax	1.0	0.24	0.16	0.10	0.09	0.09	0.09
Itr	0.5ind	0.28	0.19	0.14	0.11	0.11	0.12
10ltr	0.5ind	0.25	0.17	0.08	0.06	0.06	0.09
Imax	0.5ind	0.32	0.30	0.30	0.01	0.30	0.30



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019**3.HZ-A\*-H\*-\*1: 0,25-5(100)A**

1P2W (Phase 1)		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.44	0.30	0.21	0.11	0.11	0.11
Itr	1.0	0.39	0.20	0.11	0.06	0.10	0.14
10ltr	1.0	0.43	0.27	0.14	0.06	0.12	0.16
Imax	1.0	0.38	0.24	0.15	0.11	0.13	0.16
Itr	0.5ind	0.39	0.24	0.18	0.14	0.15	0.16
10ltr	0.5ind	0.37	0.24	0.12	0.07	0.13	0.16
Imax	0.5ind	0.32	0.26	0.23	0.22	0.23	0.23
Itr	0.8cap	0.40	0.21	0.09	0.07	0.10	0.13
10ltr	0.8cap	0.48	0.31	0.18	0.13	0.14	0.19
Imax	0.8cap	0.32	0.23	0.15	0.13	0.14	0.16

1P2W (Phase 2)		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.53	0.35	0.10	0.09	0.11	0.20
Itr	1.0	0.45	0.30	0.15	0.09	0.13	0.16
10ltr	1.0	0.47	0.32	0.17	0.14	0.16	0.21
Imax	1.0	0.48	0.36	0.30	0.27	0.28	0.30
Itr	0.5ind	0.47	0.32	0.21	0.18	0.18	0.21
10ltr	0.5ind	0.45	0.29	0.16	0.09	0.12	0.17
Imax	0.5ind	0.38	0.31	0.27	0.26	0.27	0.27
Itr	0.8cap	0.50	0.32	0.17	0.10	0.14	0.18
10ltr	0.8cap	0.49	0.34	0.21	0.12	0.14	0.22
Imax	0.8cap	0.33	0.23	0.13	0.09	0.10	0.11

1P2W (Phase 3)		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.29	0.23	0.22	0.11	0.11	0.11
Itr	1.0	0.28	0.16	0.09	0.07	0.08	0.11
10ltr	1.0	0.30	0.18	0.09	0.04	0.07	0.08
Imax	1.0	0.22	0.16	0.10	0.09	0.10	0.10
Itr	0.5ind	0.25	0.17	0.13	0.11	0.13	0.13
10ltr	0.5ind	0.27	0.18	0.08	0.05	0.08	0.07
Imax	0.5ind	0.32	0.31	0.30	0.30	0.30	0.30
Itr	0.8cap	0.28	0.17	0.10	0.08	0.10	0.12
10ltr	0.8cap	0.33	0.20	0.08	0.04	0.05	0.09
Imax	0.8cap	0.13	0.08	0.03	0.05	0.03	0.03



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019**3.HZ-A\*-D\*-\*1: 0,25-5(60)A**

3P4W		Influence Factors for Temperature. Frequency & Voltage					
Current	PF Cos	-25	-10	5	30	40	55
Imin	1.0	0.43	0.28	0.16	0.09	0.10	0.13
Itr	1.0	0.36	0.21	0.11	0.06	0.08	0.13
10ltr	1.0	0.40	0.25	0.11	0.05	0.10	0.16
Imax	1.0	0.33	0.23	0.11	0.06	0.08	0.14
Itr	0.5ind	0.30	0.17	0.10	0.07	0.09	0.12
10ltr	0.5ind	0.31	0.19	0.10	0.04	0.08	0.12
Imax	0.5ind	0.29	0.23	0.19	0.17	0.18	0.30
Itr	0.8cap	0.39	0.64	0.12	0.07	0.10	0.14
10ltr	0.8cap	0.42	0.26	0.13	0.05	0.10	0.17
Imax	0.8cap	0.30	0.19	0.10	0.05	0.09	0.15
L1							
Itr	1.0	0.23	0.14	0.08	0.05	0.05	0.06
10ltr	1.0	0.35	0.21	0.11	0.03	0.05	0.08
Imax	1.0	0.25	0.16	0.11	0.07	0.07	0.08
Itr	0.5ind	0.12	0.08	0.07	0.07	0.07	0.08
10ltr	0.5ind	0.22	0.20	0.13	0.08	0.08	0.10
Imax	0.5ind	0.20	0.13	0.12	0.17	0.10	0.11
L2							
Itr	1.0	0.34	0.19	0.09	0.05	0.07	0.13
10ltr	1.0	0.32	0.19	0.09	0.10	0.12	0.21
Imax	1.0	0.11	0.11	0.11	0.11	0.11	0.11
Itr	0.5ind	0.28	0.19	0.12	0.10	0.12	0.14
10ltr	0.5ind	0.32	0.21	0.12	0.05	0.05	0.10
Imax	0.5ind	0.27	0.21	0.18	0.16	0.16	0.17
L3							
Itr	1.0	0.46	0.28	0.13	0.07	0.12	0.17
10ltr	1.0	0.53	0.29	0.17	0.06	0.13	0.18
Imax	1.0	0.43	0.28	0.18	0.11	0.16	0.24
Itr	0.5ind	0.40	0.23	0.14	0.11	0.13	0.17
10ltr	0.5ind	0.42	0.25	0.17	0.05	0.10	0.17
Imax	0.5ind	0.38	0.24	0.17	0.01	0.14	0.17



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019**3.HZ-A\*-D\*-\*1: 0,25-5(60)A**

1P2W (Phase 1)		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.25	0.14	0.11	0.10	0.12	0.14
Itr	1.0	0.28	0.18	0.10	0.05	0.07	0.11
10ltr	1.0	0.36	0.20	0.16	0.04	0.03	0.11
Imax	1.0	0.27	0.21	0.11	0.10	0.10	0.12
	0.00						
Itr	0.5ind	0.23	0.16	0.10	0.07	0.07	0.10
10ltr	0.5ind	0.26	0.19	0.10	0.08	0.08	0.10
Imax	0.5ind	0.22	0.14	0.12	0.11	0.11	0.10
	0.00						
Itr	0.8cap	0.27	0.17	0.08	0.05	0.08	0.15
10ltr	0.8cap	0.35	0.22	0.09	0.06	0.07	0.13
Imax	0.8cap	0.22	0.12	0.08	0.09	0.06	0.12

1P2W (Phase 2)		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.44	0.30	0.16	0.09	0.09	0.11
Itr	1.0	0.34	0.20	0.08	0.05	0.08	0.13
10ltr	1.0	0.37	0.25	0.18	0.06	0.08	0.17
Imax	1.0	0.29	0.19	0.12	0.13	0.15	0.23
Itr	0.5ind	0.29	0.19	0.11	0.10	0.12	0.15
10ltr	0.5ind	0.30	0.19	0.09	0.07	0.09	0.15
Imax	0.5ind	0.27	0.20	0.19	0.16	0.16	0.19
Itr	0.8cap	0.38	0.23	0.10	0.07	0.09	0.14
10ltr	0.8cap	0.39	0.25	0.14	0.05	0.05	0.14
Imax	0.8cap	0.24	0.16	0.11	0.09	0.09	0.14

1P2W (Phase 3)		Influence Factors for Temperature, Frequency & Voltage					
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.56	0.40	0.18	0.08	0.09	0.11
Itr	1.0	0.46	0.27	0.14	0.05	0.12	0.17
10ltr	1.0	0.48	0.33	0.20	0.06	0.15	0.09
Imax	1.0	0.34	0.22	0.14	0.11	0.14	0.20
Itr	0.5ind	0.40	0.27	0.17	0.10	0.12	0.16
10ltr	0.5ind	0.38	0.29	0.13	0.08	0.14	0.16
Imax	0.5ind	0.34	0.23	0.15	0.13	0.15	0.21
Itr	0.8cap	0.48	0.29	0.14	0.06	0.12	0.17
10ltr	0.8cap	0.55	0.35	0.20	0.06	0.12	0.20
Imax	0.8cap	0.40	0.23	0.11	0.08	0.14	0.21



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019

## 5. Annex of Variants

Product Variant Identification Details:

Meter code				3.HZ		A	<input type="checkbox"/>	1				
No	Property	Value	Description	Selection								
1	Product release	A	Product release according to MS2020 specification	x	A							
2	Connection type	C	3 phases / 4 wires (with connection in 1 phase /2 wires)									
		A	1 phase / 2 wires									
3	Maximum current	D	60A									
		H	100A									
4	Metering Mode	1	+A (active import with RRS)									
		2	-A (active export with RRS)									
		3	-A (active export without RRS)									
		4	+A/-A (import/export without RRS)									
5	Class of Accuracy	A	MID A									
		B	MID B									
6	Communication	1	IR port + RS 485	x	1							

3.HZ-A\*-H\*-\*1 has 4 configurable modes:

1. +A (active import with RRS)
2. -A (active export with RRS)
3. -A (active import without RRS)
4. +A/-A (active import/export without RRS)

The meters tested were configured in Mode 4 +A/-A (import/export) as this mode covers all modes.

Modifications to the meter(s) described according to approval No.0120/ SGS0156 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



EU-Type Examination Certificate Number:

**0120/ SGS0156**

Issue Number: 8

Dated: 11<sup>th</sup> March 2019

## 6. Document Revision History

Issue	Date	Comments
1	28/11/2014	Initial Issue
2	04/06/2015	Firmware version change
3	07/03/2016	Firmware version change and minor BOM update
4	19/08/2016	Firmware version and CRC Checksum update
5	03/04/2017	Firmware version and CRC Checksum update
6	03/04/2018	Firmware version V01.05 and CRC Checksum No. 0AF8 added
7	23/08/2018	Reference to 1p2w voltage added to technical data
8	7/03/2019	Influence factors for 3.HZ-A*-H*-*1 & 3.HZ-A*-D*-*1 1P2W configuration phase 1, phase 2 & phase 3 included in certificate
9	11/03/2018	Revised codification table. Statement regarding meter configuration used for test added

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

**END OF CERTIFICATE**