

EU Type Examination Certificate Number: 0120/SGS0419

S&T Smart Energy GmbH

Industriezeile 35/4 4020 Linz Austria

Instrument Identification: MSM100 Series

Single Phase, Import/Export (KWh), Multi-rate, Smart, Electricity Meter

Instrument Traceable Number 0120/SGS0419

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B


It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 15th May 2019 until 14th May 2029 Issue 1

Certification is based on report number(s) SHES190301209901 dated 10th May 2019, EMA266641/1/TR50579 dated 9th May 2019 EMA266641/1

Authorised Signature



SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf.

The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to 7 its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

EU Type Examination Cert.

SGSPAPER 19794053





0120/SGS0419

Issue Number: 1 Dated: 15th May 2019

1. Technical Data

Manufacturer	S&T Smart Energy GmbH
Meter Type	MSM100
Voltage Rating (Un)	230V
Current Rating (Imin - Iref (Imax))	0.25-5(100)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	B (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No	ATDZY221W2305[100]10V2.00
CRC Checksum	5B324D63
Identification Location	LCD
Bill Of Materials Number	761303000061002F
IP Rating	IP54
Insulation Protective Class	Class II
LED Pulse Constant	1000 imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Outdoor
Type of Register	LCD
Terminal Arrangement(s)	DIN
Location of Manufacturers Address	Nameplate



0120/SGS0419

Issue Number: 1

Dated: 15th May 2019

2. Photograph of Meter and Sealing Plan



Main Cover Sealing Points




0120/SGS0419

Issue Number: 1

Dated: 15th May 2019

3. Examples of Nameplate





0120/SGS0419

Issue Number: 1

Dated: 15th May 2019

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$

		Influence Factors for Temperature, Voltage & Frequency							
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
lmin	1.0	0.61	0.49	0.49	0.18	0.10	0.06	0.13	0.16
ltr	1.0	0.58	0.46	0.46	0.14	0.04	0.07	0.12	0.17
10ltr	1.0	0.57	0.44	0.44	0.13	0.05	0.10	0.15	0.15
lmax	1.0	0.72	0.55	0.55	0.17	0.06	0.11	0.18	0.21
ltr	0.5ind	0.64	0.47	0.47	0.17	0.08	0.12	0.17	0.20
10ltr	0.5ind	0.58	0.41	0.41	0.11	0.07	0.12	0.18	0.18
Imax	0.5ind	0.72	0.52	0.52	0.15	0.08	0.14	0.22	0.24
ltr	0.8cap	0.57	0.41	0.41	0.16	0.06	0.09	0.14	0.15
10ltr	0.8cap	0.56	0.40	0.40	0.11	0.06	0.10	0.14	0.15
lmax	0.8cap	0.70	0.50	0.50	0.14	0.08	0.12	0.17	0.20



0120/SGS0419

SO Pulse Output

Issue Number: 1

Dated: 15th May 2019

External

Relay

1

1

1

2

1

5. **Annex of Variants**

Product Variant Identification Details:

MSM100-ABCDEFG

Modular Smart Meter - Single Phase

with magnetic tamper, LCD

Backlight

Table Ratings

Ratings

Base Current Voltage Range Frequency 220 - 240 VAC 50 HZ ± 5%

1

see Table "Ratings"

Table Optional IO's

Pulse Input

Internal Relay

A: 100 A UC3

B: 63 A UC2

C: closed

В C

D

Optional IO's

see Table "Optional

IO's" D:

D: Optional Interfaces's

A: no option

B: RS-485

Wired M-Bus C:

RS-485 and Wired

D: M-Bus

Optional Features

A: no option

B: Supercap

C: Buzzer

D: Supercap + Buzzer

Hardware Generation

1: Generation 1

Hardware Revision

Prototype

Version 1

Modifications to the meter(s) described according to approval No.0120/SGS0419 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0419

Issue Number: 1 Dated: 15th May 2019

6. Document Revision History

Issue	Date	Comments
1	15/05/2019	Initial Issue

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE