



EU Type Examination Certificate Number: 0120/ SGS0035/R1

EDMI Limited

47 Yishun Industrial Park A Singapore 768724

Instrument Identification

MK7A

Description

Single Phase, Two Element, Credit, Active Import/ Export, Multi-rate, Electricity Meter

Instrument Traceable Number 0120/ SGS0035

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid for 10 years from 30th July 2019 to 29th July 2029 Issue 1

Certification is based on report number(s) EMA125358 dated 30th July 2009, EMA269253 dated 30th July 2019

Authorised Signature

RE

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sqs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf.

The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention of the intervention of

SGSPAPER^{EU Type Examination Cont}



0120/ SGS0035/R1

Issue Number: 1

Dated: 30th July 2019

1. Technical Data


Manufacturer	EDMI Limited
Meter Type	Mk7A
Voltage Rating (Un)	220-240V
Current Rating (Imin – Iref (Imax))	0,25-5(100)A 0,5-10(100)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No's	1.363 to 1.366, 1.40 to 1.402, 1.41 to 1.417 1.42, 1.43 to 1.434, 1.45, 1.502
CRC Checksum No.	0xE225
Identification Location	LCD
Bill Of Materials No's	Mk7A BOM-AnxB MB Rev00 Mk7A BOM-AnxB Base Rev001 Mk7A BOM-AnxB HW Rev015
IP Rating	IP53
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Outdoor
Type of Register	Indoor
Terminal Arrangement(s)	BS
Location of Manufacturers Address	Associated Documents



0120/ SGS0035/R1

Issue Number: 1 Dated: 30th July 2019

2. Photograph of Meter and Sealing Plan





0120/ SGS0035/R1

Issue Number: 1

Dated: 30th July 2019

3. Nameplate

1000 imp/kWh

7A11-A344-29-F211-7L02-6011

220-240V 50Hz Class B -25°C to +55°C 0,5-10(100)A **((** M18) 0120

SAMPLE

UK/0120/SGS0035

SN:SERIALNO

2018

MADE IN MALAYSIA



0120/ SGS0035/R1

Issue Number: 1

Dated: 30th July 2019

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \varphi)$ = Additional error due to variation of the temperature at the same load

 $\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load$

 $\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$

		Influence	Factors for	or Temper	ature, Fred	uency and	d Voltage
Current	PF Cos	-25°C	-10°C	5°C	30°C	40°C	55°C
Imin	1.0	0.13	0.16	0.11	0.07	0.11	0.24
Itr	1.0	0.14	0.16	0.11	0.03	0.08	0.21
10ltr	1.0	0.01	0.06	0.04	0.01	0.04	0.11
Imax	1.0	0.13	0.14	0.14	0.13	0.14	0.18
ltr	0.5ind	1.79	1.25	0.79	0.12	0.42	1.00
10ltr	0.5ind	1.53	1.02	0.61	0.18	0.38	0.89
Imax	0.5ind	1.55	1.08	0.66	0.18	0.47	0.98
Itr	0.8cap	0.57	0.34	0.23	0.17	0.18	0.21
10ltr	0.8cap	0.61	0.36	0.19	0.09	0.17	0.27
lmax	0.8cap	0.65	0.38	0.18	0.07	0.17	0.26



0120/ SGS0035/R1

Issue Number: 1 Dated: 30th July 2019

5. Annex of Variants

Product Variant Identification Details:

Type Designation

Description of meter

```
Accuracy
    1 = Class B (Class 1)
    2 = Class A (Class 2)
      Series
     1 = Extended config (MCU4618)
         Current Range
         A = 0.5-10(100)A
         B = 0.25-5(100)A
           Terminal O/P and Phase Curent Measurement
           1 = ANNA 1 Element (1 CT for Main)
           2 = ANNBA 2 Element (2 CTs for Main & Load)
           3 = ACNNBA 2 Element Dual Load (2 CTs for Main & Load)
           5 = ANNBA 1 Element (1 CT for Main & Load)
           6 = ACNNBA 1 Element (1 CT for Main)No measurement for additional load disconnect, Config#11
             Terminal Covers
             1 = Standard Terminal Cover
             4 = Terminal Cover for ETM9300/Intercel SAM
               Button option
               1 = Single Select Button (Clear Plastic)
               2 = Select (Clear) + Second Button (Red-Plain)
               3 = Select (Clear) + Second Button (Red-B)
               4 = Select (Clear) + Second Button (Green-Plain)
               5 = Select (Clear) + Second Button (Green-B)
               6 = Select (Clear) + Second Button (Clear-Plain)
7 = Select (Clear) + Second Button (Clear-B)
                   Local Communications (Optical Port)
                   1 = IEC Flag
                   2 = ANSI C12 18 (standard)
                     Remote Communications (Modern Port)
                     0 = None
                     1 = RS232 with 1xRJ45 (Passive)
                     2 = RS232 with 1xRJ45 and Modem power supply
                     9 = RS232 with 1xRJ45 and Modem power supply + RS232 SCADA Port on Pin 7 & 8
                         EEPROM memory & MCU Option
                         A = 64kB
```

F = 16kB+2 1MB Byte Alterable

2 = 16kB+2 1MB SPI Flash (Numonyx)Different memory size and page size. New firmware v1 416 and above needed



0120/ SGS0035/R1

Issue Number: 1

Dated: 30th July 2019

Battery Options

0 = no battery fitted

2 = 950mAh internal battery

Internal Clock Options

1 = standard calibrated clock

LCD Display

1 = Standard LCD w/o backlight. \$ sign

2 = Standard LCD w/o backlight, £ sign

Standard I/O Options

0 = None

1 = 1 x Passive Input

2 = 2 x Passive Inputs

3 = 1 x S0 Output

4 = 2 x S0 Outputs

5 = 1 x Passive Input, 1 x S0 Output

6 = 1 x Active Input

7 = 2 x Active Inputs

8 = 1 x Active Input, 1 x Passive Input

9 = 1 x Active Input, 1 x S0 Output

P = Payguard Interface I/O

Extended I/O Options

A = None

B = 1 x Passive Input

C = 2 x Passive Inputs

D = 1 x S0 Output

E = 2 x S0 Outputs

F = 1 x Relay Output (240V, 2A)

G = 1 x Active Input (12V)

H = 2 x Active Inputs (12V)

I = 1 x Passive Input, 1 x S0 Output

J = 1 x Active Input, 1 x S0 Output

K = 1 x Passive Input, 1 x Relay Output

L = 1 x S0 Output, 1 x Relay Output M = 2 x Relay Output (240V, 2A)

N = 2 x BOSFET Output

0 = 1 x BOSFET Output

P = 1 x S0 Output, 1 x BOSFET Output



0120/ SGS0035/R1

Issue Number: 1 Dated: 30th July 2019

Input Voltage Options

0 = None (for S0 and Active)

A = 240V (+/-10%) Passive

B = 110V (+/-30%) Passive

C = 048V (+/-30%) Passive

D = 012V (+/-80%) Passive

E = 005V (+/-30%) Passive

Pulsing LED Options

0 = No LED fitted

1 = 1 Pulsing LED

2 = 2 Pulsing LEDs

Disconnect Terminal Relay O/P option

0 = None

1 = 1 x Main Disconnect Relay (KG) (Config #2 or #8 Based on Element)

2 = 1 x Load Disconnect Relay (60A) (Config #3)

3 = 2 x Load Disconnect Relay (60A) (Config #4)

4 = 1 x Main Relay (KG), 1 x Load Relay (Config #5)

5 = 1 x Main Relay (KG), 1 x Load Relay (Config #6)

6 = 1 x Main Relay (KG), 1 x Load Relay (Config #9)

7 = 1 x Main Relay (KG), 1 x Load Relay (Config #10)

8 = 1 x Main Relay (KG), 1 x Load Relay (Config #11)

9 = 1 x Main Relay (KG), 1 x Load Relay (Config #12)

Magnetic Temper option

0 = No magnetic temper detection

1 = Magnetic temper detection

Open cover detection option

0 = None

1 = Terminal Cover detection

Neutral Current Measurement

0 = Without Neutral current measurement

1 = Neutral current Measurement

Modifications to the meter(s) described according to approval No.0120/ SGS0035/R1 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/ SGS0035/R1

Issue Number: 1 Dated: 30th July 2019

6. Document Revision History

Issue	Date	Comments
1	30/07/2019	Re approval initial issue

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at
http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic
Documents at www.sgs.com/terms e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues
defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its
intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does
not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot
be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content
or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days
only."
** End of Document **
Dia of Document