

EU Type Examination Certificate Number: 0120/SGS0141

Zhejiang Eastron Electronic Co., Ltd

No 1369 Chengnan Road Jiaxing Zhejiang China

Instrument Identification

SDM120 Series

Single Phase, Active Import (kWh) Indoor, Electricity Meter

Instrument Traceable Number

0120/SGS0141

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of

Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 17th February 2024

Issue 4

Certification is based on report number(s) SHES130800321401 dated 18th February 2014

EMA241425

Authorised Signature

#C

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA□UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UKt +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

1. Technical Data

DU_CST-ME-002 Rev 2 EU Type Examination Cert.



0120/SGS0141

Issue Number: 4 Dated: 9th August 2019

Manufacturer	Zhejiang Eastron Electronic Co., Ltd.
Meter Types	SDM120A, SDM120D, SDM120DB, SDM120M, SDM120MB, SDM120P, SDM120CTM, SDM120CTMB, SDM120CTP
Voltage Rating (Un)	230V
Current Rating (Imin – Iref (Imax))	Direct Connected 0.25-5(45)A CT Connected 0.25-5(6)A
Frequency (Fn)	50Hz
Active Accuracy Class (kWh)	A or B (kWh)
Type of circuit	1p2w
Temperature Range	-25°C to +55°C
Software/ Firmware Version No's	SDM120A, SDM120D, SDM120DB: V1.2 SDM120M: V2.4 SDM120MB: V2.4 SDM120P: V2.4 SDM120CTM: V2.5 SDM120CTMB: V2.5 SDM120CTMB: V2.5 SDM120CTP: V2.5 SDM120CTP: V2.5
CRC Checksum No's	SDM120A, SDM120D, SDM120DB: 0x00008E1E SDM120M, SDM120MB, SDM120P: 0x0000272C SDM120CTM, SDM120CTMB, SDM120CTP: 0x0000B594 SDM120A V2, SDM120D V2, SDM120DB V2: 0x0000272C
Identification Location	Meter Case
Bill Of Materials No's	SDM120A: DH-JS-150002-1.5 SDM120A V2: DH-JS-190006-1.0 SDM120D/DB: DH-JS-170009-1.2 SDM120M: DH-JS-170026-1.0 SDM120D V2: DH-JS-190009-1.0 SDM120CTM: DH-JS-170021-1.0 SDM120CTM: DH-JS-170027-1.0 SDM120CTM: DH-JS-170025-1.0 SDM120CTP: DH-JS-170025-1.0
IP Rating	IP51
Insulation Protective Class	Class II
LED Pulse Constant	1000imp/ kWh & 100imp/kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	4 x Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Indoor
Type of Register	LCD: SDM120D, SDM120DB, SDM120M, SDM120MB, SDM120P, SDM120CTM, SDM120CTMB, SDM120CTP Mechanical: SDM120A

2. Example of Meter Sealing Points




0120/SGS0141






0120/SGS0141































0120/SGS0141

Issue Number: 4 Dated: 9th August 2019























0120/SGS0141










0120/SGS0141






























0120/SGS0141





















0120/SGS0141

Issue Number: 4 Dated: 9th August 2019

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

 $\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$

where

 $\delta e(T, I, \cos \phi) =$ Additional error due to variation of the temperature at the same load $\delta e(U, I, \cos \phi) =$ Additional error due to variation of the voltage at the same load Additional error due to variation of the frequency at the same load

	Influence Factors for temperature, frequency and voltage						l voltage
Current	PF Cos	-25℃	-10℃	5℃	30℃	40°C	55℃
Imin	1.0	0.12	0.12	0.12	0.13	0.12	0.12
ltr	1.0	0.16	0.16	0.16	0.16	0.16	0.16
10ltr	1.0	0.17	0.16	0.16	0.16	0.16	0.16
Imax	1.0	0.13	0.13	0.13	0.13	0.13	0.13
ltr	0.5ind	0.29	0.29	0.29	0.29	0.29	0.29
10ltr	0.5ind	0.40	0.40	0.40	0.40	0.40	0.40
Imax	0.5ind	0.16	0.16	0.16	0.16	0.16	0.16
ltr	0.8cap	0.24	0.24	0.24	0.24	0.24	0.24
10ltr	0.8cap	0.31	0.31	0.31	0.31	0.31	0.31
Imax	0.8cap	0.09	0.09	0.09	0.09	0.09	0.09



0120/SGS0141

Issue Number: 4 Dated: 9th August 2019

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
SDM120D	Single Phase 230V, 0.25-5(45)A
SDM120DB	Single Phase 230V, 0.25-5(45)A, backlight
SDM120A	Single Phase 230V, 0.25-5(45)A Mechanical register
SDM120M	Single Phase 230V, 0.25-5(45)A, RS485 Modbus
SDM120P	Single Phase, 230V, 0.25-5(45)A
SDM120MB	Single Phase, 230V, 0.25-5(45)A, Mbus EN13757-3
SDM120A V2	Single Phase 230V, 0.25-5(45)A Mechanical register
SDM120D V2	Single Phase 230V, 0.25-5(45)A
SDM120DB V2	Single Phase 230V, 0.25-5(45)A backlight
SDM120CTP	Single Phase 230V, 0.25-5(6)A
SDM120CTM	Single Phase 230V, 0.25-5(6)A. RS485, Modbus
SDM120CTMB	Single Phase 230V, 0.25-5(6)A. M-Bus EN13757-3

Modifications to the meter(s) described according to approval No.0120/ SGS0141 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0141

Issue Number: 4 Dated: 9th August 2019

6. Document Revision History

Issue	Date	Comments
1	18/02/2014	Initial Issue
2	27/11/2015	Version SDM120-Modbus added to approval
3	09/01/2018	SDM120CT models added to approval
4	09/08/2019	Case modification. SDM120A V2, SDM120D V2, SDM120DB V2. 100imp/kWh option included

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE