

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/CP3139QJ
The Operator is: RWE Generation UK Plc
The Installation is: Hythe Power Station
This Variation Notice number is: EPR/CP3139QJ/V002

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 2.3 Summary of how we considered the responses from public consultation.
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2016 No. 1154)
EWC	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 12th November 2018. A revised Regulation 61 Notice response was subsequently submitted on 17th January 2019 which was the basis for our determination. The revised Regulation 61 Notice response removed reference to the use of standby fuel on site.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review but not that it necessarily contained all the information we would need to complete that review. We requested additional information and the operator confirmed the proposed operating hours for the package boilers on site and provided additional information relating to energy efficiency on 31st October 2019.

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NOx is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NOx and CO.

The net thermal input of the LCPs are as follows: LCP 269: comprising 1 x gas fired 133MWth CHP and LCP 268: comprising 4 x 20.75MWth (83MWth) gas fired boilers in one windshield. LCP268 and LCP269 will operate under the TNP compliance route until June 2020.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- For LCP268 <1500 hours operation on natural gas
- For LCP269, unlimited hours operation as a combined heat and power plant (CHP) and <500 hours non-emergency plant in open cycle mode (OCGT). Both modes operate on natural gas.

Fuel oil was previously listed for use as a standby fuel in the permit but the revised Regulation 61 response confirmed that this is no longer used on site and therefore reference to it has been removed from the permit.

LCP269 is currently only operating in OCGT mode and not CHP mode as there is currently no identified customer for the steam.

The following tables outline the limits that have been incorporated into the permit for LCP 268 and LCP269, where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and

- 15% volume reference oxygen concentration in flue gases for gas turbines; and
- 3% volume reference oxygen concentration in flue gases for the package boilers.

The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

Under Chapter III gas turbines and gas engines operating for less than 500 hours per year were considered to be emergency plant and therefore were not covered by the emission limits set out in IED Annex V. However, for the purposes of the LCP BAT review, plants operated for emergency use may only be defined as plants which operate for the sole purpose of providing power at a site during an onsite emergency and/or during a black start and which do not provide balancing services or demand side response services. As LCP269 in OCGT mode runs commercially on an intermittent basis to support the Grid, it is not considered emergency plant and therefore indicative BAT applies.

In circumstances where a CCGT is in frequent use but also has the capability to operate in OCGT mode for <500 hours we do not set limits for the OCGT mode specifically because we consider the gas turbine maintenance carried out for the CCGT operation will be adequate. In this instance because the CCGT is not currently operational we have set indicative limits for NO_x for the OCGT mode as specified in BAT Conclusion 44. This requires the operator to demonstrate that maintenance of the GT is sustained.

We have set the indicative limits requiring validation through emission factors based on the principle that we will not require plant to fire up with the sole purpose of performing an emission measurement, as set out the UK Regulators Interpretation Document.

By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply.

LCP 269: Operating in CHP mode post 2021

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) – Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	55 (>75% net fuel utilisation)	55	BREF	DLN effective to baseload	Continuous
Monthly	75 (based on an efficiency of >75%)	None	60	Existing permit – no backsliding	DLN effective to baseload	
Daily	82.5	85	60	Existing permit – no backsliding	DLN effective to baseload	
95 th %ile of hr means	150	None	120	Existing permit – no backsliding	DLN effective to baseload	

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) – Existing	BREF (BAT-C 44))	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	30	30	BREF	DLN effective to baseload	Continuous
Monthly	100	None	50	Existing permit – no backsliding	DLN effective to baseload	
Daily	110	None	50	Existing permit – no backsliding	DLN effective to baseload	
95 th %ile of hr means	200	None	100	Existing permit – no backsliding	DLN effective to baseload	

An additional daily limit from start up/shut down to baseload for CHP mode has been added to the post TNP limits although the value will be defined through improvement condition IC11 in the case of the plant becoming operational as a CHP again in the future. Although this is not a regulatory requirement, it has been requested by the Operator through the trade body Energy UK. We have included a corresponding footnote.

LCP 269: Operating in OCGT mode <500 hours per year post 2021

NOx limits (mg/Nm ³) – indicative limits in italics						
Averaging	IED (Annex V Part 2) – Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None	None	NA	NA	Concentration by calculation
Monthly	None	None	None	NA	NA	
Daily	None	140	140	BREF	NA	
95 th %ile of hr means	None	None	None	NA	NA	

No carbon monoxide limits apply to the OCGT mode as it is <500 hours and the BAT Conclusions specify that the annual limits do not apply where the plant operates for <1500 hours.

LCP 268: Operating for <1500 hours post 2021

NOx limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) – Existing	BREF (Table 24 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None as <1500 hours	None	NA	NA	Periodic as <100MWth in size and <1500 hours operation
Monthly	100	None	None ^{Note 1}	NA	NA	
Daily	110	110	110	IED and BREF	MSUL/MSDL to baseload	
95 th %ile of hr means	200	None	None ^{Note 1}	NA	NA	

Note 1: where periodic monitoring is specified we have only set the daily limits specified in Article V 4(1) of IED.

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 1) – Existing	BREF (BAT-C 44))	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	None as <1500 hours	None	NA	NA	Periodic as <100MWth in size and <1500 hours operation
Monthly	100	None	None ^{Note 1}	NA	NA	
Daily	110	None	60	Existing permit – no backsliding	MSUL/MSDL to baseload	
95 th %ile of hr means	200	None	None ^{Note 1}	NA	N	

Note 1: where periodic monitoring is specified we have only set the daily limits specified in Article V 4(1) of IED.

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

Table 23 of the LCP BAT Conclusions specifies that the BAT-AEELs for this type of plant are not applicable to plant operating less than 1500 hours per year. We have therefore not assessed this operational aspect of either the gas turbine operating <500 hours in open cycle mode or the boilers operating for <1500 hours. We have assessed the gas turbine operating in CHP mode for an unlimited number of hours in the table below. This information is based on previous operation of the plant.

We have included a process monitoring requirement in table S3.4 of the consolidated variation notice for all plant. This is required to demonstrate that efficiency levels are maintained following any significant overhauls of equipment in order to fulfil the requirement of BAT Conclusion 2. For <500 hour plant we have specified that the assessment of efficiency can be based on calculation. This is because we will not require plant to fire up with the sole purpose of carrying out an assessment of efficiency.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP269: CCGT 50 – 600MWth (operating in CHP mode)					
46 - 54	65 - 95	None	NA	75.4	NA

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The conditions in the permit through which the relevant BAT Conclusions are implemented include but are not limited to the following:

BAT Conclusion requirement topic	Permit condition(s)	Permit table(s)
Environmental Management System	1.1.1	S1.2
BAT AELs	3.1.1 and 3.5.1	S3.1a
Monitoring	2.3, 3.5 and 3.6	S3.1a
Energy efficiency	1.2 and 2.3	S3.4
Noise	3.4 and 2.3	S1.2
Other operating techniques	2.3	S1.2

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	Hythe Power Station operates a local EMS which is fully integrated with the RWE Generation UK EMS and is certified to ISO14001: 2015 (certificate No:10054192).

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<p>Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.</p>		
2	<p>BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p>	CC	<p>Hythe Power Station has ceased CHP operation due to the loss of the steam customer. The GT has been reconfigured for OCGT operation and the HRSG and 4 Auxiliary boilers will be limited to <1500 hours operation from 2021.</p> <p>LCP 268: The 4 Auxiliary Boilers are Hocon SHP Series with efficiency of 88% when firing on natural gas.</p> <p>LCP 269 (<500 hr OCGT operation): The installed GT is a GE LM6000PD system with name plate efficiency of 41.7% (Gas Turbine World, 2017 Performance Specs, 33rd Edition). There have been no modifications to the GT with the potential to significantly affect efficiency.</p> <p>LCP 269 (>1500 hr CHP operation): If returned to CHP configuration, efficiency will depend heavily of a potential steam customers requirements, but has been shown to exceed 75% based on past operation.</p>
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p>	CC	<p>LCP 268: The 4 Auxiliary Boilers will operate <1500 hours per year</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	<table border="1"> <thead> <tr> <th data-bbox="322 384 689 419">Stream</th> <th data-bbox="689 384 1122 419">Parameter(s)</th> <th data-bbox="1122 384 1496 419">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 419 689 523" rowspan="3">Flue-gas</td> <td data-bbox="689 419 1122 454">Flow</td> <td data-bbox="1122 419 1496 454">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="689 454 1122 489">Oxygen content, temperature, and pressure</td> <td data-bbox="1122 454 1496 489">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="689 489 1122 523">Water vapour content ⁽³⁾</td> <td data-bbox="1122 489 1496 523"></td> </tr> <tr> <td data-bbox="322 523 689 558">Waste water from flue-gas treatment</td> <td data-bbox="689 523 1122 558">Flow, pH, and temperature</td> <td data-bbox="1122 523 1496 558">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽³⁾		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement		<p>and are <100MWth and therefore period monitoring is specified in table S3.1a.</p> <p>LCP 269 (<500 hr OCGT operation): An indicative limit for calculation through concentration for NOx has been set.</p> <p>LCP 269 (>1500 hr CHP operation): As required by BAT 3, flue gas emissions for flow, oxygen content, temperature and pressure will be monitored continuously should the site return to CHP operation. Moisture would not be monitored as the extracted gas sample is dried prior to analysis.</p> <p>Emissions of process waters (neutralised Water Treatment Plant Effluent only) are monitored for pH continuously and by routine grab sample.</p>
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content ⁽³⁾															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1"> <thead> <tr> <th data-bbox="322 1177 477 1294">Substance/Parameter</th> <th data-bbox="477 1177 790 1294">Fuel/Process/Type of combustion plant</th> <th data-bbox="790 1177 947 1294">Combustion plant total rated thermal input</th> <th data-bbox="947 1177 1126 1294">Standard(s) ⁽⁴⁾</th> <th data-bbox="1126 1177 1346 1294">Minimum monitoring frequency ⁽⁵⁾</th> <th data-bbox="1346 1177 1496 1294">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1294 477 1361">NH₃</td> <td data-bbox="477 1294 790 1361">— When SCR and/or SNCR is used</td> <td data-bbox="790 1294 947 1361">All sizes</td> <td data-bbox="947 1294 1126 1361">Generic EN standards</td> <td data-bbox="1126 1294 1346 1361">Continuous ⁽⁶⁾ ⁽⁷⁾</td> <td data-bbox="1346 1294 1496 1361">BAT 7</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	CC	<p>LCP 268: Emissions to air from the Auxiliary Boilers have periodic monitoring specified in table S3.1a as <1500 hours and <100MWth.</p> <p>LCP 269 (<500 hr OCGT operation): OCGTs operating for <500 hours are subject to indicative daily BAT-ELVs only. The requirements described in</p>	
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with											
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7											

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73		<p>BAT 4 do not apply where plant operation would be for the sole purpose of performing emissions measurement.</p> <p>LCP 269 (>1500 hr CHP operation): Emissions of CO and NO_x will be monitored continuously as required by BAT 4 for natural gas fired turbines should the site return to CHP operation.</p>
	<ul style="list-style-type: none"> — Combustion plants on offshore platforms 	All sizes	EN 14792	Once every year ⁽⁹⁾	BAT 53			
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁸⁾	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																	
		— Combustion plants on offshore platforms	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54																			
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given in BAT 5 and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	No flue-gas treatment fitted.																	
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="331 667 1494 1273"> <thead> <tr> <th data-bbox="338 671 555 703">Technique</th> <th data-bbox="562 671 994 703">Description</th> <th data-bbox="1001 671 1487 703">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 708 555 788">a. Fuel blending and mixing</td> <td data-bbox="562 708 994 788">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="1001 708 1487 788" rowspan="2">Generally applicable</td> </tr> <tr> <td data-bbox="338 793 555 873">b. Maintenance of the combustion system</td> <td data-bbox="562 793 994 873">Regular planned maintenance according to suppliers' recommendations</td> </tr> <tr> <td data-bbox="338 877 555 957">c. Advanced control system</td> <td data-bbox="562 877 994 957">See description in Section 8.1</td> <td data-bbox="1001 877 1487 957">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 962 555 1042">d. Good design of the combustion equipment</td> <td data-bbox="562 962 994 1042">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="1001 962 1487 1042">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="338 1046 555 1268">e. Fuel choice</td> <td data-bbox="562 1046 994 1268">Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td data-bbox="1001 1046 1487 1268">Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations	c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant	CC	<p>LCP 268: If returned to service, the environmental performance of the Auxiliary Boilers will be optimised through techniques b, c, d and e given in BAT 6.</p> <p>LCP 269: (<500 hr OCGT operation): The environmental performance of the combustion plant will be optimised through techniques b, c and d given in BAT 6.</p> <p>LCP 269 (>1500 hr CHP operation): If the site returned to CHP operation, the environmental performance of the combustion plant will be optimised through techniques b, c and d given in BAT 6.</p>
Technique	Description	Applicability																							
a. Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																							
b. Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																								
c. Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
d. Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																							
e. Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
7	In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO _x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO _x ratio, homogeneous reagent distribution and optimum size of the reagent drops).	NA	No SCR/SNCR.				
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	NA	No emission abatement systems.				
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="322 1082 1494 1203"> <thead> <tr> <th data-bbox="322 1082 712 1118">Fuel(s)</th> <th data-bbox="712 1082 1494 1118">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1118 712 1203">Natural gas</td> <td data-bbox="712 1118 1494 1203"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 	CC	<p>We consider that for plants which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid</p> <p>LCP 268: If returned to service, fuel gas supplied to the Auxiliary Boilers will be via local low pressure grid and will be assessed in accordance with technique (i) and periodically surveyed in accordance with technique (ii) given in BAT 9.</p> <p>LCP 269: (<500 hr OCGT operation): Fuel gas is supplied to the OCGT via local low pressure grid and has been assessed in accordance with technique (i) and is periodically surveyed in accordance with technique (ii) given in BAT 9.</p> <p>LCP 269 (>1500 hr CHP operation): If the site returned to</p>
Fuel(s)	Substances/Parameters subject to characterisation						
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			CHP operation, fuel gas will be supplied via the local low pressure grid and has been assessed in accordance with technique (i) and will be periodically surveyed in accordance with technique (ii) given in BAT 9.
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 	CC	<p>No have specific OTNOC management plan. However existing site documentation and procedures address OTNOC. Emissions to air and water are assessed as part of the annual environmental performance report. In the event of an accident or environmental incident, emissions, cause etc. are reviewed during the incident investigation process ensuring any relevant corrective and / or preventive actions are implemented.</p> <p>LCP 268: If returned to service, starts-ups and operation will be to meet customer requirements with little opportunity for optimisation.</p> <p>LCP 269 (<500 hr OCGT operation): Following reconfiguration to OCGT operation, start-ups are typically from cold and sub 15 mins duration with little remaining</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			<p>opportunity for optimisation. GT components are included within preventative maintenance programmes.</p> <p>LCP 269 (>1500 hr CHP operation): If the site returned to CHP operation, starts would likely be extremely infrequent and would be optimised based on plant condition (i.e. warmth category) to minimise emissions. GT components will be included within preventative maintenance programmes.</p>
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p>Description The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	<p>LCP 268: The Auxiliary Boilers are not fitted with CEMS for monitoring emissions to air. If returned to service, emissions to air will be monitored periodically but the requirements described in BAT 11 should not apply where plant operation would be for the sole purpose of performing emissions measurement.</p> <p>LCP 269 (<500 hr OCGT operation): Monitoring of emissions to air is not Applicable to OCGTs operating for <500 hours which are subject to indicative daily BAT-ELVs only. The requirements described in BAT 11 should not apply where plant operation would be for the</p>

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
			<p>sole purpose of performing emissions measurement.</p> <p>LCP: 269 (>1500 hr CHP operation): If the site returned to CHP operation, monitoring equipment for emissions to air would be fully operable during all operating conditions (inc. start-up and shut-down) and is not affected by OTNOC events.</p> <p>Monitoring of process waters (neutralised Water Treatment Plant Effluent only) are monitored for pH continuously and are not affected by OTNOC.</p>														
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="320 983 1494 1343"> <thead> <tr> <th data-bbox="320 983 365 1015"></th> <th data-bbox="365 983 551 1015">Technique</th> <th data-bbox="551 983 965 1015">Description</th> <th data-bbox="965 983 1494 1015">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1015 365 1126">a.</td> <td data-bbox="365 1015 551 1126">Combustion optimisation</td> <td data-bbox="551 1015 965 1126">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="965 1015 1494 1343" rowspan="3">Generally applicable</td> </tr> <tr> <td data-bbox="320 1126 365 1286">b.</td> <td data-bbox="365 1126 551 1286">Optimisation of the working medium conditions</td> <td data-bbox="551 1126 965 1286">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="320 1286 365 1343">c.</td> <td data-bbox="365 1286 551 1343">Optimisation of the steam cycle</td> <td data-bbox="551 1286 965 1343">Operate with lower turbine exhaust pressure by utilisation of the lowest</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest	CC	<p>LCP 268: Although these are not applicable to LCP268 as they will operate <1500 hours following the implementation date, the regulation 61 response confirms that if operational in the future that techniques; a, b, d and g described in BAT 12 will be used.</p> <p>LCP 269 (<500 hr OCGT operation): Not applicable.</p> <p>LCP: 269 (>1500 hr CHP operation): If returned to service, techniques; a, b, d, g, h and i</p>
	Technique	Description	Applicability														
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable														
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded															
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest															

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
			possible temperature of the condenser cooling water, within the design conditions		given in BAT 12 will be used (See BAT 40).
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)			
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions		
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions		
g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system		
h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: <ul style="list-style-type: none"> — flue-gas — grate cooling — circulating fluidised bed 	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated > 4 000 h/yr. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
13	<p>In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.</p> <table border="1" data-bbox="320 440 1494 743"> <thead> <tr> <th data-bbox="320 440 521 475">Technique</th> <th data-bbox="521 440 1066 475">Description</th> <th data-bbox="1066 440 1494 475">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 475 521 608">a. Water recycling</td> <td data-bbox="521 475 1066 608">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="1066 475 1494 608">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="320 608 521 743">b. Dry bottom ash handling</td> <td data-bbox="521 608 1066 743">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="1066 608 1494 743">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	CC	Towns water usage within the Water Treatment Plant is optimised where plant operations allows. The quality of surface water for potential re-use would have an adverse impact on the operation of the Water Treatment Plant and may lead to increased chemical and energy usage.
Technique	Description	Applicability										
a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present										
b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants										
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	<p>All emissions to water are via a single emission point. However, streams are segregated, treated and where necessary monitored separately prior to discharge.</p> <p>Surface water is collected and passed through an oil separator prior to discharge via the main emissions point. Water Treatment Plant effluent is collected, neutralised and monitored prior to discharge to the station drainage system.</p>									
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given in BAT 15, and to use secondary techniques as close as possible to the source in order to avoid dilution.	NA	No flue-gas treatment.									
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p>	CC	There are no by-products identified by BAT 16 associated with the combustion process at Hythe Power Station. Other									

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement															
	<p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="322 533 1496 1123"> <thead> <tr> <th data-bbox="322 533 573 564">Technique</th> <th data-bbox="573 533 1079 564">Description</th> <th data-bbox="1079 533 1496 564">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 564 573 724">a. Generation of gypsum as a by-product</td> <td data-bbox="573 564 1079 724">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td data-bbox="1079 564 1496 724">Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 724 573 858">b. Recycling or recovery of residues in the construction sector</td> <td data-bbox="573 724 1079 858">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> <td data-bbox="1079 724 1496 858">Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions</td> </tr> <tr> <td data-bbox="322 858 573 967">c. Energy recovery by using waste in the fuel mix</td> <td data-bbox="573 858 1079 967">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> <td data-bbox="1079 858 1496 967">Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber</td> </tr> <tr> <td data-bbox="322 967 573 1123">d. Preparation of spent catalyst for reuse</td> <td data-bbox="573 967 1079 1123">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> <td data-bbox="1079 967 1496 1123">The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO_x and NH₃ emissions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions	c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber	d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		wastes arising from site activities are dealt with according the waste hierarchy.
Technique	Description	Applicability																
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																
b. Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions																
c. Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber																
d. Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions																
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="322 1171 1496 1362"> <thead> <tr> <th data-bbox="322 1171 573 1203">Technique</th> <th data-bbox="573 1171 1079 1203">Description</th> <th data-bbox="1079 1171 1496 1203">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1203 573 1362">a. Operational measures</td> <td data-bbox="573 1203 1079 1362"> These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible </td> <td data-bbox="1079 1203 1496 1362">Generally applicable</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible 	Generally applicable	CC	Noise emissions from Hythe Power Station are reduced by the application of techniques a, b, c and d as identified in BAT 17.									
Technique	Description	Applicability																
a. Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible 	Generally applicable																

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement					
		<ul style="list-style-type: none"> — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 								
	b. Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced							
	c. Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space							
	d. Noise-control equipment	This includes: <ul style="list-style-type: none"> — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings 	The applicability may be restricted by lack of space							
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant							
Combustion of gaseous fuels										
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	LCP 268: The Auxiliary Boilers are Hocon SHP Series with name plate efficiency of 88% when firing on natural gas. Technique (a) of BAT 40 is not applicable to boilers. LCP 269 (<500 hr OCGT operation): Not Applicable as OCGT operating <500 hours per year and therefore AEEL not applicable. Name plate efficiency					
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Technique</th> <th style="width: 20%;">Description</th> <th style="width: 70%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Combined cycle</td> <td>See description in Section 8.2</td> <td> Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers </td> </tr> </tbody> </table>	Technique	Description	Applicability			a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers		
Technique	Description	Applicability								
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers								
BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																																														
	<table border="1"> <thead> <tr> <th rowspan="3">Type of combustion unit</th> <th colspan="4">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44 ⁽¹⁴¹⁾</td> <td>35–44 ⁽¹⁴¹⁾</td> <td>56–85 ⁽¹⁴¹⁾</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW_{th}</td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> <tr> <td colspan="6" style="text-align: center;">Combined cycle gas turbine (CCGT)</td> </tr> <tr> <td>CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>	Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾				Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	Combined cycle gas turbine (CCGT)						CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL			<p>41.7% (Gas Turbine World, 2017 Performance Specs, 33rd Edition). There have been no modifications to the GT with the potential to significantly affect efficiency and no recent performance test data is available.</p> <p>LCP 269 (>1500 hr CHP operation): If returned to CHP configuration, efficiency will depend heavily of a potential steam customer requirements, but will very likely exceed 75%. Technique (a) of BAT 40 and techniques; a, b, d, g, h and i given in BAT 12 will be used to optimise energy efficiency.</p>
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																																																																
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																																													
	New unit	Existing unit		New unit	Existing unit																																																												
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																																													
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																													
Open cycle gas turbine, ≥ 50 MW _{th}	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																												
Combined cycle gas turbine (CCGT)																																																																	
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																													
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																													
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																																																													
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																																																													
41	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Air and/or fuel staging</td> <td>See descriptions in Section 8.3. Air staging is often associated with low-NO_x burners</td> <td rowspan="3">Generally applicable</td> </tr> <tr> <td>b. Flue-gas recirculation</td> <td>See description in Section 8.3</td> </tr> <tr> <td>c. Low-NO_x burners (LNB)</td> <td></td> </tr> <tr> <td>d. Advanced control system</td> <td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>e. Reduction of the combustion air temperature</td> <td>See description in Section 8.3</td> <td>Generally applicable within the constraints associated with the process needs</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable	b. Flue-gas recirculation	See description in Section 8.3	c. Low-NO _x burners (LNB)		d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	Narrative	<p>LCP 268: If returned to service, NO_x emissions to air will be within the BAT-AEL ranges.</p> <p>Technique c described in BAT 28 will be used to minimise NO_x emissions to air.</p>																																														
Technique	Description	Applicability																																																															
a. Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO _x burners	Generally applicable																																																															
b. Flue-gas recirculation	See description in Section 8.3																																																																
c. Low-NO _x burners (LNB)																																																																	
d. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																																																															
e. Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																																																															

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																			
	f.	Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																				
	g.	Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW _{th} . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																				
42	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.			CC	LCP 269 (<500 hr OCGT operation): NO _x emissions are reduced by the application of techniques a and c as identified in BAT 42. The GE LM6000PD (DLE) system is already fitted with DLN combustors and NO _x emissions are within the indicative NO _x BAT-AEL range. However, due to the sensitivity of DLN systems to degradation of both mechanical components and instrumentation, it is only possible to maintain NO _x performance within the top-of-range BAT-AEL NO _x concentration of 140 mg/m ³ (JEP report UTG/18/ERG/773/R). It is unlikely NO _x would drift to a higher level without the gas turbine tripping due to high acoustic pulsations (monitored continuously) or increased exhaust gas temperatures.																			
			<table border="1"> <thead> <tr> <th data-bbox="322 799 353 831">Technique</th> <th data-bbox="353 799 533 831">Description</th> <th data-bbox="533 799 1093 831">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 831 353 943">a.</td> <td data-bbox="353 831 533 943">Advanced control system</td> <td data-bbox="533 831 1093 943">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> </tr> <tr> <td data-bbox="322 943 353 1002">b.</td> <td data-bbox="353 943 533 1002">Water/steam addition</td> <td data-bbox="533 943 1093 1002">See description in Section 8.3</td> </tr> <tr> <td data-bbox="322 1002 353 1114">c.</td> <td data-bbox="353 1002 533 1114">Dry low-NO_x burners (DLN)</td> <td data-bbox="533 1002 1093 1114">The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td data-bbox="322 1114 353 1246">d.</td> <td data-bbox="353 1114 533 1246">Low-load design concept</td> <td data-bbox="533 1114 1093 1246">Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> </tr> <tr> <td data-bbox="322 1246 353 1353">e.</td> <td data-bbox="353 1246 533 1353">Low-NO_x burners (LNB)</td> <td data-bbox="533 1246 1093 1353">See description in Section 8.3</td> </tr> </tbody> </table>	Technique	Description	Applicability	a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	b.	Water/steam addition	See description in Section 8.3	c.	Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	e.	Low-NO _x burners (LNB)	See description in Section 8.3			
Technique	Description	Applicability																						
a.	Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr																						
b.	Water/steam addition	See description in Section 8.3																						
c.	Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																						
d.	Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages																						
e.	Low-NO _x burners (LNB)	See description in Section 8.3																						

BAT Concn. Number	Summary of BAT Conclusion requirement		Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement				
	f. Selective catalytic reduction (SCR)	<p>Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MW_{th}. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</p>		<p>Whilst NO_x and CO emissions are routinely measured during a gas turbine tuning event following a major outage, there would be limited additional benefit in conducting two yearly accredited emissions testing which would be difficult to schedule from an operational viewpoint (JEP report UTG/18/ERG/773/R).</p> <p>LCP 269 (>1500 hr CHP operation): If returned to service, NO_x emissions will be reduced by the application of techniques a and c as identified in BAT 42. The GE LM6000PD (DLE) system is already fitted with DLN combustors and NO_x emissions will be within the NO_x BAT-AEL ranges. The effective DLN point will be defined through an improvement condition if the plant recommences operation in CHP mode.</p>				
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given in BAT 43.		NA	No gas engines on site.				
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts. Description - See descriptions in Section 8.3. BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines</p> <table border="1" data-bbox="322 1331 1491 1369"> <thead> <tr> <th data-bbox="322 1331 786 1369">Type of combustion plant</th> <th data-bbox="786 1331 1491 1369">BAT-AELs (mg/Nm³) ⁽¹⁴²⁾ ⁽¹⁴³⁾</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 1369 786 1394"></td> <td data-bbox="786 1369 1491 1394"></td> </tr> </tbody> </table>		Type of combustion plant	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾			CC	LCP 269 (<500 hr OCGT operation): CO emissions are reduced as far as possible by optimising combustion. CO emission is of the order of 12.5 mg/m ³ (JEP report UTG/18/ERG/773/R) but there are
Type of combustion plant	BAT-AELs (mg/Nm ³) ⁽¹⁴²⁾ ⁽¹⁴³⁾							

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		Combustion plant total rated thermal input (MW _{th})	Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾	Daily average or average over the sampling period		<p>no applicable indicative BAT AELs for CO for plant operating for less than 1500 hours per annum.</p> <p>LCP 269 (>1500 hr CHP operation): CO emissions are reduced as far as possible by optimising combustion. CO emission is of the order of 12.5 mg/m³ (JEP report UTG/18/ERG/773/R) and within the indicative BAT AEL.</p>
Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾						
New OCGT	≥ 50	15–35	25–50			
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾			
Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾						
New CCGT	≥ 50	10–30	15–40			
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾			
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾			
Open- and combined-cycle gas turbines						
Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾			
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾			
<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. 						

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— Existing OCGT of $\geq 50 \text{ MW}_{\text{th}}$ (excluding turbines for mechanical drive applications): $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of this range will generally be 80 mg/Nm^3 in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm^3 for plants that operate at low load.</p> <p>— New CCGT of $\geq 50 \text{ MW}_{\text{th}}$: $< 5\text{--}30 \text{ mg/Nm}^3$. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] $\times \text{EE}/55$, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</p> <p>— Existing CCGT of $\geq 50 \text{ MW}_{\text{th}}$: $< 5\text{--}30 \text{ mg/Nm}^3$. The higher end of this range will generally be 50 mg/Nm^3 for plants that operate at low load.</p> <p>— Existing gas turbines of $\geq 50 \text{ MW}_{\text{th}}$ for mechanical drive applications: $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of the range will generally be 50 mg/Nm^3 when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="322 791 1496 1015"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm^3)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <ul style="list-style-type: none"> — $< 5\text{--}40 \text{ mg/Nm}^3$ for existing boilers operated $\geq 1\,500 \text{ h/yr}$, — $< 5\text{--}15 \text{ mg/Nm}^3$ for new boilers, — $30\text{--}100 \text{ mg/Nm}^3$ for existing engines operated $\geq 1\,500 \text{ h/yr}$ and for new engines. 	Type of combustion plant	BAT-AELs (mg/Nm^3)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm^3)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH_4) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p>Description</p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p>	NA	No gas engines on site.																							

6. Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value

The IED enables a competent authority to allow derogations from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4):

By way of derogation from paragraph 3, and without prejudice to Article 18, the competent authority may, in specific cases, set less strict emission limit values. Such a derogation may apply only where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs compared to the environmental benefits due to:

(a) the geographical location or the local environmental conditions of the installation concerned; or

(b) the technical characteristics of the installation concerned.

As part of their Regulation 61 Note response, the operator has not requested a derogation from compliance with any AEL values.

7. Emissions to Water

The consolidated permit incorporates the current discharge to controlled waters identified as W1.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

Amendment to water emissions monitoring

We have amended the monitoring frequency from weekly to 6 monthly for the emissions to water. This is primarily because historical evidence has indicated that the site is consistently compliant with these limits. Also, it is considered that a less frequent requirement is more appropriate for the risk associated with the discharge in terms of volume and composition.

8 Additional IED Chapter II requirements:

Amendment to listed activity

We have moved the operation of the <1MWth combustion plant into the main 1.1 activity in table S1.1 because Regulatory Guidance Note RGN2 has been updated to remove the de minimis for aggregation of combustion plant.

Black start events

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.9. This conditions allows the hourly ELVs for plants operating under a black start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>

Aspect considered	Decision
	It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are [not fully] satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p> <p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>