

## Environment Agency

# **Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016**

## **Decision document recording our decision-making process following review of a permit**

The Permit number is: EPR/KP3531US  
The Operator is: RWE Generation UK plc  
The Installation is: Great Yarmouth Power Station  
This Variation Notice number is: EPR/ KP2531US /V008

### **What this document is about**

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17<sup>th</sup> August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

## How this document is structured

### Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Emissions to Water
- 7 Additional IED Chapter II requirements
- 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

## Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
Derogation	from BAT AELs stated in BAT Conclusions under specific circumstances as detailed under Article 15(4) of IED where an assessment shows that the achievement of emission levels associated with the best available techniques as described in BAT conclusions would lead to disproportionately higher costs
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2010 No. 1154)
EWG	European waste catalogue
FSA	Food Standards Agency
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO <sub>2</sub> expressed as NO <sub>2</sub> )
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note

TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

## 1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

## 2 How we reached our decision

### 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 01/05/18 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17<sup>th</sup> August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17<sup>th</sup> August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 31/10/2018 and further clarification due to turbine upgrade was received on the 19.02.2019.

We considered it was in the correct form and contained sufficient information for us to begin our determination of the permit review.

We have not received any information in relation to the Regulation 61 Notice response that appears to be confidential in relation to any party.

## **2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document**

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

## **3 The legal framework**

The consolidated variation notice will be issued under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

## **4 The key issues**

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)
- BAT 9 characterisation of fuel
- Inclusion of Black Start, Condition, IC and interpretation

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

### **4.1 Emissions to air and the emission limits applied to the plant**

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was demonstrated that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO<sub>x</sub> is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO<sub>x</sub> and CO.

The LCP on site consist of LCP267, 725MWth, CCGT burning Natural Gas.



The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 2 of Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- Unlimited hours operation

The following table outlines the limits that have been incorporated into the permit for LCP267, where these were derived from and the reference periods at which they apply. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. In line with the existing permit tighter limits are being retained in Table S3.1a Point source emissions to air. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply.

NOx limits (mg/Nm <sup>3</sup> )						
Averaging	IED (Annex V Part 2) - New	BREF (Table 25 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60	40	BREF	MSUL/MSDL to baseload	Continuous
Monthly	100	None	75	IED	MSUL/MSDL to baseload	
Daily	110	85	50	BREF	MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	200	None	90	IED	MSUL/MSDL to baseload	

CO limits (mg/Nm <sup>3</sup> )						
Averaging	IED (Annex V Part 2) - New	BREF (Table 25 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60	30	BREF	MSUL/MSDL to baseload	Continuous
Monthly	100	None	100	IED	MSUL/MSDL to baseload	
Daily	110	85	110	IED	MSUL/MSDL to baseload	
95 <sup>th</sup> %ile of hr means	200	None	150	IED	MSUL/MSDL to baseload	

## **4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions**

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The BAT Conclusions specifies that there are no AEELs for this type of plant, CCGT >600MWth. We have therefore not assessed this operational aspect of the plant.

## **5 Decision checklist regarding relevant BAT Conclusions**

BAT Conclusions for large combustion plant, were published by the European Commission on 17<sup>th</sup> August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The overall status of compliance with the BAT conclusion is indicated in the table as:

- NA Not Applicable
- CC Currently Compliant
- FC Compliant in the future (within 4 years of publication of BAT conclusions)
- NC Not Compliant
- PC Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
<b>General</b>				
1	<p><b>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</b></p> <ul style="list-style-type: none"> <li>i. commitment of the management, including senior management;</li> <li>ii. definition of an environmental policy that includes the continuous improvement of the installation by the management;</li> <li>iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment;</li> <li>iv. implementation of procedures <ul style="list-style-type: none"> <li>(a) Structure and responsibility</li> <li>(b) Training</li> <li>(c) Communication</li> <li>(d) Employee involvement</li> <li>(e) Documentation</li> <li>(f) Efficient process control</li> <li>(g) Maintenance programmes</li> <li>(h) Emergency preparedness and response</li> <li>(i) Safeguarding compliance with environmental legislation</li> </ul> </li> <li>v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> <li>(a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring)</li> <li>(b) corrective and preventive action</li> <li>(c) maintenance of records</li> <li>(d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained;</li> </ul> </li> <li>vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management;</li> <li>vii. following the development of cleaner technologies;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life;</li> <li>ix. application of sectoral benchmarking on a regular basis.</li> </ul>	CC	The operator's EMS is accredited to ISO14001 and is consistent with the requirements of BAT 1.	1.1.1

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)												
	Etc - see BAT Conclusions  <b>Applicability.</b> The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.															
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	FC	The station carried out a full load performance test on 19/05/2002, according to the appropriate standards, including ASME PTX 46, ISO2314, IEC953-2, the station had an efficiency of 56.55 %. The site has recently returned to service from an upgrade. A full performance test has not yet been carried out post upgrade as on the day the test was scheduled the plant was unable to operate at full load.	1.2 and Table S3.4												
3	<p><b>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</b></p> <table border="1"> <thead> <tr> <th>Stream</th> <th>Parameter(s)</th> <th>Monitoring</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Flue-gas</td> <td>Flow</td> <td>Periodic or continuous determination</td> </tr> <tr> <td>Oxygen content, temperature, and pressure</td> <td rowspan="2">Periodic or continuous measurement</td> </tr> <tr> <td>Water vapour content<sup>(2)</sup></td> </tr> <tr> <td>Waste water from flue-gas treatment</td> <td>Flow, pH, and temperature</td> <td>Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content <sup>(2)</sup>	Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	<p>The station continuously monitors flue gas emissions from LCP267 for oxygen content, temperature and pressure. Water content is not monitored as the sample is dried prior to analysis. Flow is calculated based on fuel consumption, and the calculation validated as required for TNP sites.</p> <p>There is no waste water from flue-gas treatment.</p>	3.1.1 and 3.5.1
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content <sup>(2)</sup>															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1"> <thead> <tr> <th>Substance/Parameter</th> <th>Fuel/Process/Type of combustion plant</th> <th>Combustion plant total rated thermal input</th> <th>Standard(s)<sup>(4)</sup></th> <th>Minimum monitoring frequency<sup>(5)</sup></th> <th>Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with							NA	No SCR/SNCR employed on site	3.1.1 and 3.5.1
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) <sup>(4)</sup>	Minimum monitoring frequency <sup>(5)</sup>	Monitoring associated with											



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
		<ul style="list-style-type: none"> <li>including waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers and engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Natural-gas-fired boilers, engines, and turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry</li> <li>— IGCC plants</li> </ul>				BAT 49 BAT 56 BAT 64 BAT 65 BAT 73	CC	The site monitors CO as required by BAT 4 for natural gas fired turbines. Monitoring is carried out continuously in accordance with EN14181.	
		<ul style="list-style-type: none"> <li>— Combustion plants on offshore platforms</li> </ul>	All sizes	EN 15058	Once every year <sup>(9)</sup>	BAT 54	NA	CCGT fired on Natural gas.	
	SO <sub>2</sub>	<ul style="list-style-type: none"> <li>— Coal and/or lignite incl waste co-incineration</li> <li>— Solid biomass and/or peat incl waste co-incineration</li> <li>— HFO- and/or gas-oil-fired boilers</li> <li>— HFO- and/or gas-oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> </ul>	All sizes	Generic EN standards and EN 14791	Continuous <sup>(6)</sup> <sub>(1)</sub>	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74	NA		

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)		
	SO <sub>3</sub>	— When SCR is used	All sizes	No EN standard available	Once every year	—	NA				
Gaseous chlorides, expressed as HCl	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	EN 1911	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57	NA					
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous <sup>(15)</sup> <sup>(16)</sup>						
	— Waste co- incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67						
HF	— Coal and/or lignite — Process fuels from the chemical industry in boilers	All sizes	No EN standard available	Once every three months <sup>(6)</sup> <sup>(13)</sup> <sup>(14)</sup>	BAT 21 BAT 57	NA					
		— Solid biomass and/or peat	All sizes	No EN standard available	Once every year						
	— Waste co- incineration	All sizes	Generic EN standards	Continuous <sup>(6)</sup> <sup>(16)</sup>	BAT 66 BAT 67						
Dust	<ul style="list-style-type: none"> <li>— Coal and/or lignite</li> <li>— Solid biomass and/or peat</li> <li>— HFO- and/or gas- oil-fired boilers</li> <li>— Iron and steel process gases</li> <li>— Process fuels from the chemical industry in boilers</li> <li>— IGCC plants</li> <li>— HFO- and/or gas- oil-fired engines</li> <li>— Gas-oil-fired gas turbines</li> </ul>	All sizes	Generic EN standards and EN 13284-1 and EN 13284-2	Continuous <sup>(6)</sup> <sup>(17)</sup>	BAT 22 BAT 26 BAT 30 BAT 35 BAT 39 BAT 51 BAT 58 BAT 75	NA					

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
		— Waste co-incineration	All sizes	Generic EN standards and EN 13284-2	Continuous	BAT 68 BAT 69	NA		
	Metals and metalloids except mercury (As, Cd, Co, Cr, Cu, Mn, Ni, Pb, Sb, Se, Tl, V, Zn)	— Coal and/or lignite — Solid biomass and/or peat — HFO- and/or gas-oil-fired boilers and engines	All sizes	EN 14385	Once every year <sub>(18)</sub>	BAT 22 BAT 26 BAT 30			
		— Waste co-incineration	< 300 MW <sub>th</sub>	EN 14385	Once every six months <sub>(13)</sub>	BAT 68 BAT 69			
			≥ 300 MW <sub>th</sub>	EN 14385	Once every three months <sub>(19)</sub> <sub>(13)</sub>				
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 14385	Once every year <sub>(18)</sub>	BAT 75			
	Hg	— Coal and/or lignite including waste co-incineration	< 300 MW <sub>th</sub>	EN 13211	Once every three months <sub>(13)</sub> <sub>(20)</sub>	BAT 23	NA		
			≥ 300 MW <sub>th</sub>	Generic EN standards and EN 14884	Continuous <sub>(16)</sub> <sub>(21)</sub>				
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year <sub>(22)</sub>	BAT 27			
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months <sub>(13)</sub>	BAT 70			
		— IGCC plants	≥ 100 MW <sub>th</sub>	EN 13211	Once every year <sub>(23)</sub>	BAT 75	NA		
	TVOC	— HFO- and/or gas-oil-fired engines	All sizes	EN 12619	Once every six months <sub>(13)</sub>	BAT 33 BAT 59			
		— Process fuels from chemical industry in boilers							
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71			



BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																											
	Formaldehyde	— Natural-gas in spark-ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45	NA																													
	CH <sub>4</sub>	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year <sup>(24)</sup>	BAT 45	NA																													
	PCDD/F	— Process fuels from chemical industry in boilers — Waste co-incineration	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months <sup>(13)</sup> <sup>(25)</sup>	BAT 59 BAT 71	NA																													
5	<p>BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="344 778 1211 1378"> <thead> <tr> <th data-bbox="344 778 600 863">Substance/Parameter</th> <th data-bbox="600 778 869 863">Standard(s)</th> <th data-bbox="869 778 1048 863">Minimum monitoring frequency</th> <th data-bbox="1048 778 1211 863">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="344 863 600 922">Total organic carbon (TOC)<sup>(26)</sup></td> <td data-bbox="600 863 869 922">EN 1484</td> <td data-bbox="869 863 1048 1378" rowspan="8">Once every month</td> <td data-bbox="1048 863 1211 1378" rowspan="8">BAT 15</td> </tr> <tr> <td data-bbox="344 922 600 981">Chemical oxygen demand (COD)<sup>(26)</sup></td> <td data-bbox="600 922 869 981">No EN standard available</td> </tr> <tr> <td data-bbox="344 981 600 1040">Total suspended solids (TSS)</td> <td data-bbox="600 981 869 1040">EN 872</td> </tr> <tr> <td data-bbox="344 1040 600 1099">Fluoride (F<sup>-</sup>)</td> <td data-bbox="600 1040 869 1099">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="344 1099 600 1158">Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td data-bbox="600 1099 869 1158">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="344 1158 600 1217">Sulphide, easily released (S<sup>2-</sup>)</td> <td data-bbox="600 1158 869 1217">No EN standard available</td> </tr> <tr> <td data-bbox="344 1217 600 1276">Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="600 1217 869 1276">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="344 1276 600 1378">Metals and metalloids</td> <td data-bbox="600 1276 869 1378"> <table border="1" data-bbox="546 1209 600 1378"> <tr><td data-bbox="546 1209 600 1241">As</td></tr> <tr><td data-bbox="546 1241 600 1273">Cd</td></tr> <tr><td data-bbox="546 1273 600 1305">Cr</td></tr> <tr><td data-bbox="546 1305 600 1337">Cu</td></tr> <tr><td data-bbox="546 1337 600 1369">Ni</td></tr> </table>           Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)         </td> </tr> </tbody> </table>						Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) <sup>(26)</sup>	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F <sup>-</sup> )	EN ISO 10304-1	Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1	Sulphide, easily released (S <sup>2-</sup> )	No EN standard available	Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3	Metals and metalloids	<table border="1" data-bbox="546 1209 600 1378"> <tr><td data-bbox="546 1209 600 1241">As</td></tr> <tr><td data-bbox="546 1241 600 1273">Cd</td></tr> <tr><td data-bbox="546 1273 600 1305">Cr</td></tr> <tr><td data-bbox="546 1305 600 1337">Cu</td></tr> <tr><td data-bbox="546 1337 600 1369">Ni</td></tr> </table> Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	As	Cd	Cr	Cu	Ni	NA	No Flue gas treatment on site.	3.1.1 and 3.5.1
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																	
Total organic carbon (TOC) <sup>(26)</sup>	EN 1484	Once every month	BAT 15																																	
Chemical oxygen demand (COD) <sup>(26)</sup>	No EN standard available																																			
Total suspended solids (TSS)	EN 872																																			
Fluoride (F <sup>-</sup> )	EN ISO 10304-1																																			
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	EN ISO 10304-1																																			
Sulphide, easily released (S <sup>2-</sup> )	No EN standard available																																			
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	EN ISO 10304-3																																			
Metals and metalloids	<table border="1" data-bbox="546 1209 600 1378"> <tr><td data-bbox="546 1209 600 1241">As</td></tr> <tr><td data-bbox="546 1241 600 1273">Cd</td></tr> <tr><td data-bbox="546 1273 600 1305">Cr</td></tr> <tr><td data-bbox="546 1305 600 1337">Cu</td></tr> <tr><td data-bbox="546 1337 600 1369">Ni</td></tr> </table> Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)			As	Cd	Cr	Cu	Ni																												
As																																				
Cd																																				
Cr																																				
Cu																																				
Ni																																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																									
	<table border="1"> <tr> <td data-bbox="349 336 546 400"></td> <td data-bbox="546 336 595 368">Pb</td> <td data-bbox="595 336 864 400"></td> <td data-bbox="864 336 1043 400"></td> <td data-bbox="1043 336 1211 400"></td> </tr> <tr> <td data-bbox="349 400 546 432"></td> <td data-bbox="546 400 595 432">Zn</td> <td data-bbox="595 400 864 432"></td> <td data-bbox="864 400 1043 432"></td> <td data-bbox="1043 400 1211 432"></td> </tr> <tr> <td data-bbox="349 432 546 512"></td> <td data-bbox="546 432 595 512">Hg</td> <td data-bbox="595 432 864 512">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> <td data-bbox="864 432 1043 512"></td> <td data-bbox="1043 432 1211 512"></td> </tr> <tr> <td data-bbox="349 512 546 616">Chloride (Cl<sup>-</sup>)</td> <td data-bbox="546 512 595 616"></td> <td data-bbox="595 512 864 616">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="864 512 1043 616"></td> <td data-bbox="1043 512 1211 616">—</td> </tr> <tr> <td data-bbox="349 616 546 655">Total nitrogen</td> <td data-bbox="546 616 595 655"></td> <td data-bbox="595 616 864 655">EN 12260</td> <td data-bbox="864 616 1043 655"></td> <td data-bbox="1043 616 1211 655">—</td> </tr> </table>		Pb					Zn					Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)			Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen		EN 12260		—			
	Pb																												
	Zn																												
	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																											
Chloride (Cl <sup>-</sup> )		Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																									
Total nitrogen		EN 12260		—																									
6	<p>In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="349 799 517 831">Technique</th> <th data-bbox="517 799 842 831">Description</th> <th data-bbox="842 799 1211 831">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 831 517 967">a Fuel blending and mixing</td> <td data-bbox="517 831 842 967">Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type</td> <td data-bbox="842 831 1211 967">Generally applicable</td> </tr> <tr> <td data-bbox="349 967 517 1070">b Maintenance of the combustion system</td> <td data-bbox="517 967 842 1070">Regular planned maintenance according to suppliers' recommendations</td> <td data-bbox="842 967 1211 1070"></td> </tr> <tr> <td data-bbox="349 1070 517 1206">c Advanced control system</td> <td data-bbox="517 1070 842 1206">See description in Section 8.1</td> <td data-bbox="842 1070 1211 1206">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="349 1206 517 1318">d Good design of the combustion equipment</td> <td data-bbox="517 1206 842 1318">Good design of furnace, combustion chambers, burners and associated devices</td> <td data-bbox="842 1206 1211 1318">Generally applicable to new combustion plants</td> </tr> <tr> <td data-bbox="349 1318 517 1374">e Fuel choice</td> <td data-bbox="517 1318 842 1374">Select or switch totally or partially to another fuel(s) with a</td> <td data-bbox="842 1318 1211 1374">Applicable within the constraints associated with the availability of</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable	b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations		c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	d Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants	e Fuel choice	Select or switch totally or partially to another fuel(s) with a	Applicable within the constraints associated with the availability of	CC	The site uses techniques b,c,d and e.	1.1.1 and 2.3							
Technique	Description	Applicability																											
a Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable																											
b Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations																												
c Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																											
d Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants																											
e Fuel choice	Select or switch totally or partially to another fuel(s) with a	Applicable within the constraints associated with the availability of																											

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)				
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%;"></td> <td style="width: 30%;">better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used</td> <td style="width: 40%;">suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant</td> </tr> </table>			better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant			
		better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant					
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO<sub>x</sub> emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO<sub>x</sub> ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p><b>BAT-associated emission levels</b></p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH<sub>3</sub> to air from the use of SCR and/or SNCR is &lt; 3–10 mg/Nm<sup>3</sup> as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm<sup>3</sup>.</p>	NA	SCR/SNCR are not used on site.	2.3				
8	<p>In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.</p>	NA	Site employs CCGT technology with no requirement for abatement.	?				
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> <li>(i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality;</li> <li>(ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of</li> </ul>	CC	<p>BAT 9 requires the operator to carry out fuel characterisation.</p> <p>We consider that for plant which burn natural gas from the National Grid as a fuel that it is not necessary for the operator to replicate the testing carried out by the National Grid</p>	1.1.1				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																				
	<p>testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed);</p> <p>(iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)).</p> <p><b>Description</b> Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="338 639 1218 1362"> <thead> <tr> <th data-bbox="338 639 633 671">Fuel(s)</th> <th data-bbox="633 639 1218 671">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 671 633 879" rowspan="3">Biomass/peat</td> <td data-bbox="633 671 1218 703">— LHV</td> </tr> <tr> <td data-bbox="633 703 1218 751">— moisture</td> </tr> <tr> <td data-bbox="633 751 1218 879">           — Ash            — C, Cl, F, N, S, K, Na            — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)         </td> </tr> <tr> <td data-bbox="338 879 633 1118" rowspan="4">Coal/lignite</td> <td data-bbox="633 879 1218 911">— LHV</td> </tr> <tr> <td data-bbox="633 911 1218 943">— Moisture</td> </tr> <tr> <td data-bbox="633 943 1218 991">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> <tr> <td data-bbox="633 991 1218 1118">           — Br, Cl, F            — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)         </td> </tr> <tr> <td data-bbox="338 1118 633 1198" rowspan="2">HFO</td> <td data-bbox="633 1118 1218 1150">— Ash</td> </tr> <tr> <td data-bbox="633 1150 1218 1198">— C, S, N, Ni, V</td> </tr> <tr> <td data-bbox="338 1198 633 1278" rowspan="2">Gas oil</td> <td data-bbox="633 1198 1218 1230">— Ash</td> </tr> <tr> <td data-bbox="633 1230 1218 1278">— N, C, S</td> </tr> <tr> <td data-bbox="338 1278 633 1362" rowspan="2">Natural gas</td> <td data-bbox="633 1278 1218 1310">— LHV</td> </tr> <tr> <td data-bbox="633 1310 1218 1362">— CH<sub>4</sub>, C<sub>2</sub>H<sub>6</sub>, C<sub>3</sub>, C<sub>4+</sub>, CO<sub>2</sub>, N<sub>2</sub>, Wobbe index</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)	HFO	— Ash	— C, S, N, Ni, V	Gas oil	— Ash	— N, C, S	Natural gas	— LHV	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index			
Fuel(s)	Substances/Parameters subject to characterisation																							
Biomass/peat	— LHV																							
	— moisture																							
	— Ash — C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)																							
Coal/lignite	— LHV																							
	— Moisture																							
	— Volatiles, ash, fixed carbon, C, H, N, O, S																							
	— Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)																							
HFO	— Ash																							
	— C, S, N, Ni, V																							
Gas oil	— Ash																							
	— N, C, S																							
Natural gas	— LHV																							
	— CH <sub>4</sub> , C <sub>2</sub> H <sub>6</sub> , C <sub>3</sub> , C <sub>4+</sub> , CO <sub>2</sub> , N <sub>2</sub> , Wobbe index																							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)						
	<table border="1"> <tr> <td data-bbox="338 331 629 437">Process fuels from the chemical industry <sup>(27)</sup></td> <td data-bbox="629 331 1211 437"> <ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul> </td> </tr> <tr> <td data-bbox="338 437 629 507">Iron and steel process gases</td> <td data-bbox="629 437 1211 507"> <ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul> </td> </tr> <tr> <td data-bbox="338 507 629 687">Waste <sup>(28)</sup></td> <td data-bbox="629 507 1211 687"> <ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul> </td> </tr> </table>	Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>	Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>	Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>			
Process fuels from the chemical industry <sup>(27)</sup>	<ul style="list-style-type: none"> <li>— Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>									
Iron and steel process gases	<ul style="list-style-type: none"> <li>— LHV, CH<sub>4</sub> (for COG), C<sub>x</sub>H<sub>y</sub> (for COG), CO<sub>2</sub>, H<sub>2</sub>, N<sub>2</sub>, total sulphur, dust, Wobbe index</li> </ul>									
Waste <sup>(28)</sup>	<ul style="list-style-type: none"> <li>— LHV</li> <li>— Moisture</li> <li>— Volatiles, ash, Br, C, Cl, F, H, N, O, S</li> <li>— Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Ti, V, Zn)</li> </ul>									
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> <li>— appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines),</li> <li>— set-up and implementation of a specific preventive maintenance plan for these relevant systems,</li> <li>— review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary,</li> <li>— periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary.</li> </ul>	CC	Although there is no specific OTNOC management plan, the operator states they are compliant with BAT10 through design of plant, maintenance regimes, review and recording of emissions, to identify any corrective actions required and periodic assessments during OTNOC.							
11	<p>BAT is to appropriately monitor emissions to air and/or to water during OTNOC.</p> <p><b>Description</b></p> <p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>	CC	Monitoring equipment for emissions to air and water is fully operable including during OTNOC.							

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																					
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated <math>\geq 1\,500</math> h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="338 411 1218 1331"> <thead> <tr> <th data-bbox="338 411 533 443">Technique</th> <th data-bbox="533 411 891 443">Description</th> <th data-bbox="891 411 1218 443">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 443 533 579">a. Combustion optimisation</td> <td data-bbox="533 443 891 579">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="891 443 1218 579" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="338 579 533 762">b. Optimisation of the working medium conditions</td> <td data-bbox="533 579 891 762">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO<sub>x</sub> emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="338 762 533 898">c. Optimisation of the steam cycle</td> <td data-bbox="533 762 891 898">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="338 898 533 978">d. Minimisation of energy consumption</td> <td data-bbox="533 898 891 978">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="338 978 533 1066">e. Preheating of combustion air</td> <td data-bbox="533 978 891 1066">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="891 978 1218 1066">Generally applicable within the constraints related to the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="338 1066 533 1169">f. Fuel preheating</td> <td data-bbox="533 1066 891 1169">Preheating of fuel using recovered heat</td> <td data-bbox="891 1066 1218 1169">Generally applicable within the constraints associated with the boiler design and the need to control NO<sub>x</sub> emissions</td> </tr> <tr> <td data-bbox="338 1169 533 1331">g. Advanced control system</td> <td data-bbox="533 1169 891 1331">See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved</td> <td data-bbox="891 1169 1218 1331">Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded	c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions	f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions	g. Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	CC	The site uses techniques a,b,c,d, f and g as well as complying with BAT40 a.	
Technique	Description	Applicability																							
a. Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																							
b. Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO <sub>x</sub> emissions or the characteristics of energy demanded																								
c. Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																								
d. Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																								
e. Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO <sub>x</sub> emissions																							
f. Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO <sub>x</sub> emissions																							
g. Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system																							

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat		
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile		
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit		
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat		
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand		
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD		
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
	o. Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations			
	p. Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units			
	q. Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants			
	r. Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime			
	s. Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{th}$ operated $> 4\,000 \text{ h/yr}$ . Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode.			



BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)									
	<table border="1"> <tr> <td></td> <td></td> <td></td> <td>For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses</td> </tr> </table>				For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses								
			For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses										
13	<p>In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a Water recycling</td> <td>Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td>Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td>b Dry bottom ash handling</td> <td>Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td>Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	CC	Water used within the cooling water system is estuarine and not suitable to be used in other processes. The site is direct cooled and therefore water use for cooling is non consumptive. Process water usage including boiler feed water is optimised through minimisation of blowdown from the water steam cycle. Based on these scenarios, any recovered water would have an adverse impact on the operation of the water treatment plant and may lead to increased chemical usage and energy use.	
Technique	Description	Applicability											
a Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present											
b Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants											
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p><b>Description</b> Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p><b>Applicability</b> The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	All waste water streams are segregated, treated and where necessary monitored separately prior to discharge; Effluent from the turbine hall discharges to sewer via an oil interceptor in accordance with a separate trade effluent consent and is monitored in accordance with that consent. Other site drainage including boiler blowdown and surface water drains are collected and passed through oil separators to the stormwater basin prior to discharge to the controlled water system. Cooling water quality is continuously monitored prior to discharge via the stations discharge point W1.										
15	In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.	NA	No FGD on site.										

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																																													
	<table border="1"> <thead> <tr> <th data-bbox="338 331 633 389">Technique</th> <th data-bbox="633 331 869 389">Typical pollutants prevented/abated</th> <th data-bbox="869 331 1216 389">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="338 389 1216 424" style="text-align: center;"><b>Primary techniques</b></td> </tr> <tr> <td data-bbox="338 424 633 536">a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)</td> <td data-bbox="633 424 869 536">Organic compounds, ammonia (NH<sub>3</sub>)</td> <td data-bbox="869 424 1216 536">Generally applicable</td> </tr> <tr> <td colspan="3" data-bbox="338 536 1216 571" style="text-align: center;"><b>Secondary techniques <sup>(29)</sup></b></td> </tr> <tr> <td data-bbox="338 571 633 628">b. Adsorption on activated carbon</td> <td data-bbox="633 571 869 628">Organic compounds, mercury (Hg)</td> <td data-bbox="869 571 1216 628">Generally applicable</td> </tr> <tr> <td data-bbox="338 628 633 810">c. Aerobic biological treatment</td> <td data-bbox="633 628 869 810">Biodegradable organic compounds, ammonium (NH<sub>4</sub><sup>+</sup>)</td> <td data-bbox="869 628 1216 810">Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH<sub>4</sub><sup>+</sup>) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)</td> </tr> <tr> <td data-bbox="338 810 633 868">d. Anoxic/anaerobic biological treatment</td> <td data-bbox="633 810 869 868">Mercury (Hg), nitrate (NO<sub>3</sub><sup>-</sup>), nitrite (NO<sub>2</sub><sup>-</sup>)</td> <td data-bbox="869 810 1216 868">Generally applicable</td> </tr> <tr> <td data-bbox="338 868 633 925">e. Coagulation and flocculation</td> <td data-bbox="633 868 869 925">Suspended solids</td> <td data-bbox="869 868 1216 925">Generally applicable</td> </tr> <tr> <td data-bbox="338 925 633 1015">f. Crystallisation</td> <td data-bbox="633 925 869 1015">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> <td data-bbox="869 925 1216 1015">Generally applicable</td> </tr> <tr> <td data-bbox="338 1015 633 1104">g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)</td> <td data-bbox="633 1015 869 1104">Suspended solids, metals</td> <td data-bbox="869 1015 1216 1104">Generally applicable</td> </tr> <tr> <td data-bbox="338 1104 633 1161">h. Flotation</td> <td data-bbox="633 1104 869 1161">Suspended solids, free oil</td> <td data-bbox="869 1104 1216 1161">Generally applicable</td> </tr> <tr> <td data-bbox="338 1161 633 1197">i. Ion exchange</td> <td data-bbox="633 1161 869 1197">Metals</td> <td data-bbox="869 1161 1216 1197">Generally applicable</td> </tr> <tr> <td data-bbox="338 1197 633 1232">j. Neutralisation</td> <td data-bbox="633 1197 869 1232">Acids, alkalis</td> <td data-bbox="869 1197 1216 1232">Generally applicable</td> </tr> <tr> <td data-bbox="338 1232 633 1289">k. Oxidation</td> <td data-bbox="633 1232 869 1289">Sulphide (S<sup>2-</sup>), sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td data-bbox="869 1232 1216 1289">Generally applicable</td> </tr> <tr> <td data-bbox="338 1289 633 1377">l. Precipitation</td> <td data-bbox="633 1289 869 1377">Metals and metalloids, sulphate (SO<sub>4</sub><sup>2-</sup>), fluoride (F<sup>-</sup>)</td> <td data-bbox="869 1289 1216 1377">Generally applicable</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	<b>Primary techniques</b>			a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable	<b>Secondary techniques <sup>(29)</sup></b>			b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable	e. Coagulation and flocculation	Suspended solids	Generally applicable	f. Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable	g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	h. Flotation	Suspended solids, free oil	Generally applicable	i. Ion exchange	Metals	Generally applicable	j. Neutralisation	Acids, alkalis	Generally applicable	k. Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable	l. Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable			
Technique	Typical pollutants prevented/abated	Applicability																																															
<b>Primary techniques</b>																																																	
a. Optimised combustion (see BAT 6) and flue-gas treatment systems (e.g. SCR/SNCR, see BAT 7)	Organic compounds, ammonia (NH <sub>3</sub> )	Generally applicable																																															
<b>Secondary techniques <sup>(29)</sup></b>																																																	
b. Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable																																															
c. Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH <sub>4</sub> <sup>+</sup> )	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH <sub>4</sub> <sup>+</sup> ) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)																																															
d. Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO <sub>3</sub> <sup>-</sup> ), nitrite (NO <sub>2</sub> <sup>-</sup> )	Generally applicable																																															
e. Coagulation and flocculation	Suspended solids	Generally applicable																																															
f. Crystallisation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable																																															
g. Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable																																															
h. Flotation	Suspended solids, free oil	Generally applicable																																															
i. Ion exchange	Metals	Generally applicable																																															
j. Neutralisation	Acids, alkalis	Generally applicable																																															
k. Oxidation	Sulphide (S <sup>2-</sup> ), sulphite (SO <sub>3</sub> <sup>2-</sup> )	Generally applicable																																															
l. Precipitation	Metals and metalloids, sulphate (SO <sub>4</sub> <sup>2-</sup> ), fluoride (F <sup>-</sup> )	Generally applicable																																															

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																																																			
	<table border="1" data-bbox="338 328 1216 424"> <tr> <td>m.</td> <td>Sedimentation</td> <td>Suspended solids</td> <td>Generally applicable</td> </tr> <tr> <td>n.</td> <td>Stripping</td> <td>Ammonia (NH<sub>3</sub>)</td> <td>Generally applicable</td> </tr> </table> <p>The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.</p> <p><b>BAT-AELs for direct discharges to a receiving water body from flue-gas treatment</b></p> <table border="1" data-bbox="338 536 1216 1126"> <thead> <tr> <th rowspan="2">Substance/Parameter</th> <th colspan="2">BAT-AELs</th> </tr> <tr> <th colspan="2">Daily average</th> </tr> </thead> <tbody> <tr> <td>Total organic carbon (TOC)</td> <td colspan="2">20–50 mg/l <sub>(<sup>30</sup>)</sub> <sub>(<sup>31</sup>)</sub> <sub>(<sup>32</sup>)</sub></td> </tr> <tr> <td>Chemical oxygen demand (COD)</td> <td colspan="2">60–150 mg/l <sub>(<sup>30</sup>)</sub> <sub>(<sup>31</sup>)</sub> <sub>(<sup>32</sup>)</sub></td> </tr> <tr> <td>Total suspended solids (TSS)</td> <td colspan="2">10–30 mg/l</td> </tr> <tr> <td>Fluoride (F<sup>-</sup>)</td> <td colspan="2">10–25 mg/l <sub>(<sup>32</sup>)</sub></td> </tr> <tr> <td>Sulphate (SO<sub>4</sub><sup>2-</sup>)</td> <td colspan="2">1,3–2,0 g/l <sub>(<sup>32</sup>)</sub> <sub>(<sup>33</sup>)</sub> <sub>(<sup>34</sup>)</sub> <sub>(<sup>35</sup>)</sub></td> </tr> <tr> <td>Sulphide (S<sup>2-</sup>), easily released</td> <td colspan="2">0,1–0,2 mg/l <sub>(<sup>32</sup>)</sub></td> </tr> <tr> <td>Sulphite (SO<sub>3</sub><sup>2-</sup>)</td> <td colspan="2">1–20 mg/l <sub>(<sup>32</sup>)</sub></td> </tr> <tr> <td rowspan="8">Metals and metalloids</td> <td>As</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cd</td> <td>2–5 µg/l</td> </tr> <tr> <td>Cr</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cu</td> <td>10–50 µg/l</td> </tr> <tr> <td>Hg</td> <td>0,2–3 µg/l</td> </tr> <tr> <td>Ni</td> <td>10–50 µg/l</td> </tr> <tr> <td>Pb</td> <td>10–20 µg/l</td> </tr> <tr> <td>Zn</td> <td>50–200 µg/l</td> </tr> </tbody> </table>	m.	Sedimentation	Suspended solids	Generally applicable	n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable	Substance/Parameter	BAT-AELs		Daily average		Total organic carbon (TOC)	20–50 mg/l <sub>(<sup>30</sup>)</sub> <sub>(<sup>31</sup>)</sub> <sub>(<sup>32</sup>)</sub>		Chemical oxygen demand (COD)	60–150 mg/l <sub>(<sup>30</sup>)</sub> <sub>(<sup>31</sup>)</sub> <sub>(<sup>32</sup>)</sub>		Total suspended solids (TSS)	10–30 mg/l		Fluoride (F <sup>-</sup> )	10–25 mg/l <sub>(<sup>32</sup>)</sub>		Sulphate (SO <sub>4</sub> <sup>2-</sup> )	1,3–2,0 g/l <sub>(<sup>32</sup>)</sub> <sub>(<sup>33</sup>)</sub> <sub>(<sup>34</sup>)</sub> <sub>(<sup>35</sup>)</sub>		Sulphide (S <sup>2-</sup> ), easily released	0,1–0,2 mg/l <sub>(<sup>32</sup>)</sub>		Sulphite (SO <sub>3</sub> <sup>2-</sup> )	1–20 mg/l <sub>(<sup>32</sup>)</sub>		Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l			
m.	Sedimentation	Suspended solids	Generally applicable																																																				
n.	Stripping	Ammonia (NH <sub>3</sub> )	Generally applicable																																																				
Substance/Parameter	BAT-AELs																																																						
	Daily average																																																						
Total organic carbon (TOC)	20–50 mg/l <sub>(<sup>30</sup>)</sub> <sub>(<sup>31</sup>)</sub> <sub>(<sup>32</sup>)</sub>																																																						
Chemical oxygen demand (COD)	60–150 mg/l <sub>(<sup>30</sup>)</sub> <sub>(<sup>31</sup>)</sub> <sub>(<sup>32</sup>)</sub>																																																						
Total suspended solids (TSS)	10–30 mg/l																																																						
Fluoride (F <sup>-</sup> )	10–25 mg/l <sub>(<sup>32</sup>)</sub>																																																						
Sulphate (SO <sub>4</sub> <sup>2-</sup> )	1,3–2,0 g/l <sub>(<sup>32</sup>)</sub> <sub>(<sup>33</sup>)</sub> <sub>(<sup>34</sup>)</sub> <sub>(<sup>35</sup>)</sub>																																																						
Sulphide (S <sup>2-</sup> ), easily released	0,1–0,2 mg/l <sub>(<sup>32</sup>)</sub>																																																						
Sulphite (SO <sub>3</sub> <sup>2-</sup> )	1–20 mg/l <sub>(<sup>32</sup>)</sub>																																																						
Metals and metalloids	As	10–50 µg/l																																																					
	Cd	2–5 µg/l																																																					
	Cr	10–50 µg/l																																																					
	Cu	10–50 µg/l																																																					
	Hg	0,2–3 µg/l																																																					
	Ni	10–50 µg/l																																																					
	Pb	10–20 µg/l																																																					
	Zn	50–200 µg/l																																																					
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p>	CC	There are no waste products as identified by BAT16 caused directly by the combustion process of a CCGT plant. Other wastes arising from the site activities are dealt with according to the waste hierarchy.																																																				

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)															
	<p>(c) waste recycling; (d) other waste recovery (e.g. energy recovery), by implementing an appropriate combination of techniques such as:</p> <table border="1" data-bbox="338 437 1218 1251"> <thead> <tr> <th data-bbox="338 437 533 472">Technique</th> <th data-bbox="533 437 911 472">Description</th> <th data-bbox="911 437 1218 472">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 472 533 679">a .</td> <td data-bbox="533 472 911 679">Generation of gypsum as a by-product</td> <td data-bbox="911 472 1218 679">Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> </tr> <tr> <td data-bbox="338 679 533 887">b .</td> <td data-bbox="533 679 911 887">Recycling or recovery of residues in the construction sector</td> <td data-bbox="911 679 1218 887">Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)</td> </tr> <tr> <td data-bbox="338 887 533 1043">c.</td> <td data-bbox="533 887 911 1043">Energy recovery by using waste in the fuel mix</td> <td data-bbox="911 887 1218 1043">The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel</td> </tr> <tr> <td data-bbox="338 1043 533 1251">d .</td> <td data-bbox="533 1043 911 1251">Preparation of spent catalyst for reuse</td> <td data-bbox="911 1043 1218 1251">Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme</td> </tr> </tbody> </table>	Technique	Description	Applicability	a .	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	b .	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	d .	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme			
Technique	Description	Applicability																	
a .	Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced																	
b .	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)																	
c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel																	
d .	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme																	
17	<p>In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.</p> <table border="1" data-bbox="338 1326 1218 1358"> <thead> <tr> <th data-bbox="338 1326 533 1358">Technique</th> <th data-bbox="533 1326 911 1358">Description</th> <th data-bbox="911 1326 1218 1358">Applicability</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	Noise emissions are reduced by the application of techniques a, b, c and d.	3.4									
Technique	Description	Applicability																	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
	a . Operational measures	These include: — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities	Generally applicable			
	b . Low-noise equipment	This potentially includes compressors, pumps and disks	Generally applicable when the equipment is new or replaced			
	c . Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver. Appropriate obstacles include protection walls, embankments and buildings	Generally applicable to new plants. In the case of existing plants, the insertion of obstacles may be restricted by lack of space			
	d . Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space			
	e . Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant			
<b>Combustion of gaseous fuels</b>						
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	The operator uses technique (a) in BAT 40 as well as techniques; a, b, c, d, f, and g given in BAT 12.	2.3, 1.2 and table S3.4
	<b>Technique</b>	<b>Description</b>	<b>Applicability</b>			

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																																																															
	a. Combined cycle	See description in Section 8.2	<p>Generally applicable to new gas turbines and engines except when operated &lt; 1 500 h/yr.</p> <p>Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability.</p> <p>Not applicable to existing gas turbines and engines operated &lt; 1 500 h/yr.</p> <p>Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns.</p> <p>Not applicable to boilers</p>		The site has an efficiency of 56.55% which is within the BAT AEEL range for existing CCGT plant >600 MWth.																																																																
	<b>BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas</b>																																																																				
	<table border="1"> <thead> <tr> <th rowspan="3">Type of combustion unit</th> <th colspan="5">BAT-AEELs <sup>(136)</sup> <sup>(137)</sup></th> </tr> <tr> <th colspan="2">Net electrical efficiency (%)</th> <th rowspan="2">Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup></th> <th colspan="2">Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup></th> </tr> <tr> <th>New unit</th> <th>Existing unit</th> <th>New unit</th> <th>Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td>39,5–44 <sup>(141)</sup></td> <td>35–44 <sup>(141)</sup></td> <td>56–85 <sup>(141)</sup></td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td>39–42,5</td> <td>38–40</td> <td>78–95</td> <td colspan="2">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MW<sub>th</sub></td> <td>36–41,5</td> <td>33–41,5</td> <td>No BAT-AEEL</td> <td>36,5–41</td> <td>33,5–41</td> </tr> <tr> <td colspan="6" style="text-align: center;"><b>Combined cycle gas turbine (CCGT)</b></td> </tr> <tr> <td>CCGT, 50–600 MW<sub>th</sub></td> <td>53–58,5</td> <td>46–54</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW<sub>th</sub></td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW<sub>th</sub></td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW<sub>th</sub></td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td colspan="2">No BAT-AEEL</td> </tr> </tbody> </table>			Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>					Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>	Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41	<b>Combined cycle gas turbine (CCGT)</b>						CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL		CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL		CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL		CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL				
Type of combustion unit	BAT-AEELs <sup>(136)</sup> <sup>(137)</sup>																																																																				
	Net electrical efficiency (%)		Net total fuel utilisation (%) <sup>(138)</sup> <sup>(139)</sup>		Net mechanical energy efficiency (%) <sup>(139)</sup> <sup>(140)</sup>																																																																
	New unit	Existing unit		New unit	Existing unit																																																																
Gas engine	39,5–44 <sup>(141)</sup>	35–44 <sup>(141)</sup>	56–85 <sup>(141)</sup>	No BAT-AEEL.																																																																	
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																																																	
Open cycle gas turbine, ≥ 50 MW <sub>th</sub>	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																																																
<b>Combined cycle gas turbine (CCGT)</b>																																																																					
CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																																																																	
CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																																																																	
CHP CCGT, 50–600 MW <sub>th</sub>	53–58,5	46–54	65–95	No BAT-AEEL																																																																	
CHP CCGT, ≥ 600 MW <sub>th</sub>	57–60,5	50–60	65–95	No BAT-AEEL																																																																	
41	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in boilers, BAT is to use one or a combination of the techniques given below.			NA	No applicable boiler on site.	2.3																																																															

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																			
	<table border="1"> <thead> <tr> <th data-bbox="338 331 367 352">Technique</th> <th data-bbox="535 331 864 352">Description</th> <th data-bbox="864 331 1218 352">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 368 367 421">a Air and/or fuel staging</td> <td data-bbox="535 368 864 443">See descriptions in Section 8.3. Air staging is often associated with low-NO<sub>x</sub> burners</td> <td data-bbox="864 368 1218 443">Generally applicable</td> </tr> <tr> <td data-bbox="338 448 367 501">b Flue-gas recirculation</td> <td data-bbox="535 448 864 564" rowspan="2">See description in Section 8.3</td> <td data-bbox="864 448 1218 564" rowspan="2"></td> </tr> <tr> <td data-bbox="338 505 367 558">c Low-NO<sub>x</sub> burners (LNB)</td> </tr> <tr> <td data-bbox="338 563 367 724">d Advanced control system</td> <td data-bbox="535 563 864 724">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="864 563 1218 724">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="338 729 367 804">e Reduction of the combustion air temperature</td> <td data-bbox="535 729 864 804" rowspan="3">See description in Section 8.3</td> <td data-bbox="864 729 1218 804">Generally applicable within the constraints associated with the process needs</td> </tr> <tr> <td data-bbox="338 809 367 1011">f Selective non-catalytic reduction (SNCR)</td> <td data-bbox="864 809 1218 1011">Not applicable to combustion plants operated &lt; 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads</td> </tr> <tr> <td data-bbox="338 1016 367 1235">g Selective catalytic reduction (SCR)</td> <td data-bbox="864 1016 1218 1235">Not applicable to combustion plants operated &lt; 500 h/yr. Not generally applicable to combustion plants of &lt; 100 MW<sub>th</sub>. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </tbody> </table>	Technique	Description	Applicability	a Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable	b Flue-gas recirculation	See description in Section 8.3		c Low-NO <sub>x</sub> burners (LNB)	d Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	e Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs	f Selective non-catalytic reduction (SNCR)	Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads	g Selective catalytic reduction (SCR)	Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr				
Technique	Description	Applicability																							
a Air and/or fuel staging	See descriptions in Section 8.3. Air staging is often associated with low-NO <sub>x</sub> burners	Generally applicable																							
b Flue-gas recirculation	See description in Section 8.3																								
c Low-NO <sub>x</sub> burners (LNB)																									
d Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																							
e Reduction of the combustion air temperature	See description in Section 8.3	Generally applicable within the constraints associated with the process needs																							
f Selective non-catalytic reduction (SNCR)		Not applicable to combustion plants operated < 500 h/yr with highly variable boiler loads. The applicability may be limited in the case of combustion plants operated between 500 h/yr and 1 500 h/yr with highly variable boiler loads																							
g Selective catalytic reduction (SCR)		Not applicable to combustion plants operated < 500 h/yr. Not generally applicable to combustion plants of < 100 MW <sub>th</sub> . There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																							
42	<p>In order to prevent or reduce NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1"> <thead> <tr> <th data-bbox="338 1353 501 1374">Technique</th> <th data-bbox="501 1353 920 1374">Description</th> <th data-bbox="920 1353 1218 1374">Applicability</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	From BAT 42, the following techniques apply: a & c. Techniques b and d are not practicable due to gas turbine design, technique e is applicable to supplementary firing in HRSGs which does not	2.3															
Technique	Description	Applicability																							

BAT Conc. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)
	a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		<p>apply at Great Yarmouth power station. Retrofitting SCR is not practicable on a plant with an unknown closure date and is also constrained by the availability of sufficient space and layout of the existing plant.</p> <p>From table 24: As an existing CCGT plant with a thermal input &gt;600 MWth and a net fuel utilisation of &lt;75% the annual limit for NOx is 40 mg/m3 and the daily limit is 50 mg/m3. These limits are only applicable when the DLN system is fully effective. The DLN system premixes the fuel with a large excess of combustion air, upstream of the combustor. The lean premix combustion system is much more complex, and more dependent on precision engineered components, than conventional diffusion flame systems and the NOx can increase over time, across outage cycles, due to degradation of the fuel injection system, air leakage into the combustor and/or instrumentation issues. The NOx emissions are also more sensitive to fluctuations in fuel quality and ambient conditions. For all of these reasons, the top-of-range BAT-AEL values are appropriate.</p> <p>Effective-DLN (E-DLN) is defined as the operating point above which compliance with the Annual NOx and CO ELVs can be achieved with the DLN combustion system. The proposed E-DLN operating point is therefore defined as 294 MWe (equivalent to 70% of full load). As the attached graphs demonstrate CO emissions are compliant with the BREF limits at a lower load, however NOx emissions do not reach their lowest level until a much higher load and therefore the higher E-DLN point is appropriate. Operation between the Minimum Start Up Load (MSUL) and the E-DLN operating point is</p>	
b Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability				
c Dry low-NOx burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed				
d Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design				
e Low-NOx burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants				
f Selective catalytic reduction (SCR)		Not applicable in the case of combustion plants operated < 500 h/yr. Not generally applicable to existing combustion plants of < 100 MWth. Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for				



BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)														
			retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		<p>regulated by specifying an additional Daily ELV for both NO<sub>x</sub> and CO as per current UK arrangements. These additional Daily ELVs apply to all operation above MSUL. The proposed Daily ELVs are 82.5 mg/m<sup>3</sup> (NO<sub>x</sub>) and 110 mg/m<sup>3</sup> (CO) in accordance with the current permit. MSUL is defined as 180 MWh output (43% of full load).</p> <p>Both E-DLN and MSUL are defined in relation to the current combustion and emissions characteristics whilst also taking into account potential future mechanical degradation of the gas turbine and the, as yet unknown, post-2021 operating regimes.</p>															
43	In order to prevent or reduce NO <sub>x</sub> emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	No engines on site.	2.3														
<table border="1"> <thead> <tr> <th data-bbox="322 847 506 879">Technique</th> <th data-bbox="506 847 846 879">Description</th> <th data-bbox="846 847 1227 879">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="322 879 506 1038">a Advanced control system</td> <td data-bbox="506 879 846 1038">See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated &lt; 500 h/yr</td> <td data-bbox="846 879 1227 1038">The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td data-bbox="322 1038 506 1126">b Lean-burn concept</td> <td data-bbox="506 1038 846 1126">See description in Section 8.3. Generally used in combination with SCR</td> <td data-bbox="846 1038 1227 1126">Only applicable to new gas-fired engines</td> </tr> <tr> <td data-bbox="322 1126 506 1206">c Advanced lean-burn concept</td> <td data-bbox="506 1126 846 1206" rowspan="2">See descriptions in Section 8.3</td> <td data-bbox="846 1126 1227 1206">Only applicable to new spark plug ignited engines</td> </tr> <tr> <td data-bbox="322 1206 506 1348">d Selective catalytic reduction (SCR)</td> <td data-bbox="846 1206 1227 1348">Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated &lt; 500 h/yr.</td> </tr> </tbody> </table>							Technique	Description	Applicability	a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines	c Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines	d Selective catalytic reduction (SCR)	Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr.
Technique	Description	Applicability																		
a Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																		
b Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines																		
c Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines																		
d Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr.																		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																																																		
	<table border="1"> <tr> <td data-bbox="338 328 501 440"></td> <td data-bbox="501 328 853 440"></td> <td data-bbox="853 328 1216 440">There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr</td> </tr> </table>			There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																		
		There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr																																																				
44	<p>In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description - See descriptions in Section 8.3.</b></p> <p><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in gas turbines</b></p> <table border="1"> <thead> <tr> <th data-bbox="338 592 685 762" rowspan="2">Type of combustion plant</th> <th data-bbox="685 592 869 762" rowspan="2">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="2" data-bbox="869 592 1216 624">BAT-AELs (mg/Nm<sup>3</sup>) <sup>(142)</sup> <sup>(143)</sup></th> </tr> <tr> <th data-bbox="869 624 1037 762">Yearly average <sup>(144)</sup> <sup>(145)</sup></th> <th data-bbox="1037 624 1216 762">Daily average or average over the sampling period</th> </tr> </thead> <tbody> <tr> <td colspan="4" data-bbox="338 762 1216 794" style="text-align: center;"><b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b></td> </tr> <tr> <td data-bbox="338 802 685 834">New OCGT</td> <td data-bbox="685 802 869 834">≥ 50</td> <td data-bbox="869 802 1037 834">15–35</td> <td data-bbox="1037 802 1216 834">25–50</td> </tr> <tr> <td data-bbox="338 834 685 954">Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated &lt; 500 h/yr</td> <td data-bbox="685 834 869 954">≥ 50</td> <td data-bbox="869 834 1037 954">15–50</td> <td data-bbox="1037 834 1216 954">25–55 <sup>(148)</sup></td> </tr> <tr> <td colspan="4" data-bbox="338 954 1216 986" style="text-align: center;"><b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b></td> </tr> <tr> <td data-bbox="338 994 685 1026">New CCGT</td> <td data-bbox="685 994 869 1026">≥ 50</td> <td data-bbox="869 994 1037 1026">10–30</td> <td data-bbox="1037 994 1216 1026">15–40</td> </tr> <tr> <td data-bbox="338 1026 685 1090">Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td data-bbox="685 1026 869 1090">≥ 600</td> <td data-bbox="869 1026 1037 1090">10–40</td> <td data-bbox="1037 1026 1216 1090">18–50</td> </tr> <tr> <td data-bbox="338 1090 685 1153">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="685 1090 869 1153">≥ 600</td> <td data-bbox="869 1090 1037 1153">10–50</td> <td data-bbox="1037 1090 1216 1153">18–55 <sup>(150)</sup></td> </tr> <tr> <td data-bbox="338 1153 685 1217">Existing CCGT with a net total fuel utilisation of &lt; 75 %</td> <td data-bbox="685 1153 869 1217">50–600</td> <td data-bbox="869 1153 1037 1217">10–45</td> <td data-bbox="1037 1153 1216 1217">35–55</td> </tr> <tr> <td data-bbox="338 1217 685 1281">Existing CCGT with a net total fuel utilisation of ≥ 75 %</td> <td data-bbox="685 1217 869 1281">50–600</td> <td data-bbox="869 1217 1037 1281">25–50 <sup>(151)</sup></td> <td data-bbox="1037 1217 1216 1281">35–55 <sup>(152)</sup></td> </tr> <tr> <td colspan="4" data-bbox="338 1281 1216 1313" style="text-align: center;"><b>Open- and combined-cycle gas turbines</b></td> </tr> <tr> <td data-bbox="338 1313 685 1377">Gas turbine put into operation no later than 27 November 2003, or</td> <td data-bbox="685 1313 869 1377">≥ 50</td> <td data-bbox="869 1313 1037 1377">No BAT-AEL</td> <td data-bbox="1037 1313 1216 1377">60–140 <sup>(153)</sup> <sup>(154)</sup></td> </tr> </tbody> </table>	Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period	<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>				New OCGT	≥ 50	15–35	25–50	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>	<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>				New CCGT	≥ 50	10–30	15–40	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>	<b>Open- and combined-cycle gas turbines</b>				Gas turbine put into operation no later than 27 November 2003, or	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>	CC	CO emissions are reduced as far as possible by optimising combustion. An increase in CO emissions is an indication of possible combustion problems and would be investigated. The indicative yearly average of 30 mg/Nm <sup>3</sup> for existing CCGTs will be met at loads above 180 MW. The existing limits will continue to apply above the MSUL load (currently set at 180 MW but may change once commissioning is complete.)	2.3 and Table S1.6
Type of combustion plant	Combustion plant total rated thermal input (MW <sub>th</sub> )			BAT-AELs (mg/Nm <sup>3</sup> ) <sup>(142)</sup> <sup>(143)</sup>																																																		
		Yearly average <sup>(144)</sup> <sup>(145)</sup>	Daily average or average over the sampling period																																																			
<b>Open-cycle gas turbines (OCGTs) <sup>(146)</sup> <sup>(147)</sup></b>																																																						
New OCGT	≥ 50	15–35	25–50																																																			
Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 <sup>(148)</sup>																																																			
<b>Combined-cycle gas turbines (CCGTs) <sup>(146)</sup> <sup>(149)</sup></b>																																																						
New CCGT	≥ 50	10–30	15–40																																																			
Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50																																																			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 <sup>(150)</sup>																																																			
Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55																																																			
Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 <sup>(151)</sup>	35–55 <sup>(152)</sup>																																																			
<b>Open- and combined-cycle gas turbines</b>																																																						
Gas turbine put into operation no later than 27 November 2003, or	≥ 50	No BAT-AEL	60–140 <sup>(153)</sup> <sup>(154)</sup>																																																			

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																															
	<table border="1" data-bbox="338 331 1216 475"> <tr> <td data-bbox="338 331 685 387">existing gas turbine for emergency use and operated &lt; 500 h/yr</td> <td data-bbox="685 331 869 387"></td> <td data-bbox="869 331 1034 387"></td> <td data-bbox="1034 331 1216 387"></td> </tr> <tr> <td data-bbox="338 387 685 475">Existing gas turbine for mechanical drive applications — All but plants operated &lt; 500 h/yr</td> <td data-bbox="685 387 869 475">≥ 50</td> <td data-bbox="869 387 1034 475">15–50 <sup>(155)</sup></td> <td data-bbox="1034 387 1216 475">25–55 <sup>(156)</sup></td> </tr> </table> <p data-bbox="338 480 1216 555">As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul data-bbox="338 560 1216 1007" style="list-style-type: none"> <li>— New OCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–40 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing OCGT of ≥ 50 MW<sub>th</sub> (excluding turbines for mechanical drive applications): &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of this range will generally be 80 mg/Nm<sup>3</sup> in the case of existing plants that cannot be fitted with dry techniques for NO<sub>x</sub> reduction, or 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— New CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] × EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</li> <li>— Existing CCGT of ≥ 50 MW<sub>th</sub>: &lt; 5–30 mg/Nm<sup>3</sup>. The higher end of this range will generally be 50 mg/Nm<sup>3</sup> for plants that operate at low load.</li> <li>— Existing gas turbines of ≥ 50 MW<sub>th</sub> for mechanical drive applications: &lt; 5–40 mg/Nm<sup>3</sup>. The higher end of the range will generally be 50 mg/Nm<sup>3</sup> when plants operate at low load.</li> </ul> <p data-bbox="338 1011 1216 1067">In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p data-bbox="338 1072 1216 1128"><b>BAT-associated emission levels (BAT-AELs) for NO<sub>x</sub> emissions to air from the combustion of natural gas in boilers and engines</b></p> <table border="1" data-bbox="338 1128 1216 1345"> <thead> <tr> <th data-bbox="338 1128 555 1278" rowspan="3">Type of combustion plant</th> <th colspan="4" data-bbox="555 1128 1216 1160">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th colspan="2" data-bbox="555 1160 819 1216">Yearly average <sup>(157)</sup></th> <th colspan="2" data-bbox="819 1160 1216 1216">Daily average or average over the sampling period</th> </tr> <tr> <th data-bbox="555 1216 658 1278">New plant</th> <th data-bbox="658 1216 819 1278">Existing plant <sup>(158)</sup></th> <th data-bbox="819 1216 981 1278">New plant</th> <th data-bbox="981 1216 1216 1278">Existing plant <sup>(159)</sup></th> </tr> </thead> <tbody> <tr> <td data-bbox="338 1278 555 1310">Boiler</td> <td data-bbox="555 1278 658 1310">10–60</td> <td data-bbox="658 1278 819 1310">50–100</td> <td data-bbox="819 1278 981 1310">30–85</td> <td data-bbox="981 1278 1216 1310">85–110</td> </tr> <tr> <td data-bbox="338 1310 555 1345">Engine <sup>(160)</sup></td> <td data-bbox="555 1310 658 1345">20–75</td> <td data-bbox="658 1310 819 1345">20–100</td> <td data-bbox="819 1310 981 1345">55–85</td> <td data-bbox="981 1310 1216 1345">55–110 <sup>(161)</sup></td> </tr> </tbody> </table> <p data-bbox="338 1350 1216 1374">As an indication, the yearly average CO emission levels will generally be:</p>	existing gas turbine for emergency use and operated < 500 h/yr				Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>	Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )				Yearly average <sup>(157)</sup>		Daily average or average over the sampling period		New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>	Boiler	10–60	50–100	30–85	85–110	Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>			
existing gas turbine for emergency use and operated < 500 h/yr																																			
Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 <sup>(155)</sup>	25–55 <sup>(156)</sup>																																
Type of combustion plant	BAT-AELs (mg/Nm <sup>3</sup> )																																		
	Yearly average <sup>(157)</sup>		Daily average or average over the sampling period																																
	New plant	Existing plant <sup>(158)</sup>	New plant	Existing plant <sup>(159)</sup>																															
Boiler	10–60	50–100	30–85	85–110																															
Engine <sup>(160)</sup>	20–75	20–100	55–85	55–110 <sup>(161)</sup>																															

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	Relevant permit condition (s)																		
	<ul style="list-style-type: none"> <li>— &lt; 5–40 mg/Nm<sup>3</sup> for existing boilers operated ≥ 1 500 h/yr,</li> <li>— &lt; 5–15 mg/Nm<sup>3</sup> for new boilers,</li> <li>— 30–100 mg/Nm<sup>3</sup> for existing engines operated ≥ 1 500 h/yr and for new engines.</li> </ul>																					
45	<p>In order to reduce non-methane volatile organic compounds (NMVOC) and methane (CH<sub>4</sub>) emissions to air from the combustion of natural gas in spark-ignited lean-burn gas engines, BAT is to ensure optimised combustion and/or to use oxidation catalysts.</p> <p><b>Description</b></p> <p>See descriptions in Section 8.3. Oxidation catalysts are not effective at reducing the emissions of saturated hydrocarbons containing less than four carbon atoms.</p> <p><b>BAT-associated emission levels (BAT-AELs) for formaldehyde and CH<sub>4</sub> emissions to air from the combustion of natural gas in a spark-ignited lean-burn gas engine</b></p> <table border="1" data-bbox="338 772 1218 991"> <thead> <tr> <th data-bbox="338 772 757 935" rowspan="3">Combustion plant total rated thermal input (MW<sub>th</sub>)</th> <th colspan="3" data-bbox="757 772 1218 807">BAT-AELs (mg/Nm<sup>3</sup>)</th> </tr> <tr> <th data-bbox="757 807 958 842">Formaldehyde</th> <th colspan="2" data-bbox="958 807 1218 842">CH<sub>4</sub></th> </tr> <tr> <th colspan="3" data-bbox="757 842 1218 877">Average over the sampling period</th> </tr> <tr> <th data-bbox="338 877 757 935"></th> <th data-bbox="757 877 958 935">New or existing plant</th> <th data-bbox="958 877 1070 935">New plant</th> <th data-bbox="1070 877 1218 935">Existing plant</th> </tr> </thead> <tbody> <tr> <td data-bbox="338 935 757 991">≥ 50</td> <td data-bbox="757 935 958 991">5–15 <sup>(162)</sup></td> <td data-bbox="958 935 1070 991">215–500 <sup>(163)</sup></td> <td data-bbox="1070 935 1218 991">215–560 <sup>(162)</sup> <sup>(163)</sup></td> </tr> </tbody> </table>	Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )			Formaldehyde	CH <sub>4</sub>		Average over the sampling period				New or existing plant	New plant	Existing plant	≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>	NA	No spark ignition engines on site.	
Combustion plant total rated thermal input (MW <sub>th</sub> )	BAT-AELs (mg/Nm <sup>3</sup> )																					
	Formaldehyde		CH <sub>4</sub>																			
	Average over the sampling period																					
	New or existing plant	New plant	Existing plant																			
≥ 50	5–15 <sup>(162)</sup>	215–500 <sup>(163)</sup>	215–560 <sup>(162)</sup> <sup>(163)</sup>																			

## 6. Emissions to Water

The consolidated permit incorporates the current discharge to controlled waters identified as W1.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

Currently water used within the cooling water system is estuarine and not suitable to be used in other processes. The site is direct cooled and therefore water use for cooling is non consumptive. Process water usage including boiler feed water is optimised through minimisation of blowdown from the water steam cycle. Based on these scenarios, any recovered water would have an adverse impact on the operation of the water treatment plant and may lead to increased chemical usage and energy use.

All waste water streams are segregated, treated and where necessary monitored separately prior to discharge; Effluent from the turbine hall discharges to sewer via an oil interceptor in accordance with a separate trade effluent consent and is monitored in accordance with that consent.

Other site drainage including boiler blowdown and surface water drains are collected and passed through oil separators to the stormwater basin prior to discharge to the controlled water system. Cooling water quality is continuously monitored prior to discharge via the stations discharge point W1.

## 7 Additional IED Chapter II requirements:

Condition 3.1.4 relating to protection of soil, groundwater and groundwater monitoring, has been added in compliance with IED requirements. Conditions 4.3.1 and 4.3.2 relating to notifications have been amended in compliance with IED requirements.

In the event of a black out National Grid would call on combustion plant to operate and may require them to do so outside their permitted conditions. We have dedicated black start plant and they are permitted to run as such but this scenario is relevant to the rest of the large combustion plant which could be called depending on the circumstances.

A risk assessment will be carried out by Energy UK/Joint Environmental Programme on behalf of Large Combustion Plant connected to the National Transmission System. Air emissions modelling will be based on generic black start scenarios to establish whether they have the potential to have local impact on the environment or not (on a national basis). If the modelling demonstrates that no significant impacts are likely, the plant can operate under condition 2.3.7. This conditions allows the hourly ELVs for plants operating under a black

start instruction to be discounted for the purpose of reporting. We would also require there to be a procedure in place for minimisation of emissions in the case of a black start event and for reporting in the event of a black start. This modelling and the procedures have not been agreed in advance of the issue of the permit review and therefore a condition linking back to an improvement condition have been included in the permit.

## 8 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
<b>Receipt of application</b>	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential. The decision was taken in accordance with our guidance on confidentiality.
<b>The site</b>	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
<b>Operating techniques</b>	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
<b>Permit conditions</b>	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.5 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> <li>• Nitrogen dioxide</li> <li>• Carbon monoxide</li> <li>• Sulphur dioxide</li> <li>• Dust</li> </ul> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
<b>Operator competence</b>	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
<b>Growth Duty</b>	
Section 108 Deregulation Act 2015 – Growth duty	<p>We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.</p> <p>Paragraph 1.3 of the guidance says:</p>



	<p>“The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>
--	--