

Environment Agency

Review of an Environmental Permit for an Installation subject to Chapter II of the Industrial Emissions Directive under the Environmental Permitting (England & Wales) Regulations 2016

Decision document recording our decision-making process following review of a permit

The Permit number is: EPR/NP3033RD

The Operator is: Uniper UK Limited

The Installation is: Cottam Development Centre Power Station

This Variation Notice number is: EPR/NP3033RD/V005

What this document is about

Article 21(3) of the Industrial Emissions Directive (IED) requires the Environment Agency to review conditions in permits that it has issued and to ensure that the permit delivers compliance with relevant standards, within four years of the publication of updated decisions on best available techniques (BAT) conclusions.

We have reviewed the permit for this installation against the revised BAT Conclusions for large combustion plant published on 17th August 2017. This is our decision document, which explains the reasoning for the consolidated variation notice that we are issuing.

It explains how we have reviewed and considered the techniques used by the Operator in the operation and control of the plant and activities of the installation. This review has been undertaken with reference to the decision made by the European Commission establishing best available techniques (BAT) conclusions ('BAT Conclusions') for large combustion plant as detailed in document reference IEDC-7-1. It is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position. It also provides a justification for the inclusion of any specific conditions in the permit that are in addition to those included in our generic permit template.

As well as considering the review of the operating techniques used by the Operator for the operation of the plant and activities of the installation, the consolidated variation notice takes into account and brings together in a single document all previous variations that relate to the original permit

issued. It also modernises the entire permit to reflect the conditions contained in our current generic permit template.

The introduction of new template conditions makes the Permit consistent with our current general approach and philosophy and with other permits issued to installations in this sector. Although the wording of some conditions has changed, while others have been removed because of the new regulatory approach, it does not reduce the level of environmental protection achieved by the Permit in any way. In this document we therefore address only our determination of substantive issues relating to the new BAT Conclusions.

This is our record of our decision-making process and shows how we have taken into account all relevant factors in reaching our position.

Throughout this document we will use a number of expressions. These are as referred to in the glossary and have the same meaning as described in “Schedule 6 Interpretation” of the Permit.

We try to explain our decision as accurately, comprehensively and plainly as possible. We would welcome any feedback as to how we might improve our decision documents in future. A lot of technical terms and acronyms are inevitable in a document of this nature: we provide a glossary of acronyms near the front of the document, for ease of reference.

How this document is structured

Glossary of terms

- 1 Our decision
- 2 How we reached our decision
- 2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant
- 2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document
- 2.3 Summary of how we considered the responses from public consultation.
- 3 The legal framework
- 4 Key Issues
- 5 Decision checklist regarding relevant BAT Conclusions
- 6 Review and assessment of derogation requests made by the operator in relation to BAT Conclusions which include an associated emission level (AEL) value
- 7 Emissions to Water
- 8 Additional IED Chapter II requirements
- 9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

Glossary of acronyms used in this document

(Please note that this glossary is standard for our decision documents and therefore not all these acronyms are necessarily used in this document.)

APC	Air Pollution Control
BAT	Best Available Technique(s)
BAT-AEEL	BAT Associated Energy Efficiency Level
BAT-AEL	BAT Associated Emission Level
BATc	BAT conclusion
BREF	Best available techniques reference document
CCGT	Combined Cycle Gas Turbine
CEM	Continuous emissions monitor
CHP	Combined heat and power
CV	Calorific value
DAA	Directly associated activity – Additional activities necessary to be carried out to allow the principal activity to be carried out
DLN	Dry Low NOx burners
DLN-E	Dry Low NOx effective
EIONET	European environment information and observation network is a partnership network of the European Environment Agency
ELV	Emission limit value derived under BAT or an emission limit value set out in IED
EMS	Environmental Management System
EPR	Environmental Permitting (England and Wales) Regulations 2016 (SI 2010 No. 1154)
EWC	European waste catalogue
IC	Improvement Condition
IED	Industrial Emissions Directive (2010/75/EU)
IPPCD	Integrated Pollution Prevention and Control Directive (2008/1/EC) – now superseded by IED
LCP	Large Combustion Plant subject to Chapter III of IED
MSUL/MSDL	Minimum start up load/minimum shut-down load
NOx	Oxides of nitrogen (NO plus NO ₂ expressed as NO ₂)
NPV	Net Present Value
OCGT	Open Cycle Gas Turbine
PHE	Public Health England
SAC	Special Area of Conservation
SGN	Sector guidance note
TGN	Technical guidance note
TNP	Transitional National Plan
TOC	Total Organic Carbon
WFD	Water Framework Directive (2000/60/EC)

1 Our decision

We have decided to issue the consolidated variation notice to the Operator. This will allow it to continue to operate the Installation, subject to the conditions in the consolidated variation notice.

We consider that, in reaching that decision, we have taken into account all relevant considerations and legal requirements and that the varied permit will ensure that a high level of protection is provided for the environment and human health.

The consolidated variation notice contains many conditions taken from our standard Environmental Permit template including the relevant Annexes. We developed these conditions in consultation with industry, having regard to the legal requirements of the Environmental Permitting Regulations and other relevant legislation. This document does not therefore include an explanation for these standard conditions. Where they are included in the Notice, we have considered the techniques identified by the operator for the operation of their installation, and have accepted that the details are sufficient and satisfactory to make those standard conditions appropriate. This document does, however, provide an explanation of our use of “tailor-made” or installation-specific conditions, or where our Permit template provides two or more options.

2 How we reached our decision

2.1 Requesting information to demonstrate compliance with BAT Conclusions for Large Combustion Plant

We issued a Notice under Regulation 61(1) of the Environmental Permitting (England and Wales) Regulations 2016 (a Regulation 61 Notice) on 1st May 2018 requiring the Operator to provide information to demonstrate how the operation of their installation currently meets, or will subsequently meet, the revised standards described in the large combustion plant BAT Conclusions document. The Notice also required that where the revised standards are not currently met, the operator should provide information that:

- Describes the techniques that will be implemented before 17th August 2021, which will then ensure that operations meet the revised standard, or
- Justifies why standards will not be met by 17th August 2021, and confirmation of the date when the operation of those processes will cease within the installation or an explanation of why the revised BAT standard is not applicable to those processes, or
- Justifies why an alternative technique will achieve the same level of environmental protection equivalent to the revised standard described in the BAT Conclusions.

Where the Operator proposed that they were not intending to meet a BAT standard that also included a BAT Associated Emission Level (BAT AEL) described in the BAT Conclusions Document, the Regulation 61 Notice requested that the Operator make a formal request for derogation from compliance with that AEL (as provisioned by Article 15(4) of IED). In this circumstance, the Notice identified that any such request for derogation must be supported and justified by sufficient technical and commercial information that would enable us to determine acceptability of the derogation request.

The Regulation 61 Notice response from the Operator was received on 05/11/2018, with email responses on the 23/04/2019 with respect to a typographical error changing the stated thermal input from 419MWe to 435MWe, and further clarifications on thermal input when in OCGT and limits applied when in OCGT. A request for information regarding the Energy efficiency of the plant received 10/07/19. .

2.2 Review of our own information in respect to the capability of the installation to meet revised standards included in the BAT Conclusions document

Based on our records and previous regulatory activities with the facility we have no reason to consider that the operator will not be able to comply with the conditions that we include in the permit.

3 The legal framework

The consolidated variation notice will be issued, under Regulation 20 of the EPR. The Environmental Permitting regime is a legal vehicle which delivers most of the relevant legal requirements for activities falling within its scope. In particular, the regulated facility is:

- an *installation* as described by the IED;
- subject to aspects of other relevant legislation which also have to be addressed.

We consider that, the consolidated variation notice will ensure that the operation of the Installation complies with all relevant legal requirements and that a high level of protection will be delivered for the environment and human health.

We explain how we have addressed specific statutory requirements more fully in the rest of this document.

4 The key issues

The key issues arising during this permit review are:

- Emissions to air and the emission limits applied to the plant.
- The energy efficiency levels associated with the Best Available Techniques (BAT-AEELs)

We therefore describe how we determined these issues in most detail in the relevant sections of this document.

4.1 Emissions to air and the emission limits applied to the plant

A number of general principles were applied during the permit review. These included:

- The upper value of the BAT AELs ranges specified were used unless use of the tighter limit was justified.
- The principle of no backsliding where if existing limits in the permit were already tighter than those specified in the BREF, the existing permit limits were retained.
- Where a limit was specified in both IED Annex V and the BAT Conclusions for a particular reference period, the tighter limit was applied and in the majority of cases this was from the BAT Conclusions.
- Where AELs are indicative in the BAT Conclusions, these were applied unless adequate justification was provided by the operator to demonstrate that an alternative limit was more appropriate.
- For gas turbines where the IED specified that limits applied over 70% load and the BAT Conclusions specified that AELs applied when dry low NO_x is effective (DLN-E), we have used DLN-E as a default across all monitoring requirements for NO_x and CO.

The LCP on site consists of 1 x 755, MWth, CCGT gas turbine burning natural gas, the plant also has the capacity to run in OCGT for a limit of <1500 hrs per year.

The plant was put into operation before IED came into force and therefore the existing limits in the permit are from Part 1 of IED Annex V applicable to existing plant.

The ELVs and AELs are based on the following operating regime:

- <1500 hours operation in OCGT
- Unlimited hours operation in CCGT

The same limits are applied to both operating regimes as the operator has stated they can meet the limits in both cycles.

The following tables outline the limits that have been incorporated into the permit for LCP100 where these were derived from and the reference periods at which they apply. The emission limits refer to concentrations, expressed as mass of emitted substance per volume of flue-gas under the following standard conditions: dry gas at a temperature of 273,15 K, pressure of 101,3 kPa and 15% volume reference oxygen concentration if flue gases. The emission limits and monitoring requirements have been incorporated into Schedule 3 of the permit.

By the end of the TNP on 30 June 2020, as a minimum plant must meet the limits set out in Annex V of the Industrial Emission Directive subject to BAT assessment and the principle of no backsliding. From the implementation date of the BAT Conclusion in 2021 the relevant AELs will also apply. The Operator applied for an uplift in NO_x ELV's (Annual and Daily) via Note 8 of Table 24 in the BATc document, they supplied documented evidence of the energy efficiency for the plant, COTTAM DEVELOPMENT CENTRE: OPEN CYCLE & COMBINED CYCLE PERFORMANCE TESTS JUNE & SEPTEMBER 2018, we agree with the report and have implemented the uplift.

NO _x limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 25 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60	42	BREF	MSUL/MSDL to baseload	Continuous
Monthly	100	None	50	IED	MSUL/MSDL to baseload	
Daily	110	85	52.5	BREF	MSUL/MSDL to baseload	
95 th %ile of hr means	200	None	60	IED	MSUL/MSDL to baseload	

CO limits (mg/Nm ³)						
Averaging	IED (Annex V Part 2) - New	BREF (Table 25 BAT-c)	Expected permit limits	Basis	Limits apply	Monitoring
Annual	None	60	50	BREF	MSUL/MSDL to baseload	Continuous
Monthly	100	None	50	IED	MSUL/MSDL to baseload	
Daily	110	85	110	IED	MSUL/MSDL to baseload	
95 th %ile of hr means	200	None	50	IED	MSUL/MSDL to baseload	

4.2 The energy efficiency levels associated with the Best Available Techniques Conclusions

An energy efficiency level associated with the best available techniques (BAT-AEEL) refers to the ratio between the combustion unit's net energy output(s) and the combustion unit's fuel/feedstock energy input at actual unit design. The net energy output(s) is determined at the combustion unit boundaries, including auxiliary systems (e.g. flue-gas treatment systems), and for the unit operated at full load.

The table below sets out the BAT-AEELs specified in the LCP BAT Conclusions for the large combustion plant on the site and the energy efficiency levels confirmed through the Regulation 61 notice response. The evidence provided to demonstrate that the AEELs are met was in the form of a report, COTTAM DEVELOPMENT CENTRE, Open cycle and combined Cycle performance tests, June & September 2018. We consider this plant is BAT in relation to the AEELs.

BAT AEELs (%)			Plant efficiency (%)		
Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency	Net electrical efficiency	Net total fuel utilisation	Net mechanical efficiency
LCP100: unit description from the AEEL table					
50-60	No BAT-AEEL	No BAT-AEEL	57.6	NA	NA

5 Decision checklist regarding relevant BAT Conclusions

BAT Conclusions for large combustion plant, were published by the European Commission on 17th August 2017. There are 75 BAT Conclusions. Only the BAT Conclusions relevant to the particular fuel type used on site have been replicated below.

This annex provides a record of decisions made in relation to each relevant BAT Conclusion applicable to the installation. This annex should be read in conjunction with the Consolidated Variation Notice.

The overall status of compliance with the BAT conclusion is indicated in the table as:

NA	Not Applicable
CC	Currently Compliant
FC	Compliant in the future (within 4 years of publication of BAT conclusions)
NC	Not Compliant
PC	Partially Compliant

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
General			
1	<p>In order to improve the overall environmental performance, BAT is to implement and adhere to an environmental management system (EMS) that incorporates all of the following features:</p> <ul style="list-style-type: none"> i. commitment of the management, including senior management; ii. definition of an environmental policy that includes the continuous improvement of the installation by the management; iii. planning and establishing the necessary procedures, objectives and targets, in conjunction with financial planning and investment; iv. implementation of procedures <ul style="list-style-type: none"> (a) Structure and responsibility (b) Training (c) Communication (d) Employee involvement (e) Documentation (f) Efficient process control (g) Maintenance programmes (h) Emergency preparedness and response (i) Safeguarding compliance with environmental legislation v. checking performance and taking corrective action, paying particular attention to: <ul style="list-style-type: none"> (a) monitoring and measurement (see also the Reference Document on the General Principles of Monitoring) (b) corrective and preventive action (c) maintenance of records (d) independent (where practicable) internal and external auditing in order to determine whether or not the EMS conforms to planned arrangements and has been properly implemented and maintained; vi. review of the EMS and its continuing suitability, adequacy and effectiveness by senior management; vii. following the development of cleaner technologies; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; viii. consideration for the environmental impacts from the eventual decommissioning of the installation at the stage of designing a new plant, and throughout its operating life; ix. application of sectoral benchmarking on a regular basis. <p>Etc - see BAT Conclusions</p>	CC	The operator's EMS is accredited to ISO14001 and is consistent with the requirements of BAT 1.

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement													
	Applicability. The scope (e.g. level of detail) and nature of the EMS (e.g. standardised or non-standardised) will generally be related to the nature, scale and complexity of the installation, and the range of environmental impacts it may have.															
2	BAT is to determine the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the gasification, IGCC and/or combustion units by carrying out a performance test at full load (1), according to EN standards, after the commissioning of the unit and after each modification that could significantly affect the net electrical efficiency and/or the net total fuel utilisation and/or the net mechanical energy efficiency of the unit. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.	FC	CDC has installed the latest software package and associated equipment from the OEM (original equipment manufacturer) Service Pack Seven this ensures that CDC is operating at the optimum efficiency where possible. Following the SP7 upgrade, the ISO Base load output is now 435MWe, with an efficiency of 57.6%.													
3	<p>BAT is to monitor key process parameters relevant for emissions to air and water including those given below.</p> <table border="1" data-bbox="320 778 1400 1026"> <thead> <tr> <th data-bbox="320 778 656 810">Stream</th> <th data-bbox="656 778 1059 810">Parameter(s)</th> <th data-bbox="1059 778 1400 810">Monitoring</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 810 656 970" rowspan="3">Flue-gas</td> <td data-bbox="656 810 1059 874">Flow</td> <td data-bbox="1059 810 1400 874">Periodic or continuous determination</td> </tr> <tr> <td data-bbox="656 874 1059 938">Oxygen content, temperature, and pressure</td> <td data-bbox="1059 874 1400 938">Periodic or continuous measurement</td> </tr> <tr> <td data-bbox="656 938 1059 970">Water vapour content⁽²⁾</td> <td data-bbox="1059 938 1400 970"></td> </tr> <tr> <td data-bbox="320 970 656 1026">Waste water from flue-gas treatment</td> <td data-bbox="656 970 1059 1026">Flow, pH, and temperature</td> <td data-bbox="1059 970 1400 1026">Continuous measurement</td> </tr> </tbody> </table>	Stream	Parameter(s)	Monitoring	Flue-gas	Flow	Periodic or continuous determination	Oxygen content, temperature, and pressure	Periodic or continuous measurement	Water vapour content ⁽²⁾		Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement	CC	Cottam Development Centre monitors all relevant parameters as laid out in the BAT conclusions document for Combined Cycle Gas Turbines firing natural gas through compliance with its environmental permit. This includes monitoring flow, oxygen content, temperature, pressure, and water vapour for the function of its CEMS equipment in line with the EN14181 standard. CDC does not use FGD therefore, BAT techniques for this process are not relevant to CDC.
Stream	Parameter(s)	Monitoring														
Flue-gas	Flow	Periodic or continuous determination														
	Oxygen content, temperature, and pressure	Periodic or continuous measurement														
	Water vapour content ⁽²⁾															
Waste water from flue-gas treatment	Flow, pH, and temperature	Continuous measurement														
4	<p>BAT is to monitor emissions to air with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.</p> <table border="1" data-bbox="320 1153 1400 1342"> <thead> <tr> <th data-bbox="320 1153 461 1273">Substance/Parameter</th> <th data-bbox="461 1153 752 1273">Fuel/Process/Type of combustion plant</th> <th data-bbox="752 1153 898 1273">Combustion plant total rated thermal input</th> <th data-bbox="898 1153 1059 1273">Standard(s)⁽⁴⁾</th> <th data-bbox="1059 1153 1263 1273">Minimum monitoring frequency⁽⁵⁾</th> <th data-bbox="1263 1153 1400 1273">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1273 461 1342">NH₃</td> <td data-bbox="461 1273 752 1342">— When SCR and/or SNCR is used</td> <td data-bbox="752 1273 898 1342">All sizes</td> <td data-bbox="898 1273 1059 1342">Generic EN standards</td> <td data-bbox="1059 1273 1263 1342">Continuous⁽⁶⁾⁽⁷⁾</td> <td data-bbox="1263 1273 1400 1342">BAT 7</td> </tr> </tbody> </table>	Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with	NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7	NA	No SCR/SNCR employed on site	
Substance/Parameter	Fuel/Process/Type of combustion plant	Combustion plant total rated thermal input	Standard(s) ⁽⁴⁾	Minimum monitoring frequency ⁽⁵⁾	Monitoring associated with											
NH ₃	— When SCR and/or SNCR is used	All sizes	Generic EN standards	Continuous ⁽⁶⁾ ⁽⁷⁾	BAT 7											

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	NO _x	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 	All sizes	Generic EN standards	Continuous ₍₆₎ (8)	BAT 20 BAT 24 BAT 28 BAT 32 BAT 37 BAT 41 BAT 42 BAT 43 BAT 47 BAT 48 BAT 56 BAT 64 BAT 65 BAT 73	CC	Cottam Development Centre station meets the monitoring requirements that are relevant to natural gas fired turbines as set out in BAT4. These being NO _x and CO, and O ₂ for correction purposes, as set out in the current environmental permit for CDC. Emissions of these species is on a continuous basis and the continuous emission monitors meet the required EN standard this being EN14181.
N ₂ O	<ul style="list-style-type: none"> — Coal and/or lignite in circulating fluidised bed boilers — Solid biomass and/or peat in circulating fluidised bed boilers 	All sizes	EN 14792	Once every year ₍₉₎	BAT 53	NA		
CO	<ul style="list-style-type: none"> — Coal and/or lignite including waste co-incineration — Solid biomass and/or peat including waste co-incineration — HFO- and/or gas-oil-fired boilers and engines — Gas-oil-fired gas turbines 	All sizes	Generic EN standards	Continuous ₍₆₎ (8)	BAT 20 BAT 24 BAT 28 BAT 33 BAT 38 BAT 44 BAT 49 BAT 56 BAT 64 BAT 65 BAT 73			

BAT Concn. Number	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		<ul style="list-style-type: none"> — Natural-gas-fired boilers, engines, and turbines — Iron and steel process gases — Process fuels from the chemical industry — IGCC plants 					CC	The site monitors CO as required by BAT 4 for natural gas fired turbines. Monitoring is carried out continuously in accordance with EN14181.
		Combustion plants on offshore platforms	All sizes	EN 15058	Once every year ⁽⁹⁾	BAT 54		
SO ₂		<ul style="list-style-type: none"> — Coal and/or lignite incl waste co-incineration — Solid biomass and/or peat incl waste co-incineration — HFO- and/or gas-oil-fired boilers — HFO- and/or gas-oil-fired engines — Gas-oil-fired gas turbines — Iron and steel process gases — Process fuels from the chemical industry in boilers — IGCC plants 	All sizes	Generic EN standards and EN 14791	Continuous ⁽⁶⁾ ⁽¹¹⁾ ⁽¹²⁾	BAT 21 BAT 25 BAT 29 BAT 34 BAT 39 BAT 50 BAT 57 BAT 66 BAT 67 BAT 74	NA	CCGT fired on Natural gas.
SO ₃		— When SCR is used	All sizes	No EN standard available	Once every year	—	NA	
Gaseous chlorides, expressed as HCl		<ul style="list-style-type: none"> — Coal and/or lignite — Process fuels from the chemical industry in boilers 	All sizes	EN 1911	Once every three months ⁽⁶⁾ ⁽¹³⁾ ⁽¹⁴⁾	BAT 21 BAT 57	NA	
		— Solid biomass and/or peat	All sizes	Generic EN standards	Continuous ⁽¹⁵⁾ ⁽¹⁶⁾	BAT 25		

BAT Concn. Numbe r	Summary of BAT Conclusion requirement						Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement		
		—	≥ 300 MW _{th}	EN 14385	Once every three months ₍₁₉₎ ₍₁₃₎		NA			
		— IGCC plants	≥ 100 MW _{th}	EN 14385	Once every year ₍₁₈₎	BAT 75				
	Hg	— Coal and/or lignite including waste co- incineration	< 300 MW _{th}	EN 13211	Once every three months ₍₁₃₎ ₍₂₀₎	BAT 23				
			≥ 300 MW _{th}	Generic EN standards and EN 14884	Continuous ₍₁₆₎ ₍₂₁₎					
		— Solid biomass and/or peat	All sizes	EN 13211	Once every year ₍₂₂₎	BAT 27				
		— Waste co-incineration with solid biomass and/or peat	All sizes	EN 13211	Once every three months ₍₁₃₎	BAT 70				
		— IGCC plants	≥ 100 MW _{th}	EN 13211	Once every year ₍₂₃₎	BAT 75				
	TVOC	— HFO- and/or gas-oil- fired engines	All sizes	EN 12619	Once every six months ₍₁₃₎	BAT 33 BAT 59			NA	
		— Process fuels from chemical industry in boilers								
		— Waste co-incineration with coal, lignite, solid biomass and/or peat	All sizes	Generic EN standards	Continuous	BAT 71				
	Formaldehyde	— Natural-gas in spark- ignited lean-burn gas and dual fuel engines	All sizes	No EN standard available	Once every year	BAT 45	NA			
	CH ₄	— Natural-gas-fired engines	All sizes	EN ISO 25139	Once every year ₍₂₄₎	BAT 45	NA			
	PCDD/F	— Process fuels from chemical industry in boilers	All sizes	EN 1948-1, EN 1948-2, EN 1948-3	Once every six months ₍₁₃₎ ₍₂₅₎	BAT 59 BAT 71	NA			
5	BAT is to monitor emissions to water from flue-gas treatment with at least the frequency given below and in accordance with EN standards. If EN standards are not available, BAT is to use ISO, national or other international standards that ensure the provision of data of an equivalent scientific quality.						NA	No Flue gas treatment on site.		

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																									
	<table border="1"> <thead> <tr> <th data-bbox="331 363 636 448">Substance/Parameter</th> <th data-bbox="636 363 969 448">Standard(s)</th> <th data-bbox="969 363 1189 448">Minimum monitoring frequency</th> <th data-bbox="1189 363 1397 448">Monitoring associated with</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 448 636 507">Total organic carbon (TOC)₍₂₆₎</td> <td data-bbox="636 448 969 507">EN 1484</td> <td data-bbox="969 448 1189 507" rowspan="10">Once every month</td> <td data-bbox="1189 448 1397 507" rowspan="10">BAT 15</td> </tr> <tr> <td data-bbox="331 507 636 566">Chemical oxygen demand (COD)₍₂₆₎</td> <td data-bbox="636 507 969 566">No EN standard available</td> </tr> <tr> <td data-bbox="331 566 636 603">Total suspended solids (TSS)</td> <td data-bbox="636 566 969 603">EN 872</td> </tr> <tr> <td data-bbox="331 603 636 639">Fluoride (F⁻)</td> <td data-bbox="636 603 969 639">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 639 636 676">Sulphate (SO₄²⁻)</td> <td data-bbox="636 639 969 676">EN ISO 10304-1</td> </tr> <tr> <td data-bbox="331 676 636 713">Sulphide, easily released (S²⁻)</td> <td data-bbox="636 676 969 713">No EN standard available</td> </tr> <tr> <td data-bbox="331 713 636 750">Sulphite (SO₃²⁻)</td> <td data-bbox="636 713 969 750">EN ISO 10304-3</td> </tr> <tr> <td data-bbox="331 750 573 986">Metals and metalloids</td> <td data-bbox="573 750 969 986"> <table border="1"> <tbody> <tr> <td data-bbox="573 750 636 778">As</td> <td data-bbox="636 750 969 825" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="573 778 636 807">Cd</td> </tr> <tr> <td data-bbox="573 807 636 836">Cr</td> </tr> <tr> <td data-bbox="573 836 636 865">Cu</td> </tr> <tr> <td data-bbox="573 865 636 893">Ni</td> </tr> <tr> <td data-bbox="573 893 636 922">Pb</td> </tr> <tr> <td data-bbox="573 922 636 951">Zn</td> </tr> <tr> <td data-bbox="573 986 636 1061">Hg</td> <td data-bbox="636 986 969 1061">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> </tbody> </table> </td> <td data-bbox="1189 986 1397 1061"></td> </tr> <tr> <td data-bbox="331 1061 636 1150">Chloride (Cl⁻)</td> <td data-bbox="636 1061 969 1150">Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)</td> <td data-bbox="969 1061 1189 1150"></td> <td data-bbox="1189 1061 1397 1150">—</td> </tr> <tr> <td data-bbox="331 1150 636 1187">Total nitrogen</td> <td data-bbox="636 1150 969 1187">EN 12260</td> <td data-bbox="969 1150 1189 1187"></td> <td data-bbox="1189 1150 1397 1187">—</td> </tr> </tbody> </table>	Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with	Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15	Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available	Total suspended solids (TSS)	EN 872	Fluoride (F ⁻)	EN ISO 10304-1	Sulphate (SO ₄ ²⁻)	EN ISO 10304-1	Sulphide, easily released (S ²⁻)	No EN standard available	Sulphite (SO ₃ ²⁻)	EN ISO 10304-3	Metals and metalloids	<table border="1"> <tbody> <tr> <td data-bbox="573 750 636 778">As</td> <td data-bbox="636 750 969 825" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="573 778 636 807">Cd</td> </tr> <tr> <td data-bbox="573 807 636 836">Cr</td> </tr> <tr> <td data-bbox="573 836 636 865">Cu</td> </tr> <tr> <td data-bbox="573 865 636 893">Ni</td> </tr> <tr> <td data-bbox="573 893 636 922">Pb</td> </tr> <tr> <td data-bbox="573 922 636 951">Zn</td> </tr> <tr> <td data-bbox="573 986 636 1061">Hg</td> <td data-bbox="636 986 969 1061">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> </tbody> </table>	As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr	Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)		Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—	Total nitrogen	EN 12260		—		
Substance/Parameter	Standard(s)	Minimum monitoring frequency	Monitoring associated with																																									
Total organic carbon (TOC) ₍₂₆₎	EN 1484	Once every month	BAT 15																																									
Chemical oxygen demand (COD) ₍₂₆₎	No EN standard available																																											
Total suspended solids (TSS)	EN 872																																											
Fluoride (F ⁻)	EN ISO 10304-1																																											
Sulphate (SO ₄ ²⁻)	EN ISO 10304-1																																											
Sulphide, easily released (S ²⁻)	No EN standard available																																											
Sulphite (SO ₃ ²⁻)	EN ISO 10304-3																																											
Metals and metalloids	<table border="1"> <tbody> <tr> <td data-bbox="573 750 636 778">As</td> <td data-bbox="636 750 969 825" rowspan="7">Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)</td> </tr> <tr> <td data-bbox="573 778 636 807">Cd</td> </tr> <tr> <td data-bbox="573 807 636 836">Cr</td> </tr> <tr> <td data-bbox="573 836 636 865">Cu</td> </tr> <tr> <td data-bbox="573 865 636 893">Ni</td> </tr> <tr> <td data-bbox="573 893 636 922">Pb</td> </tr> <tr> <td data-bbox="573 922 636 951">Zn</td> </tr> <tr> <td data-bbox="573 986 636 1061">Hg</td> <td data-bbox="636 986 969 1061">Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)</td> </tr> </tbody> </table>			As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)	Cd	Cr			Cu	Ni	Pb	Zn	Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																													
As	Various EN standards available (e.g. EN ISO 11885 or EN ISO 17294-2)																																											
Cd																																												
Cr																																												
Cu																																												
Ni																																												
Pb																																												
Zn																																												
Hg	Various EN standards available (e.g. EN ISO 12846 or EN ISO 17852)																																											
Chloride (Cl ⁻)	Various EN standards available (e.g. EN ISO 10304-1 or EN ISO 15682)		—																																									
Total nitrogen	EN 12260		—																																									
6	<p data-bbox="331 1217 1397 1297">In order to improve the general environmental performance of combustion plants and to reduce emissions to air of CO and unburnt substances, BAT is to ensure optimised combustion and to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="331 1297 1397 1334"> <thead> <tr> <th data-bbox="331 1297 539 1334">Technique</th> <th data-bbox="539 1297 943 1334">Description</th> <th data-bbox="943 1297 1397 1334">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="331 1334 539 1382"></td> <td data-bbox="539 1334 943 1382"></td> <td data-bbox="943 1334 1397 1382"></td> </tr> </tbody> </table>	Technique	Description	Applicability				CC	Cottam Development Centre is compliant with BAT 6 by using a combination of techniques B and C. The station completes regular maintenance as suggested by the OEM. Engine mapping is also carried out as part of the Return to Service procedure after																																			
Technique	Description	Applicability																																										

BAT Concn. Number	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	a.	Fuel blending and mixing	Ensure stable combustion conditions and/or reduce the emission of pollutants by mixing different qualities of the same fuel type	Generally applicable		every outage and periodically as part of ongoing maintenance when this is required. It also has an advanced control system which measures multiple metrics such as gas preheat temperatures and burner status through the DCS.
b.	Maintenance of the combustion system	Regular planned maintenance according to suppliers' recommendations				
c.	Advanced control system	See description in Section 8.1	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system			
d.	Good design of the combustion equipment	Good design of furnace, combustion chambers, burners and associated devices	Generally applicable to new combustion plants			
e.	Fuel choice	Select or switch totally or partially to another fuel(s) with a better environmental profile (e.g. with low sulphur and/or mercury content) amongst the available fuels, including in start-up situations or when back-up fuels are used	Applicable within the constraints associated with the availability of suitable types of fuel with a better environmental profile as a whole, which may be impacted by the energy policy of the Member State, or by the integrated site's fuel balance in the case of combustion of industrial process fuels. For existing combustion plants, the type of fuel chosen may be limited by the configuration and the design of the plant			
7	<p>In order to reduce emissions of ammonia to air from the use of selective catalytic reduction (SCR) and/or selective non-catalytic reduction (SNCR) for the abatement of NO_x emissions, BAT is to optimise the design and/or operation of SCR and/or SNCR (e.g. optimised reagent to NO_x ratio, homogeneous reagent distribution and optimum size of the reagent drops).</p> <p>BAT-associated emission levels</p> <p>The BAT-associated emission level (BAT-AEL) for emissions of NH₃ to air from the use of SCR and/or SNCR is < 3–10 mg/Nm³ as a yearly average or average over the sampling period. The lower end of the range can be achieved when using SCR and the upper end of the range can be achieved when using SNCR without wet abatement techniques. In the case of plants combusting biomass and operating at variable loads as well as in the case of engines combusting HFO and/or gas oil, the higher end of the BAT-AEL range is 15 mg/Nm³.</p>				NA	SCR/SNCR are not used on site

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement											
8	In order to prevent or reduce emissions to air during normal operating conditions, BAT is to ensure, by appropriate design, operation and maintenance, that the emission abatement systems are used at optimal capacity and availability.	NA	SCR/SNCR are not used on site. Cottam Development Centre uses Dry Low-NOx burners to abate NOx emissions. It is currently an operational requirement that this is engaged before synchronisation with the grid.											
9	<p>In order to improve the general environmental performance of combustion and/or gasification plants and to reduce emissions to air, BAT is to include the following elements in the quality assurance/quality control programmes for all the fuels used, as part of the environmental management system (see BAT 1):</p> <ul style="list-style-type: none"> (i) Initial full characterisation of the fuel used including at least the parameters listed below and in accordance with EN standards. ISO, national or other international standards may be used provided they ensure the provision of data of an equivalent scientific quality; (ii) Regular testing of the fuel quality to check that it is consistent with the initial characterisation and according to the plant design specifications. The frequency of testing and the parameters chosen from the table below are based on the variability of the fuel and an assessment of the relevance of pollutant releases (e.g. concentration in fuel, flue-gas treatment employed); (iii) Subsequent adjustment of the plant settings as and when needed and practicable (e.g. integration of the fuel characterisation and control in the advanced control system (see description in Section 8.1)). <p>Description Initial characterisation and regular testing of the fuel can be performed by the operator and/or the fuel supplier. If performed by the supplier, the full results are provided to the operator in the form of a product (fuel) supplier specification and/or guarantee.</p> <table border="1" data-bbox="320 1018 1400 1377"> <thead> <tr> <th data-bbox="320 1018 680 1054">Fuel(s)</th> <th data-bbox="680 1018 1400 1054">Substances/Parameters subject to characterisation</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 1054 680 1257" rowspan="4">Biomass/peat</td> <td data-bbox="680 1054 1400 1091">— LHV</td> </tr> <tr> <td data-bbox="680 1091 1400 1134">— moisture</td> </tr> <tr> <td data-bbox="680 1134 1400 1177">— Ash</td> </tr> <tr> <td data-bbox="680 1177 1400 1257">— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)</td> </tr> <tr> <td data-bbox="320 1257 680 1377" rowspan="3">Coal/lignite</td> <td data-bbox="680 1257 1400 1300">— LHV</td> </tr> <tr> <td data-bbox="680 1300 1400 1343">— Moisture</td> </tr> <tr> <td data-bbox="680 1343 1400 1377">— Volatiles, ash, fixed carbon, C, H, N, O, S</td> </tr> </tbody> </table>	Fuel(s)	Substances/Parameters subject to characterisation	Biomass/peat	— LHV	— moisture	— Ash	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)	Coal/lignite	— LHV	— Moisture	— Volatiles, ash, fixed carbon, C, H, N, O, S	CC	All of the parameters specified for natural gas in BAT 9 are measured or calculated semi-continuously. CDC has installed service pack 7 from the OEM that assist overall environmental performance. The fuel gas supplied to the site has been assessed in accordance with technique (i) and is continuously monitored in accordance with technique (ii) Measurement of LHV, CH ₄ , C ₂ H ₆ , C ₃ , C ₄ +, CO ₂ and Wobbe index is carried out continuously using an online gas chromatograph which carries out calculations in accordance with ISO6976. The gas chromatograph is calibrated annually in accordance with ISO17025. The data supplied from the gas monitoring system is used to assess the performance of the plant in accordance with technique (iii)
Fuel(s)	Substances/Parameters subject to characterisation													
Biomass/peat	— LHV													
	— moisture													
	— Ash													
	— C, Cl, F, N, S, K, Na — Metals and metalloids (As, Cd, Cr, Cu, Hg, Pb, Zn)													
Coal/lignite	— LHV													
	— Moisture													
	— Volatiles, ash, fixed carbon, C, H, N, O, S													

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement														
	<table border="1"> <tr> <td data-bbox="322 357 680 475"></td> <td data-bbox="680 357 1400 475"> <ul style="list-style-type: none"> — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="322 475 680 560">HFO</td> <td data-bbox="680 475 1400 560"> <ul style="list-style-type: none"> — Ash — C, S, N, Ni, V </td> </tr> <tr> <td data-bbox="322 560 680 644">Gas oil</td> <td data-bbox="680 560 1400 644"> <ul style="list-style-type: none"> — Ash — N, C, S </td> </tr> <tr> <td data-bbox="322 644 680 729">Natural gas</td> <td data-bbox="680 644 1400 729"> <ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index </td> </tr> <tr> <td data-bbox="322 729 680 836">Process fuels from the chemical industry⁽²⁷⁾</td> <td data-bbox="680 729 1400 836"> <ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> <tr> <td data-bbox="322 836 680 904">Iron and steel process gases</td> <td data-bbox="680 836 1400 904"> <ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index </td> </tr> <tr> <td data-bbox="322 904 680 1088">Waste⁽²⁸⁾</td> <td data-bbox="680 904 1400 1088"> <ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) </td> </tr> </table>		<ul style="list-style-type: none"> — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 	Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 	Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 	Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 	Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 	Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 		
	<ul style="list-style-type: none"> — Br, Cl, F — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																
HFO	<ul style="list-style-type: none"> — Ash — C, S, N, Ni, V 																
Gas oil	<ul style="list-style-type: none"> — Ash — N, C, S 																
Natural gas	<ul style="list-style-type: none"> — LHV — CH₄, C₂H₆, C₃, C₄₊, CO₂, N₂, Wobbe index 																
Process fuels from the chemical industry ⁽²⁷⁾	<ul style="list-style-type: none"> — Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																
Iron and steel process gases	<ul style="list-style-type: none"> — LHV, CH₄ (for COG), C_xH_y (for COG), CO₂, H₂, N₂, total sulphur, dust, Wobbe index 																
Waste ⁽²⁸⁾	<ul style="list-style-type: none"> — LHV — Moisture — Volatiles, ash, Br, C, Cl, F, H, N, O, S — Metals and metalloids (As, Cd, Co, Cr, Cu, Hg, Mn, Ni, Pb, Sb, Tl, V, Zn) 																
10	<p>In order to reduce emissions to air and/or to water during other than normal operating conditions (OTNOC), BAT is to set up and implement a management plan as part of the environmental management system (see BAT 1), commensurate with the relevance of potential pollutant releases, that includes the following elements:</p> <ul style="list-style-type: none"> — appropriate design of the systems considered relevant in causing OTNOC that may have an impact on emissions to air, water and/or soil (e.g. low-load design concepts for reducing the minimum start-up and shutdown loads for stable generation in gas turbines), — set-up and implementation of a specific preventive maintenance plan for these relevant systems, 	CC	<p>The EMS incorporates many of the key aspects of BAT 10. The site operates a risk based review with the EMS (Aspects and impacts) which includes a review of potential impacts of OTNOC.</p> <p>The power station was purpose designed to minimise environmental impact throughout during operational / non operational conditions. e.g. primary, secondary and</p>														

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	<ul style="list-style-type: none"> — review and recording of emissions caused by OTNOC and associated circumstances and implementation of corrective actions if necessary, — periodic assessment of the overall emissions during OTNOC (e.g. frequency of events, duration, emissions quantification/estimation) and implementation of corrective actions if necessary. 		<p>tertiary containment measures to prevent emissions to soil or water from incidents. Emissions to Air and Water are continually monitored with early warning alarms set on all notable parameters to bring instant notification of potential issue to plant operators. Start up and shut down times are minimised as much as possible to reduce emissions and inefficient use of fuel. Control systems are designed to ensure if the plant is operating in low load then emission limits are still met. Gas turbine starts are optimised based on plant condition (i.e warmth category) to minimise emissions during start-up.</p> <p>The power station is maintained in accordance with a full and active preventative maintenance program operated via computer software known as SAP. All plant components are included within the site specific preventative maintenance programmes. The frequency of maintenance is dependent on component duty and manufacturers requirements. This programme is supported risk assessment to identify environmentally critical plant (ECP), and emergency procedures for plant failure. Emissions are recorded during periods of OTNOC and in the event of an accident or environmental incident, the operator would review the emissions, cause etc as part of our incident investigation process and ensure any relevant corrective and / or preventive action is implemented.</p>
11	BAT is to appropriately monitor emissions to air and/or to water during OTNOC. <i>Description</i>	CC	Emissions during start-up and shut-down operations are monitored and reviewed to

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																									
	<p>The monitoring can be carried out by direct measurement of emissions or by monitoring of surrogate parameters if this proves to be of equal or better scientific quality than the direct measurement of emissions. Emissions during start-up and shutdown (SU/SD) may be assessed based on a detailed emission measurement carried out for a typical SU/SD procedure at least once every year, and using the results of this measurement to estimate the emissions for each and every SU/SD throughout the year.</p>		<p>identify if corrective actions are required. Emissions to atmosphere are assessed as part of the annual environmental performance review carried out by sites. In the event of an accident or environmental incident, the operator would review the emissions, cause etc. as part of our incident investigation process and ensure any relevant corrective and / or preventive action is implemented.</p>																									
12	<p>In order to increase the energy efficiency of combustion, gasification and/or IGCC units operated $\geq 1\,500$ h/yr, BAT is to use an appropriate combination of the techniques given below.</p> <table border="1" data-bbox="320 703 1400 1369"> <thead> <tr> <th data-bbox="320 703 365 735"></th> <th data-bbox="365 703 557 735">Technique</th> <th data-bbox="557 703 1001 735">Description</th> <th data-bbox="1001 703 1400 735">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 735 365 850">a.</td> <td data-bbox="365 735 557 850">Combustion optimisation</td> <td data-bbox="557 735 1001 850">See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues</td> <td data-bbox="1001 735 1400 850" rowspan="4">Generally applicable</td> </tr> <tr> <td data-bbox="320 850 365 986">b.</td> <td data-bbox="365 850 557 986">Optimisation of the working medium conditions</td> <td data-bbox="557 850 1001 986">Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO_x emissions or the characteristics of energy demanded</td> </tr> <tr> <td data-bbox="320 986 365 1177">c.</td> <td data-bbox="365 986 557 1177">Optimisation of the steam cycle</td> <td data-bbox="557 986 1001 1177">Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions</td> </tr> <tr> <td data-bbox="320 1177 365 1257">d.</td> <td data-bbox="365 1177 557 1257">Minimisation of energy consumption</td> <td data-bbox="557 1177 1001 1257">Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)</td> </tr> <tr> <td data-bbox="320 1257 365 1369">e.</td> <td data-bbox="365 1257 557 1369">Preheating of combustion air</td> <td data-bbox="557 1257 1001 1369">Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion</td> <td data-bbox="1001 1257 1400 1369">Generally applicable within the constraints related to the need to control NO_x emissions</td> </tr> <tr> <td data-bbox="320 1369 365 1374">f.</td> <td data-bbox="365 1369 557 1374">Fuel preheating</td> <td data-bbox="557 1369 1001 1374">Preheating of fuel using recovered heat</td> <td data-bbox="1001 1369 1400 1374">Generally applicable within the constraints associated with the boiler design and the need to control NO_x emissions</td> </tr> </tbody> </table>		Technique	Description	Applicability	a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable	b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded	c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions	d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)	e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions	f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions	CC	<p>Cottam Development Centre uses a combination of techniques to increase the energy efficiency of the station including techniques A, D, E, F and G.</p> <p>A: the use of an advanced control system and the mixing of combustion air and fuel</p> <p>D: the cooling water pump has a variable speed drive, which reduces the internal energy consumption</p> <p>F: Steam is diverted from the Rankine cycle to preheat the fuel before combustion</p>
	Technique	Description	Applicability																									
a.	Combustion optimisation	See description in Section 8.2. Optimising the combustion minimises the content of unburnt substances in the flue-gases and in solid combustion residues	Generally applicable																									
b.	Optimisation of the working medium conditions	Operate at the highest possible pressure and temperature of the working medium gas or steam, within the constraints associated with, for example, the control of NO _x emissions or the characteristics of energy demanded																										
c.	Optimisation of the steam cycle	Operate with lower turbine exhaust pressure by utilisation of the lowest possible temperature of the condenser cooling water, within the design conditions																										
d.	Minimisation of energy consumption	Minimising the internal energy consumption (e.g. greater efficiency of the feed-water pump)																										
e.	Preheating of combustion air	Reuse of part of the heat recovered from the combustion flue-gas to preheat the air used in combustion	Generally applicable within the constraints related to the need to control NO _x emissions																									
f.	Fuel preheating	Preheating of fuel using recovered heat	Generally applicable within the constraints associated with the boiler design and the need to control NO _x emissions																									

BAT Concn. Numbe r	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	g.	Advanced control system	See description in Section 8.2. Computerised control of the main combustion parameters enables the combustion efficiency to be improved	Generally applicable to new units. The applicability to old units may be constrained by the need to retrofit the combustion system and/or control command system	
	h.	Feed-water preheating using recovered heat	Preheat water coming out of the steam condenser with recovered heat, before reusing it in the boiler	Only applicable to steam circuits and not to hot boilers. Applicability to existing units may be limited due to constraints associated with the plant configuration and the amount of recoverable heat	
	i.	Heat recovery by cogeneration (CHP)	Recovery of heat (mainly from the steam system) for producing hot water/steam to be used in industrial processes/activities or in a public network for district heating. Additional heat recovery is possible from: — flue-gas — grate cooling — circulating fluidised bed	Applicable within the constraints associated with the local heat and power demand. The applicability may be limited in the case of gas compressors with an unpredictable operational heat profile	
	j.	CHP readiness	See description in Section 8.2.	Only applicable to new units where there is a realistic potential for the future use of heat in the vicinity of the unit	
	k.	Flue-gas condenser	See description in Section 8.2.	Generally applicable to CHP units provided there is enough demand for low-temperature heat	
	l.	Heat accumulation	Heat accumulation storage in CHP mode	Only applicable to CHP plants. The applicability may be limited in the case of low heat load demand	
	m.	Wet stack	See description in Section 8.2.	Generally applicable to new and existing units fitted with wet FGD	
	n.	Cooling tower discharge	The release of emissions to air through a cooling tower and not via a dedicated stack	Only applicable to units fitted with wet FGD where reheating of the flue-gas is necessary before release, and where the unit cooling system is a cooling tower	

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	o.	Fuel pre-drying	The reduction of fuel moisture content before combustion to improve combustion conditions	Applicable to the combustion of biomass and/or peat within the constraints associated with spontaneous combustion risks (e.g. the moisture content of peat is kept above 40 % throughout the delivery chain). The retrofit of existing plants may be restricted by the extra calorific value that can be obtained from the drying operation and by the limited retrofit possibilities offered by some boiler designs or plant configurations	
	p.	Minimisation of heat losses	Minimising residual heat losses, e.g. those that occur via the slag or those that can be reduced by insulating radiating sources	Only applicable to solid-fuel-fired combustion units and to gasification/IGCC units	
	q.	Advanced materials	Use of advanced materials proven to be capable of withstanding high operating temperatures and pressures and thus to achieve increased steam/combustion process efficiencies	Only applicable to new plants	
	r.	Steam turbine upgrades	This includes techniques such as increasing the temperature and pressure of medium-pressure steam, addition of a low-pressure turbine, and modifications to the geometry of the turbine rotor blades	The applicability may be restricted by demand, steam conditions and/or limited plant lifetime	
	s.	Supercritical and ultra-supercritical steam conditions	Use of a steam circuit, including steam reheating systems, in which steam can reach pressures above 220,6 bar and temperatures above 374 °C in the case of supercritical conditions, and above 250 – 300 bar and temperatures above 580 – 600 °C in the case of ultra-supercritical conditions	Only applicable to new units of $\geq 600 \text{ MW}_{\text{th}}$ operated $> 4\,000 \text{ h/yr}$. Not applicable when the purpose of the unit is to produce low steam temperatures and/or pressures in process industries. Not applicable to gas turbines and engines generating steam in CHP mode. For units combusting biomass, the applicability may be constrained by high-temperature corrosion in the case of certain biomasses	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement									
13	<p>In order to reduce water usage and the volume of contaminated waste water discharged, BAT is to use one or both of the techniques given below.</p> <table border="1" data-bbox="320 411 1397 715"> <thead> <tr> <th data-bbox="320 411 506 448">Technique</th> <th data-bbox="506 411 1003 448">Description</th> <th data-bbox="1003 411 1397 448">Applicability</th> </tr> </thead> <tbody> <tr> <td data-bbox="320 448 506 580">a. Water recycling</td> <td data-bbox="506 448 1003 580">Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant</td> <td data-bbox="1003 448 1397 580">Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present</td> </tr> <tr> <td data-bbox="320 580 506 715">b. Dry bottom ash handling</td> <td data-bbox="506 580 1003 715">Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.</td> <td data-bbox="1003 580 1397 715">Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present	b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants	CC	Water Recycling: Water usage is reduced and opportunities to recycle water are implemented where practicable to do so. Cottam Development Centre employs a system whereby boiler blow down is captured then stored before being then passed back through the water treatment plant for reuse. This represents BAT for water usage.
Technique	Description	Applicability										
a. Water recycling	Residual aqueous streams, including run-off water, from the plant are reused for other purposes. The degree of recycling is limited by the quality requirements of the recipient water stream and the water balance of the plant	Not applicable to waste water from cooling systems when water treatment chemicals and/or high concentrations of salts from seawater are present										
b. Dry bottom ash handling	Dry, hot bottom ash falls from the furnace onto a mechanical conveyor system and is cooled down by ambient air. No water is used in the process.	Only applicable to plants combusting solid fuels. There may be technical restrictions that prevent retrofitting to existing combustion plants										
14	<p>In order to prevent the contamination of uncontaminated waste water and to reduce emissions to water, BAT is to segregate waste water streams and to treat them separately, depending on the pollutant content.</p> <p>Description Waste water streams that are typically segregated and treated include surface run-off water, cooling water, and waste water from flue-gas treatment.</p> <p>Applicability The applicability may be restricted in the case of existing plants due to the configuration of the drainage systems.</p>	CC	At Cottam Development Centre there are two separate streams: surface water which is isolated in its own system and discharged as uncontaminated surface water, and process/cooling water. The process/cooling water is discharged through the same system, as their pollution levels are largely similar. The volume of cooling water serves to balance the quality of the process water to allow discharge to the nearby river in compliance with the Environmental Permit. Information on these systems has been provided in the original environmental permit application.									
15	<p>In order to reduce emissions to water from flue-gas treatment, BAT is to use an appropriate combination of the techniques given below, and to use secondary techniques as close as possible to the source in order to avoid dilution.</p> <table border="1" data-bbox="320 1219 1397 1374"> <thead> <tr> <th data-bbox="320 1219 680 1283">Technique</th> <th data-bbox="680 1219 965 1283">Typical pollutants prevented/abated</th> <th data-bbox="965 1219 1397 1283">Applicability</th> </tr> </thead> <tbody> <tr> <td colspan="3" data-bbox="320 1283 1397 1315" style="text-align: center;">Primary techniques</td> </tr> <tr> <td data-bbox="320 1315 680 1374">a. Optimised combustion (see BAT 6) and flue-gas treatment</td> <td data-bbox="680 1315 965 1374">Organic compounds, ammonia (NH₃)</td> <td data-bbox="965 1315 1397 1374">Generally applicable</td> </tr> </tbody> </table>	Technique	Typical pollutants prevented/abated	Applicability	Primary techniques			a. Optimised combustion (see BAT 6) and flue-gas treatment	Organic compounds, ammonia (NH ₃)	Generally applicable	NA	No FGD on site.
Technique	Typical pollutants prevented/abated	Applicability										
Primary techniques												
a. Optimised combustion (see BAT 6) and flue-gas treatment	Organic compounds, ammonia (NH ₃)	Generally applicable										

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	systems (e.g. SCR/SNCR, see BAT 7)				
	Secondary techniques⁽²⁹⁾				
	b.	Adsorption on activated carbon	Organic compounds, mercury (Hg)	Generally applicable	
	c.	Aerobic biological treatment	Biodegradable organic compounds, ammonium (NH ₄ ⁺)	Generally applicable for the treatment of organic compounds. Aerobic biological treatment of ammonium (NH ₄ ⁺) may not be applicable in the case of high chloride concentrations (i.e. around 10 g/l)	
	d.	Anoxic/anaerobic biological treatment	Mercury (Hg), nitrate (NO ₃ ⁻), nitrite (NO ₂ ⁻)	Generally applicable	
	e.	Coagulation and flocculation	Suspended solids	Generally applicable	
	f.	Crystallisation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	g.	Filtration (e.g. sand filtration, microfiltration, ultrafiltration)	Suspended solids, metals	Generally applicable	
	h.	Flotation	Suspended solids, free oil	Generally applicable	
	i.	Ion exchange	Metals	Generally applicable	
	j.	Neutralisation	Acids, alkalis	Generally applicable	
	k.	Oxidation	Sulphide (S ²⁻), sulphite (SO ₃ ²⁻)	Generally applicable	
	l.	Precipitation	Metals and metalloids, sulphate (SO ₄ ²⁻), fluoride (F ⁻)	Generally applicable	
	m.	Sedimentation	Suspended solids	Generally applicable	
	n.	Stripping	Ammonia (NH ₃)	Generally applicable	
	The BAT-AELs refer to direct discharges to a receiving water body at the point where the emission leaves the installation.				
	BAT-AELs for direct discharges to a receiving water body from flue-gas treatment				
	Substance/Parameter			BAT-AELs	
				Daily average	
	Total organic carbon (TOC)			20–50 mg/l ⁽³⁰⁾ ⁽³¹⁾ ⁽³²⁾	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																			
	<table border="1"> <tr> <td colspan="2">Chemical oxygen demand (COD)</td> <td>60–150 mg/l ⁽³⁰⁾ ₍₃₁₎ ₍₃₂₎</td> </tr> <tr> <td colspan="2">Total suspended solids (TSS)</td> <td>10–30 mg/l</td> </tr> <tr> <td colspan="2">Fluoride (F⁻)</td> <td>10–25 mg/l ⁽³²⁾</td> </tr> <tr> <td colspan="2">Sulphate (SO₄²⁻)</td> <td>1,3–2,0 g/l ⁽³²⁾ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎</td> </tr> <tr> <td colspan="2">Sulphide (S²⁻), easily released</td> <td>0,1–0,2 mg/l ⁽³²⁾</td> </tr> <tr> <td colspan="2">Sulphite (SO₃²⁻)</td> <td>1–20 mg/l ⁽³²⁾</td> </tr> <tr> <td rowspan="8">Metals and metalloids</td> <td>As</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cd</td> <td>2–5 µg/l</td> </tr> <tr> <td>Cr</td> <td>10–50 µg/l</td> </tr> <tr> <td>Cu</td> <td>10–50 µg/l</td> </tr> <tr> <td>Hg</td> <td>0,2–3 µg/l</td> </tr> <tr> <td>Ni</td> <td>10–50 µg/l</td> </tr> <tr> <td>Pb</td> <td>10–20 µg/l</td> </tr> <tr> <td>Zn</td> <td>50–200 µg/l</td> </tr> </table>	Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ₍₃₁₎ ₍₃₂₎	Total suspended solids (TSS)		10–30 mg/l	Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾	Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎	Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾	Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾	Metals and metalloids	As	10–50 µg/l	Cd	2–5 µg/l	Cr	10–50 µg/l	Cu	10–50 µg/l	Hg	0,2–3 µg/l	Ni	10–50 µg/l	Pb	10–20 µg/l	Zn	50–200 µg/l		
Chemical oxygen demand (COD)		60–150 mg/l ⁽³⁰⁾ ₍₃₁₎ ₍₃₂₎																																				
Total suspended solids (TSS)		10–30 mg/l																																				
Fluoride (F ⁻)		10–25 mg/l ⁽³²⁾																																				
Sulphate (SO ₄ ²⁻)		1,3–2,0 g/l ⁽³²⁾ ₍₃₃₎ ₍₃₄₎ ₍₃₅₎																																				
Sulphide (S ²⁻), easily released		0,1–0,2 mg/l ⁽³²⁾																																				
Sulphite (SO ₃ ²⁻)		1–20 mg/l ⁽³²⁾																																				
Metals and metalloids	As	10–50 µg/l																																				
	Cd	2–5 µg/l																																				
	Cr	10–50 µg/l																																				
	Cu	10–50 µg/l																																				
	Hg	0,2–3 µg/l																																				
	Ni	10–50 µg/l																																				
	Pb	10–20 µg/l																																				
	Zn	50–200 µg/l																																				
16	<p>In order to reduce the quantity of waste sent for disposal from the combustion and/or gasification process and abatement techniques, BAT is to organise operations so as to maximise, in order of priority and taking into account life-cycle thinking:</p> <p>(a) waste prevention, e.g. maximise the proportion of residues which arise as by-products;</p> <p>(b) waste preparation for reuse, e.g. according to the specific requested quality criteria;</p> <p>(c) waste recycling;</p> <p>(d) other waste recovery (e.g. energy recovery),</p> <p>by implementing an appropriate combination of techniques such as:</p> <table border="1"> <thead> <tr> <th>Technique</th> <th>Description</th> <th>Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Generation of gypsum as a by-product</td> <td>Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced</td> <td>Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions	NA	This BAT is not relevant to Cottam Development Centre as it covers wastes from process and abatement. CDC is a natural gas fired turbine, and does not therefore have process or abatement wastes.																													
Technique	Description	Applicability																																				
a. Generation of gypsum as a by-product	Quality optimisation of the calcium-based reaction residues generated by the wet FGD so that they can be used as a substitute for mined gypsum (e.g. as raw material in the plasterboard industry). The quality of limestone used in the wet FGD influences the purity of the gypsum produced	Generally applicable within the constraints associated with the required gypsum quality, the health requirements associated to each specific use, and by the market conditions																																				

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement	
	b.	Recycling or recovery of residues in the construction sector	Recycling or recovery of residues (e.g. from semi-dry desulphurisation processes, fly ash, bottom ash) as a construction material (e.g. in road building, to replace sand in concrete production, or in the cement industry)	Generally applicable within the constraints associated with the required material quality (e.g. physical properties, content of harmful substances) associated to each specific use, and by the market conditions		
	c.	Energy recovery by using waste in the fuel mix	The residual energy content of carbon-rich ash and sludges generated by the combustion of coal, lignite, heavy fuel oil, peat or biomass can be recovered for example by mixing with the fuel	Generally applicable where plants can accept waste in the fuel mix and are technically able to feed the fuels into the combustion chamber		
	d.	Preparation of spent catalyst for reuse	Preparation of catalyst for reuse (e.g. up to four times for SCR catalysts) restores some or all of the original performance, extending the service life of the catalyst to several decades. Preparation of spent catalyst for reuse is integrated in a catalyst management scheme	The applicability may be limited by the mechanical condition of the catalyst and the required performance with respect to controlling NO _x and NH ₃ emissions		
17	In order to reduce noise emissions, BAT is to use one or a combination of the techniques given below.			CC	Cottam Development Centre uses a combination of all the techniques laid out in BAT 17. A: operations are undertaken by trained staff, closing of doors to noisy activities including signage where necessary. B: any new purchased equipment is purchased based on noise attributes C: buildings and walls surround the louder equipment providing attenuation. D: the turbine is enclosed in a noise dampening case and the buildings are soundproofed. E: The site is on the land of another, much larger power station, and in the vicinity of other industrial processes.	
	Technique	Description				Applicability
a.	Operational measures	These include: <ul style="list-style-type: none"> — improved inspection and maintenance of equipment — closing of doors and windows of enclosed areas, if possible — equipment operated by experienced staff — avoidance of noisy activities at night, if possible — provisions for noise control during maintenance activities 				Generally applicable
b.	Low-noise equipment	This potentially includes compressors, pumps and disks				Generally applicable when the equipment is new or replaced
c.	Noise attenuation	Noise propagation can be reduced by inserting obstacles between the emitter and the receiver.		Generally applicable to new plants. In the case of existing plants, the		

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																																	
		Appropriate obstacles include protection walls, embankments and buildings	insertion of obstacles may be restricted by lack of space																																			
	d. Noise-control equipment	This includes: — noise-reducers — equipment insulation — enclosure of noisy equipment — soundproofing of buildings	The applicability may be restricted by lack of space																																			
	e. Appropriate location of equipment and buildings	Noise levels can be reduced by increasing the distance between the emitter and the receiver and by using buildings as noise screens	Generally applicable to new plant																																			
40	In order to increase the energy efficiency of natural gas combustion, BAT is to use an appropriate combination of the techniques given in BAT 12 and below.			CC	CDC operates in combined cycle mode, and combustion optimisation through Service Pack 7, along with an advanced control system as outlined above. CDC is an existing CCGT plant and as such the appropriate AEEL for 50-60%. CDC efficiency is plant is 57.6% efficient and this level meets the BAT requirements.																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">Technique</th> <th style="width:20%;">Description</th> <th style="width:70%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Combined cycle</td> <td>See description in Section 8.2</td> <td>Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers</td> </tr> </tbody> </table>						Technique	Description	Applicability	a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																											
Technique	Description	Applicability																																				
a. Combined cycle	See description in Section 8.2	Generally applicable to new gas turbines and engines except when operated < 1 500 h/yr. Applicable to existing gas turbines and engines within the constraints associated with the steam cycle design and the space availability. Not applicable to existing gas turbines and engines operated < 1 500 h/yr. Not applicable to mechanical drive gas turbines operated in discontinuous mode with extended load variations and frequent start-ups and shutdowns. Not applicable to boilers																																				
BAT-associated energy efficiency levels (BAT-AEELs) for the combustion of natural gas																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="3" style="width:20%;">Type of combustion unit</th> <th colspan="5" style="text-align:center;">BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾</th> </tr> <tr> <th colspan="2" style="text-align:center;">Net electrical efficiency (%)</th> <th rowspan="2" style="text-align:center;">Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾</th> <th colspan="2" style="text-align:center;">Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾</th> </tr> <tr> <th style="text-align:center;">New unit</th> <th style="text-align:center;">Existing unit</th> <th style="text-align:center;">New unit</th> <th style="text-align:center;">Existing unit</th> </tr> </thead> <tbody> <tr> <td>Gas engine</td> <td style="text-align:center;">39,5–44 ⁽¹⁴¹⁾</td> <td style="text-align:center;">35–44 ⁽¹⁴¹⁾</td> <td style="text-align:center;">56–85 ⁽¹⁴¹⁾</td> <td colspan="2" style="text-align:center;">No BAT-AEEL.</td> </tr> <tr> <td>Gas-fired boiler</td> <td style="text-align:center;">39–42,5</td> <td style="text-align:center;">38–40</td> <td style="text-align:center;">78–95</td> <td colspan="2" style="text-align:center;">No BAT-AEEL.</td> </tr> <tr> <td>Open cycle gas turbine, ≥ 50 MWth</td> <td style="text-align:center;">36–41,5</td> <td style="text-align:center;">33–41,5</td> <td style="text-align:center;">No BAT-AEEL</td> <td style="text-align:center;">36,5–41</td> <td style="text-align:center;">33,5–41</td> </tr> </tbody> </table>						Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾					Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾		New unit	Existing unit	New unit	Existing unit	Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.		Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.		Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41
Type of combustion unit	BAT-AEELs ⁽¹³⁶⁾ ⁽¹³⁷⁾																																					
	Net electrical efficiency (%)		Net total fuel utilisation (%) ⁽¹³⁸⁾ ⁽¹³⁹⁾	Net mechanical energy efficiency (%) ⁽¹³⁹⁾ ⁽¹⁴⁰⁾																																		
	New unit	Existing unit		New unit	Existing unit																																	
Gas engine	39,5–44 ⁽¹⁴¹⁾	35–44 ⁽¹⁴¹⁾	56–85 ⁽¹⁴¹⁾	No BAT-AEEL.																																		
Gas-fired boiler	39–42,5	38–40	78–95	No BAT-AEEL.																																		
Open cycle gas turbine, ≥ 50 MWth	36–41,5	33–41,5	No BAT-AEEL	36,5–41	33,5–41																																	

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																				
	<p style="text-align: center;">Combined cycle gas turbine (CCGT)</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">CCGT, 50–600 MW_{th}</td> <td style="width: 10%;">53–58,5</td> <td style="width: 10%;">46–54</td> <td style="width: 20%;">No BAT-AEEL</td> <td style="width: 35%;">No BAT-AEEL</td> </tr> <tr> <td>CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>No BAT-AEEL</td> <td>No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, 50–600 MW_{th}</td> <td>53–58,5</td> <td>46–54</td> <td>65–95</td> <td>No BAT-AEEL</td> </tr> <tr> <td>CHP CCGT, ≥ 600 MW_{th}</td> <td>57–60,5</td> <td>50–60</td> <td>65–95</td> <td>No BAT-AEEL</td> </tr> </table>	CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL	CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL	CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL	CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL		
CCGT, 50–600 MW _{th}	53–58,5	46–54	No BAT-AEEL	No BAT-AEEL																			
CCGT, ≥ 600 MW _{th}	57–60,5	50–60	No BAT-AEEL	No BAT-AEEL																			
CHP CCGT, 50–600 MW _{th}	53–58,5	46–54	65–95	No BAT-AEEL																			
CHP CCGT, ≥ 600 MW _{th}	57–60,5	50–60	65–95	No BAT-AEEL																			
42	<p>In order to prevent or reduce NO_x emissions to air from the combustion of natural gas in gas turbines, BAT is to use one or a combination of the techniques given below.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Technique</th> <th style="width: 40%;">Description</th> <th style="width: 50%;">Applicability</th> </tr> </thead> <tbody> <tr> <td>a. Advanced control system</td> <td>See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr</td> <td>The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system</td> </tr> <tr> <td>b. Water/steam addition</td> <td rowspan="2">See description in Section 8.3</td> <td>The applicability may be limited due to water availability</td> </tr> <tr> <td>c. Dry low-NO_x burners (DLN)</td> <td>The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed</td> </tr> <tr> <td>d. Low-load design concept</td> <td>Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages</td> <td>The applicability may be limited by the gas turbine design</td> </tr> <tr> <td>e. Low-NO_x burners (LNB)</td> <td rowspan="2">See description in Section 8.3</td> <td>Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants</td> </tr> <tr> <td>f. Selective catalytic</td> <td>Not applicable in the case of combustion plants operated < 500 h/yr.</td> </tr> </tbody> </table>	Technique	Description	Applicability	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system	b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability	c. Dry low-NO _x burners (DLN)	The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed	d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design	e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants	f. Selective catalytic	Not applicable in the case of combustion plants operated < 500 h/yr.	CC	<p>Cottam Development Centre uses an appropriate combination of the techniques listed in BAT 42, such as techniques A and C which are applicable to the combustion of natural gas.</p> <p>A: It has an advanced control system which measures multiple metrics such as gas preheat temperatures and burner status through the DCS.</p> <p>C: Dry low-NO_x burners are used to reduce NO_x emissions further. This is imitated as part of the start-up routine and is a requirement for synchronisation.</p> <p>Both E-DLN and MSUL are defined in relation to the current combustion and emissions characteristics. CDC have less than 12 months operation following the Service Pack 7 upgrade and therefore need to understand the longer-term implications of this upgrade and in particular the potential future mechanical degradation of the gas turbine.</p>	
Technique	Description	Applicability																					
a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system																					
b. Water/steam addition	See description in Section 8.3	The applicability may be limited due to water availability																					
c. Dry low-NO _x burners (DLN)		The applicability may be limited in the case of turbines where a retrofit package is not available or when water/steam addition systems are installed																					
d. Low-load design concept	Adaptation of the process control and related equipment to maintain good combustion efficiency when the demand in energy varies, e.g. by improving the inlet airflow control capability or by splitting the combustion process into decoupled combustion stages	The applicability may be limited by the gas turbine design																					
e. Low-NO _x burners (LNB)	See description in Section 8.3	Generally applicable to supplementary firing for heat recovery steam generators (HRSGs) in the case of combined-cycle gas turbine (CCGT) combustion plants																					
f. Selective catalytic		Not applicable in the case of combustion plants operated < 500 h/yr.																					

BAT Concn. Number	Summary of BAT Conclusion requirement			Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
	reduction (SCR)		Not generally applicable to existing combustion plants of < 100 MW _{th} . Retrofitting existing combustion plants may be constrained by the availability of sufficient space. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
43	In order to prevent or reduce NO _x emissions to air from the combustion of natural gas in engines, BAT is to use one or a combination of the techniques given below.			NA	No engines on site.
	Technique	Description	Applicability		
	a. Advanced control system	See description in Section 8.3. This technique is often used in combination with other techniques or may be used alone for combustion plants operated < 500 h/yr	The applicability to old combustion plants may be constrained by the need to retrofit the combustion system and/or control command system		
	b. Lean-burn concept	See description in Section 8.3. Generally used in combination with SCR	Only applicable to new gas-fired engines		
	c. Advanced lean-burn concept	See descriptions in Section 8.3	Only applicable to new spark plug ignited engines		
	d. Selective catalytic reduction (SCR)		Retrofitting existing combustion plants may be constrained by the availability of sufficient space. Not applicable to combustion plants operated < 500 h/yr. There may be technical and economic restrictions for retrofitting existing combustion plants operated between 500 h/yr and 1 500 h/yr		
44	In order to prevent or reduce CO emissions to air from the combustion of natural gas, BAT is to ensure optimised combustion and/or to use oxidation catalysts. Description - See descriptions in Section 8.3. BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in gas turbines			CC	CDC optimises the combustion process for CO emissions and carry's out routine maintenance of the combustion system.
	Type of combustion plant		BAT-AELs (mg/Nm³) <u>(142)</u> <u>(143)</u>		

BAT Concn. Numbe r	Summary of BAT Conclusion requirement				Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement
		Combustion plant total rated thermal input (MW_{th})	Yearly average ⁽¹⁴⁴⁾ ⁽¹⁴⁵⁾ []	Daily average or average over the sampling period		
	Open-cycle gas turbines (OCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁷⁾					
	New OCGT	≥ 50	15–35	25–50		
	Existing OCGT (excluding turbines for mechanical drive applications) — All but plants operated < 500 h/yr	≥ 50	15–50	25–55 ⁽¹⁴⁸⁾		
	Combined-cycle gas turbines (CCGTs) ⁽¹⁴⁶⁾ ⁽¹⁴⁹⁾					
	New CCGT	≥ 50	10–30	15–40		
	Existing CCGT with a net total fuel utilisation of < 75 %	≥ 600	10–40	18–50		
	Existing CCGT with a net total fuel utilisation of ≥ 75 %	≥ 600	10–50	18–55 ⁽¹⁵⁰⁾		
	Existing CCGT with a net total fuel utilisation of < 75 %	50–600	10–45	35–55		
	Existing CCGT with a net total fuel utilisation of ≥ 75 %	50–600	25–50 ⁽¹⁵¹⁾	35–55 ⁽¹⁵²⁾		
	Open- and combined-cycle gas turbines					
	Gas turbine put into operation no later than 27 November 2003, or existing gas turbine for emergency use and operated < 500 h/yr	≥ 50	No BAT-AEL	60–140 ⁽¹⁵³⁾ ⁽¹⁵⁴⁾		
	Existing gas turbine for mechanical drive applications — All but plants operated < 500 h/yr	≥ 50	15–50 ⁽¹⁵⁵⁾	25–55 ⁽¹⁵⁶⁾		
	<p>As an indication, the yearly average CO emission levels for each type of existing combustion plant operated ≥ 1 500 h/yr and for each type of new combustion plant will generally be as follows:</p> <ul style="list-style-type: none"> — New OCGT of ≥ 50 MW_{th}: < 5–40 mg/Nm³. For plants with a net electrical efficiency (EE) greater than 39 %, a correction factor may be applied to the higher end of this range, corresponding to [higher end] × EE/39, where EE is the net electrical energy efficiency or net mechanical energy efficiency of the plant determined at ISO baseload conditions. 					

BAT Concn. Number	Summary of BAT Conclusion requirement	Status NA/ CC / FC / NC	Assessment of the installation capability and any alternative techniques proposed by the operator to demonstrate compliance with the BAT Conclusion requirement																							
	<p>— Existing OCGT of $\geq 50 \text{ MW}_{th}$ (excluding turbines for mechanical drive applications): $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of this range will generally be 80 mg/Nm^3 in the case of existing plants that cannot be fitted with dry techniques for NO_x reduction, or 50 mg/Nm^3 for plants that operate at low load.</p> <p>— New CCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}30 \text{ mg/Nm}^3$. For plants with a net electrical efficiency (EE) greater than 55 %, a correction factor may be applied to the higher end of the range, corresponding to [higher end] \times EE/55, where EE is the net electrical energy efficiency of the plant determined at ISO baseload conditions.</p> <p>— Existing CCGT of $\geq 50 \text{ MW}_{th}$: $< 5\text{--}30 \text{ mg/Nm}^3$. The higher end of this range will generally be 50 mg/Nm^3 for plants that operate at low load.</p> <p>— Existing gas turbines of $\geq 50 \text{ MW}_{th}$ for mechanical drive applications: $< 5\text{--}40 \text{ mg/Nm}^3$. The higher end of the range will generally be 50 mg/Nm^3 when plants operate at low load.</p> <p>In the case of a gas turbine equipped with DLN burners, these indicative levels correspond to when the DLN operation is effective.</p> <p>BAT-associated emission levels (BAT-AELs) for NO_x emissions to air from the combustion of natural gas in boilers and engines</p> <table border="1" data-bbox="320 762 1400 986"> <thead> <tr> <th rowspan="3">Type of combustion plant</th> <th colspan="4">BAT-AELs (mg/Nm^3)</th> </tr> <tr> <th colspan="2">Yearly average ⁽¹⁵⁷⁾</th> <th colspan="2">Daily average or average over the sampling period</th> </tr> <tr> <th>New plant</th> <th>Existing plant ⁽¹⁵⁸⁾</th> <th>New plant</th> <th>Existing plant ⁽¹⁵⁹⁾</th> </tr> </thead> <tbody> <tr> <td>Boiler</td> <td>10–60</td> <td>50–100</td> <td>30–85</td> <td>85–110</td> </tr> <tr> <td>Engine ⁽¹⁶⁰⁾</td> <td>20–75</td> <td>20–100</td> <td>55–85</td> <td>55–110 ⁽¹⁶¹⁾</td> </tr> </tbody> </table> <p>As an indication, the yearly average CO emission levels will generally be:</p> <p>— $< 5\text{--}40 \text{ mg/Nm}^3$ for existing boilers operated $\geq 1\,500 \text{ h/yr}$,</p> <p>— $< 5\text{--}15 \text{ mg/Nm}^3$ for new boilers,</p> <p>— $30\text{--}100 \text{ mg/Nm}^3$ for existing engines operated $\geq 1\,500 \text{ h/yr}$ and for new engines.</p>	Type of combustion plant	BAT-AELs (mg/Nm^3)				Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period		New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾	Boiler	10–60	50–100	30–85	85–110	Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾		
Type of combustion plant	BAT-AELs (mg/Nm^3)																									
	Yearly average ⁽¹⁵⁷⁾		Daily average or average over the sampling period																							
	New plant	Existing plant ⁽¹⁵⁸⁾	New plant	Existing plant ⁽¹⁵⁹⁾																						
Boiler	10–60	50–100	30–85	85–110																						
Engine ⁽¹⁶⁰⁾	20–75	20–100	55–85	55–110 ⁽¹⁶¹⁾																						

6. Emissions to Water

The consolidated permit incorporates the current discharges to controlled waters identified as W1 and W2.

There are no BAT AELs specified in the BAT Conclusions for this type of plant. There are also no additional treatment options identified as BAT for the installation. We have therefore not carried out any additional assessment of the emissions to water as part of this review.

8 Additional IED Chapter II requirements:

We have introduced a limit on operating hours in Open Cycle Mode for the LCP in line with our guidance 'BAT for Balancing Plant' as we do not consider this mode of operation as BAT for plant operating over 1,500 hours.

9 Review and assessment of changes that are not part of the BAT Conclusions derived permit review.

This document should be read in conjunction with the application, supporting information and notice.

Aspect considered	Decision
Receipt of application	
Confidential information	A claim for commercial or industrial confidentiality has not been made.
Identifying confidential information	We have not identified information provided as part of the application that we consider to be confidential. The decision was taken in accordance with our guidance on confidentiality.
The site	
Biodiversity, heritage, landscape and nature conservation	<p>The application is within the relevant distance criteria of a site of heritage, landscape or nature conservation, and/or protected species or habitat.</p> <p>A full assessment of the application and its potential to affect the site(s)/species/habitat has not been carried out as part of the permit review process. We consider that the review will not affect the features of the site(s)/species/habitat as the conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.</p> <p>We have not consulted Natural England on the application. The decision was taken in accordance with our guidance.</p>
Operating techniques	
General operating techniques	<p>We have reviewed the techniques used by the operator where they are relevant to the BAT Conclusions and compared these with the relevant guidance notes.</p> <p>The permit conditions ensure compliance with the relevant BREF, BAT Conclusions. The ELVs deliver compliance with the BAT-AELs.</p>
Permit conditions	
Updating permit conditions during consolidation	We have updated permit conditions to those in the current generic permit template as part of permit consolidation. The conditions will provide at least the same level of protection as those in the previous permit and in some cases will provide a higher level of protection to those in the previous permit.

Aspect considered	Decision
Changes to the permit conditions due to an Environment Agency initiated variation	We have varied the permit as stated in the variation notice.
Emission limits	<p>We have decided that emission limits should be set for the parameters listed in the permit.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>It is considered that the ELVs/equivalent parameters or technical measures described above will ensure that significant pollution of the environment is prevented and a high level of protection for the environment is secured.</p>
Monitoring	<p>We have decided that monitoring should be carried out for the parameters listed in the permit, using the methods detailed and to the frequencies specified.</p> <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p> <p>Table S3.4 Process monitoring requirements was amended to include the requirement to monitor energy efficiency after overhauls on site in line with BAT2.</p> <p>Based on the information in the application we are satisfied that the operator's techniques, personnel and equipment have either MCERTS certification or MCERTS accreditation as appropriate.</p>
Reporting	<p>We have specified reporting in the permit for the following parameters:</p> <ul style="list-style-type: none"> • Nitrogen dioxide • Carbon monoxide • Sulphur dioxide • Dust <p>These are described in the relevant BAT Conclusions in Section 5 of this document.</p>
Operator competence	
Management system	There is no known reason to consider that the operator will not have the management system to enable it to comply with the permit conditions.
Growth Duty	
Section 108 Deregulation Act 2015 – Growth duty	We have considered our duty to have regard to the desirability of promoting economic growth set out in section 108(1) of the Deregulation Act 2015 and the guidance issued under section 110 of that Act in deciding whether to grant this permit.

Aspect considered	Decision
	<p>Paragraph 1.3 of the guidance says: “The primary role of regulators, in delivering regulation, is to achieve the regulatory outcomes for which they are responsible. For a number of regulators, these regulatory outcomes include an explicit reference to development or growth. The growth duty establishes economic growth as a factor that all specified regulators should have regard to, alongside the delivery of the protections set out in the relevant legislation.”</p> <p>We have addressed the legislative requirements and environmental standards to be set for this operation in the body of the decision document above. The guidance is clear at paragraph 1.5 that the growth duty does not legitimise non-compliance and its purpose is not to achieve or pursue economic growth at the expense of necessary protections.</p> <p>We consider the requirements and standards we have set in this permit are reasonable and necessary to avoid a risk of an unacceptable level of pollution. This also promotes growth amongst legitimate operators because the standards applied to the operator are consistent across businesses in this sector and have been set to achieve the required legislative standards.</p>